

Predesign Report Volume III RP-5 Solids Treatment Facility



in association with



TABLE OF CONTENTS

VOLUME I: RP-1 LIQUIDS AND SOLIDS TREATMENT SYSTEM REHABILITATION

- Chapter 1: Executive Summary
- Chapter 2: Approved Project Requirements
- Chapter 3: Evaluation of Elimination of Primary Effluent Flow Equalization at RP-1
- Chapter 4: Evaluation of Advanced Water Treatment at RP-1 and RP-5
- Chapter 5: Evaluation of RP-1 and RP-5 Onsite Centrate Treatment
- Chapter 6: Evaluation of RP-1 Liquids Treatment Capacities
- Chapter 7: Evaluation of RP-1 Solids Treatment Capacities

VOLUME II: RP-5 LIQUIDS TREATMENT SYSTEM EXPANSION

- Chapter 1: Executive Summary
- Chapter 2: Approved Project Requirements
- Chapter 3: Evaluation of the Decommissioning of CCWRF
- Chapter 4: Evaluation of Ultimate Expansion of RP-5
- Chapter 5: Evaluation of Advanced Water Treatment at RP-1 and RP-5
- Chapter 6: Evaluation of RP-1 and RP-5 Onsite Centrate Treatment
- Chapter 7: Evaluation of RP-5 Liquid Treatment Alternative Technologies
- Chapter 8: Methodology for Selection for MBR System Manufacturer
- Chapter 9: Integrated Strategy for Electrical, Instrumentation and Control and SCADA Systems at RP-5
- Chapter 10: Existing Equipment Condition Assessment

VOLUME III: RP-5 SOLIDS TREATMENT FACILITY

- Chapter 1: Executive Summary
- Chapter 2: Approved Project Requirements
- Chapter 3: Evaluation of the Decommissioning of RP-2
- Chapter 4: Evaluation of the Relocation of RP-2 Lift Station
- Chapter 5: Evaluation of the Relocation of IEBL Discharge Station
- Chapter 6: Evaluation of RP-1 and RP-5 Onsite Centrate Treatment
- Chapter 7: Evaluation of the RP-5 Solids Treatment Alternative Technologies
- Chapter 8: Evaluation of RP-5 Food Waste Treatment System
- Chapter 9: Evaluation of Beneficial Use of RP-5 Digester Gas

VOLUME IV: RP-2 PHASE I ENVIRONMENTAL SITE ASSESSMENT

APPENDICES

VOLUME I

Appendix 2-A: RP-1 Liquids and Solids Rehabilitation Approved Project Detailed Costs
Appendix 3-A: BiowinTM Parameters Adjusted
Appendix 6-A: BiowinTM Parameters Adjusted
Appendix 6-B: Influent Pollutant Percentile Curves
Appendix 6-C: Existing Liquids Treatment Facilities at RP-1
Appendix 6-D: BiowinTM Calibration
Appendix 6-E: Capacity Calculations
Appendix 7-A: Sludge Production Calculations

VOLUME II

Appendix 2-A: RP-5 Liquids Treatment System Approved Project Detailed Costs Appendix 9-A: RP-5 Preliminary Single Line Diagrams

VOLUME III

Appendix 2-A: RP-5 Solids Treatment Facility Approved Project Detailed Costs Appendix 5-A: Other Alternatives Considered for the Relocation of IEBL Discharge Station Appendix 7-A: RP-1 and RP-5 Expansion Flow Validation Appendix 7-B: RP-5 and CCWRF Sludge Quantity Estimates

EXHIBITS

VOLUME I

Exhibit I – RP-1 Liquids and Solids Treatment Systems Rehabilitation Business Case Evaluations and Detailed Cost Estimates

VOLUME II

Exhibit I – RP-5 Liquids Treatment System Business Case Evaluations and Detailed Cost Estimates

VOLUME III

Exhibit I – RP-5 Solids Treatment Facility Business Case Evaluations and Detailed Cost Estimates



Executive Summary for the RP-5 Solids Treatment Facility





in association with



TABLE OF CONTENTS

CHAPTER 1: EXE	CUTIVE SUMMARY1-1
1.1	Introduction1-1
1.2	Evaluation of the Decommissioning of RP-21-1
1.3	Evaluation of the Relocation of the RP-2 Lift Station1-2
1.4	Evaluation of the Relocation of the IEBL Discharge Station1-2
1.5	Evaluation of Off-Site Recycle Flow Discharge1-4
1.6	Evaluation of RP-5 Solids Treatment Alternatives1-4
	1.6.1Thickening1-41.6.2Anaerobic Digestion and Hot Water System1-51.6.3Struvite Control Systems1-61.6.4Dewatering, Cake Transfer, Storage, and Loadout1-61.6.5Biogas Conditioning and Utilization/Waste Gas Burners1-71.6.6Odor Control1-7
1.7	Evaluation of RP-5 Food Waste Treatment System1-7
1.8	Evaluation of Beneficial Use of RP-5 Digester Gas1-8
1.9	Site Layout1-8
1.10	Permitting1-8
1.11	Project Schedule1-9
1.12	Overall Project Cost Estimate1-9

LIST OF FIGURES

Figure 1-1: New Force Mains Locations	1-3
Figure 1-2: RP-5 Approved Expansion Project Site Layout	-10

LIST OF TABLES

Table 1-1: Project Milestone Schedule	. 1-9
Table 1-2: Solids Treatment Approved Project Cost Estimate	. 1-9

LIST OF ACRONYMS

• 51	
2-Phase	two-phase anaerobic digestion
AACE	American Association of Cost Engineers
ACH	air changes per hour
AHU	air handling unit
ANSI	American National Standards Institute
AOP	advanced oxidation process
ASTM	American Society for Testing and Materials
AWWA	American Water Works Association
AWWARF	American Water Works Research Foundation
BACT	best available control technology
BCE	business case evaluation
BFP	belt filter press
bgs	below ground surface
bhp	brake horsepower
BNR	biological nutrient removal
BOD	biochemical oxygen demand
Btu; BTU	British thermal unit
Cal-OSHA	California Occupational Safety and Health Administration
CAS	conventional activated sludge
CCR	California Code of Regulations
CCWRF	Carbon Canyon Water Recycling Facility
CEC	contaminant of emerging concern
CEQA	California Environmental Quality Act
CFD	computational fluid dynamics
cfm	cubic feet per minute
CIDS	Chino Interceptor Diversion Structure
CIP	clean-in-place
CIW	Chino Institute for Women
СМ	construction management
СО	carbon monoxide
COD	chemical oxygen demand
D/T	dilution(s) to threshold
DAFT	dissolved air flotation thickener
DDW	Division of Drinking Water
deg F	degree Fahrenheit
DŠ	digested solids
EIR	Environmental Impact Report
EOP	Emergency Overflow Pond
EPA	Environmental Protection Agency
ESA	Environmental Site Assessment
ESB	Emergency Storage Basin
FeCl ₃	ferric chloride
FePO ₄	iron phosphate
FOG	fats, oils, and grease

	rie Besignikepe
fpm	feet per minute
FRP	fiberglass-reinforced plastic
ft	foot; feet
ft/min	feet per minute
ft ²	square foot; square feet
ft ³	cubic foot; cubic feet
ft ³ /MG	cubic feet per million gallons
FTE	
	full-time equivalent
FW	food waste
G	gravitational unit
g/L	grams per liter
gal	gallon; gallons
GBT	gravity belt thickener
gfd	gallons per square foot per day
GHG	greenhouse gas
gpd	gallon(s) per day
gpm	gallon(s) per minute
G's	gravitational units
H_2S	hydrogen sulfide
HAP	hazardous air pollutant
HDPE	high-density polyethylene
HEX	heat exchanger
HGL	hydraulic grade line
hp	horsepower
hr	hour(s)
HSW	high-strength waste
HVAC	heating, ventilation, and air conditioning
I&C	instrumentation and controls
IBE	Inland Bioenergy
IC	internal combustion
IEBL	Inland Empire Brine Line
IEUA	Inland Empire Utilities Agency
in	inch(es)
inches w.c.	inches water column
kW	kilowatt
LAER	lowest achievable emission rate
lb	pound(s)
lb/d	pounds per day
lb/ft²/hr	pounds per square foot per hour
lb/ft ³	pounds per cubic foot
lb/hr/m	pounds per hour per meter
lb/MG	pound(s) per million gallon
lb/MMBtu	pounds per million Btu
lb/MMBTU	pounds per million Btu
lb/ton	
	pounds per ton
m	meter(s)

MAD	mesophilic anaerobic digestion
MBR	membrane bioreactor
MCC	motor control center
MG	million gallons
mg/L	milligrams per liter
mgd	million gallons per day
min	minute(s)
mJ/cm ²	millijoules per square centimeter
ML	mixed liquor
MLR	mixed liquor return
MLSS	mixed liquor suspended solids
MM	maximum month
mm	millimeter
MMBTU	million British thermal units
MW	megawatt
NaOCl	sodium hypochlorite
	51
NaOH	sodium hydroxide
NARUC	National Association of Regulatory Utility Commissioners
NFPA	National Fire Protection Association
NG	natural gas
NH3-N	ammonia as nitrogen
NH4	ammonium as nitrogen
NOx	nitrous oxide(s)
NPDES	National Pollutant Discharge Elimination System
NPV	net present value
NRW	non-reclaimable water
NTU	nephelometric turbidity unit
NWRI	National Water Research Institute
O&M	operation(s) and maintenance
ORC	organic Rankine cycle
OSHA	Occupational Safety and Health Administration
PAC	polyaluminum chloride
PDR	Pre-Design Report
PFD	process flow diagram
ppbv	part(s) per billion volume
ppd	pounds per day
ppm	parts per million
ppmv	part(s) per million volume
PS	pump station
psi	pound(s) per square inch
psig	pound(s) per square inch gage
PVC	polyvinyl chloride
R&R	repair and replacement
RAS	return activated sludge
rdoN	recalcitrant dissolved organic nitrogen
RDT	rotary drum thickener
	,

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 1: Executive Summary

REC	recognized environmental conditions
REEP	Renewable Energy Efficiency Project
RFP	Request for Proposal
RO	reverse osmosis
RP	Regional Water Recycling Plant
RP-1	Regional Water Recycling Plant 1
RP-2	Regional Water Recycling Plant 2
RP-4	Regional Water Recycling Plant 2 Regional Water Recycling Plant 4
RP-5	Regional Water Recycling Plant 5
-	revolutions per minute
rpm RW	recycled water
SARI	Santa Ana Regional Interceptor
SAWPA	Santa Ana Water Protection Authority
SCADA	supervisory control and data acquisition
SCAQMD	South Coast Air Quality Management District
SCE	South Coast All Quality Management District
scfm	standard cubic feet per minute
SCR	1
SUK	selective catalytic reduction
SOR	solids handling facility surface overflow rate
SRF	State Revolving Fund
SRT	solids retention time
SSO	sanitary sewer overflow
STF	solids treatment facility
SVI	sludge volume index
SWD	side water depth
TDH	total dynamic head
TDS	total dissolved solids
THP	Thermal Hydrolysis Process Anaerobic Digestion
TIN	total inorganic nitrogen
TKN	total Kjeldahl nitrogen
TM	technical memorandum
TMP	trans-membrane pressure
TN	total nitrogen
TOC	total organic carbon
TPAD	temperature-phased anaerobic digestion
TPHD	thermal hydrolysis process anaerobic digestion
TS	total solids
TSS	total suspended solids
Two-Phase	two-phase anaerobic digestion
USA	United States of America
USACE	United States Army Corps of Engineers
UV	ultraviolet
UVT	ultraviolet transmittance
VFA	volatile fatty acid(s)
VFD	variable frequency drive

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 1: Executive Summary

VOC	volatile organic carbon; volatile organic compound
VS	volatile solids
VSR	volatile solids reduction
VSS	volatile suspended solids
WAS	waste activated sludge
WFMP	Wastewater Facilities Master Plan
wk	week
WWTP	wastewater treatment plant
yr	year

CHAPTER 1: EXECUTIVE SUMMARY

1.1 INTRODUCTION

Volume III of the Pre-Design Report (PDR) includes discussion on subjects directly or indirectly related to the expansion of Regional Water Recycling Plant #5 (RP-5) solids treatment processes:

- Chapter 3: Evaluation of the Decommissioning of RP-2
- Chapter 4: Evaluation of the Relocation of the RP-2 Lift Station
- Chapter 5: Evaluation of the Relocation of Inland Empire Brine Line (IEBL) Discharge Station
- Chapter 6: Evaluation of Off-Site Recycle Flow Discharge
- Chapter 7: Evaluation of RP-5 Solids Treatment Alternatives
- Chapter 8: Evaluation of Food Waste Treatment System
- Chapter 9: Evaluation of Beneficial Use of RP-5 Digester Gas

In each chapter, different alternatives were considered and if required, business case evaluations (BCEs) were developed to compare the alternatives (Exhibit 1).

1.2 EVALUATION OF THE DECOMMISSIONING OF RP-2

Regional Plant No. 2 (RP-2) is located in the city of Chino within the flood zone upstream of the Prado Dam, on land leased from the United States Army Corps of Engineers (USACE). To increase the available Orange County water storage, USACE will increase the maximum operational water level upstream of the dam by raising the Prado Dam Spillway. This increase will cause RP-2 to be within the 566-foot inundation area.

In accordance with the easement renewal for the right-of-way for RP-2 granted by USACE that extended the easement term from May 9, 2010 to May 8, 2035, IEUA is required to remove RP-2 facilities and restore the plant site and utilities upon expiration or termination of the easement. The decommissioning of the plant facilities must follow USACE and US Environmental Protection Agency (EPA) requirements supplemented by state requirements.

Chapter 3 of this volume presents preliminary cost estimates of demolishing the facilities at RP-2 and requirements for restoring the site and utilities. The elements addressed for decommissioning and performing demolition activities include the following:

- Identification of infrastructure and equipment to be removed and preliminary demolition cost estimates
- Environmental Site Assessment (ESA) for the identification and sampling of recognized environmental conditions (RECs) in the soil, surface water, and groundwater. Phase I ESA has been completed and is provided in Volume IV of this PDR.
- Hazardous Waste Survey for the identification and sampling of any buildings or materials that are suspected of containing hazardous materials.
- Regulatory coordination with affected agencies: USACE, Regional Water Control Board (RWQCB), Santa Ana Water Protection Authority (SAWPA), California Occupational Safety and Health Administration (Cal-OSHA), City of Chino, and South Coast Air Quality Management District (SCAQMD).
- Identification of required permits and notifications.

- Liquids, biosolids, solid waste, and industrial waste management and disposal.
- Site restoration requirements.

The worst-case scenario costs are as high as \$42.5 million with respect to the potential costs of hazardous materials abatement and soils remediation, as detailed in Volume III Chapter 3. These costs are expected to be determined with greater accuracy during the Phase II ESA and Hazardous Materials Survey.

1.3 EVALUATION OF THE RELOCATION OF THE RP-2 LIFT STATION

The existing RP-2 lift station receives raw sewage from the 24-inch diameter Mountain Avenue interceptor sewer, 10-inch diameter Chino Institute for Women (CIW) sewer, 10-inch-diameter Butterfield force main, and recycled flows from the solids treatment facilities at RP-2. The 10-inch-diameter CIW sewer receives sewage flows from both the CIW and the El Prado Golf Course clubhouse. Each pump discharges into a 14-inch-diameter discharge pipe connecting to a 24-inch-diameter discharge manifold that conveys flows to the RP-5 headworks.

Due to the anticipated decommissioning of RP-2, the lift station must be relocated above the Prado Dam inundation area above elevation 566, and the associated collection/discharge system must be modified to account for these changes.

As discussed in Chapter 4, the collection system will be modified so that the CIW flows and golf course will be handled separately in a joint agreement with City of Chino. Thus, the flows to be received and pumped at the new location include the Mountain Avenue Sewer, which will be renamed as the Mountain Avenue Lift Station. The Butterfield Ranch lift station flows are discussed below, and will be combined with the discharge of the Mountain Avenue Lift Station.

The Butterfield Ranch Lift Station, located about 2 miles south of RP-2 as shown in Figure 1-1, is owned and operated by the City of Chino Hills. Due to the anticipated decommissioning of RP-2, the flows from Butterfield Ranch will have to be conveyed to the Kimball Avenue Interceptor as illustrated in Figure 1-1, combining the Butterfield Ranch peak flows of about 1,100 gpm with the Mountain Avenue flows of up to 560 gpm. The Butterfield Ranch force main will be extended by 3,000 feet of 10-inch diameter, followed by 3,200 feet of 12-inch force main once the flows are combined with the new lift station for Mountain Avenue.

The Butterfield Ranch lift station pumps, motors, and electrical system will be modified for the additional power requirements to achieve the additional pump discharge head required to pump the additional distance and to a somewhat higher elevation. The details of these modifications will be determined during the design phase when the current and future flows are confirmed with the City of Chino Hills.

1.4 EVALUATION OF THE RELOCATION OF THE IEBL DISCHARGE STATION

The existing IEBL Discharge Station is currently located at the RP-2 site along El Prado Road, near the intersection with the southern end of Mountain Avenue. The IEBL Discharge Station is a septage receiving station that receives trucked liquid waste from permitted haulers and discharges the waste to the 27-inch diameter IEBL (previously known as the Santa Ana Regional Interceptor [SARI]) on El Prado Road. Due to the anticipated decommissioning of RP-2, the station may be relocated to a site within the Agency-owned Solids Handling Facility at Mountain Avenue and Flower Street, as discussed in Chapter 5 of this volume.

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Desian Report Volume III, Chapter 1: Executive Summary




Figure 1-1: New Force Mains Locations

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 1: Executive Summary

The IEBL Discharge Station will feature a dump station manhole, which receives septage/permitted liquid waste from two receiving stations, and two catch basins that capture any stormwater and spray-down waste. Each receiving station will include a quick disconnect coupling where hauling trucks can connect in order to discharge the waste. The incoming waste is analyzed for pH, temperature, conductivity, and sulfide, ensuring that the waste does not surpass the IEBL disposal limits. A magnetic flow meter and automatic sampler will be provided in the station. The dump station manhole will route septage/liquid waste through an 8-inch-diameter pipeline to the 27-inch-diameter IEBL. In this design, the septage is contained and odors are limited from escaping into the atmosphere.

1.5 EVALUATION OF OFF-SITE RECYCLE FLOW DISCHARGE

Centrate equalization and return to the primary influent splitter box will be provided for centrate from the dewatering treatment facility at RP-5. Centrate is a nutrient-rich residual stream produced by dewatering digestate. The stream is recycled to the head of the liquid stream treatment train and can represent 15% to 25% of the total nutrient load. To minimize the impact of centrate recycle to the secondary system, an equalization tank will be provided to evenly distribute the centrate over a 24-hour period. Centrate can also be returned to the liquid stream in a diurnal pattern to increase periods of low nutrient loading.

The centrate equalization tanks receive centrate 5 days/week during the 8-hour dewatering shift. Centrate will be stored in the equalization tanks and recycled to the liquid stream process at a constant rate over a 24-hour period. Two equalization tanks will be provided to allow one tank to be temporarily taken offline for cleaning or maintenance. Each tank will use a variable frequency drive (VFD) controlled mixer to keep particulates in suspension. A VFD driven feed pump controls centrate flow back to the liquid stream.

Centrate equalization tanks can be a source of odor; therefore, air from the headspace of the tanks will be collected and treated in the centralized odor treatment system. The amount of foul air will be sized to maintain a slight negative pressure within the tank preventing odorous air emissions to the atmosphere.

1.6 EVALUATION OF RP-5 SOLIDS TREATMENT ALTERNATIVES

RP-5 Solids Treatment Facility will be constructed to support an average plant capacity of 30 mgd, the projected 2035 flows for both CCWRF plus RP-5. The facility infrastructure will be sized to accommodate future expansion to 40 mgd. This section briefly describes all new solids process facilities required to achieve 30-mgd capacity.

1.6.1 Thickening

The new solids treatment facility at RP-5 will received primary sludge and waste activated sludge (WAS) generated at RP-5 and the Carbon Canyon Water Recycling Facility (CCWRF). A new solids thickening building will be constructed as part of Phase 1. The separate primary sludge and WAS streams from each facility (RP-5 and CCWRF) will be blended into a homogenous mix to be co-thickened. Consideration must be given to in the future being able to thicken streams separately.

Rotary drum thickener (RDT) was the selected technology for RP-5 solids thickening. In rotary drum thickeners the incoming sludge is mixed with polymer and flocculated to enhance particle

separation before being introduced into a slow rotating screen. Filtrate from the RDTs drains through the screen openings and collects in a trough underdrain. Thickened sludge is conveyed through the rotating drum and out the discharge end via a continuous internal screw or angled flights.

The thickening facility will house a total of seven RDTs at build-out. Phase 1 will consist of the installation of five RDTs (four duty, one standby). Each RDT will have a dedicated sludge feed pump and polymer feed pump. Therefore, five sludge feed pumps and five polymer feed pumps will be installed during Phase 1, with space allocated for the future pumps in the pump room and polymer room. The polymer system will have one bulk storage tank, two makeup units, and two aging tanks to allow for one to be down for maintenance.

Rotary drum thickeners will be fully enclosed and provided with foul air take-off connections to tie into the odor scrubber system to help reduce odors from this area. Point source control of odors greatly reduces the amount of foul air and ultimately the size of the odor treatment system. Sludge storage tanks and filtrate tanks will also be ventilated to reduce the potential for odor and corrosion.

1.6.2 Anaerobic Digestion and Hot Water System

Two-phase anaerobic digestion (2-phase acid/gas) with thermophilic temperatures in the gas phase digestion was the selected technology for RP-5 solids digestion. Acid/gas (2-phase) digestion is a two-stage anaerobic digestion process comprising acid- and gas-phase anaerobic digesters. Acid-phase digestion is the first digestion phase, and is operated with a short solids retention time (SRT) of 1 to 1.5-days, during which the substrates are hydrolyzed to produce volatile fatty acids (VFAs). In the second digestion phase, methanogens are grown on the VFAs, which require a longer SRT of 14 days and are thus excluded from this acid-phase digester (aka acid silo). Although the second digestion phase can be operated at either thermophilic or mesophilic temperatures, the intended operation will be thermophilic (typically 131°F). This separation in phases has been demonstrated through long-term operation by IEUA to improve solids reduction and increase gas production.

One new acid phase anaerobic (acid phase) digester and three new thermophilic gas phase anaerobic (gas phase) digesters and a solids storage tank/gas phase digester will be constructed as part of Year 2035 (Phase 1). A second acid phase digester and two additional thermophilic gas phase anaerobic digester may be installed for the 2060 build-out requirements. Space has been reserved on site for these future facilities; it should be noted, however, that other technologies or innovations may be widely proven in the interim period, which might preclude the need to construct this additional tankage. Examples include the process of recuperative thickening, which provides an increase in SRT without additional tankage, as currently planned for RP-1.

Digester gas generated by the digesters will be used for gas utilization equipment, specifically cogeneration (Renewable Energy Efficiency Project [REEP] facility), and/or the plant's central heating facility boilers. Digester gas that cannot be used by either of these end uses would be disposed of in waste gas flares. A central heating facility housing new boilers will be provided and will use natural gas, or digester gas if available, to provide additional heat for the digestion process. The boilers for the new central heating facility would include three hot water boilers. Flexible water-tube boilers are recommended for this application because the flexible tubes are tolerant of thermal cycling and other WWTP's have reported less siloxane buildup compared to fire-tube boilers. The boilers shown are of adequate size to meet 2035 heat demands. Adequate floor space and ventilation in the boiler room would be included to permit larger boilers to replace the proposed boilers in the future, if necessary, to meet future heat demands.

1.6.3 Struvite Control Systems

Struvite is a magnesium ammonium phosphate mineral (Mg $NH_4PO_4 + 6H_2O$) with the characteristics of a white crystalline solid. Under the digestion process, ammonia and phosphorus are released and if sufficient magnesium is present, struvite may form in the anaerobic digester tanks, digested sludge piping, and downstream dewatering equipment and centrate piping. Once formed struvite may coat the interior surfaces of tanks, piping and dewatering equipment which reduces efficiencies, and can be difficult and costly to remove. Ferric Chloride (FeCl₃) has been shown to be effective in struvite control by binding phosphorous (PO₄) to form iron phosphate (FePO₄). Ferric chloride has also been demonstrated to reduce hydrogen sulfide (H₂S) concentrations in digesters.

IEUA stores a 38% solution of ferric chloride at the primary chemical facility in a single fiberglass reinforced concrete containment area. To precipitate phosphorus and inhibit struvite from forming, a 38% ferric chloride solution will be metered into an injection point prior to either or both the acid and gas phase digesters. A day tank and meter pump will be provided for ferric chloride injection at the two-phase digestion facilities. The ferric chloride dosing facilities at the 2-phase digestion process will be sized for both ortho-phosphorous and sulfur removal. Although orthophosphorous is the primary target, the presence of hydrogen sulfide will compete for ferric chloride and result in additional ferric chloride demand.

1.6.4 Dewatering, Cake Transfer, Storage, and Loadout

Centrifuges are the preliminary selected technology for RP-5 solids dewatering. A centrifuge is composed of two cylinders, rotating at slightly different speeds. In the outer cylinder, centrifugal force propels the heavier digested solids to the wall of the outer cylinder at accelerations of approximately 3,000 gravitational units (Gs). Centrate, the remaining residual liquid, accumulates along the axis of rotation and is discharged over a concentric weir. The inner cylinder has a scroll encircling its outer surface. Because the inner cylinder rotates at a slightly slower rotational speed than the outer cylinder (the differential), the scroll moves along the inner surface of the outer cylinder, conveying the dewatered solids to a dewatering beach, and then to its discharge. The liquid centrate is conveyed via an overflow weir to a liquid drain.

Four centrifuges will be constructed as part of Year 2035 (Phase 1). The centrifuges will be sized to dewatering both digested sludge from RP-5 and food waste digestate from the Solids Handling Facility (SHF). In order to provide redundancy for dewatering operations to maintain required capacity during extended maintenance events, one full standby dewatering unit along with all ancillary equipment will be provided. Supporting systems such as polymer, feed pumping, cake pumping and electrical will be designed to allow for operation of all dewatering units (including standby) to operate simultaneously in order to provide maximum operational flexibility in the event that plant operators decided to temporarily operate at a higher dewatering system throughput than the design basis.

Three days of upstream digested sludge storage is provided in the digested sludge storage tank to eliminate the need for dewatering shifts during 3-day weekends and also to provide additional operational flexibility for the dewatering system. The digested sludge storage tank will also serve as a redundant anaerobic digester to provide additional digestion capacity during maintenance operations.

One day of storage is provided in the cake storage bins to facilitate truck loadout. Two 6,000-cubic-foot (ft³) cake bins provide redundancy and allow trucks transfer.

Dewatering centrifuges are totally enclosed and equipped with foul air takeoff connections on the unit housings, centrate chutes and the solids chutes. It is also recommended that foul air connections be provided on all conveyors used to move solids between processes because they can be a significant odor source. Point source control of odors greatly reduces the quantity of foul air and ultimately the size of the odor control system. The foul air extracted from processes in the dewatering building will be conveyed to the centralized odor control facility.

1.6.5 Biogas Conditioning and Utilization/Waste Gas Burners

Waste gas burners are required anaerobic digestion safety equipment used for eliminating excess biogas. The selection of two-phase anaerobic digestion technology for RP-5 solids digestion will produce two separate biogas streams. The first phase or acid-phase will generate a relatively small amount of lower quality gas containing methane, carbon dioxide (CO₂) and H₂S. The second digestion phase will be a thermophilic (digester) process and will generate a gas with favorable methane concentrations for beneficial utilization; in the REEP or the boilers.

Ultra-low emissions enclosed flares have a similar configuration to standard enclosed combustion flares in regard to the flaring section with an enclosed tower that promotes flame stability. Where the ultra-low emissions flare differs is the addition of specialized combustion air blowers and an extended fuel/air pre-mixing section upstream of the flare to ensure a consistent homogenous air/fuel mixture. These blowers bring in additional air that is blended with the biogas prior to combustion resulting in lower emissions of criteria pollutants.

To meet air permitting regulations, two ultra-low emissions enclosed flares were the selected waste gas flaring alternative. The recommended configuration combines the acid-phase and the digester gas streams into a single flow stream which can then either be flared or beneficially used.

1.6.6 Odor Control

The solids facilities, including thickening, dewatering, cake storage and truck loadout, and centrate equalization will require odor control. Odor control ducts from each facility will be routed to a centralized facility designed to treat foul air from both the liquids and solids process facilities.

1.7 EVALUATION OF RP-5 FOOD WASTE TREATMENT SYSTEM

Food waste is currently accepted at RP-5 SHF for processing, digestion, and dewatering. As part of this project, all food waste will continue to be processed at RP-5 SHF, and digestate from SHF will be pumped to RP-5 for dewatering. A new food waste receiving station, capable of receiving an average of 50,000 gallons per day (gpd) of pre-processed slurry, will be constructed at the RP-5 SHF, including a truck unloading pad, transfer/mixing pumps, storage tanks, and digester feed pumps. After digestion at RP-5 SHF, digestate will be pumped via a new transfer pump station and pipeline to the digested sludge storage tank at RP-5, where it will be dewatered along with the biosolids digestate. Dewatering food waste digestate in addition to the biosolids digestate will require an additional centrifuge, larger cake storage, and larger centrate equalization tanks. The main drivers for accepting food waste at RP-5 SHF only and routing digestate back to RP-5 are as follows:

- Avoidance of potential for digester upsets at RP-5 due to inconsistent food waste composition
- Elimination of dewatering operations at RP-5 SHF, which have reportedly been a bottleneck due to limited capacity
- Economies of scale associated with dewatering both digested solids streams together (food waste digestate from SHF and biosolids digestate from RP-5)
- Avoidance of costs associated with centrate discharge to IEBL at RP-5 SHF

1.8 EVALUATION OF BENEFICIAL USE OF RP-5 DIGESTER GAS

The digester gas produced from biosolids digestion at RP-5 and food waste digestion at RP-5 SHF will be beneficially used in a digester gas utilization facility. Currently, digester gas from the RP-5 SHF is used at the RP-5 REEP, which consists of two internal combustion (IC) engines.

As part of this project, digester gas from the new RP-5 Solids Treatment Facility (STF) will be combined with digester gas from SHF and used in the existing two IC engines for power generation and heat recovery. RP-5 digester gas will require gas conditioning, including H₂S removal, moisture removal via refrigeration, and siloxane removal. With additional food waste deliveries at SHF, the RP-5 SHF digester gas quantity is anticipated to increase, so the existing H₂S removal system at SHF will require expansion with two iron sponges similar to the existing. In addition, exhaust from the IC engines requires treatment to comply with SCAQMD NOx emission limits per Rule 1110.2. Thus, two selective catalytic reduction (SCR) units will be installed – one for each of the engines. Finally, the existing REEP heat recovery system requires modifications to allow heat produced in the engines to be used for RP-5 digester heating. These modifications will include hot water piping and heat exchangers.

1.9 SITE LAYOUT

The complete site layout for the approved expansion project, including space allocation for future processes, is shown in Figure 1-2.

1.10 PERMITTING

Required permits include the following:

- Permits for on-site facilities:
 - City of Chino building permit (IEUA may be exempt from local requirements for wastewater treatment process related facilities)
 - Chino Valley Fire District fire protection permit
 - State Water Resources Control Board waste discharge requirements amendment
 - South Coast Air Quality Management District air quality permit to construct
 - Title 22 Permit Update
- Permit for Off-Site Facilities:
 - City of Chino Public Works Department encroachment permit for new pipelines in public rights-of-way
 - City of Chino Hills building permit (for the Butterfield Lift Station upgrade)

1.11 PROJECT SCHEDULE

The project milestone schedule is shown in Table 1-1.

Table 1-1: Project Milestone Schedule

Project Milestone	Target Date (mm/dd/yyyy)
Design Contract Board Award/Approval	04/19/2017
30% Design Completion	11/01/2017
50% Design Completion	04/01/2018
85% Design Completion	11/01/2018
100% Design Completion	04/01/2019

1.12 OVERALL PROJECT COST ESTIMATE

The overall solids treatment project cost estimate is shown in Table 1-2.

Table 1-2: Solids Treatment Approved Project Cost Estimate

Major Systems	Estimated Cost
Thickening	\$10,426,000
Digestion	\$51,632,000
Dewatering	\$42,912,000
Odor Control	\$1,882,000
Digester Gas Treatment, Flaring, and Emissions Controls	\$9,992,000
Permanent Power System Expansion	\$2,064,000
Site Work	\$7,875,000
Food Waste System	\$9,411,000
Estimated Construction Cost	\$135,383,000
Design & Project Management (20%)	\$27,076,000
Total Project Cost	\$162,459,000



15D. Ferric Chloride Transfer Pump Station 15B. Methane-phase Digesters 15A. Acid-phase Digesters Solids Thickening Hot Water Boiler Site Plan Solids 15C. 23C. 16. 17. 18. 19B. 14. 19A. 20. 21. 23A. 19C. 22. 23B. Modifications to Existing Aeration Basins - Includes: replacement of existing diffuser system. replacement of aeration blowers. addition of air piping, and installation of submersible mixers Off-Specification and Emergency Storage - Includes: interconnection of the two storage basins, new pump station at the EOP. lining the EOP, and repair of concrete and seals in the ESB Disinfection Facility - Includes: New UV treatment system Chino Interceptor Sewer Protection System (not shown) Aluminum Flat Covers on Existing Clarifiers Membrane Tanks and Equipment Building New Primary Effluent Diversion Structure Demolition of RAS/WAS Pump Station New Aeration Blowers and Building Convert to Recycled Water Storage Demolition of Secondary Clarifiers Modifications to Power Center : New backpulse & CIP systems Liquids & Solids Odor Control Demolition of Tertiary Filters Methanol Injection System New Primary Clarifiers Influent Pump Station Power Center 1A Power Center 2A Power Center 3A Power Center 4 Headworks

Operations and Maintenance Building Side stream centrate treatment, food waste/FOG receiving, thickening building expansion, future solids Parking Area/Digester Gas Utilization Solids Train Odor Control (combined Centrate Equalization and Pumping RP-5 Food Waste Treatment Facility Advanced Water Treatment System Expanded Recycled Water Pumping Selective Catalytic Reduction on IC Engine Exhaust Dewatering and Cake Storage Utility System Expansions Digested Sludge Storage Gas Purification System treatment processes CNG/RNG Station Enclosed Flares (not shown) with liquids) Equipment 23D. 23E. 23F. 23G.

200 \$100 ZIM

Lab

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION



Approved Project Requirements for RP-5 Solids Treatment Facility





in association with



TABLE OF CONTENTS

CHAPTER 2: APP	ROVED	PROJECT REQUIREMENTS	2-1
2.1	Introd	uction	2-1
	2.1.1 2.1.2	Description of Approved Project Solids Treatment Facility Flows and Loads	
2.2	Thicke	ening	2-9
	2.2.1	Background	2-9
	2.2.2	Description of Approved Thickening Technology	
	2.2.3	Thickening Schematic and Preliminary Facility Layout	
	2.2.4	Thickening Design Data	
	2.2.5	Thickening Odor Control	2-14
2.3	Anaero	obic Digestion and Hot Water System	2-15
	2.3.1	Background	2-15
	2.3.2	Description of Approved Anaerobic Digestion and Boiler Technology	
	2.3.3	Anaerobic Digestion and Central Heating Schematic and	
		Preliminary Facility Layout	
	2.3.4	Anaerobic Digestion and Boiler Design Data	2-19
2.4	Struvit	te Control Systems	2-21
	2.4.1	Background	2-21
	2.4.2	Description of Approved Struvite Control System	
	2.4.3	Design Criteria	2-22
2.5	Dewate	ering, Cake Transfer, Storage, and Loadout	2-22
	2.5.1	Background	2-22
	2.5.2	Description of Approved Dewatering Technology	
	2.5.3	Dewatering Schematic and Preliminary Facility Layout	
	2.5.4	Dewatering Design Data	
	2.5.5 2.5.6	Struvite Management Dewatering Odor Control	
•		e e	
2.6		te Equalization & Return to Primary Influent Splitter Box	
	2.6.1	Background.	
	2.6.2	Description of Approved Centrate Equalization	
	2.6.3 2.6.4	Design Criteria Centrate Odor Control	
2.7		Vaste Receiving and Feed to SHF Digesters	
2.1	2.7.1		
	2.7.1	Description of Approved Food Waste project Schematic and Preliminary Facility Layout	
	2.7.2	Design Criteria.	
2.8		er Gas Utilization	

	2.8.1	Description of Approved Digester Gas Utilization Project	2-34
	2.8.2	Schematic and Preliminary Facility Layout	2-34
	2.8.3	Design Criteria	2-36
2.9	Biogas	Conditioning / Waste Gas Burners	2-37
	2.9.1	Background	2-37
	2.9.2	Description of Approved Waste Gas Elimination Technology	2-37
	2.9.3	Waste Gas Elimination Schematic and Preliminary Layout	2-38
	2.9.4	Waste Gas Elimination Design Data	2-39
2.10	IEBL I	Discharge Station Relocation	2-39
2.11	RP-2 L	ift Station Relocation and New Force Main	2-41
	2.11.1	Lift Station Capacity	2-42
	2.11.2	Influent Gravity Sewer	2-43
	2.11.3	Sewage Force Main	2-43
	2.11.4	Wet Well	2-43
	2.11.5	Valve/Meter Vault and Appurtenances	2-43
2.12	Butterf	ïeld Ranch Lift Station Modifications and Force Main	
	Extens	ion	2-44
2.13	SCADA	A Integration	2-45
2.14	Permit	ting	2-47
2.15	Detaile	d Project Schedule	2-47
2.16	Overal	l Project Cost Estimate	2-48

LIST OF APPENDICES

Appendix 2-A: RP-5 Solids Treatment Facility Approved Project Detailed Costs......2-51

LIST OF FIGURES

Figure 2-1: RP-5 Facility Layout	
Figure 2-2: RP-5 Process Flow Diagram	
Figure 2-3: Rotary Drum Thickener	
Figure 2-4: RDT for Sludge Thickening Facility Process Schematic	
Figure 2-5: RDT for Sludge Thickening Facility Layout	
Figure 2-6: Phase Digestion Process Schematic	
Figure 2-7: Water-Tube Boiler	
Figure 2-8: Two-Phase Anaerobic Digestion PFD	
Figure 2-9: Acid Reactor Layout	
Figure 2-10: Thermophilic Digesters Layout	

Figure 2-11: New Central Heating Facility Layout	
Figure 2-12: Dewatering Centrifuge	
Figure 2-13: Dewatering Centrifuge Ground Floor Layout	
Figure 2-14: Dewatering Centrifuge Upper Floor Layout	
Figure 2-15: Food Waste Receiving Schematic	
Figure 2-16: Food Waste Receiving Station Layout	
Figure 2-17: Digestate Pipeline Route	
Figure 2-18: Gas Utilization Schematic	
Figure 2-19: Gas Conditioning System Layout	
Figure 2-20: Preliminary Schematic of Modified Heat Recovery System	
Figure 2-21: Enclosed Flare	
Figure 2-22: Waste Gas Flare PFD	
Figure 2-23: Waste Gas Facility Layout	
Figure 2-24: Site Layout	
Figure 2-25: RP-2 Lift Station	
Figure 2-26: Butterflied Ranch Lift Station	

LIST OF TABLES

Table 2-1: Plant Influent Flow at Average Condition, MGD	
Table 2-2: Sludge Production Rates at Max Month Condition, lb/MG	
Table 2-3: Sludge Production Peaking Factors ^a	
Table 2-4: Projected Sludge Productions in 2035 and 2060	
Table 2-5: Digested Solids and Hydraulic Loading Projections	
Table 2-6: Digested Solids and Digestate Loading Projections	
Table 2-7: Thickening System Performance Goals	
Table 2-8: RDT Design Criteria	
Table 2-9: Thickening Facility Tankage Design Data	
Table 2-10: Pumping Systems Design Data	
Table 2-11: Emulsion Polymer System Design Data	
Table 2-12: Odor Control Design Data	
Table 2-13: Two-Phase Digestion Performance and Sizing Data	
Table 2-14: Two-Phase Digestion Design Data	
Table 2-15: Projected Digestion Feed Characteristics	
Table 2-16: Boiler Design Criteria	
Table 2-17: Ferric Chloride Day Tank and Metering Sizing Design Data	
Table 2-18: Dewatering Centrifuge Equipment Number of Operating (Duty) Units	
Table 2-19: Digested Sludge Minimum Storage Requirement (3 days' storage)	

Table 2-20: Projected Dewatering Feed Characteristics	2-26
Table 2-21: Dewatering System Performance Requirements	2-26
Table 2-22: Centrifuge Design Criteria	2-27
Table 2-23: Ancillary Equipment Design Criteria	2-27
Table 2-24: Odor Control Design Criteria	2-28
Table 2-25: Ancillary Equipment Design Criteria	2-29
Table 2-26: Ancillary Equipment Design Criteria	2-29
Table 2-27: Equipment for Food Waste Approved Project	2-31
Table 2-28: Required Equipment for Gas Utilization Project	2-34
Table 2-29: Digester Gas Quantity Projections	2-37
Table 2-30: Biogas Design Criteria	2-39
Table 2-31: Liquids Treatment Processes PCNs	2-45
Table 2-32: Solids Treatment Processes PCNs	2-46
Table 2-33: Offsite Facilities PCNs	2-47
Table 2-34: Project Milestone Schedule	2-47
Table 2-35: Solids Treatment Approved Project Cost Estimate	2-48
Table 2-36: Solids Treatment Approved Project Additional Project Options Cost Estimate	2-49

CHAPTER 2: APPROVED PROJECT REQUIREMENTS

2.1 INTRODUCTION

The Wastewater Facilities Master Plan (WFMP) of 2013 evaluated and concluded that RP-5's existing wastewater treatment capacity would be exceeded by the year 2025. Additionally, the solids loading from Carbon Canyon Waste Recycling Facility (CCWRF) and RP-5 already exceeds the digester capacity at RP-2, where these solids streams are currently treated. Due to the United States Army Corps of Engineers (USACE) project to raise the Prado Dam Spillway, the RP-2 solids treatment facility will need to be decommissioned and a new RP-5 solids treatment facility constructed with a design capacity to treat the projected flows.

In Chapter 2, RP-5 facility needs were combined with needs arising from service area expansion and level of service requirements to generate a list of preliminary design decisions. Each decision was granted a set of alternatives, which were assessed using business case evaluations, recommendations from workshops, and direction and preferences identified by IEUA. The evaluations and recommendations led to the advancement of selected alternatives. The IEUA standard business case evaluation (BCE) template was utilized to develop comparative net present values for solids facilities with construction starting in 2022 and operating through 2035.

In this chapter, the selected alternatives are integrated into a preliminary design of the RP-5 Solids Treatment Facility. This chapter summarizes the basis of design of each unit process, presenting design criteria and details of how each system fits into the overall operation of the Plant.

2.1.1 Description of Approved Project Solids Treatment Facility

The RP-5 Solids Treatment Facility will be located east of secondary and tertiary treatment processes at RP-5. As shown on Figure 2-1, the new RP-5 facility foot print comprises an area of approximately 7 acres. The chosen technologies for RP-5 solids treatment include:

- Rotary drum thickening
- Two-phase (acid/gas) digestion
- Centrifuge dewatering
- Centrate equalization
- Biogas conditioning, waste gas burners, and hot water boilers
- Cogeneration engine exhaust treatment and heat recovery system
- Food waste receiving facility at the SHF site (space allocated for future FW receiving at RP-5)



2-2

- Influent Pump Station 4
- Chino Interceptor Sewer Protection System (not shown) Headworks e
- 4A. New Primary Clarifiers
- Aluminum Flat Covers on Existing Clarifiers 48.
- New Primary Effluent Diversion Structure 40.
- Modifications to Existing Aeration Basins Includes; replacement of existing diffuser system, replacement of aeration blowers, addition of air piping, and installation of submersible mixers s
 - Membrane Tanks and Equipment Building
- New Aeration Blowers and Building
- New backpulse & CIP systems
- Demolition of RAS/WAS Pump Station 00
- Demolition of Secondary Clarifiers 9E
 - Demolition of Tertiary Filters
 - Methanol Injection System ~
- Disinfection Facility Includes: New UV treatment system ø
 - Convert to Recycled Water Storage
- Liquids & Solids Odor Control
- Off-Specification and Emergency Storage Includes: interconnection of the two storage busins, new pump station at the EOP, lining the EOP, and repair of concrete and seals in the ESB
- Modifications to Power Center 12A.
- Power Center 1A
- Power Center 2A 120.
- Power Center 3A 120.
 - Power Center 4 12E.
- Replacement of air relief valve in Recycled Water Pump Station 13A.
 - - Shading of chemical storage area
- Install curb and gutter along the west and south roads 130.

Solids

- 15A. Acid-phase Digesters 14. Solids Thickening
- 15B. Methane-phase Digesters
 - 15C. Hot Water Boiler
- 15D. Ferric Chloride Transfer Pump Station
 - 17. Dewatering and Cake Storage 16. Digested Sludge Storage
- Centrate Equalization and Pumping 18.
 - **Gas Purification System** 19A.
 - Enclosed Flares 198.
- Selective Catalytic Reduction on IC Engine Exhaust 190
- Solids Train Odor Control (combined 20.
 - with liquids)
- RP-5 Food Waste Treatment Facility (not shown) 27
- Utility System Expansions 55

Site Plan

- 23A. Side stream centrate treatment, food waste/FOG receiving, thickening building expansion, future solids treatment processes
- **Operations and Maintenance Building** 238.
- Parking Area/Digester Gas Utilization Equipment 23C.
 - 23D. Advanced Water Treatment System
- 23E. Expanded Recycled Water Pumping

 - 23F. CNG/RNG Station 236.

Lab

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION

Figure 2-1 RP-5 Facility Layout

2.1.2 Flows and Loads

Based on the background of the project, the new solids treatment facility at RP-5 will be sized to process future solids production at RP-5 and CCWRF. The principal solids treatment processes will consist of thickening, digestion, dewatering, and digester gas treatment and use.

Projected plant influent flows at various IEUA's facilities through 2060 under various flow diversion scenarios were provided by IEUA (Volume III, Chapter 7, Appendix A). The projected plant influent flows at RP-5 and CCWRF are summarized in Table 2-1.

Year	RP-5	CCWRF
2016	9.3	7.4
2020	14.2	7.6
2025	16.0	7.6
2030	20.2	7.8
2035	22.8	7.9
2040	25.5	8.1
2045	27.6	8.2
2050	29.5	8.3
2060	30.0	8.5

Table 2-1: Plant Influent Flow at Average	Condition, MGD
---	----------------

Sludge production values were estimated on a per-million-gallon basis using the influent design pollutant concentrations selected on the RP-1 & RP-5 Expansion PDR Monthly Progress Meeting on March 7, 2016. These influent design concentrations were chosen after analysis of five years of the existing plant data with consensus among the design team and IEUA staff. The design concentrations chosen were based on maximum month values. If the 90th percentile concentration was greater than the max month value, then the 90th percentile value was used. The selected design concentrations are provided in Volume III, Chapter 7. Sludge production rates resulting from this analysis are summarized in Table 2-2.

Table 2-2: Sludge Production Rates at Max Month Condition, Ib/MG

Parameter	RP-5	CCWRF
Max Month Primary Sludge	2,335	2,919
Max Month WAS	1,297	1,633
Max Month Total Sludge	3,632	4,552

^a FOG and food waste are not included in these sludge quantity estimates

Sludge production fluctuates throughout the year as the plant influent flow and characteristics change. The solids handling facilities and associated equipment must be sized properly to be able to handle solids production during peak events. Therefore, several peaking factors are needed to design the solids handling systems, including maximum day, maximum week, maximum 2-week, and maximum month. However, there is not enough data available to determine all peaking factors to a high level of precision. Therefore, the peaking factors were determined by reviewing the available influent data as well as using the design team's engineering judgement, knowledge, and

experience. Influent data were used to develop peaking factors because there was not enough available data on primary sludge and waste activated sludge (WAS) flow and solids percentages.

The peaking factors were developed for combined sludge as well as separate primary sludge and WAS. Peaking factors for combined sludge were used to size equipment after the two sludge streams are combined, such as combined thickening, digestion, and dewatering. Peaking factors for separate primary sludge and WAS production were used to size equipment for separate sludge thickening alternatives. The peaking factors for separate sludge streams are slightly higher than those of combined sludge because peak sludge production of primary sludge and WAS typically do not occur simultaneously. The peaking factors selected for this project are summarized in Table 2-3.

Parameter	Combined Sludge	Separate Sludge ^{b,c,d}
Max Month / Annual Average	1.40 ^a	1.60
Max 2-Week / Max Month	1.68 ^b	1.75
Max Week / Max Month	1.75 ^b	1.90
Max Day / Max Month	1.82 ^a	2.10

Table 2-3: Sludge Production Peaking Factors^a

^a Based on a review of existing plant data.

^b Not enough existing data to determine this precise peaking factor – value based on the judgment and experience of the design team and interpolated from influent data (See Vol. II, Chapter 7)

^c Peaking factors for separate sludge streams are higher than those of combined sludge because peak primary sludge and WAS productions typically do not occur simultaneously

^d Peaking factors for PS and WAS are assumed to be the same

Solids flows and loads in the year 2060 were used for equipment and facility sizing and site planning. Solids flows and loads at the 2045 average annual condition were used for the BCE evaluations (Volume III, Chapter 7). Initial approved project construction will include equipment and facilities to process 2035 solids flows and loads, with some buildings sized and constructed now to accommodate future 2060 equipment.

Projected solids flow and loads at 2035 and 2060 are summarized in Table 2-4. Combined sludge flows and loads were used to size process equipment that treats combined sludge, such as combined thickening, digestion, and dewatering. Separate primary and WAS flows and loads were used to size process equipment that treat the two sludge streams separately, such as separate thickening and associated pumps and piping.

Year 2035			2060				
Type of	Sludge	PS	WAS	Combined ^a	PS	WAS	Combined ^a
	Average Annual	54,500	30,300	84,800	67,800	37,700	105,500
	Max Month	87,200	48,500	118,800	110,700	61,600	147,700
TS (lb/day)	Max 2 Week	95,400	53,100	142,500	121,100	67,400	177,200
	Max Week	103,500	57,600	148,500	131,500	73,200	184,600
	Max Day	114,400	63,700	154,400	145,300	80,900	191,900
	Average Annual	46,300	26,800	73,200	57,600	33,300	90,900
	Max Month	74,100	42,900	102,400	94,100	54,500	127,300
VS (lb/day)	Max 2 Week	81,100	46,900	122,900	102,900	59,600	152,800
	Max Week	88,000	51,000	128,000	111,800	64,700	159,100
	Max Day	97,300	56,300	133,100	123,500	71,500	165,500
	Average Annual	816,800	454,700	1,271,500	1,015,600	565,200	1,580,700
	Max Month	1,306,900	727,500	1,780,100	1,659,600	923,500	2,213,000
Flow ^b (gal/day)	Max 2 Week	1,429,400	795,700	2,136,200	1,815,200	1,010,100	2,655,600
	Max Week	1,552,000	863,900	2,225,200	1,970,800	1,096,700	2,766,300
	Max Day	1,715,300	954,900	2,314,200	2,178,300	1,212,200	2,876,900

Table 2-4: Projected Sludge Productions in 2035 and 2060

a. Because peak production of primary sludge and WAS sludge occur at different times, combined peaking factors were developed for sludge production at peak conditions for combined sludge.

b. Based on raw sludge TS of 0.8%.

The thickening equipment and facilities were sized based on 2060 max day conditions shown in Table 2.1-4. The thickeners will be sized for either combined or separate primary sludge and WAS thickening. However, only thickening units required for combined thickening through 2035 will be constructed as part of the Approved Project. Based on the results of the BCE evaluations (Volume III, Chapter 7), IEUA staff has selected Rotary Drum Thickeners (RDTs) for sludge thickening. Thickened sludge flows and loads at different design conditions are summarized in Table 2-4.

The anaerobic digestion system was sized based on 2060 average annual and max 2-week conditions shown in Table 2-5. However, only digestion units required through 2035 will be constructed as part of the Approved Project.

Performance	Parameter	2035	2060
Solida Looding andb	Average Annual	80,600	100,200
Solids Loading, ppd ^b Max 2-Week		135,400	168,300
VS Looding and	Average Annual	69,500	86,400
VS Loading, ppd	Max 2-Week	116,700	145,100
Hydraulic Loading,	Average Annual	193,300	240,300
gpd ^c	Max 2-Week	324,700	403,700
Sludge VS, % of TS			86

Table 2-5: Digested Solids and Hydraulic Loading Projections

a. based on thickening process solids capture rate of 95%

b. pounds per day

c. gallons per day

Digested sludge will be transferred to digested sludge storage tank prior to dewatering. During the workshop conducted on January 11, 2017, IEUA staff and the design team made the decision that all FOG and food waste will be directed to the RP-5 Solids Handling Facility (SHF) for digestion. Details of identifying quantities and qualities of FOG and food waste are discussed in Volume III, Chapter 8. The digestate from the SHF will be piped to RP-5 digested sludge storage tank for dewatering. The anticipated flows and loads for digested sludge and digestate from the SHF are summarized in Table 2-6. Theses flows and loads were used for storage tank and dewatering equipment and facility sizing. Figure 2-2 shows the process flow diagram.

Performance Parameter		2035	2060	
	Solids Loading,	Average Annual	38,900	48,400
Digested	ppd^b	Max Month	54,500	67,700
Sludge Hydraulic Loading, gpd ^c	Average Annual	193,300	240,300	
	gpd ^c	Max Month	270,600	336,400
Solids Loading,	Average Annual	19,800	22,500	
Digestate	ppd ^b	Max Month	19,800	22,500
2	Hydraulic Loading,	Average Annual	82,000	93,000
	gpd ^c	Max Month	82,000	93,000

Table 2-6: Digested Solids and Digestate Loading Projections




Figure 2-2: RP-5 Process Flow Diagram

NOTES 1. ALL PROCESS PUMPS ARE ASSUMED TO REQUIRE SEAL WATER.

2.2 THICKENING

2.2.1 Background

The new solids treatment facility at RP-5 will received sludge generated from the primary clarifiers (Primary Sludge) and from the secondary treatment process (WAS), from Carbon Canyon Water Recycling Plant, and RP-5. Thickening is used to increase the solids content of sludge and reduce its volume by removing a portion of water from the sludge feed. This reduction in volume increases the solids retention time in a subsequent digester, relative to digestion without thickening. Thickening, reduces the overall costs of sludge processing and handling.

Rotary drum thickeners (RDTs) were the selected technology for RP-5 solids thickening. Technologies screened during the selection process in Volume III, Chapter 7 included: gravity thickener; dissolved air flotation thickener (DAFT); centrifuge; membrane thickener; and gravity belt thickener (GBT). The selection of RDTs was based on the results from comparative analyses using criteria such as the effectiveness of the technology for both separate thickening and combined sludge co-thickening, agency direction during the August 11, 2016 workshop, and a BCE.

2.2.2 Description of Approved Thickening Technology

In rotary drum thickeners, the incoming sludge is mixed with polymer and flocculated to enhance particle separation before being introduced into a slowly rotating screen. Filtrate from the RDTs drains through the screen openings and collects in a trough underdrain. Thickened sludge is conveyed through the rotating drum and out the discharge end via a continuous internal screw or angled flights. The drum is sometimes inclined to aid in dewatering. An example of a single-drum style rotary drum thickener is shown in Figure 2-3.



Figure 2-3: Rotary Drum Thickener

(Photo courtesy of Parkson)


2.2.3 Thickening Schematic and Preliminary Facility Layout

The new solids treatment facility at RP-5 will receive primary sludge and waste activated sludge (WAS) generated at RP-5 and CCWRF. A new solids thickening building to house the RDTs will be constructed as part of the Approved Project. The separate primary sludge and WAS streams from each facility (RP-5 and CCWRF) will be blended into a homogenous mixed sludge to be co-

thickened. Consideration and a design configuration will be provided to allow the system to thicken streams separately in the future.

The thickening building, concrete sludge storage tanks, polymer storage and aging tanks, and filtrate pump station will be sized for 2060 build-out conditions, while the sludge handling equipment and piping will be installed under the Approved Project to handle design maximum flows and loads projected for 2035, with one redundant unit. Two sludge tanks at the front of the thickening operation will serve as the blending tanks. Two thickened sludge hoppers will be installed at the tail end of the RDTs. Hard piped bypasses will be provided to be used in the event of an emergency or when units are down for maintenance.

The thickening facility will house a total of 7 RDTs at 2060 build-out. Phase 1 will consist of the installation of 5 RDTs, with 4 units on duty during max day flows. Each RDT will have a dedicated sludge feed pump and polymer feed pump. As such, five (5) sludge feed pumps and five (5) polymer feed pumps will be installed during Phase 1, with space being allocated for the future pumps in the pump room and polymer room. The polymer system will have one bulk storage tank, two (2) makeup units, and two (2) aging tanks to allow for one to be down for maintenance. The preliminary process schematic for the thickening facilities is shown in Figure 2-4 and the proposed preliminary layout for the RDT thickening facility is provided in Figure 2-5.



Rotary Drum Thickener

Figure 2-4: RDT for Sludge Thickening Facility Process Schematic




Figure 2-5: RDT for Sludge Thickening Facility Layout

2.2.4 Thickening Design Data

Projected maximum day and average annual flows and loads are summarized above in Table 2.1-4. The development and assumptions to produce flow and loads projections are presented in Chapter 2.1. Maximum day flows and loads were used to size the thickening facility to ensure facility is not hydraulically limited. If desired, during detail design, this assumption can be reassessed based on available equalization in upstream processes and to more closely match the digestion facility. Thickening operation is assumed to be continuous, 24 hours per day/ 7 days per week.

Rotary drum thickener performance goals shown in Table 2-7 were established for the purpose of evaluating the thickening technologies. These can be refined during detailed design based on IEUA objectives and related process selections.

Table 2-7: Thickening System	Performance Goals
------------------------------	-------------------

Performance Requirement	Value
Minimum thickened solids concentration	6% for 2-Phase Digestion
Minimum Solids Capture	95%

The RDT design criteria and sizing results are summarized in Table 2-8 and assume the "Basis of Design Manufacturer/ Model". Mechanical equipment installed during Phase 1 will be sized for enough capacity to handle 2035 maximum day flows and loads. One redundant unit will be available during max day flows and loads. Bypasses will be provided to manage flows in the event of an emergency.

2-11

Design Parameter	Unit	Primary Sludge	WAS	Combined Sludge
2035 Max. Day hydraulic Loading Rate	gpm	1,200	665	1,605
Unit Hydraulic Loading Rate, max	gpm/unit	400	400	400
Polymer Dosage	lb/dry ton	5	10	8
Wash Water Requirement	gpm	50	50	50
Energy Consumption	hp	10	10	10
Basis of Design Manufacturer/ Model		Parkson RDT-400	Parkson RDT-400	Parkson RDT-400
Drum Diameter	in	44	44	44

Table 2-8: RDT Design Criteria

Design criteria and preliminary sizing results for the thickening facility tanks are presented in Table 2-9. Raw sludge tanks, thickened sludge hoppers, and filtrate tank, being potentially concrete structures, will be sized for 2060 maximum day flows. The raw sludge and thickened sludge tanks will be designed for a minimum 20-minute detention time, affording the raw sludge feed pumps and thickened sludge pumps to operate without abrupt hydraulic changes.

Depending on final project elevations it could be determined that sufficient differential is available to gravity drain to filtrate to the front of the plant. However, for planning purposes it is assumed that the filtrate will need to be pumped and a filtrate pumping station is required. The filtrate tank will not be sized to provide hydraulic detention as the pumps will operate in fill and draw.

Table 2-9: Thickening Facility Tankage Design Data

Design Criteria	Unit	Value
Sludge Tanks		
2060 Max. Day Hydraulic Loading Rate	gpm	2,000
Hydraulic Detention Time	min	20
Number of Tanks		2
Tank Dimensions		
Height	ft	10
Width	ft	15
Length	ft	40
Thickened Sludge Hopper		
Hydraulic Loading Rate	gpm	304
Hydraulic Detention Time	min	20
Number of Hoppers		2
Hopper Dimensions		
Height	ft	10
Width	ft	5
Length	ft	20
Filtrate Tank		
Hydraulic Loading Rate	gpm	1,700
Hydraulic Detention Time	min	N/A

Design Criteria	Unit	Value
Number of Tanks		1
Tank Dimensions		
Height	ft	10
Width	ft	5
Length	ft	10

The pumping systems and conveyance will be designed to account and accommodate a wide range of thickening equipment performance (i.e. higher %TS of thickened sludge). Phase 1 sludge handling equipment will be sized to handle the 2035 maximum day flows and loads. The filtrate system will be sized to handle 2035 maximum day flows and load plus one redundant unit. Piping systems will be lined to prevent build-up of grease and to allow pumping of high viscosity sludge. Table 2-10 shows the preliminary sizing results for the thickening facility's pumping systems.

Design Criteria	Unit	Value
Sludge Feed Pumps		
2035 Max. Day Hydraulic Loading Rate	gpm	1,605
Capacity	gpm	400
Pressure	psi	15
Number of pumps		5
Motor size	hp	30
Thickened Sludge Pumps		
Hydraulic Loading Rate	gpm	250
Capacity	gpm	100
Pressure	psi	15
Number of pumps		4
Motor size	hp	30
Filtrate Pumps		
Hydraulic Loading Rate	gpm	1,400
Capacity	gpm	2000
Pressure	ft	30
Number of pumps (duty / standby)		1 / 1
Motor size	hp	20

Table 2-10: Pumping Systems Design Data

The emulsion polymer system will be sized for 10 lb/ton, which is the maximum polymer dosage requirement expected for the RDT system operation. Preliminary sizing results for Phase 1, based on 2035 maximum daily solids loading is presented in Table 2-11. One polymer feed pump will be provided per RDT. For Phase 1 no redundant unit is assumed.

The polymer system and other ancillary systems such as wash/spray water and electrical will be designed to allow for operation of all thickening units simultaneously in order to provide maximum operational flexibility.

	-	-
Design Criteria	Unit	Value
2035 Max. Day Solids Loading	lb/hr	154,400
Polymer Dosage	lb/ton	10
Neat Polymer Storage Tank		
Number of Storage Tanks		1
Capacity	gal	
Recirculation Pump		
Capacity	gpm	100
Motor size	hp	7.5
Make-up Unit		
Capacity	gph	40
Electrical requirement	hp	1
Aging Tanks		
Number of Aging Tanks		2
Detention Time	min	30
Capacity	gal	4,000
Polymer Feed Pumps		
Capacity	gpm	5
Pressure	psi	50
Number of pumps		5
Motor size	hp	3

Table 2-11: Emulsion Polymer System Design Data

2.2.5 Thickening Odor Control

Rotary drum thickeners will be fully enclosed and provided with foul air take-off connections to tie into the odor scrubber system to reduce odors from this area. Point source control of odors greatly reduces the amount of foul air and ultimately the size of the odor treatment system. Sludge storage tanks and filtrate tanks will also be ventilated to reduce the potential for odor and corrosion. Table 2-12 show the preliminary odor control design criteria for the thickening facility. The foul air extracted from the thickening building processes will be conveyed to a centralized plant-wide odor treatment facility.

Table 2-12 :	Odor Co	ntrol Design	Data
---------------------	---------	--------------	------

Source Design Criteria		Air Flow Rate per unit	Total Air Flow
Source	Design Criteria	cfm	cfm
RDT	Parkson-400	430	3000
Sludge Blend Tanks	Leakage Rate, 0.5 cfm/sq. ft.	300	300
Thickened Sludge Tanks	Leakage Rate, 0.5 cfm/sq. ft.	50	50
Filtrate Tanks	Leakage Rate, 0.5 cfm/sq. ft.	50	50

2.3 ANAEROBIC DIGESTION AND HOT WATER SYSTEM


2.3.1 Background

The new anaerobic digestion facility at RP-5 will receive solids generated from the RDT thickening facility to stabilize and reduce the mass solids through an anaerobic digestion treatment process. Two-phase anaerobic digestion (2-phase acid/gas) with thermophilic temperatures in gas phase digestion was the selected technology for RP-5 solids digestion. Technologies screened during the selection process described in Volume III, Chapter 7 included: mesophilic anaerobic digestion (MAD); 2-phase acid/gas phase digestion; and thermal hydrolysis process (THP). The selection of 2-phase acid/gas digestion was based on favorable historical experience by IEUA, projected improved biogas production and increased digestion efficiency, BCE evaluation results, and recommendations developed during the August 11, 2016 Workshop and October 2016 Board Workshop.

Digester gas generated by the digesters will be used for gas utilization equipment, specifically cogeneration (REEP facility), and/or the plant's central heating facility boilers. Digester gas will preferentially be directed to the REEP facility for cogeneration to produce electricity and hot water. Hot water generated at the REEP will be used to meet digester and building heating demands at RP-5, but the quantity of heat may not always be adequate to meet these needs. A central heating facility housing new boilers will be provided and will use natural gas, or digester gas if available, to provide additional heat for the digestion process. Digester gas that cannot be used by either of these end uses would be disposed of in waste gas flares.

2.3.2 Description of Approved Anaerobic Digestion and Boiler Technology

Acid/gas (2-phase) digestion is a two-stage anaerobic digestion process comprising separate acid and gas phase anaerobic digesters. Acid-phase digestion is the first digestion phase, and is operated with a short solids retention time (SRT) of 1-2 days, during which the substrates are hydrolyzed to produce volatile fatty acids (VFAs). In the second digestion phase, methanogen bacteria are grown on these VFA's which require a longer SRT (greater than 5 days) and are thus excluded from this acid-phase digester (aka acid silo). The recommended total SRT for optimum digestion of 15 days will be met with the acid-phase and gas-phase digesters operated in series. Although the second digestion phase can be operated at either thermophilic or mesophilic temperatures, the intended operation will be thermophilic (typically, 131 degrees Fahrenheit). This separation in phases has been demonstrated through long term operation by IEUA to improve solids reduction and increase gas production. A PFD for 2-Phase digestion process is provided in Figure 2-6. It should be noted that IEUA is interested in exploring two stages of gas phase digestion in series, potentially thermophilic followed by mesophilic. That process configuration would require larger pipes and pumps between stages and will be evaluated in detailed design.



Gas-Phase HRT: 14 days, Max 2-week OLR: up to 270 lb-VS/1000ft³-d

Figure 2-6: Phase Digestion Process Schematic

The boilers for the new central heating facility would include three hot water boilers. Flexible water-tube boilers (Figure 2-7) are recommended for this application because the flexible tubes are tolerant of thermal cycling and other WWTPs have reported less siloxane buildup with them compared to fire-tube boilers.



Figure 2-7: Water-Tube Boiler

Photos courtesy of Bryan Steam LLC

2.3.3 Anaerobic Digestion and Central Heating Schematic and Preliminary Facility Layout

Process schematics and conceptual facility layouts for the two-phase digestion system are provided in Figures 2-8 through 2-10.

The new anaerobic digestion facility will receive thickened primary and waste activated sludge discharged from the new solids thickening facility RDT's. FOG and food wastes will be treated separately at the existing RP-5 SHF digestion facility. The resulting FOG and food waste digestate will be pumped to the digested sludge storage tank downstream of the new anaerobic digesters in preparation for dewatering at the new solids dewatering facility (refer to section 2.5).

One new acid phase digester and three new thermophilic gas phase digesters and one sludge storage tank, configured to be capable of operating as a backup gas phase digester, will be constructed as part of the year 2035 Approved Project (Phase 1). A second acid phase digester and a fourth and fifth thermophilic gas phase digesters are planned to be installed in the future for the 2060 build-out requirements. Under Phase 1 and buildout, all gas phase digesters will be equipped identically to function as thermophilic anaerobic digesters even though up to two digesters can serve also as digested sludge holding tanks.


As stated above, IEUA is interested in exploring two stages of gas phase digestion in series, potentially thermophilic followed by mesophilic. That process configuration would require larger pipes and pumps between stages and will be evaluated in detailed design.

The acid phase digestion facility will be configured to house a total of two acid digesters at 2060 build-out. Phase 1 will consist of the installation of one acid phase digester with two feed control valves, two heat exchangers, two grinders and circulation pumps, two sludge mixing pumps and

sludge transfer pumps. One of the sludge HEX, mixing and transfer pumps will be provided as standby; in the future the standby equipment will serve the second acid digester. An electrical room will be sized for buildout conditions but equipped for the Phase 1 power requirements.


The gas phase digestion facility will house a total of five gas phase digesters and one storage tank at 2060 build-out. Phase 1 will consist of the installation of three gas phase tanks each with a dedicated feed control valve, heat exchanger, grinder and circulation pump, a sludge mixing pump and sludge transfer pump. Shared standby sludge mixing and transfer pumps will be provided between each pair of gas phase digesters.

The equipment gallery and electrical room will be sized for the three Phase 1 gas phase digesters and one storage tank. The buildout condition will be accommodated with a future building expansion.



TWO PHASE PFD

Figure 2-8: Two-Phase Anaerobic Digestion PFD





TWO PHASE DIGESTION (80 ft diameter, 42 ft SWD digesters)




Figure 2-10: Thermophilic Digesters Layout

The central heating facility will be located just west of the dewatering facility and will occupy about 3,000 sqft. The building will house the two duty and one standby boilers, hydronic pumps, and related electrical and HVAC equipment (Figure 2-11).

The boilers shown are of adequate size to meet 2035 heat demands. Adequate floor space and ventilation in the boiler room would be included to permit larger boilers to replace the proposed boilers in the future, if necessary, to meet future heat demands. Overhead doors would provide access to the boilers for maintenance. The boilers could be installed and removed through the overhead doors via a forklift.

The hydronic pumping system includes two variable-speed duty/standby main heat loop pumps for circulating hot water for digester and building heat, as well as an expansion tank and air separator. One side-loop pump and 3-way valve for each boiler would be provided for circulating hot water from and to the main heat loop through the boilers.




Figure 2-11: New Central Heating Facility Layout

2.3.4 Anaerobic Digestion and Boiler Design Data

Projections for the solids flows and loads to the digestion facility following solids thickening for both the maximum day and maximum 2-week conditions have been developed and are presented above.

Digester sizing and site layout is based on year 2060 (build-out). Max 2-week flows and loads were used to size digestion facility total 15-day SRT and acid reactors were sized for max day. Redundancy is provided with standby pump and HEX, recirculation pump for mixing, and a digested sludge storage tank to operate as a standby anaerobic digester. In the event the acid tank

needs to be taken off line, operators will convert to straight single stage digestion. If a digester is off line during a high load period, operations can elect to operate at shorter than 15-day SRT or utilize the storage tank for digestion and operate dewatering for longer periods. Digested sludge and received digestate from digested FOG/food waste will be blended in the storage tank prior to transfer to dewatering. Digester performance and sizing data is provided in Table 2-13 and digester tank design data is provided in Table 2-14.

Design Condition	2025	2035	2060		
Digester Tank Volume and N	umber				
Acid Tank Volume, mgal		0.35			
Acid Feed Tank Number	1	1	2		
Digester Volume, mgal		1.52			
Digester Tank Number	3	3	5		
Acid Digester SRT, day	Acid Digester SRT, day				
Max Day, all in service	1.3	1.0	1.6		
Gas Digester SRT, day					
Max 2-week, all in service	17.9	14.0	19.0		
Acid Digester VS Loading, lb/	Acid Digester VS Loading, lb/cuft				
Max Day, all in service	2.1	2.7	1.7		
Gas Digester VS Loading, lb/cuft					
Max 2-week, all in service	0.15	0.19	0.14		

Table 2-13: Two-Phase Digestion Performance and Sizing Data

a. At one tank out of service.

Table 2-14: Two-Phase Digestion Design Data

Design Criteria	Unit	Value
Acid Phase Digester		
Diameter	ft	36
Height ^a	ft	50
SWD	ft	46
Gas Phase Digester		
Diameter	ft	80
Height	ft	50
SWD	ft	40

a. Includes 4 ft freeboard.

b. Includes 3 ft freeboard and 15% volume expansion.

The solids feed characteristics that will impact digestion are summarized in Table 2-15.

Sludge Characteristic	Average Value
Nominal Sludge Composition, Total Dry Solids Weight Basis	Blend of primary sludge and waste activated sludge
Total solids concentration, %TS	5
Volatile solids (VS), % dry mass basis	86
Temperature, deg F	65 - 85
Average pH	7

Table 2-15: Projected Digestion Feed Characteristics

a. After pre-dewatering facility

The preliminary selection for the boilers was based on 2035 projected peak 14-day digester and building heating demands, and area emissions requirements. The design requirements for the boilers are presented in Table 2-16. The design includes 3 steel flexible water tube type boilers, each with capacities of 175 boiler horsepower (5.9 MMBtuh). This provides slightly more boiler capacity than required, but any standard boiler size smaller than 175 boiler horsepower would not provide adequate heating capacity.

Parameter	Unit	Value
Total heat demand (peak 14-day, 2035)	MMBtuh	11.1
Digester heat demand	MMBtuh	8.7
Building heat demand	MMBtuh	2.4
Fuel input gas input (peak 14-day, 2035)	MMBtuh	13.9
Fuel type		Natural gas / conditioned digester gas ^a
Number of Boilers	Duty / Standby	2 / 1
Maximum hot water output, each	MMBtuh	5.9
Minimum hot water output, each	MMBtuh	1.5
Water temperature	Deg F	180 - 200
Boiler NOx emissions ^b , natural gas / digester gas	ppm	12 / 15
Required fuel pressure (natural gas and digester gas)	psig	5
Boiler type		Flexible steel water tube
Boiler Basis of Design Model		Bryan RW850-W (hot water)

Table 2-16: Boiler Design Criteria

a. Conditioned digester gas is assumed to be provided at a pressure of 5 psig, have a minimum energy content of 550 Btu/scf, less than 40 ppm H₂S, dew point of 40 deg F, and less than 0.5 mg Si / Nm³.

b. South Coast Air Quality Management District boiler emissions requirement.

2.4 STRUVITE CONTROL SYSTEMS

2.4.1 Background

Struvite is a magnesium ammonium phosphate mineral (Mg NH4PO4 +6H2O) with the characteristics of a white crystalline solid. Under the digestion process, ammonia and phosphorus are released and if sufficient magnesium is present, struvite may form in the anaerobic digester tanks, digested sludge piping, and downstream dewatering equipment and centrate piping. Struvite

also forms under turbulent conditions where carbon dioxide is released. Once formed struvite may coat the interior surfaces of tanks, piping and dewatering equipment which reduces efficiencies, and can be difficult and costly to remove. Ferric Chloride (FeCl3) has been shown to be effective in struvite control by binding phosphorous (PO4) to form Iron Phosphate (FePO4). Ferric Chloride has also been demonstrated to reduce hydrogen sulfide concentrations in digesters.

2.4.2 Description of Approved Struvite Control System

IEUA stores a 38 percent solution of ferric chloride at the primary chemical facility in a single fiberglass reinforced concrete containment area. To precipitate phosphorus and inhibit struvite from forming, a 38 percent ferric chloride solution will be metered into an injection point prior to either or both the acid and gas phase digesters. A day tank and metering pump will be provided for ferric chloride injection at the 2-phase digestion facilities.

2.4.3 Design Criteria

The ferric chloride dosing facilities at the 2-phase digestion process will be sized for both orthophosphorous and sulfur removal. Although ortho-phosphorous is the primary target, the presence of hydrogen sulfide will compete for ferric chloride and result in additional ferric chloride demand. Preliminary sizing will assume up to 500 mg/l hydrogen sulfide removal and up to 100 mg/l orthophosphate removal. The preliminary equipment sizing at a 1.5 peaking factor above average annual is provided in Table 2-17. The preliminary day tank size for the Year 2035 deign condition is 3500 gallons which can provide 10 days' storage at Year 2025 and 6 days' storage at Year 2060. The initial ferric chloride day tank sizing was conservative to account for infrequent ferric deliveries to the plant and anticipated dosing rates related to struvite and H₂S control. It is likely smaller sized ferric day tanks may be applied for this application, but further evaluation is required. In addition, ferric chloride dosing rates and metering facilities will be confirmed during detailed design, as both will impact day tank sizing.

Performance Parameter	2025	2035	2060
Average Annual Solids Loading, ppd (RP- 5 and CCWRF)	66,200	98,300	105,500
FeCl3 flow rate, gph	15	23	24
FeCl3 Day Tank size at 7-day storage, gal	2500	3800	4100
Metering pump size, gph	32		
Day Tank Size, gal	3500		

Table 2-17: Ferric Chloride Day Tank and Metering Sizing Design Data

2.5 DEWATERING, CAKE TRANSFER, STORAGE, AND LOADOUT

2.5.1 Background

The new solids dewatering treatment facility at RP-5 will received digested solids generated from 2-phase anaerobic digestion and digestate received from the FOG and food waste digestion at the SHF facility. Dewatering is the final stage of solids treatment prior to disposal of solids.

Centrifuges are the preliminary selected technology for RP-5 solids dewatering. Technologies screened during the selection process included: centrifuge; belt filter press (BFP); and screw press (Volume III, Chapter 7). The selection of centrifuge dewatering was based on results from screening evaluations, high cake solids and solids capture, low daily maintenance, low equipment repair, minimal odor, IEUA familiarity with equipment, and discussion during the August 11, 2016 Workshop and October 2016 Board Workshop.

2.5.2 Description of Approved Dewatering Technology

A centrifuge is composed of two concentric cylinders, rotating at slightly different speeds. In the outer cylinder, centrifugal force propels the heavier digested solids to the wall of the outer cylinder at accelerations of approximately 3,000 gravitational units (Gs). Centrate, the remaining residual liquid, accumulates along the axis of rotation and is discharged over a concentric weir. The inner cylinder has a scroll encircling its outer surface. Because the inner cylinder rotates at a slightly slower rotational speed than the outer cylinder (the differential), the scroll moves along the inner surface of the outer cylinder, conveying the dewatered solids to a dewatering beach, and then to its discharge. The liquid centrate is conveyed via an overflow weir to a liquid drain. A picture of a dewatering centrifuge is presented in Figure 2-12.



Figure 2-12: Dewatering Centrifuge

Image courtesy of Alfa Laval

2.5.3 Dewatering Schematic and Preliminary Facility Layout

A schematic of the dewatering facility is shown in Figures 2-13 and 2-14. Four centrifuges will be provided for 2035. No redundant unit is provided. In an emergency, if a unit is off line during a high load period, operations can elect to increase centrifuge loading rates, continue to store until back on line or an extended operating period can be used up to 24-hour per day operation. - Supporting systems such as polymer, feed pumping, cake pumping and electrical will be designed to allow for operation of all dewatering units to operate simultaneously.

Three days of upstream digested sludge storage is provided to eliminate the need for dewatering shifts during three day weekends and also to provide additional operational flexibility for the dewatering system. To provide additional flexibility in operation, the digested sludge storage tank was sized to match the gas phase digesters. At this size, the tank will provide over three days of sludge storage and can serve as a backup digester if desired.




Figure 2-13: Dewatering Centrifuge Ground Floor Layout




Figure 2-14: Dewatering Centrifuge Upper Floor Layout

Results for centrifuge sizing are presented in Table 2-18 based on IEUA's preliminary selection of this dewatering technology.

Parameter	2025	2035	2060
Maximum month loading	3.1	3.9	4.7
Average annual loading	2.5	3.0	3.7

Table 2-18: Dewatering Centrifuge Equipment Number of Operating (Duty) Units

Digested sludge storage tank mixing will be provided to keep solids in suspension and digested sludge storage will be connected to the low pressure digester gas management system. Minimum total digested sludge storage requirements are shown in Table 2-19 to provide 3 days of storage. As previously described, the digested sludge storage tank was sized to match the gas phase digesters. At this size, the tank will provide over three days of sludge storage and can serve as a backup digester if desired.

Table 2-19: Digested Sludge Minimum Storage Requirement (3 days' storage)

Loading Condition	2025	2035	2060
Maximum month	901	1,101	1,344
Average annual	711	857	1,039

a. Storage requirements are shown in 1,000 gallons.

2.5.4 Dewatering Design Data

Projections for the solids flows and loads from anaerobic digestion to dewatering for both the maximum month and annual average conditions have been developed and are presented above.

The solids feed characteristics from anaerobic digestion that may impact dewaterability are summarized in Table 2-19.

Sludge Characteristics	Value
Nominal Sludge Composition, Total Dry Solids Weight Basis	Anaerobically digested blend of primary sludge, waste activated sludge, food waste and FOG
Total solids concentration, %TS	2.5
Volatile solids (VS), % dry mass basis	72
Temperature, deg F	85-100
Average pH	7

Table 2-20: Projected Dewatering Feed Characteristics

These design performance requirements (Table 2-21) will be refined based upon IEUA objectives and related process selections during detailed design. Maximum month digested sludge was selected for the design basis with the understanding that 3 days of upstream digested sludge storage will be provided, the operating schedule may be extended slightly during peak digested sludge production and a full standby unit will be provided.

Table 2-21: Dewatering System Performance Requirements

Performance Requirement	Value
Dewatering system solids processing capacity ^a , dry lb TS/hour	13,500
Dewatering system hydraulic processing capacity ^a , gpm	1,070
Minimum cake solids, % TS	24
Minimum solids capture efficiency, %	95

a. Based upon maximum month projection for 2035 and 8 hours/day, 5 day/week operating schedule.

Design criteria for the centrifuges and sizing results are summarized in Table 2-22. The design criteria for centrifuges are based on the "Basis of Design Manufacturer/ Model". Sizing for Phase 1 will be based on capacity to dewater the 2035 maximum month digested sludge production plus one standby unit. Initial sizing of the dewatering centrifuges assumed a capacity of 3,500 gpm. It is anticipated that greater capacities, up to possibly 4,000 gpm may be possible. The difference in centrifuge capacity does not impact the number of units required; therefore, this evaluation assumes 3,500 gpm. Further investigation into centrifuge capacity is recommended during detailed design. Ancillary equipment design data is provided in Table 2-23.

Table 2-22: Centrifuge Design Criteria

Design Parameter	Unit	Value
Number of Units		3+1
Unit Solids Loading Rate Capacity	lb/hr	4,000
Unit Hydraulic Loading Rate Capacity	gpm	300
Polymer Dosage	lb APS/dry ton	35
Connected Horsepower	hp	250
Basis of Design Manufacturer/ Model		Andritz D7LL
Bowl Diameter	in	30

Table 2-23: Ancillary Equipment Design Criteria

Design Parameter	Unit	Value
Dewatering Feed Pumps		
Number of Units		3+1
Capacity	gpm	300
Cake Pumps		
Number of Units		3+1
Capacity	lb/hr	4,000
Emulsion Polymer Bulk Storage		
Number of Units		2
Total Storage Provided	gallons	16,000
Polymer Make-Up Units		
Number of Units		1+1
Capacity	gpm	TBD
Polymer Solution Feed Pumps		
Number of Units		3+1
Capacity	gpm	70
Cake Storage Bins		
Number of Units		2
Total Storage Provided	cubic yards	425
Truck Loading Conveyors		
Number of Units		2
Capacity	wet tons/hr	250

2.5.5 Struvite Management

Current practices at RP-1 includes dosing of FlowSperse to control formation of struvite in the dewatering centrate lines. FlowSperse is a liquid dispersant design to reduce the potential for struvite accumulation in centrate piping downstream of the dewatering equipment. The dewatering facility will allow provisions for the storage and dosing of FlowSperse into the centrate system downstream of dewatering. It is intended that this practice will protect the centrate lines and centrate equalization system downstream of the dewatering from struvite accumulation.

2.5.6 Dewatering Odor Control

Dewatering centrifuges are totally enclosed and equipped with foul air take-off connections on the unit housings, centrate chutes and the solids chutes. Additionally, it is recommended that foul air connections be provided on all of the conveyors used to move solids between processes as they can be a significant odor source. Point source control of odors greatly reduces the quantity of foul air and ultimately the size of the odor control system. Sludge storage tanks and filtrate tanks will also be ventilated to reduce the potential for odor and corrosion. The foul air extracted from processes in the dewatering building will be conveyed to the centralized odor control facility. Odor control design criteria are presented in Table 2-24.

Location	Source	Design Criteria	Air Flow Rate per unit	Total Air Flow
Location	Source		cfm	cfm
	Centrifuge Per manufacturer		400	1000
	Conveyors	5 cfm/lf	200	1000
Dewatering Cake Bins	Leakage Rate, 1 cfm/sq. ft.	500	1000	
Truck Load Out 12 ACH Room		12 ACH	8500 (per bay)	17,000
e	Leakage Rate, 1 cfm/sq. ft.	1000	2000	

Table 2-24: Odor Control Design Criteria

2.6 CENTRATE EQUALIZATION & RETURN TO PRIMARY INFLUENT SPLITTER BOX

2.6.1 Background

Centrate from the dewatering treatment facility at RP-5 will received digested solids generated from 2-Phase anaerobic digestion, dewatering is the final stage prior to disposal of solids. Returning Centrate flows to RP-5 liquids process was the selected treatment alternative. Technologies screened during the selection process included disposal in an existing brine pipeline, side stream nitrogen removal, and side stream phosphorus removal (Predesign Report Volume II, Chapter 2). Returning Centrate flows to the RP-5 liquid process was the simplest alternative requiring only equalization tanks, minimal mechanical equipment, and odor control (supplied by a centrally located system). The selection of liquid stream treatment was based on results from screening evaluations, a BCE, IEUA familiarity of equipment, and recommendations during Workshops.

2.6.2 Description of Approved Centrate Equalization

Centrate is a nutrient rich residual stream produced by dewatering digestate. The stream is recycled to the head of the liquid stream treatment train and can represent 15-25% of the total nutrient load. Often requiring an increase in aeration basin volume and aeration demands to meet treatment limits for the additional load. Ammonia in Centrate can cause fluctuations in effluent pH and alkalinity, especially if Centrate is returned over a short duration of time. If total nitrogen removal is required Centrate can also represent a significant chemical demand for carbon limited facilities which require additional carbon sources (typically methanol) to balance the nutrient load. To prevent a short Centrate return duration an equalization tank is recommended to evenly distribute the Centrate over a 24-hour period. Centrate can also be returned to the liquid stream in a diurnal pattern to increase periods of low nutrient loading.

2.6.3 Design Criteria

The Centrate equalization tanks receive Centrate five days a week during the eight-hour dewatering shift, daily flows are reported in Table 2-25. Centrate will be stored in the equalization tanks and recycled to the liquid stream process at a constant rate over a 24-hour period. Alternatively, the centrate could be recycled to equalize the nitrogen loading to the secondary process. Centrate equalization equipment sizes are reported in Table 2-26. Two tanks are recommended to allow one to be temporarily taken offline for cleaning or maintenance. The total volume is sized based on the peak week Centrate flow. Each tank will use a VFD controlled mixer to keep particulates in suspension, mixers are sized based on a horizontal mixer orientation and industry standard 0.19 to 0.27 hp/1,000 cubic feet (Water Environment Federation, 2012). The mixer speed will be controlled based on tank level to prevent overmixing and air entrainment. A VFD driven feed pump controls Centrate flow back to the liquid stream, a small manual daily adjustment of the VFD will be required to adjust for daily Centrate volume fluctuations. During peak Centrate flow or when one tank is offline the Centrate return period will have to be shortened.

	Average Annual	Max Month	Max 2- Week	Max Week	Max Day
Centrate Flow (gpd)	333,270	429,377	496,653	513,472	530,291

Table 2-25: Ancillary Equipment Design Criteria

Table 2-26: Ancillary Equipment Design Criteria

Centrate Equalization Sizing	Value
Tank Volume (MG)	0.29
Number of Tanks	2
Mixer Power (hp)	8.0
Feed Pump (gpm)	400

2.6.4 Centrate Odor Control

Centrate equalization tanks can be a source of odor; therefore, it is recommended that air from the headspace of the tanks be collected and treated in the centralized odor treatment system. The amount of foul air will be sized to maintain a slight negative pressure within the tank preventing odorous air emissions to the atmosphere. This is based on a number of items including liquid level in the tank, common leakage rates for the tank material and leakage rates from access hatches and other openings.

2.7 FOOD WASTE RECEIVING AND FEED TO SHF DIGESTERS

RP-5 SHF currently accepts food waste for processing, digestion, and dewatering. Several alternatives were evaluated for handling, processing, and digestion of food waste. These alternatives included the following:

- 1. No food waste digestion (base case)
- 2. Co-digestion of food waste with biosolids at RP-5
- 3. All food waste processed and digested at RP-5 SHF

The selected alternative was to send all food waste for processing and digestion to RP-5 SHF and bring the food waste digestate to RP-5 for dewatering. The main drivers for this decision are

- Avoidance of potential for digester upsets at RP-5 due to inconsistent food waste composition
- Elimination of dewatering operations at RP-5 SHF, which have reportedly been a bottleneck due to limited capacity
- Economies of scale associated with dewatering both digested solids streams together (food waste digestate from SHF and biosolids digestate from RP-5)
- Avoidance of costs associated with centrate discharge to IEBL at RP-5 SHF

2.7.1 Description of Approved Food Waste project

A new food waste receiving station will be constructed at RP-5 SHF to increase the quantity of food waste that can be processed. The Agency decided that receiving station will be designed to handle only food waste in the form of a pre-processed slurry; FOG will not be accepted. The new receiving station will be capable of processing up to 50,000 gallons per day of food waste. The receiving station will have two days of storage capacity to accommodate processing of food waste deliveries that are expected to occur only on weekdays. In addition, the approved project considers transferring all digestate from RP-5 SHF to RP-5 for dewatering. A new digestate transfer pump station and pipeline will be installed at SHF. The digestate will be transferred to the RP-5 digested sludge holding tank prior to dewatering.

Sending digestate to RP-5 will require an additional centrifuge to handle the increased dewatering load. The cake storage silos must also increase in size due to the added dewatered solids. Additionally, the centrate equalization tanks and pumps must be larger due to the increased centrate quantity. The major equipment required for the food waste approved project is listed below in Table 2-27.

Item	Units	Value	Remarks
Food Waste Storage/Receiving Tanks	-	2	
Capacity, each	gallons	50,000	
Food Waste Mixing/Transfer Pumps	-	2	1 per storage/receiving tank
Capacity, each	gpm	850	
SHF Digester Feed Pumps	-	2	
Capacity, each	gpm	35	
Digestate Transfer Pumps	-	2	
Capacity, each	gpm	70	
Additional Centrifuge	-	1	
Capacity, each	gpm	300	

Table 2-27: Equipment for Food Waste Approved Project

2.7.2 Schematic and Preliminary Facility Layout

The new food waste receiving station at RP-5 SHF will be capable of processing up to 50,000 gallons per day. A schematic for the receiving station is shown in Figure 2-15 and a layout of the facility is shown in Figure 2-16.




Figure 2-15: Food Waste Receiving Schematic




Figure 2-16: Food Waste Receiving Station Layout

The digestate pipeline route from RP-5 SHF to RP-5 is shown in Figure 2-17. This route follows the Agency's easements and does not encroach on properties owned by others. The pump station location is yet to be determined and must be coordinated with IBE (current operators of SHF).



Figure 2-17: Digestate Pipeline Route

2.7.3 Design Criteria

The food waste receiving station will be designed to handle 50,000 gallons per day of preprocessed slurry. The digestate pump station and pipeline will be designed to transfer up to 100,000 gallons per day of digestate – 50,000 gallons per day of the pre-processed slurry plus approximately 50,000 gallons per day of industrial food waste (currently being received at SHF).

Design of the food waste receiving station considers deliveries of 70,000 gallons per day (equivalent to 14 truckloads) five days per week, providing two days of storage over the weekend.

2.8 DIGESTER GAS UTILIZATION

The digester gas produced from biosolids digestion at RP-5 and food waste digestion at RP-5 solids handling facility (SHF) will be beneficially used in a digester gas utilization facility. Several alternatives were evaluated (Refer to Chapter 9) for the utilization of digester gas, including:

- 1. Utilize existing IC engines for cogeneration
- 2. Install microturbines for a new cogeneration system
- 3. Install gas turbines for cogeneration with combined gas from RP-5 and RP-1
- 4. Install gas upgrading system for production of renewable natural gas (RNG) for pipeline injection
- 5. Install gas upgrading system for production of compressed natural gas (CNG) for vehicle fuel

The utilization of the existing IC engines is the selected alternative for digester gas utilization. This alternative was chosen because it allows the Agency to fully utilize the capacity of the REEP engines while simultaneously exploring alternative gas utilization technologies, such as production of CNG or RNG.

2.8.1 Description of Approved Digester Gas Utilization Project

Digester gas produced at RP-5 will be sent to a new gas conditioning facility prior to utilization in the two existing REEP engines. Gas conditioning will consist of H2S removal, moisture removal (refrigeration), and siloxane removal. After treatment, the gas will be used either in the boiler facility to produce hot water for digester heating or in the REEP IC engines for cogeneration of heat and power. The digester gas from RP-5 will be combined with food waste digester gas from RP-5 SHF to be used together in the IC engines. The existing heat recovery system at REEP will be modified to allow for waste heat recovery and to use heat produced by the engines for digester heating. Selective Catalytic Reduction (SCR) units will be added to treat the exhaust from the two IC engines at REEP to meet SCAQMD NOx emission limits. Further, additional gas treatment is required at SHF for projected gas quantities. Two iron sponges, similar to existing, will be installed at SHF. The equipment required for the approved gas utilization project is listed below in Table 2-28.

Item	Units	Value	Remarks
RP-5 H2S Removal Units	-	4	iron sponges or SulfaTreat TM
Capacity, each	scfm	230	lead/lag configuration; adequate for 2035 gas projections
Refrigeration Unit		1	
Capacity, each	scfm	460	
Siloxane Removal Units	-	4	
Capacity, each	scfm	230	lead/lag configuration; adequate for 2035 gas projections
SCR Units	-	2	one for each IC engine
RP-5 SHF H2S Removal Units	-	2	iron sponges
Capacity, each	scfm	TBD	Will match capacity of existing units

Table 2-28: Required Equipment for Gas Utilization Project

2.8.2 Schematic and Preliminary Facility Layout

A schematic of the approved digester gas utilization project is shown below in Figure 2-18. The acid gas and methane-phase gas are blended together and will be pulled through the H2S removal units by two booster blowers. The refrigeration system will chill the gas and moisture is removed in the form of condensate, which incidentally removes a portion of siloxanes from the gas. The downstream siloxane removal system will remove the remainder for siloxanes from the gas. Gas will then either be used at the boilers or will be boosted to about 45 psi to mix with SHF gas and be used at the REEP engines.




Figure 2-18: Gas Utilization Schematic

A layout of the gas treatment facility is shown in Figure 2-19.




Figure 2-19: Gas Conditioning System Layout

A schematic of the modified heat recovery system is shown in Figure 2-20.




Figure 2-20: Preliminary Schematic of Modified Heat Recovery System

2.8.3 Design Criteria

Gas projections for RP-5 were calculated using the sludge quantity projections and the following assumptions:

- RP-5 Digester volatile solids reduction (VSR) = 60%
- Gas production = 15 cu. ft. per lb VS reduced

Gas projections for RP-5 SHF were calculated based on existing data and the following assumptions:

- 3,200 cu. ft. per wet ton of EBS
 - o Based on OCSD pilot study and operational data from EBMUD
- 2,230 cu. ft. per wet ton of industrial food waste
 - o Based on operational data from RP-5 SHF

The projections of gas quantities (based on annual average biosolids and food waste and FOG availability) for both sources (RP-5 and RP-5 SHF) are shown in Table 2-29.



	Year					
Digester Gas Source	2025	2030	2035	2040	2045	2060
Digester Gas from RP-5 Biosolids Only	360	420	460	500	530	570
Digester Gas from food waste at RP-5 SHF	590	600	620	640	660	700

Table 2-29: Digester Gas Quantity Projections

2.9 BIOGAS CONDITIONING / WASTE GAS BURNERS

2.9.1 Background

Waste gas burners are required anaerobic digestion safety equipment used for eliminating excess biogas. The selection of two-phase anaerobic digestion technology for RP-5 solids digestion will produce two separate biogas streams. The first phase or acid-phase vessels will generate a relatively small amount of lower quality gas containing methane, CO_2 and H_2S . The second digestion phase will be a thermophilic (digester) process and will generate a gas with favorable methane concentrations for beneficial utilization; in the Renewable Energy Efficiency Project (REEP) or the boilers.

With two very different biogas streams generated by the selected digestion method, an evaluation of varying technologies and process configurations was performed to determine the most efficient and cost-effective approach for waste gas burning.

To meet air permitting regulations two ultra-low emissions enclosed flares were the selected waste gas flaring alternative. The recommended configuration combines the acid-phase and the digester gas streams into a single flow stream which can then either be flared or beneficially utilized.

The selected waste gas technology was based on screening results, regulatory emission standards, and a Business Case Evaluation (BCE). The selected waste gas technology and configuration for 2-phase digestion is a refinement of the initial discussion in Volume III, Chapter 7. This was due to the increased capital and Net Present Value (NPV) costs incorporated into each alternative.

2.9.2 Description of Approved Waste Gas Elimination Technology

Ultra-low emissions enclosed flares (shown in Figure 2-21) have a similar configuration to standard enclosed combustion flares in regard to the flaring section with an enclosed tower that promotes flame stability. Where the ultra-low emissions flare differs is the addition of specialized combustion air blowers and an extended fuel/air pre-mixing section upstream of the flare to ensure a consistent homogenous air/fuel mixture. These blowers bring in additional air that is blended with the biogas prior to combustion resulting in lower emissions of criteria pollutants.



Figure 2-21: Enclosed Flare

Note: Image courtesy of John Zink

2.9.3 Waste Gas Elimination Schematic and Preliminary Layout

Figure 2-22 shows the recommended preliminary waste gas elimination schematic. Redundancy is recommended for both the H_2S removal system and the gas booster blowers, both of which are critical components in the waste gas flaring process.




Figure 2-22: Waste Gas Flare PFD

The preliminary layout of the waste gas elimination equipment places the gas treatment equipment and the flares near the boiler, dewatering, and power buildings south of the digesters is presented in Figure 2-23 below.




Figure 2-23: Waste Gas Facility Layout

2.9.4 Waste Gas Elimination Design Data

Design criteria for flare type and sizing are set by calculated biogas production and regulatory emissions requirements. The flares are sized to handle the peak design gas production when all other utilization equipment is out of service, but also to handle small amounts of gas when production minimally exceeds utilization. For this reason, two independent flares, of differing sizes and capacities, are needed to turn down for the lower gas flows while still meeting the maximum case capacity. Biogas design criteria for the waste gas flares are presented in Table 2-30.

Parameter	Unit	Value
Biogas Production, average day (2045)	scfm	530
Biogas Production, peak day (2045)	scfm	965
Gas Peaking Factor (waste gas)		1.5
Design Biogas to Flares, maximum (2045)	scfm	1,450
Design Acid-Phase Gas, maximum (2045)	scfm	100
Treated Biogas H ₂ S Concentration to the Flares	ppmv	40
Methane Concentration in Thermophilic Gas	% mole	~60
Methane Concentration in Acid-Phase Gas	% mole	13-25

Table 2-30: Biogas Design Criteria

As a data reference for the biogas constituents, digester gas sample data from the IEUA RP-1 facility was obtained, for both acid-phase and thermophilic phase. The RP-1 facility also utilizes a two-phase digestion method. The 40 ppm H₂S concentration to the flares is a plant-wide air quality requirement per SCAQMD Rule 431.1 that will be achieved by the H₂S removal system.

2.10 IEBL DISCHARGE STATION RELOCATION

The existing IEBL Discharge Station is currently located at the RP-2 site along El Prado Road, near the intersection with the southern end of Mountain Avenue, as shown in Figure 2-24. The IEBL Discharge Station is a septage receiving station that receives trucked liquid waste from permitted haulers and discharges the waste to the 27-inch diameter IEBL (previously known as the Santa Ana Regional Interceptor – SARI) on El Prado Road. The IEBL is owned by the Santa Ana Watershed Project Authority (SAWPA) while IEUA owns and maintains the IEBL Discharge

Station and the 8-inch diameter sewer lateral connecting the Discharge Station to the IEBL. The IEBL transports salty wastewater to the Orange County Sanitation District's wastewater treatment facility (Plant 2) in Huntington Beach.

Due to the anticipated decommissioning of RP-2, the station may be relocated to a site within the Agency-owned Solids Handling Facility at Mountain Avenue and Flower Street, as discussed in Chapter 5 of this volume.

IEBL DISCHARGE STATION DISCHARGE STATION FENCE **INV EL: 566** GATES FG EL: 570 WB-50 SEMI TRAILER ROUTE AC PAVEMENT GATES ENTRANCE / EXIT GATE POTENTIAL FOOD WASTE RECEIVING STATION **RP-5 SOLIDS** HANDLING ALTERNATE FACILITY EXIT PATHWAY

The proposed configuration of the relocated facility is illustrated below.

Figure 2-24: Site Layout

The IEBL Discharge Station will feature a dump station manhole, which receives septage/permitted liquid waste from two receiving stations, and two catch basins that capture any stormwater and spray down waste. Each receiving station will include a quick disconnect coupling where hauling trucks can connect in order to discharge the waste. The incoming waste is analyzed for pH, temperature, conductivity, and sulfide—ensuring the waste does not surpass the IEBL disposal limits. A magnetic flow meter and automatic sampler will be provided in the station. The dump station manhole will route septage/liquid waste through an 8-inch diameter pipeline to the 27-inch diameter IEBL. In this design, the septage is contained and odors are limited from escaping into the atmosphere.

The IEBL Discharge Station will have restricted access where only permitted waste haulers can enter the fenced area. Several instruments and electrical equipment will be provided at the IEBL Discharge Station as listed below:

- (4) Proximity Card Readers
- (4) Gate Controllers, (4) Gate Actuators with (3) Detector Loops each

- (2) Flood Light/Camera supported on a Pole
- Modular Enclosure: Lighting Panel, SCADA Panel, Security Panel, and Irrigation Controller

Two of the proximity card readers will be provided outside of the fence, where the trucks enter the station while the other two are featured inside of the fence, where the trucks exit the station. Signals from the card readers will be sent to the gate controllers, which together with the detector loops, control the opening and closing of the gates. A pair of flood lights and cameras will be included at the station to enforce site security. The panels in the modular enclosure will receive and transmit signals to the communication panel located in the SHF plant control station.

2.11 RP-2 LIFT STATION RELOCATION AND NEW FORCE MAIN

The existing RP-2 lift station receives raw sewage from the 24-inch diameter Mountain Avenue interceptor sewer, 10-inch diameter Chino Institute for Women (CIW) sewer, 10-inch diameter Butterfield force main, and recycled flows from the solids treatment facilities at RP-2, as shown in Figure 2-25. The 10-inch diameter CIW sewer receives sewage flows from both the CIW and the El Prado Golf Course clubhouse. Each pump discharges into a 14-inch diameter discharge pipe connecting to a 24-inch diameter discharge manifold that conveys flows to the RP-5 headworks.

Due to the anticipated decommissioning of RP-2, the lift station must be relocated above the Prado Dam inundation area above elevation 566, and the associated collection/discharge system must be modified to account for these changes.

As discussed in Chapter 4 of this volume, the new location for the lift station has been established at the Agency-owned Solids Handling Facility along Mountain Avenue near Flowers St., as shown in Figure 2-25.




Figure 2-25: RP-2 Lift Station

As discussed in Chapter 4, the collection system will be modified such that the CIW flows and golf course will be handled separately in a joint agreement with City of Chino. Thus, the flows to be received and pumped at the new location include the Mountain Avenue Sewer, thus the facility will be renamed as the Mountain Avenue Lift Station. The Butterfield Ranch lift station flows are discussed in a separate subsection below, and will be combined with the discharge of the Mountain Avenue Lift Station.

2.11.1 Lift Station Capacity

The Agency has forecasted that the average flows of the new lift station would be 0.3 mgd from present day to year 2040 and 0.4 mgd from 2040 to 2060. Assuming a peaking factor of 2.0, the design flow for this lift station is 0.8 mgd or 560 gpm. Therefore, two pumps (one duty and one standby) sized at 0.8 mgd (560 gpm) each will be provided to meet peak flows.



2.11.2 Influent Gravity Sewer

The invert elevation of the Mountain Avenue sewer manhole ("Manhole No. 8") at Kimball Avenue is 559.96¹. The invert elevation of the Mountain Avenue sewer near SHF was assumed to be 556.75, with the assumption that the Mountain Avenue sewer shares the same slope as the Mountain Avenue.

The sewage flows in the Mountain Avenue interceptor sewer will be intercepted with a new diversion manhole. With a minimum slope of 0.0056 ft/ft and pipe diameter of 10 inches, the velocity of sewage flowing full through the pipe will be 3.0 ft/s. To reach the new wet well, the pipeline will be approximately 40 feet in length and enter at an invert elevation of 556.53.

2.11.3 Sewage Force Main

The lift station will discharge the sewage flows to an existing manhole on the Kimball Avenue Interceptor sewer, approximately 3,200 feet north on Kimball Avenue, through a new force main. The recommended size of the force main is 12-inch diameter, accounting for the flows from Butterfield Ranch as discussed below.

2.11.4 Wet Well

The wet well will have an inner diameter of 8 feet and be constructed of either concrete or fiberglass material. The wet well will contain two rail-mounted submersible pumps. The lead pump will stop at an elevation no less than the minimum submergence level per the selected pump's specifications. The bottom of the wet well elevation will be set to limit the motor to maximum six starts per hour.

2.11.5 Valve/Meter Vault and Appurtenances

Each pump will discharge into a respective 8-inch diameter lateral pipe, which will enter a valve/meter vault containing check valves, isolation valves, and a flow meter. One of the 8-inch discharge pipelines will include a quick disconnect coupling for a bypass connection to a portable pump in the event of pump failure.

The wet well and valve vault will be provided with ventilation pipes. Additionally, a 2-inch diameter drain will be provided between the valve/meter vault and wet well to drain any water that may enter the vault. A plant water line will be provided for a hose bibb connection to allow for wash down activities. An above ground control panel in a NEMA-4 enclosure will be provided along with electrical conduits for power and signaling. The pumps will be designed to alternate daily to extend the life of the pumping equipment.

In-line emergency storage of 60 minutes at peak flow (or 4,500 ft³) can be provided in the 24-inch diameter Mountain Avenue Interceptor sewer that connects to the 8-inch diameter influent pipeline. The MCC will be equipped with a manual transfer switch and connectors suitable for connection to a potable emergency generator in the event of a power failure. Alternatively, by connecting to the provided quick disconnect coupling, a portable pump can pump flows in the wet well to the force main and bypass the submersible pumps should it be required.

¹ Project No. EN97004-3 Phase II record drawings.

2.12 BUTTERFIELD RANCH LIFT STATION MODIFICATIONS AND FORCE MAIN EXTENSION

The Butterfield Ranch Lift Station (Figure 2-26), located about 2 miles south of RP-2, is owned and operated by the City of Chino.




Figure 2-26: Butterflied Ranch Lift Station

Due to the anticipated decommissioning of RP-2, the flows from Butterfield Ranch will need to be conveyed to the Kimball Avenue Interceptor as illustrated herewith, combining the Butterfield Ranch peak flows of around 1100 gpm, with the Mountain Avenue flows of up to 560 gpm. The Butterfield Ranch force main will be extended by 3000 feet of 10-inch diameter, followed by 3200 feet of 12-inch force main once the flows are combined with the new lift station for Mountain Avenue.

The Butterfield Ranch lift station pumps, motors, and electrical system will be modified for the additional power requirements to achieve the additional pump discharge head required to pump the additional distance and to a somewhat higher elevation. The details of these modifications will be determined during the design phase when the current and future flows are confirmed with the City of Chino.

2.13 SCADA INTEGRATION

The following list of Process Control Narratives (PCNs) is required to complete the project (see Table 2-31 through 2-33). The developed PCNs will be used by the system integrator or vendor to program the PACs and PLCs to monitor and operate as required. The PCNs will ensure that the new processes will seamlessly connect to and operate through the upcoming SCADA Enterprise System.

Process/Area	System/Equipment PCN
Influent Pump Station	Influent Pumps
Headworks	Mechanical Bar Screens
	Fine Screens
	Screenings Washer/Compactors
	Grit Removal System, Pumps, Classifiers
Primary Clarifiers	Primary Sludge Grinders
	Primary Sludge Pumps
	Primary Scum Pumps
	Primary Diversion Structure Gates
	Ferric Chloride Storage and Feed System
Odor Control System	Foul Air Fans
	Recirculation Pumps
Aeration Basins	Aeration Blowers
	Aeration Flow Control Valves
	Anoxic Mixers
	MLR Pumps
MBR Treatment System	Membrane Tank Inlet Gates
	Membrane Tank Drain Valves
	Membrane Tank Drainage Pump
	Scour Air Blowers
	Scour Air Valves
	Filtrate Pumps/Valves
	Backpulse Pumps/Valves
	Chemical CIP Pumps/Valves Citric Acid Feed
	Sodium Hypochlorite Feed
	Compressed Air System

Table 2-31: Liquids Treatment Processes PCNs

Process/Area	System/Equipment PCN
	RAS Pumps
	WAS Pumps
Methanol Injection System	Metering Pumps
UV Disinfection System	UV Channel Outlet Gates
	UV Lamps
	Wiper System
	Off-Spec Valve
Off-Spec and Emergency Storage	EOP Pumps
Recycled Water & Plant Water	Non-chlorinated plant water pump station
Systems	Sodium Hypochlorite Feed System for Recycled Water Storage
	Chlorinated plant water pump station

Process/Area	System/Equipment PCN
Solids Thickening	Rotary Drum Thickeners Sludge Blending and Thickener Feed Pump Station Emulsion Polymer Make-up and Feed System Thickened Sludge Pumps Filtrate Return Pumps Sump Pumps
Digestion	Acid and Methane Phase Sludge Feed Control Valves Sludge Mixing Pumps Sludge Heating System Sludge Transfer Pumps Sludge Grinders Ferric Chloride Injection System Sump Pumps
Dewatering & Cake Storage	Centrifuges Dewatering Feed Pumps Emulsion Polymer Make-up and Feed System Dewatered Sludge Cake Conveyors and Pumps Flosperse Feed System for Struvite Control Building Sump Wastewater Pumps Cake Storage Silos Dewatered Sludge Pumps Truck Loading Screw Conveyors
Centrate Equalization and Pumping	Centrate Transfer Pumps
Gas Purification and Flare System	H2S Removal System Siloxane Removal System Enclosed Flare System
Renewable Energy Efficiency Project (REEP)	SCRs – Engine Exhaust Cleaning Systems Heat Recovery System
Boilers	Boilers

Table 2-32: Solids Treatment Processes PCNs

Table 2-33: Offsite Facilities PCNs

Process/Area	System/Equipment PCN
Mountain Ave Lift Station	Lift Pumps
Chino Hills Butterfield Ranch Lift Station	Lift Pumps
IEBL Discharge Station	Septage Receiving Station
Food Waste System	Food Waste Receiving at SHF
	Digestate Transfer from SHF to RP-5

The primary goal of the IEUA SCADA Master Plan is to define the path to build a fully integrated and uniform SCADA system that provides enterprise-wide control and the information necessary to optimize operations. To fulfill this goal, IEUA is currently migrating all facilities to a Rockwell Automation PlantPAx SCADA Enterprise System. Parsons assumes that the migration of the SCADA system at RP-5 will be complete and operational prior to this expansion project.

The IEUA Engineering Design Guidelines was developed to provide consulting engineers/designers the design preferences of the Agency to improve consistency and efficiency to project deliveries. Within these guidelines are the Agency's standards for PAC programming, High-Performance HMI programming and Alarm Management. It also includes the Agency's preferences for control panel components, control system hardware and software and instrumentation.

2.14 PERMITTING

Required permits include the following:

- Permits for on-site facilities:
 - City of Chino building permit (IEUA may be exempt from local requirements for wastewater treatment process related facilities)
 - Chino Valley Fire District fire protection permit
 - State Water Resources Control Board waste discharge requirements amendment
 - South Coast Air Quality Management District air quality permit to construct
 - Title 22 Permit Update
- Permit for Off-Site Facilities:
 - City of Chino Public Works Department encroachment permit for new pipelines in public rights-of-way
 - City of Chino Hills building permit (for the Butterfield Lift Station upgrade)

2.15 DETAILED PROJECT SCHEDULE

The project milestone schedule is shown below in Table 2-34.

Table 2-34: Project Milestone Schedule

Project Milestone	Target Date (mm/dd/yyyy)
30% Design Completion	11/01/2017
50% Design Completion	04/01/2018
85% Design Completion	11/01/2018
100% Design Completion	04/01/2019

2.16 OVERALL PROJECT COST ESTIMATE

The overall solids train project cost estimate is shown below in Table 2-35.

Item Number	System Components	Cost
	ds Treatment Facility Costs	
1	Piping from CCWRF to Thickening & Pump Modifications @ CCWRF	\$303,000
2	Thickening (RDTs)	\$6,012,000
3	Acid Phase Digestion	\$3,041,000
4	Gas Phase Digestion - Thermophilic/Mesophilic	\$19,287,000
5	Digested Sludge Storage/Backup Digester	\$6,000,000
6	Dewatering, Cake Storage, and Truck Loadout	\$24,780,000
7	Odor Control Ductwork to Centralized Odor Control	\$1,140,000
8	Centrate Handling	\$720,000
9	Boilers	\$2,945,000
10	Digester Gas Conditioning	\$1,845,000
11	Waste Gas Flares	\$2,700,000
12	Power Generation	\$1,002,000
13	Heat Recovery Modifications	\$505,000
14	Power Building	\$1,250,000
15	Site Work	\$4,770,120
16	Base Biosolids Cost (w/o SHF)	\$76,300,120
17	Overhead & Profit, Inflation, Bonds & Insurances, Contingency (30%)	\$49,671,000
18	Total Biosolids Construction Cost (w/o SHF)	\$125,971,000
19	Design & Administration	\$25,194,000
20	Total Biosolids Project Cost (w/o SHF)	\$151,165,000
Food Wa	ste Receiving Costs	
22	HSW Receiving Station	\$2,000,000
23	Transfer Pumps & Piping from SHF to Digested Sludge Storage	\$296,000
24	RP-5 SHF Dewatering Centrifuge, Hopper, Centrate and Building Allocation	\$2,750,000
25	Digester Gas Storage	\$0
26	RP-5 SHF Digester Gas Conditioning & HP Storage	\$654,000
27	Base SHF Cost Allocation	\$5,700,000

Table 2-35: Solids Treatment Approved Project Cost Estimate

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 2: Approved Project Requirements

Item Number	System Components	Cost				
28	Overhead & Profit, Inflation, Bonds & Insurances, Contingency (30%)	\$3,711,000				
29	Total SHF Construction Cost	\$9,412,000				
30	Design & Administration	\$1,882,000				
Total Foo	Total Food Waste Receiving Cost					
Total Pro	Total Project Cost (RP-5 Solids and Food Waste)					

Additional items were identified as preferred options during development of the approved project, but due to anticipated budgetary limitations, were not included in the base project. These optional items may be added to the base project during the next project phase, budget allowing. The cost estimate for these additional optional items are shown in Table 2-36.

Table 2-36: Solids Treatment Approved Project Additional Project Options Cost Estimate

	Additional	
Additional System Components	Project Cost	Description
Acid Phase Digestion	\$2,098,000	1 Acid (0.37 MG) (1+1)
Gas Phase Digestion - Thermophilic/Mesophilic	\$9,139,000	1 Thermo (1.52 MG) (3+1)
Dewatering, Cake Storage, and Truck Loadout	\$4,557,000	1 centrifuge @ 300 gpm
		Cake storage, 2 x 6,000 cf

THIS PAGE INTENTIONALLY LEFT BLANK.

APPENDIX 2-A: RP-5 SOLIDS TREATMENT FACILITY APPROVED PROJECT DETAILED COSTS

THIS PAGE INTENTIONALLY LEFT BLANK.

Mountain Ave. Lift Station - Pre-packaged									
	Cost Estimate								
ltem No.	Description	No. of Items	Units	Quantity	Unit Cost (\$)	Cost (\$)			
	EQUIPMENT								
1	Pre-packaged Lift Station			1	\$ 112,000	\$ 112,000			
2	Excavation			1	\$ 14,000	\$ 14,000			
	Equipment Installation		%		15%	1 - 1			
	Electrical & Instrumentation, SCADA interface		%		15%	\$16,800			
	FITTINGS, VALVES, FLOW METER								
3	8"x6" Reducer			2	\$ 239	\$ 500			
4	8-inch 90-degree elbow			4	\$ 350	\$ 1,400			
5	8-inch tee			1	\$ 521	\$ 521			
6	Quick disconnect			1	\$ 1,200	\$ 1,200			
	Equipment Installation		%		45%	\$1,629			
	PIPELINE								
7	8-inch Pipeline	50	ft	1	\$ 192	\$ 10,000			
8	10-inch Pipeline	40	ft	1	\$ 200	\$ 8,000			
9	8-inch Pipeline	3100	ft	1	\$ 192	\$ 595,000			
	MANHOLE MODIFICATIONS								
10	Connect to Kimball manhole, add diversion manhole			1	\$ 20,000	\$ 20,000			
	SITE IMPROVMENTS								
11	Block Wall			1	\$ 9,700	\$ 9,700			
12	AC Pavement			1	\$22,000	\$ 22,000			
13	Slide Gate			2	\$ 9,000	\$ 18,000			
14	Security Gate	-	-	1	\$3,200	\$ 3,200			
15	Fence			1	\$ 7,425	\$ 7,425			
	Total Equipment and Structures Cost					\$858,000			
3.1	Sales Tax		%		9%				
	Unit Cost Estimate					\$886,000			

	IEBL Discharge Station Approved Project Cost Estimate								
ltem No.	Description	No. of Items		Quantity	ι	Jnit Cost (\$)	Cost (\$)		
	Piping								
1	8-inch Pipeline	750	ft	1	\$	192	\$144,000		
	STRUCTURES								
2	IEBL Structures			1	\$	11,300	\$11,300		
3	Manhole			1	\$	7,000	\$7,000		
	Installation			1		15%	\$2,745		
	Excavation			1	\$	15,000	\$15,000		
	CIVIL WORK								
4	Asphalt Paving			1	\$	186,000	\$186,000		
	SECURITY								
6	Security gate, card reader, bollards			1	\$	15,000	\$15,000		
	Electrical & Instrumentation		%			15%	\$2,250		
	EQUIPMENT								
7	Equipment Relocation		LS	1		\$10,000	\$10,000		
	Total Equipment Cost								
	Subtotal of above items						\$393,000		
3.1	Sales Tax		%			9.000%	\$11,000		
	Construction Cost Estimate						\$404,000		

	Thickening Facility Cost Estimate							
ltem No.	Description	No. of Items	Units	Quantity	Unit Cost (\$)	Cost (\$)		
	Equipment							
1.1	Rotary Drum Thickener (Parkson) Package	4	each	4	\$190,000.00	\$760,000		
1.2	Feed Solids Pumps	4	each	4	\$40,668.74	\$162,675		
1.3	Thickened Sludge Pumps	4	each	4	\$21,543.76	\$86,175		
1.4	Effluent Pumps	2	each	2	\$31,329.84	\$62,660		
1.5	Polymer System	1	each	1	\$257,000.00	\$257,000		
	Structures							
1.6	Concrete for Blending Tank	1	CY	116	\$800.00	\$92,800		
1.7	Concrete for Filtrate Tank		CY	25	\$800.00	\$20,000		
1.8	Excavation for Blending Tank		CY	716	\$16.90	\$12,100		
1.9	Excavation for Filtrate Tank	1	CY	130	\$16.90	\$2,197		
1.10	Ground level builing	1	sqft	10950	175	\$1,917,000		
1.11	Basement level builing	1	sqft	6750	148.75	\$1,005,000		
	Total Equipment Cost					\$1,328,509.70		
	Total Structures Cost					\$3,049,097.40		
2.1	Equipment Submittal and Testing markups		%		15%	\$114,000.00		
2.2	Equipment Installation		%		23%	\$305,557.23		
2.3	Mechanical and Piping		%		23%	\$305,557.23		
2.4	Electrical and I&C		%		30%	\$398,552.91		
2.5	Coatings		%		6.5%	\$86,353.13		
2.6	Odor Control		scfm	1800	\$40.88	\$73,584.00		
	Total Cost					\$5,661,211.60		

	Digestion (incl Digested Sludge Sto	rage) Fac	cility Cost	t Estimate	e	
ltem No.	Description	No. of Items	Units	Quantity	Unit Cost (\$)	Cost (\$)
	Acid Silo Equipment					
1.1	Acid Silo Cover - 30 ft dia	2	each	2	\$54,122.00	\$108,244
1.2	Acid Silo Mixer - Pumped Mixing System (1 Per Digester)	2	each	2	\$129,550.00	\$259,100
1.3	Acid Silo HEX (1 Duty + 0 Stand-By Per Digester)	2	each	2	\$150,000.00	\$300,000
1.4	Acid Silo Solid Circulation Pump (1 Duty Per Digester + 1 Stand-By Every Two Digesters)	3	each	3	\$61,000.00	\$183,000
1.5	Silo Feed Control Valves (1 Per Silo)	2	each	2	\$6,500.00	\$13,000
	Digester Equipment					
1.6	Digester Feed Control Valves (1 Per Digester)	4	each	4	\$6,500.00	\$26,000
1.7	Digester Cover	4	each	4	\$384,868.16	\$1,539,473
1.8	Digester Mixer - Pumped Mixing System (1 Per Digester)	4	each	4	\$295,290.50	\$1,181,162
1.9	Digester HEX (1 Duty + 0 Stand-By Per Digester)	4	each	4	\$150,000.00	\$600,000
1.10	Digester Feed Pump	2	each	2	\$61,000.00	\$122,000
1.11	Digester Solid Circulation Pump (1 Duty Per Digester + 1 Stand-By Every Two Digesters)	6	each	6	\$61,000.00	\$366,000
1.12	Digester Withdrawal/Standpipe Pump(1 Duty + 1 Stand-By Per Digester)	6	each	6	\$35,000.00	\$210,000
1.13	Inline Grinder (1 Duty Per Digester + 0 Stand-By Every Two Digesters)	4	each	4	\$25,000.00	\$100,000
1.14	Standpipe, 316 SS, 36" (1 Per Digester)	4	each	4	\$40,000.00	\$160,000
1.15	Digester Gas Foam Suppression Tank (1 Per Digester)	4	each	4	\$44,000.00	\$176,000
1.16	Digester Gas PVRV Assembly (1 Per Digester)	4	each	4	\$8,000.00	\$32,000
1.17	Digester Gas Safety Selector Valve (1 Per Digester)	4	each	4	\$16,000.00	\$64,000
1.18	Sump Pumps (2 Duty + 2 Stand-By)	4	each	4	\$5,000.00	\$20,000
	Acid Silo Structures					
1.21	Acid Silo Site Preparation Allowance	1	sqft	7550	\$19.50	\$147,225
1.22	Acid Building	1	sqft	4000	\$175.00	\$700,000
1.23	Acid Silo Tank	1	cyd	900	\$800.00	\$720,000
1.24	Acid Silo wall coating	1	sf	4000	\$20.00	\$80,000
	Digester Structures					
1.25	Digestion Site Preparation Allowance	1	sqft	59750	\$19.50	\$1,165,125
1.26	Digester Building	1	sft	22667	\$175.00	\$3,966,725
1.27	Digester Tank	4	cyd	4710	\$800.00	\$3,768,000
1.28	Digester wall coating	1	sf	25000	\$20.00	\$500,000
1.29	Walkway Allowance Per Digesters	4	ea	4	\$200,000.00	\$800,000
1.30	Bridges Allowance Per Digesters	4	ea	4	\$200,000.00	\$800,000
1.31	Miscellaneous Structural Work per Digester	4	ea	4	\$ 200,000.00	\$800,000
	Total Equipment Cost					\$5,459,978.66
	Total Structures Cost					\$13,447,075.00
2.1	Equipment Submittal and Testing markups		%		15%	\$818,996.80
2.2			%		30%	\$1,637,993.60
2.3			%		30%	\$720,000.00
2.4			%		80%	\$1,318,173.31
2.5	Mechanical and Piping		%		25%	\$2,308,785.59
2.6	Electrical and I&C		%		25%	\$2,308,785.59
2.7	Acid Silo and Digester and Wall Coating Installation		%		55%	\$319,000.00
	Total Cost					\$28,338,788.55

	Dewatering Facility Cost Estimate								
ltem No.	Description	No. of Items	Units	Quantity	Unit Cost (\$)	Cost (\$)			
	Equipment								
1.1	Centrifuge (Andritz)	4	each	4	\$680,000.00	\$2,720,000			
1.2	Dewatering Feed Grinders	4	each	4	\$25,000.00	\$100,000			
1.3	Dewatering Feed Pumps	4	each	4	\$55,000.00	\$220,000			
1.4	Polymer Solution Feed Pumps	4	each	4	\$25,000.00	\$100,000			
1.5	Cake Transfer Pumps	4	each	4	\$550,000.00	\$2,200,000			
1.6	Polymer Make up Units	2	each	2	\$75,000.00	\$150,000			
1.7	Polymer Solution/ Mix Age Tanks	2	each	2	\$15,000.00	\$30,000			
1.8	Bridge Crane	1	each	1	\$190,000.00	\$190,000			
1.9	Cake Storage Bin & Truck Loading Equipment	1	each	1	\$2,500,000.00	\$2,500,000			
2	Truck Scales	2	each	2	\$60,000.00	\$120,000			
	Structures								
2.2	Base Building	1	sf	28000	\$300.00	\$8,400,000			
2.3	Truck Loading	1	sf	4250	\$250.00	\$1,062,500			
	Total Equipment Cost					\$8,330,000.00			
	Total Structures Cost					\$9,462,500.00			
2.1	Equipment Installation		%		30%	\$2,873,850.00			
2.2	Equipment Submittal and Testing markups		%		15%	\$1,249,500.00			
2.3	Mechanical and Piping		%		20%	\$1,915,900.00			
2.4	Electrical and I&C		%		25%	\$2,394,875.00			
2.5	Coatings		%		4%	\$409,836.00			
2.6	Odor Control		scfm	21,800	\$40.88	\$891,184.00			
	Total Cost					\$27,527,645.00			

Centrat	te Equalization Cost Estimate					
ltem No.	Description	No. of Items	Units	Quantity	Unit Cost (\$)	Cost (\$)
	Equipment					
1.1	Transfer Pumps	2	each	2	\$50,000.00	\$100,000
1.2	Mixing Pumps	2	each	2	\$40,000.00	\$80,000
	Structures					
2.2	Concrete for EQ tanks	1	cf	78000	\$5.95	\$464,100
2.3						
	Total Equipment Cost					\$180,000.00
	Total Structures Cost					\$464,100.00
2.1	Equipment Installation		%		5%	\$9,450.00
2.2	Equipment Submittal and Testing markups		%		5%	\$9,000.00
2.3	Mechanical and Piping		%		10%	\$18,900.00
2.4	Electrical and I&C		%		10%	\$18,900.00
2.5	Coatings		%		5%	\$9,945.00
2.6	Odor Control		%		5%	\$9,945.00
	Total Cost					\$720,240.00

Boiler Facility Cost Estimate									
ltem No.	Description	No. of Items	Units	Quantity	Unit Cost (\$)	Cost (\$)			
	Equipment								
1.1	Boilers	3	each	3	\$250,000.00	\$750,000			
1.2	Boiler Stacks	3	each	3	\$10,000.00	\$30,000			
1.3	Boiler hot water circulation pumps	3	each	3	\$5,000.00	\$15,000			
1.4	Air separator and expansion tanks	1	ls	1	\$15,000.00	\$15,000			
1.5	Main hot water circulation pumps	2	each	2	\$10,000.00	\$20,000			
1.6	Make-up water and Btu meters	1	ls	1	\$5,000.00	\$5,000			
1.7	Sump Pumps (1 Duty + 1 Stand-By)	2	each	2	\$7,500.00	\$15,000			
	Structures								
1.6	Site Preparation Allowance	1	sqft	10000	\$19.00	\$190,000			
1.7	Central heating building	1	sqft	3800	\$300.00	\$1,140,000			
	Total Equipment Cost					\$850,000.00			
	Total Structures Cost					\$1,330,000.00			
2.1	Equipment Installation		%		30%	\$255,000.00			
2.2	Equipment Submittal and Testing markups		%		15%	\$127,500.00			
2.3	Mechanical and Piping		%		20%	\$170,000.00			
2.4	Electrical and I&C		%		25%	\$212,500.00			
	Total Cost					\$2,945,000.00			

RP-5 Digester Gas Utilization Approved Project Detailed Costs

	No. of				
Description	Items	Units	Unit Cost (\$)	Cost (\$)	Comments
SCR	2	LS	\$500,000	\$1,000,000	2 SCRs for existing engines
Gas Conditioning @ RP-5	-	LS	\$1,000,000	\$1,000,000	H2S & siloxane removal
SHF Gas Conditioning	2	LS	\$96,300	\$192,600	H2S removal
REEP Heat Recovery System Modifications					
Hot water piping		LS	\$140,000	\$140,000	
Water to water HEX		LS	\$100,000	\$100,000	
Transfer pumps	2	LS	\$14,000	\$28,000	
Total Equipment Cost				\$2,320,600	
Total Equipment + Structures Cost				\$2,460,600	
Sales Tax		%	9.000%	\$208,854	
Equipment Installation		%	45%	\$1,044,270	
Civil Site Work, Mechanical, Plumbing &		%	10%	\$146.060	
HVAC		/0	10%	φ140,000	
Electrical & Instrumentation		%	10%	\$146,060	
Construction Cost Estimate				\$4,006,000	



Evaluation of the Decommissioning of RP-2



Brown AND Caldwell

TABLE OF CONTENTS

CHAPTER 3: EVA	LUATION	OF THE DECOMMISSIONING OF RP-2	3-1
3.1	Introdu	ıction	3-1
	3.1.1 3.1.2	Background Understanding and Approach	
3.2	Pre-der	nolition Activities	3-3
	3.2.1 3.2.2 3.2.3 3.2.4	Environmental Site Assessment Hazardous Materials Presence and Documentation Regulatory Coordination Permits and Notifications	. 3-3 . 3-4
3.3	Demoli	tion Activities	3-7
	3.3.1 3.3.2 3.3.3	Plant Decommissioning and Demolition Waste Management Abatement and Remediation	. 3-9
3.4	Post-de	molition Activities	. 3-9
	3.4.1	Site Restoration	. 3-9

LIST OF FIGURES

Figure 3-1: RP-2 Process Flow Diagram	. 3-	2
Figure 3-2: RP-2 Site Plan	. 3-	7

LIST OF TABLES

Table 3-1: Preliminar	y Cost Estimate	3-	8
-----------------------	-----------------	----	---

THIS PAGE INTENTIONALLY LEFT BLANK.

CHAPTER 3: EVALUATION OF THE DECOMMISSIONING OF RP-2

3.1 INTRODUCTION

3.1.1 Background

Regional Plant No. 2 (RP-2) is located in the city of Chino within the flood zone upstream of the Prado Dam, on land leased from the United States Army Corps of Engineers (USACE). To increase the available Orange County water storage, USACE will increase the maximum operational water level upstream of the dam by raising the Prado Dam Spillway. This increase will cause RP-2 to be within the 566-foot (ft) inundation area.

In accordance with the easement renewal for the right-of-way for RP-2 granted by USACE that extended the easement term from May 9, 2010, to May 8, 2035, Inland Empire Utilities Agency (IEUA) is required to remove RP-2 facilities and restore the plant site and utilities upon expiration or termination of the easement. The decommissioning of the plant facilities must follow USACE and US Environmental Protection Agency (EPA) requirements supplemented by state requirements.

RP-2 has been in operation since 1960 and includes both liquid and solids treatment facilities; however, only the solids treatment facilities are currently in operation. Since the inception of RP-5 in 2002, liquids have been sent to RP-5 for treatment, leaving the liquid treatment facilities abandoned in place. RP-2 receives solids from the Carbon Canyon Water Recycling Facility (CCWRF) and RP-5; therefore, new solids treatment facilities would need to be constructed at RP-5 (forecasted for 2022) before the decommissioning and demolition of RP-2 solids treatment facilities.

RP-2 has a design capacity of 26.4 million gallons per day (mgd) for solids treatment. The solids treatment train consists of the following processes: gravity thickening or dissolved air floatation thickening, two-stage anaerobic digestion process, digester gas cogeneration, and dewatering through belt presses (or standby centrifuges). Centrate and thickener overflows are sent to the RP-2 lift station, which sends liquids to RP-5 for treatment. The dewatered solids are hauled to the Inland Empire Regional Composting Facility for further treatment to produce Class A compost. A process flow diagram (PFD) of the solids treatment configuration is illustrated in Figure 3-1.

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 3: Evaluation of the Decommissioning of RP-2




Figure 3-1: RP-2 Process Flow Diagram

Aside from the RP-2 facilities, the IEBL Discharge Station would also require decommissioning and demolition. The relocation of the IEBL Discharge Station is discussed later in this report.

3.1.2 Understanding and Approach

This chapter presents preliminary cost estimates of demolishing the facilities at RP-2 and requirements for restoring the site and utilities. The elements addressed in this chapter for decommissioning and performing demolition activities include the following:

- Identification of infrastructure and equipment to be removed and preliminary demolition cost estimates
- Environmental Site Assessment for the identification and sampling of recognized environmental conditions (RECs) in the soil, surface water, and groundwater
- Hazardous Waste Survey for the identification and sampling of any buildings or materials that are suspected of containing hazardous materials
- Regulatory coordination with affected agencies: USACE, Regional Water Quality Control Board (RWQCB), Santa Ana Watershed Project Authority (SAWPA), State of California Division of Occupational Safety and Health (Cal/OSHA), City of Chino, and South Coast Air Quality Management District (SCAQMD)

- Identification of required permits and notifications
- Liquids, biosolids, solid waste, and industrial waste management and disposal
- Site restoration requirements

3.2 PRE-DEMOLITION ACTIVITIES

While the demolition of RP-2 cannot occur until RP-5 solids train facilities have been commissioned and the RP-2 Lift Station has been replaced by changes in the collection system, several activities can commence earlier.

3.2.1 Environmental Site Assessment

An Environmental Site Assessment (ESA) is required in order to assess the extent of soil and groundwater contamination, if any, and provide as needed recommendations for remediation. The ESA is conducted in phases, known as Phase I and Phase II, as discussed below.

The objective of the Phase I ESA, already completed and provided in Volume IV of this Pre-Design Report (PDR), was to evaluate if past or current site activities have resulted in "recognized environmental conditions (RECs)" as defined in ASTM E1527-13. Reconnaissance of the site and adjacent properties were performed to document current land usage and existing operations. In addition, inquiries were made with regulatory agencies that had knowledge of possible RECs. Based on the results of this evaluation, recommendations for Phase II sampling to address identified RECs were compiled.

As a result of the completion and analysis of the Phase I ESA, Phase II ESA may commence in the coming months to confirm/quantify the presence of hazardous materials in the soil and/or groundwater. The activities involved in Phase II include: collection of soil and/or groundwater samples, field work, laboratory analysis, and data reporting. Based upon the results of Phase II, remediation activities (if needed) may be recommended.

3.2.2 Hazardous Materials Presence and Documentation

The SCAQMD requires a pre-demolition, asbestos, and hazardous material survey and notification prior to demolition activities. Because SCAQMD requires the hazardous materials survey to be less than five (5) years old (and no survey on the RP-2 site within that timeframe currently exists), a survey will be required to occur within five years to the start of demolition. The survey should be pursuant to the documentation requirements specified by SCAQMD.

Because some buildings at RP-2 have already been demarked with asbestos presence, RP-2 is known to contain certain hazardous materials. Conducting the survey would further verify and quantify the presence of asbestos and other hazardous materials. Other hazardous materials include (but are not limited to) lead, polychlorinated biphenyl (PCB)-contaminated ballasts in fluorescent light fixtures, PCB-contaminated transformers and capacitors, unused paint, lead paint chips and cylinders, mercury vapor lamps, mercury thermometers and Freon in air conditioners.

The hazardous materials survey involves the following steps:

1. Procure the services of a Certified Asbestos Consultant (CAC), who has Cal/OSHA certification, to inspect the facility for asbestos-containing materials (ACMs) and other hazardous materials.

- 2. After surveying the site, the CAC will document and collect samples of the suspected materials and send the samples to the laboratory for analysis.
- 3. The CAC will generate a Survey report documenting the results and other requirements per SCAQMD's Rule 1403 checklist.

3.2.3 Regulatory Coordination

Before the onset of decommissioning and demolition of RP-2 facilities, IEUA will need to coordinate with several regulatory agencies. The regulatory agencies and their roles are discussed in the following subsections.

3.2.3.1 United States Environmental Protection Agency (USEPA)

On February 19, 1993, the USEPA issued a final rule for the use and disposal of sewage sludge, 40 Code of Federal Regulations (CFR), Part 503, which requires that producers of sewage sludge meet certain reporting, handling, and disposal requirements. The State of California has not been delegated the authority to implement this program and therefore, the USEPA is the implementing agency.

Any proposed change in biosolids use or disposal practice from a previously approved practice should be reported to the Executive Officer and EPA Regional Administrator at least 90 days in advance of the change.

3.2.3.2 Regional Water Quality Control Board (RWQCB)

The Santa Ana RWQCB (or Santa Ana Regional Water Board) is part of the State Water Resources Control Board which in turn is part of the California EPA (CalEPA). The RWQCB will be involved in multiple facets of the decommissioning and demolishing activities including: notification of changes in sludge use or disposal practices; issuance of the Construction General Permit; and potential issuance of waste discharge requirements (WDRs) for remediation activities.

Even though the USEPA is the implementing agency of 40 CFR, Part 503, NPDES Permit No. CA8000409 (Order No. R8-2009-0021) issued by the California RWQCB includes sludge and biosolids disposal requirements. The disposal methods of collected screenings, sludge, and other solids removed from liquid wastes were required to be approved by the Regional Water Board's Executive Officer. In addition, for any significant changes in a Discharger's sludge use or disposal practices, the Regional Water Board is required to be notified. Because the transferring of sludge treatment processes from RP-2 to RP-5 constitutes as a significant change, RWQCB should be notified as soon as possible.

RWQCB also issues the Construction General Permit, which is required for projects that disturb one (1) or more acres of soil. The RP-2 site occupies around 40 acres; therefore, the Construction General Permit is required for demolition activities. The Permit Registration Documents (PRDs) are discussed in Section 3.2.4.3.

In the event that land or groundwater remediation is found to be required per the results from the ESA, coordination with RWQCB may also be required. Depending upon the type of remediation applied to RP-2, the RWQCB may issue WDRs (e.g., applying oxidizing agents).

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 3: Evaluation of the Decommissioning of RP-2

3.2.3.3 Santa Ana Watershed Project Authority (SAWPA)

The SAWPA owns and maintains the Inland Empire Brine Line (IEBL), also known as the Brine Line or the Santa Ana Regional Interceptor (SARI). The IEBL Discharge Station located on the premises of RP-2 connects to the 27-inch (in) diameter SARI line with an 8-in-diameter lateral pipeline. This pipeline along with the Discharge Station would be demolished and capped. The relocated IEBL discharge station will require a new 8-in-diameter lateral connection to the SARI line.

Because the relocated Discharge Station would be on a new premise, SAWPA requires the following:

- 1.) Contact SAWPA for discharge requirements and costs.
- 2.) Purchase capacity to dispose and treat the waste.
- 3.) Complete and submit a Discharger Permit Application (see Section 3.2.4.4).
- 4.) Submit construction plans for approval to SAWPA and the City of Chino.
- 5.) Once the contracts are in place, the permit is approved/issued and the lateral line constructed, the tie-in can be made and operation can begin.
- 6.) The permit will include disposal limits on metals and other specific contaminants, monitoring and reporting requirements, and a variety of other administration requirements

To make the connection to the new SARI line, a new manhole would be constructed on the SARI line wherein the new 8-in-diameter pipeline could connect to.

3.2.3.4 United States Army Corps of Engineers (USACE)

The United States Army Corps of Engineers has leased RP-2 to IEUA since 1960 and has since approved an easement extension through May 8, 2035. In accordance with the renewal of Easement No. DA-04-353-CIVENG-60-242, IEUA is required to remove all RP-2 facilities and restore the premises to the satisfaction of the USACE. If IEUA were to not remove the facilities and restore the premises, the United States can pursue the option of taking over the facilities without compensation or remove the facilities and perform restoration at the expense of IEUA.

3.2.3.5 South Coast Air Quality Management District (SCAQMD)

The EPA has delegated the SCAQMD the authority to enforce the federal asbestos National Emission Standards for Hazardous Air Pollutants (NESHAP) and SCAQMD is the local enforcement authority for asbestos. SCAQMD adopted AQMD Rule 1403 on October 6, 1989, which established survey requirements, notification, and work practice requirements to prevent asbestos emissions from emanating during demolition activities. The survey and notification requirements are discussed in sections 3.2.2 and 3.2.4.4, respectively. SCAQMD may also conduct inspections during the abatement operations.

3.2.3.6 Cal/OSHA

Cal/OSHA (other known as the Division of Occupational Safety and Health) requires notification for asbestos construction work. Any Contractor or employer who engages in asbestos-related work are also required to be registered with Cal/OSHA.

3.2.3.7 City of Chino

The City of Chino and the Fire Marshall with jurisdiction should also be notified of upcoming demolition activities.

3.2.3.8 Communications Plan

IEUA will work with the public agencies with jurisdiction, to conduct the required public information/involvement, post the required notifications in the appropriate publications, websites, and physical locations, and generally respond to relevant inquiries about the scope of upcoming/ongoing work and schedule for completion.

3.2.4 Permits and Notifications

Before the onset of decommissioning and demolition of RP-2 facilities, IEUA will need to secure several permits and file Rule 1403 Notification form.

3.2.4.1 CEQA

The California Environmental Quality Act (CEQA) is a self-executing statute that requires state and local agencies to identify the significant environmental impacts of their actions and to avoid or mitigate those impacts, if feasible. The California Code of Regulations (CCR), Chapter 3 of Title 14 presents the CEQA guidelines, which provide the objectives, criteria and procedures for the orderly evaluation of projects and the preparation of environmental impact reports (EIRs), negative declarations, and mitigated negative declarations (MNDs) by public agencies.

IEUA is responsible for determining whether the decommissioning and demolition activities require an EIR, negative declaration, or MND. Potential environmental effects from demolishing activities could include the introduction of dust, noise, and traffic of heavy equipment.

3.2.4.2 IEBL Discharge Permit

Prior to the connection or discharge to the Brine Line, an IEBL Discharge Permit application will need to be filed with SAWPA. The application requires the submission of monitoring data, wastewater quantities, the proposed lateral connection, etc.

3.2.4.3 Construction General Permit

For any construction or demolition activities such as concrete and asphalt cutting and removal, trenching, and excavation a Construction General Permit is required. To obtain this permit, IEUA is required to electronically file the following documents with the Regional Water Board: Notice of Intent (NOI), Storm Water Pollution Prevention Plan (SWPPP), and other compliance related documents required including the appropriate permit fee.

The SWPPP is required to be written, amended, and certified by a Qualified SWPPP Developer. The SWPPP has two primary objectives: (1) to help identify the sources of sediment and other pollutants that affect the quality of storm water discharges; and (2) to describe and ensure the implementation of best management practices (BMPs) to reduce or eliminate sediment and other pollutants in storm water and non-storm water discharges. The BMPs in the SWPPP should address source control, pollutant control, and treatment control, and the SWPPP must remain on the site throughout the life of the project to protect water quality at all times.

3.2.4.4 AQMD Rule 1403

Contractors removing the asbestos/and or demolishing the ACM structures are required to submit a notification form online in accordance to AQMD Rule 1403. The notification form must be submitted at least ten (10) days before the start of demolition work.

3.3 DEMOLITION ACTIVITIES

3.3.1 Plant Decommissioning and Demolition

3.3.1.1 Site Plan

The facilities to be decommissioned and demolished are shown on the site plan in Figure 3-2 below.




Figure 3-2: RP-2 Site Plan

3.3.1.2 Cost Estimates

A preliminary cost estimate is presented below in Table 3-1. The demolition/site restoration cost for existing facilities was estimated based on record drawings, publicly available aerial photos, and a brief overview tour of the site. Quantity take-offs were prepared based on the record drawings. The estimate is considered incomplete until the Phase 2 ESA and Hazardous Materials Survey can be completed in the coming months, and these values will be updated at that time.

Based upon the Phase 1 ESA, the costs for sampling, analysis, monitoring, modeling, etc. associated with the Phase 2 ESA and hazardous materials survey may range from \$625,000 to \$787,000. The costs associated with potential abatement of hazardous materials, and potential

remediation due to contamination of soils, could be as much as \$17 million based on abatement and remediation of most of the site, though the findings of the Phase II ESA and detailed hazardous materials survey will likely result in significantly less cost for abatement and remediation.

	Item	
1	Cut Concrete and CMU Walls	\$130,000
2	Remove Concrete and CMU Walls	\$110,000
3	Concrete and Materials Removal	\$330,000
4	Core Drill/Drain Rock	\$150,000
5	Compacted Fill	\$695,000
6	Grating and Equipment Removal	\$460,000
7	Rough Grading	\$25,000
8	Electrical Materials Removal	\$300,000
9	Yard Piping Removal (8-in-diameter and above)	\$560,000
10	Not used	
11	Hazardous Materials Survey	\$165,000
12	Phase II ESA	\$622,000
13	Waste Management Allowance	\$500,000
14	Hazardous Materials Abatement (Hazardous Materials Survey findings are needed to determine extent of this item)	\$91 7,000
15	Site Restoration Allowance	\$200,000
16	Soils Remediation Allowance (Phase II ESA findings are needed to determine extent of this item)	\$16,320,000
17		
18	Subtotal of Items 1 thru 16	\$21,484,000
19	15% Overhead and Profit	\$3,223,000
20	8% Inflation to Midpoint of Construction/Remediation	\$1,719,000
21	4% Bonds and Insurances	\$859,000
22	Subtotal – Construction Costs	\$27,285,000
23	30% Contingency (30% of Construction Subtotal)	\$8,186,000
24	Total Construction Cost	\$35,471,000
25	Design, Permits, CM, Monitoring, Eng. Contingency (20% of Total Construction Cost)	\$7,094,000
26	Total Project Cost Estimate	\$42,565,000

Table 3-1: Preliminary Cost Estimate

Note: Costs for abatement and remediation are considered highly uncertain till completion of the Phase II ESA and Hazardous Materials Survey

3.3.2 Waste Management

Most of the process liquids, chemicals, fuel, lubricants, solids, and other plant operations and maintenance (O&M) and repair materials and tools are expected to be removed from the site and disposed of properly prior to the initiation of demolition. Remaining materials will need to be tested prior to disposal in the appropriate manner to comply with relevant rules and regulations as determined during the pre-demolition activities.

3.3.3 Abatement and Remediation

There is a distinct probability that asbestos, lead, and other regulated substances will be found in quantities sufficient to require abatement and remediation steps. These steps, and the associated procedures and costs, will be determined during the Phase 2 ESA and Hazardous Materials Surveys to be conducted in the coming months.

3.4 POST-DEMOLITION ACTIVITIES

3.4.1 Site Restoration

The site will be required to be restored to the extent necessary to protect the surrounding environment from dust or other airborne debris, storm-water runoff, and sedimentation. To that end, in all likelihood, there will have to be a durable vegetative or other type of cover compatible with the plans to raise the Prado Dam spillway, and storm water may be allowed to percolate in the existing earthen basins once these are cleared from an environmental standpoint.

THIS PAGE INTENTIONALLY LEFT BLANK.



Evaluation of the Relocation of the RP-2 Lift Station



submitted by



in association with



TABLE OF CONTENTS

CHA	PTER 4: EV	ALUATIO	N OF THE RELOCATION OF RP-2 LIFT STATION	4-1
	4.1	Reloca	ation of the RP-2 Lift Station	4-1
		4.1.1	Background	4-1
		4.1.2	Design Objectives	
		4.1.3	Mountain Avenue Lift Station Location	
		4.1.4	Mountain Avenue Lift Station Design Criteria	
		4.1.5	Butterfield Ranch Lift Station	
		4.1.6	Preliminary Cost Estimate	
		4.1.7	Conclusions and Recommendations	

LIST OF FIGURES

Figure 4-1: Existing RP-2 Lift Station	4-1
Figure 4-2: Proposed Force Main System	4-3
Figure 4-3: New Lift Station Layout	4-5
Figure 4-4: Pump System Curve	4-6
Figure 4-5: Pump Wet Well and Valve/Meter Vault	4-7
Figure 4-6: Butterfield Lift Station Pump and System Curves (Xylem NP 3171 SH 3~277)	4-9

LIST OF TABLES

Table 4-1: Preliminary Pump Operating Elevations	
Table 4-2: Pump Station Design Flows	
Table 4-3: Existing Pumps at the Butterfield Ranch Lift Station	
Table 4-4: Estimated Capital Costs	4-10

THIS PAGE INTENTIONALLY LEFT BLANK.

CHAPTER 4: EVALUATION OF THE RELOCATION OF RP-2 LIFT STATION

4.1 RELOCATION OF THE RP-2 LIFT STATION

4.1.1 Background

The Regional Water Recycling Plant #2 (RP-2; Figure 4-1) Lift Station was constructed in 2010 and includes an inlet box, two wet wells, and three pumps. The lift station receives raw sewage from the 24-inch (in) diameter Mountain Avenue interceptor sewer, 10-in-diameter Chino Institute for Women (CIW) sewer, 10-in-diameter Butterfield force main, and recycled flows from the solid treatment facilities at RP-2. The 10-in-diameter CIW sewer receives sewage flows from both the CIW and the El Prado Golf Course clubhouse. Each pump discharges into a 14-in-diameter discharge pipe connecting to a 24-in-diameter discharge manifold that conveys flows to the RP-5 headworks. A backup generator has been provided if utility power fails.



Figure 4-1: Existing RP-2 Lift Station

4.1.2 Design Objectives

In accordance with the easement renewal for the right-of-way for RP-2 granted by the United States Army Corps of Engineers (USACE) that extended the easement term from May 9, 2010, to May 8, 2035, the Inland Empire Utilities Agency (IEUA) is required to remove all RP-2 facilities, which includes the RP-2 Lift Station. The RP-2 Lift Station is below the 566 elevation associated with the Prado Dam inundation area. Therefore, under the agreement established with the USACE, IEUA is required to decommission, demolish, and remove the RP-2 Lift Station and its associated appurtenances and restore the site and utilities. The decommissioning of the RP-2 Lift Station is discussed in Chapter 3 of Volume III.

The flows that currently enter the RP-2 Lift Station will need to be rerouted to the influent of RP-5. The following sections present the proposed systems for conveying the flows upstream to RP-5.

4.1.2.1 Butterfield Ranch Force Main

The City of Chino Hills owns and operates the Butterfield Ranch Lift Station, with sewage pumps and 10-in-diameter force main that currently transport flows to RP-2. The Butterfield Ranch Lift Station will require an upgrade of the existing pumps to overcome the additional head losses and convey the flow to RP-5. The existing 10-in-diameter force main to RP-2 may be reused; however, since this pipeline terminates at RP-2, a new 10-in-diameter force main extension will need to be constructed along El Prado Road and Mountain Avenue. The 10-in-diameter force main will connect to a new 12-in force main on Mountain Avenue and will be conveyed to RP-5 via the new Mountain Avenue Lift Station at the RP-5 solids handling facility (SHF) site. These proposed modifications in the collection system are illustrated below in Figure 4-2.

4.1.2.2 CIW Sewer

The City of Chino is planning to construct a new lift station to convey flows from CIW to RP-5. The new lift station will be located next to the existing Prado chlorination facility. The golf course clubhouse flows will be discharged to a new sealed double-wall underground fiberglass reinforced plastic storage tank. The tank will have anchor straps that can either attach to a deadmen anchoring system or an anchor pad. Anchoring the system prevents the tank from floating during flood events. The sewage accumulated in the tank can be removed by periodic pumping with vacuum trucks. A vacuum system conveying the golf course flows through a pipeline under negative pressure to a vacuum pumping station above the flood inundation area was also considered. However, the length of the vacuum pipeline and the static head required deemed the system as hydraulically infeasible.

4.1.2.3 Mountain Avenue Sewer

The flows from the Mountain Avenue Sewer will be intercepted and discharge to the wet well of a new lift station. The new lift station will be located in an area meeting the following criteria: proximity to the Mountain Avenue Sewer; land owned by the IEUA; ease of egress and ingress for maintenance vehicles; and proximity to an interceptor upstream to RP-5.

While odors are not anticipated to be an issue, the potential location will not be near a public space where potential odors will be a nuisance to the public. The new lift station will also include security, drainage, and site improvement measures.

4.1.3 Mountain Avenue Lift Station Location

The RP-5 SHF is located alongside Mountain Avenue and the existing 24-in-diameter Mountain Avenue Interceptor Sewer. The SHF is located at or above the flood inundation level of 566 and is owned by the IEUA. Space is currently available for a new lift station wet well, valve/meter vault, and pathway for maintenance vehicles in the southeast corner of the SHF, northeast to the existing stormwater pond and away from existing operations.

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION

e-Design Report Volume III, Chapter 4: Evaluation of the Relocation of RP-2 Lift Statio




Figure 4-2: Proposed Force Main System

The lift station will be located in an area that would cause less disturbance to current IEUA onsite operations and be accessible through a new gate on Mountain Avenue separate from the existing main entrance of the site. The new lift station space will be separated from the rest of the SHF with a new fence. Trucks will not need to use the existing main entrance to SHF to perform routine maintenance. A secondary gate will be provided, however, on the new fence for access to the SHF facilities by operations staff. The maintenance trucks are assumed to be single unit trucks, having an overall length of 30 feet (ft) and minimum design turning radius of 42 ft¹.

The existing site has unpaved ground surface and will require approximately 4,200 square feet (sf) of asphalt pavement for all weather access. The site is adjacent to Mountain Avenue and new openings can be created in the existing perimeter chain linked fence to provide new gates for access by maintenance vehicles and a new block wall will be constructed in-between the entrance and exit gates to conceal the lift station operations from public viewing. Because the new entrance and exit pathways will cross over the existing sidewalk and planters, the sidewalk and vegetation will need to be restored. A preliminary layout for the new lift station is shown in Figure 4-3 below.

4.1.4 Mountain Avenue Lift Station Design Criteria

4.1.4.1 Lift Station Capacity

The Agency has forecasted that the average flows of the new Mountain Avenue Lift Station will be about 0.3 million gallons per day (mgd) from present day to year 2040, and 0.4 mgd from 2040 to 2060. Using a peaking factor of 2.0, the design flow for this lift station is 0.8 mgd or 560 gallons per minute (gpm). Therefore, two pumps (one duty and one standby) sized at 0.8 mgd (560 gpm) each will be provided to meet peak flows.

4.1.4.2 Influent Gravity Sewer

The invert elevation of the Mountain Avenue sewer manhole ("Manhole No. 8") at Kimball Avenue is 559.96². The invert elevation of the Mountain Avenue sewer near SHF was assumed to be 556.75, with the assumption that the Mountain Avenue sewer shares the same slope as the Mountain Avenue.

The sewage flows in the Mountain Avenue interceptor sewer will be intercepted with a new diversion manhole. With a minimum slope of 0.0056 ft/ft and pipe diameter of 10 in, the velocity of sewage flowing full through the pipe will be 3.0 ft/second (s). To reach the new wet well, the pipeline will be approximately 40 ft in length and enter at an invert elevation of 556.53.

4.1.4.3 Sewage Force Main

The lift station will discharge the sewage flows to an existing manhole on the Kimball Avenue Interceptor sewer, approximately 3,200 ft north on Kimball Avenue, through a new force main. The new force main is expected to have a 12-in diameter, based on conveyance of the additional discharge flows of up to 1,100 gpm currently projected for the Butterfield Ranch Lift Station. The proposed force main system is shown above in Figure 4-2.

¹ AASHTO, A Policy on Geometric Design of Highways and Streets, 6th Edition, 2011

² Project No. EN97004-3 Phase II record drawings.




Figure 4-3: New Lift Station Layout

4.1.4.4 Pump Sizing

The invert of the existing manhole on the Kimball Interceptor is 559.96. Assuming the interceptor is 90% full, the water level elevation will be 564.91. If the low water level at the wet well is 550.5, the static head the pumps will need to overcome will be 14.4 ft. The head loss at 560 gpm through the 8-in force main will be approximately 21.4 ft. Therefore, the total dynamic head (TDH) of each pump will be approximately 36 ft. The pumps will be constant speed driven with 10-horsepower (hp) motors. Figure 4-4 shows the pump-system curves at different flow rates.




Figure 4-4: Pump System Curve

4.1.4.5 Wet Well

The wet well will have an inner diameter of 8 ft and be constructed of either concrete or fiberglass material. The wet well will contain two rail-mounted submersible pumps. The lead pump will stop at an elevation no less than the minimum submergence level per the selected pump's specifications. The bottom of the wet well elevation will be set to limit the motor to maximum six starts per hour. Preliminary pump operating elevations are presented in Table 4-1.

Parameter	Elevation (ft)
High-High Water Level (HHWL)	556.0
High Water Level (HWL)	555.5
Lead Pump Start	555.0
Lead Pump Stop	551.0
Low Water Level (LWL)	550.5

Table 4-1: Preliminary Pump Operating Elevations

4.1.4.6 Valve/Meter Vault and Appurtenances

Each pump will discharge into a respective 8-in-diameter lateral pipe, which will enter a valve/meter vault containing check valves, isolation valves, and a flow meter (Figure 4-5). One of the 8-in discharge pipelines will include a quick disconnect coupling for a bypass connection to a portable pump in the event of pump failure.




Figure 4-5: Pump Wet Well and Valve/Meter Vault

The wet well and valve vault will be provided with ventilation pipes. Additionally, a 2-in-diameter drain will be provided between the valve/meter vault and wet well to drain any water that may enter the vault. A plant water line will be provided for a hose bibb connection to allow for wash down activities. An above-ground control panel in a NEMA-4 enclosure will be provided along with electrical conduits for power and signaling. The pumps will be designed to alternate daily to extend the life of the priming equipment.

In-line emergency storage of 60 minutes at peak flow (or 4,500 cubic feet [ft³]) can be provided in the 24-in-diameter Mountain Avenue Interceptor sewer that connects to the 8-in-diameter influent pipeline. The MCC will be equipped with a manual transfer switch and connectors suitable for connection to a potable emergency generator in the event of a power failure. Alternatively, by connecting to the provided quick disconnect coupling, a portable pump can pump flows in the wet well to the force main and bypass the submersible pumps should it be required.

4.1.5 Butterfield Ranch Lift Station

4.1.5.1 Background

The Butterfield Ranch Lift Station, located at 14754 Brookwood Lane, Chino Hills, consisting of four self-priming centrifugal pumps. The lift station receives flow through a 15-in-diameter gravity sewer from the east. The 15-in-diameter sewer connects to a manhole on site prior to entering from a manhole on site. After the manhole, the sewage flow goes through an in-channel comminutor before entering the wet well. The design criteria³ for the lift station are shown in **Table 4-2**.

³ "Improvement plans for the construction of the Butterfield Sewage Lift Station," record drawings prepared by Hall & Foreman, Inc. for the Butterfield Ranch Company, October 30, 1987.

Table 4-2: Pump Station Design Flows

	Design Flow	Flow Rate
1.	Peak sewage flow	1,064 gpm
2.	Average sewage flow	368 gpm
3.	Minimum pump station flow	400 gpm
4.	Maximum pump station flow	1,064 gpm

The Butterfield Ranch Lift Station contains four self-priming centrifugal pumps (Table 4-3) located on the ground floor in the pump room.

Pump No.	Service	Flow Rate (gpm)	TDH (ft)	Motor Size (hp)
P1	Raw sewage	1,080	90	60
P2	Raw sewage	1,080	90	60
P3	Raw sewage	750	50	20
P4	Raw sewage	750	50	20

Table 4-3: Existing Pumps at the Butterfield Ranch Lift Station

The lift station has a 200-kilowatt (kW) diesel generator and a 500-gallon (gal) fuel tank to provide standby power in case of a power failure.

In order to bypass the RP-2 Lift Station and pump sewage flows to RP-5, the force main will require to be extended (as described previously) and the pumps will require upgrade to overcome the additional head in the new force main system.

4.1.5.2 Design Criteria

The design flow for the upgraded lift station will remain the same as the existing lift station as listed in Table 4-2. The lift station will be capable of pumping incoming flows between the minimum pumping station flow of 400 gpm and the maximum pumping station flow of 1,064 gpm. The new pumps will have a design capacity of 1,065 gpm to meet the peak flow, with three 355-gpm duty pumps and a 355-gpm standby pump having a 40-hp motor for each pump.

In order to overcome the additional friction losses associated with the extended force main, the existing single-stage self-priming pumps (Gorman Rupp Models T6A3-B and T8A3-B) will need to be replaced with new pumps capable of handing the additional head. However, a single-stage self-priming pump will not be capable of handing the additional head and a two-stage self-priming replacement pump that meets the design condition will require an additional 17 in of vertical space compared to the existing pumps that may not be able to be accommodated by the existing discharge piping and valves connecting to the pumps due to existing piping and site constraints.

An alternative to the self-priming pumps would be the installation of four submersible pumps in the existing wet well to replace the existing suction pipes and above-floor self-priming pumps. The pump-system curves for the submersible pumps that could be used to replace the existing pumps are shown in Figure 4-6.

Pump-System Head Curves




Figure 4-6: Butterfield Lift Station Pump and System Curves (Xylem NP 3171 SH 3~277)

The upgrade of the lift station will meet the following criteria:

- Capable of pump flows to the Kimball Interceptor and meet the minimum flow of 400 gpm and the peak flow of 1,064 gpm.
- Capable of pumping the peak flow with three duty pumps and one standby pump.
- Pumps suitable for raw wastewater.
- Capable of operating the pumps within high efficiency range on the pump curve and within the pump manufacturer's recommended operating range.
- Use of premium efficiency motors.
- Not relying on self-priming to start pumps.
- Upsized diesel engine generator and fuel tank to provide the same duration of standby power as the existing unit.
- New valves, piping and accessories as required for the installation of the new pumps.
- Modifications to the motor control center (MCC) and electrical equipment as required for the new pumps and motors.
- Provisions for bypass pumping to maintain continuous operation of the lift station during construction.

4.1.6 Preliminary Cost Estimate

4.1.6.1 Basis of Cost Estimate

The costs presented herein reflect an *Engineering News-Record* Construction Cost Index of 11555 (*ENR* CCI – Los Angeles, December 2016). The estimate was developed using historical costs from recent projects, proprietary cost data, and vendor quote information. The cost includes major

project elements plus indirect costs (markups) associated with completion of the estimate. Project markups include contractor overhead and profit, contingency, and escalation to midpoint of construction. The contingency provides for unknown construction conditions and final design completion variations.

The construction cost estimate is referred to as Class 3 - "Budget Level Estimate" based on the cost estimate classifications by the American Association of Cost Engineers (AACE) International⁴. The final construction costs will depend on final project scope, actual labor and material costs, market conditions, actual site conditions, implementation schedule and other factors that may impact the project costs.

4.1.6.2 Preliminary Cost Estimates

Table 4-4 provides the estimated capital costs of the lift stations and force mains.

	Item	Estimated Cost
1	Mountain Avenue Lift Station	\$319,000
2	12-in force main (3,200 ft)	\$768,000
3	Chino Hills Butterfield Ranch Lift Station Improvements	\$300,000
4	10-in force main to Mountain Ave. Lift Station	\$600,000
8	Subtotal 1	\$1,987,000
9	15% Overhead and Profit	\$298,000
10	8% Inflation	\$159,000
11	4% Bonds and Insurances	\$79,000
12	30% Contingency	\$757,000
13	Subtotal 2	\$3,280,000
14	Design and Project Administration (20%)	\$656,000
15	Total Construction Cost (Sum of Items 13 and 14)	\$3,936,000

Table 4-4: Estimated Capital Costs

4.1.7 Conclusions and Recommendations

The new Mountain Avenue Lift Station will be located in an unoccupied area southeast of the SHF. The construction of the new lift station, force mains, and Butterfield Ranch Lift Station improvements should be completed at least 6 months prior to the decommissioning of the existing RP-2 Lift Station.

⁴ AACE Recommended Practice No. 18R-97, "Cost Estimate Classification System – as applied in Engineering, Procurement, and Construction for the Process Industries," Rev. 3/1/2016.



Evaluation of the Relocation of the IEBL Discharge Station



submitted by



in association with



TABLE OF CONTENTS

CHAPTER 5: EV	ALUATIO	N OF THE RELOCATION OF IEBL DISCHARGE STATION	5-1
5.1	Inland	Empire Brine Line (IEBL) Discharge Station	5-1
	5.1.1	Background	5-1
	5.1.2	Design Objectives	
	5.1.3	Alternatives for the Relocation of IEBL Discharge Station	5-3
	5.1.4	Business Case Evaluation (BCE)	5-10
	5.1.5	Implementation Schedule	
	516	Conclusions and Recommendations	5-12

LIST OF APPENDICES

Appendix 5-	-A: Other Alternatives Considered for the Relocation of IEBL Discharge	
C.	Station	-13

LIST OF FIGURES

Figure 5-1: Existing IEBL Discharge Station	5-1
Figure 5-2: Alternative 1 Overall Layout	5-4
Figure 5-3: Available Space West of the CCWRF Headworks	5-4
Figure 5.4: Proposed Opening for Exiting or Entering	5-5
Figure 5-5: Alternative 1 Enlarged Layout	5-6
Figure 5-6: Alternative 2 Enlarged Lay	5-6
Figure 5-7: Alternative 2 Overall Layout	5-7
Figure 5-8: Alternative 3 Enlarged Layout	5-8
Figure 5-9: Alternative 3 Overall Layout	5-9
Figure 5-10: Alternative Layout to Alternative 3	5-10

LIST OF TABLES

Table 5-1: Comparison of Alternatives for the Relocation of the IEBL Discharge Station	5-10
Table 5-2: Estimated Capital Costs	5-11
Table 5-3: IEBL Discharge Station Capital and O&M Costs and BCE Results	5-12

THIS PAGE INTENTIONALLY LEFT BLANK.

CHAPTER 5: EVALUATION OF THE RELOCATION OF IEBL DISCHARGE STATION

5.1 INLAND EMPIRE BRINE LINE (IEBL) DISCHARGE STATION

5.1.1 Background

In accordance with the easement renewal for the right-of-way for Regional Water Recycling Plant #2 (RP-2) granted by the United States Army Corps of Engineers (USACE) that extended the easement term from May 9, 2010 to May 8, 2035, IEUA is required to remove all RP-2 facilities, which includes the Inland Empire Brine Line (IEBL) Discharge Station at RP-2, which is one of the four waste collection stations on the IEBL system. The IEBL Discharge Station, shown in Figure 5-1 below, is a septage receiving station that receives trucked liquid waste from permitted haulers and discharges the waste to the 27-inch (in) diameter IEBL (previously known as the Santa Ana Regional Interceptor [SARI]) on El Prado Road. The IEBL is owned by the Santa Ana Watershed Project Authority (SAWPA) while IEUA owns and maintains the IEBL Discharge Station and the 8-in-diameter sewer lateral connecting the Discharge Station to the IEBL. The IEBL transports salty wastewater to the Orange County Sanitation District's wastewater treatment facility (Plant 2) in Huntington Beach.

The IEBL Discharge Station is located near RP-2 and is below the 566 elevation associated with the Prado Dam inundation area. Therefore, under the agreement established with the USACE, IEUA is required to decommission, demolish, and remove the IEBL discharge station and 8-in sewer lateral and restore the site and utilities. The decommissioning of the IEBL discharge station is discussed in Chapter 3 of Volume III.



Figure 5-1: Existing IEBL Discharge Station

The IEBL Discharge Station was constructed in 2010 and has a dump station manhole, which receives septage from two septage receiving stations, and two catch basins that capture any stormwater and spray down waste. Each septage receiving station includes a quick disconnect coupling where hauling trucks can connect to and send septage through. The incoming septage is analyzed for pH, temperature, conductivity, and sulfide—ensuring the waste does not surpass the IEBL disposal limits. A magnetic flow meter and automatic sampler are also provided in the station. As currently configured, the dump station manhole sends septage through an 8-in-diameter pipeline to a previously constructed dump station, which then sends septage through an 8-in-diameter pipeline to the 27-in-diameter IEBL. In this design, most of the septage is contained and odors are limited from escaping into the atmosphere.

The IEBL Discharge Station has restricted access where only permitted waste haulers can enter the fenced area. Several instrumentation and electrical equipment are provided at the existing IEBL Discharge Station as listed below:

- (4) Proximity Card Readers
- (4) Gate Controllers, (4) Gate Actuators with (3) Detector Loops each
- (2) Flood Light/Camera supported on a Pole
- Modular Enclosure: Lighting Panel, Supervisory Control and Data Acquisition (SCADA) Panel, Security Panel, and Irrigation Controller

Two of the proximity card readers are provided outside of the fence, where the trucks enter the station while the other two are featured inside of the fence, where the trucks exit the station. Signals from the card readers will be sent to the gate controllers, which together with the detector loops, control the opening and closing of the gates. A pair of flood lights and cameras are also included at the station to enforce site security. The panels in the modular enclosure receive and transmit signals to the communication panel located in the RP-2 plant control station.

5.1.2 Design Objectives

To replace the existing IEBL Discharge station, a new IEBL Discharge Station will be constructed in an area outside of the 566-foot (ft) Prado Dam inundation area. The new discharge station will have a similar configuration and design as the existing. Because the existing system was constructed in 2010, less than 7 years ago, the two existing septage receiving stations could be relocated to the new discharge station. Based upon record drawings, the hauling trucks were assumed to be large semitrailers, WB-50, having an overall length of 55 feet¹, similar to the trucks currently being used by the waste haulers.

Considerations for locating the site for the new discharge station included the following: proximity to the IEBL; truck accessibility and ease of egress and ingress; available IEUA properties, and existing utilities. Utilities that will be required include utility water for wash down and electrical to power the septage receiving stations and, where applicable, surveillance systems. The electrical and instrumentation equipment will also send and transmit signals to an IEBL's operations center; therefore, potential locations in proximity to IEUA's water reclamation facilities adjacent to the IEBL (e.g., RP-5 and Carbon Canyon Water Recycling Facility [CCWRF]) were evaluated.

¹ AASHTO, A Policy on Geometric Design of Highways and Streets, 6th Edition, 2011

5.1.3 Alternatives for the Relocation of IEBL Discharge Station

Initially, eight locations were considered for the new IEBL Discharge station. These options were as follows:

- A. Chino Creek Wetlands and Education Park where trucks enter from El Prado Road and exit to Kimball Avenue
- B. West of the Chino Creek Wetlands and Education Park where trucks enter and exit from and to El Prado Road
- C. South of the Chlorine Contact Tanks at CCWRF where trucks enter and exit through a new opening to and from Telegraph Avenue
- D. North of the Solar Panels at CCWRF where trucks enter and exit through the existing entrance off Telegraph Avenue
- E. West of Existing Solar Panels at RP-5.
- F. West of the Headworks at CCWRF where trucks enter through the existing entrance off Telegraph Avenue and exit through a new opening onto Chino Hills Parkway
- G. Northeast corner of RP-5 near the entrance off Kimball Avenue.
- H. West of the RP-5 Solids Handling Facility where trucks will enter and exit through existing openings off Mountain Avenue.

Options A, B, C, D, and E were considered infeasible; evaluation of these options including concerns and design constraints are presented in Appendix A. Options F, G, and H are considered as feasible alternatives and are presented in the sections below and renamed as Alternatives 1, 2 and 3.

5.1.3.1 Alternative 1: Located West of the Headworks at CCWRF

Alternative 1 has the new IEBL Discharge Station located on the north side of the CCWRF, west to the Headworks. Under this alternative, incoming hauling trucks will enter CCWRF through the existing entrance off of Telephone Avenue. Upon entering the plant, the trucks will follow the pathways shown on Figure 5-2.



Figure 5-2: Alternative 1 Overall Layout

The trucks will be directed to the new discharge station located west of the existing headworks. The existing site contains trees and soil, the former which will need to be uprooted and removed while the latter will be paved with about 13,000 square feet (ft^2) of asphalt concrete. Between the headworks and the boundary wall, around 65 ft is available for the construction of a new discharge station as shown on Figure 5-3.




Figure 5-3: Available Space West of the CCWRF Headworks

To exit, the trucks will pass through a new slide gate, where a pair of proximity card readers will be provided along with two gate controllers and two gate actuators with detector loops. Upon passing through the slide gate, the trucks will exit the premises through a new opening to Chino Hills Parkway. The new opening (Figure 5-4) will require part of the existing CMU wall be demolished. While not recommended, the hauling trucks could also enter the discharge station through this new opening. Therefore, a pair of proximity card readers will be provided on the street side of the slide gate. Because the new discharge station will be within the CCWRF, security measures such as a fence and security camera are not required. Signals will still need to be

transmitted to and from the plant control station to monitor the dumping activities at the new discharge station.



Figure 5.4: Proposed Opening for Exiting or Entering

A new 80-ft-long, 8-in-diameter sewer pipeline will be constructed to connect the new dump station manhole to a new manhole (Figure 5-5). The new manhole will connect to an existing manhole on the IEBL with a new 40-ft-long, 8-in-diameter sewer pipeline. The existing IEBL is located approximately 25 ft west of the headworks. The new discharge station will also include connections to existing recycled water pipelines for wash down activities and a power source for the septage receiving stations and entering/exiting gate.




Figure 5-5: Alternative 1 Enlarged Layout

5.1.3.2 Alternative 2: Located Northeast of RP-5

Alternative 2 locates the new IEBL Discharge Station at the northeast corner of RP-5, near the main entrance to RP-5. Truck haulers would enter off Kimball Avenue through the existing driveway (see Figure 5-6). Instead of entering the RP-5 facility, however, trucks will enter through a new opening in the existing west CMU wall.




Figure 5-6: Alternative 2 Enlarged Lay

Approximately 17,000 ft² of asphalt concrete pavement will be laid down to construct this new pathway. To exit, a new opening will be created in the existing north CMU wall. Trucks leaving the discharge station will only be allowed to turn right due to safety concerns and the limited turning radii. Enough space has been provided for trucks at the entrance in the event that both septage receiving stations are occupied. Even though adequate space and turning radii have been provided, coordination with City of Chino will occur during the design phase to confirm that this configuration meets City standards. It is likely that a dedicated right-turn approach lane encroaching into the RP-5 north property may be required to stage incoming waste hauling trucks and minimize impact on the traffic on Kimball Avenue.

To isolate the discharge station from RP-5, new security fencing and gates will be constructed along with a security camera. Both the entrance and exit gates will have two gate controllers and two gate actuators along with detector loops. Signals will be transmitted to and from the RP-5 plant control station to monitor the dumping events at the new discharge station.

Because the new discharge station is approximately 2,400 ft away from the IEBL, the new dump station manhole will connect to a new lift station, which will be required to avoid the existing underground utilities. The new lift station will have a pair of submersible pumps that will send flows through a 2,100-ft-long, 4-in-diameter force main to a new manhole (Figure 5-7). The new manhole will connect to an existing manhole on the IEBL with a new 300-ft-long, 8-in-diameter gravity pipeline. The new discharge station will also include connections to recycled water pipelines for wash down activities and a power source for the septage receiving stations and entering and exiting gates.



Figure 5-7: Alternative 2 Overall Layout

5.1.3.3 Alternative 3: Located West of the RP-5 Solids Handling Facility

Alternative 3 presents a new discharge station at the RP-5 Solids Handling Facility (SHF). Trucks will enter and exit through an existing gate off Mountain Avenue. As shown in Figure 5-8, the trucks will enter the new discharge station that will be fenced off from the rest of the RP-5 SHF. Gates with gate controllers and gate actuators along with detector loops will be constructed at both the entrance and exit of the discharge station. Security cameras will also be constructed as a

security measure. Signals will be transmitted to and from the RP-5 plant control station to monitor the dumping events at the new discharge station.

Approximately 35,500 ft^2 of asphalt concrete will be constructed for the new pathway. The new discharge station will also include connections to recycled water pipelines for wash down activities and a power source for the septage receiving stations and entering/exiting gate.




Figure 5-8: Alternative 3 Enlarged Layout

The dump station manhole will send the waste through a 100-ft-long, 8-in-diameter sewer pipeline to a new manhole (Figure 5-9). From this new manhole, another 8-in-diameter pipeline measuring 650 ft in length will send the flows to another new manhole located on Flowers Street. This new manhole will connect the new 8-in-diameter pipeline to the existing 8-in-diameter pipeline that connects to the IEBL.

Because the discharge station is located to the north of the Solids Handling Facility (SHF), space would be available for a potential food waste receiving station. In addition, a secondary exit pathway could be constructed for trucks to leave the site through Flowers Street except during a flood event. This secondary pathway will require extensive re-grading, however, as the grade separation between SHF and Flowers Street is approximately 5 ft to 6 ft and 13,500 ft² of additional asphalt concrete pavement.




Figure 5-9: Alternative 3 Overall Layout

Locating the discharge station west of the SHF was also evaluated, where trucks will enter from Mountain Avenue and exit onto Flower Street (Figure 5-10). As mentioned earlier, exiting onto Flower Street will require extensive regarding due to the elevation difference between SHF and Flowers Street. A secondary exit pathway will be provided that can be used during a flood event; however, IEUA staff has expressed a preference for the private haulers not to enter the SHF on a regular basis. In this configuration, the septage receiving stations were arranged in linear fashion instead of side-by-side. Approximately 32,000 ft² of asphalt concrete pavement will be required. Because the Discharge Station is closer to the existing 8-in pipeline, only around 500 ft of 8-in gravity sewer pipeline will be required along with the two new manholes.




Figure 5-10: Alternative Layout to Alternative 3

Despite the savings in pipe length, locating the IEBL discharge station north of the SHF is preferable because less asphalt concrete pavement and regrading will be required for trucks to exit the premise. Therefore, the layout shown on Figures 5-9 and 5-10 will be considered in the business case evaluations.

5.1.4 Business Case Evaluation (BCE)

5.1.4.1 Alternatives Comparison

The advantages and disadvantages of the three alternatives are presented in Table 5-1.

Alternative	Advantages	Disadvantages
Alternative 1: West of	Located on existing IEUA property	Requiring a new exit gate on Chino Hills Pkwy and demolishing at existing perimeter wall
CCWRF	Utilizing unoccupied space at CCWRF	Requiring trees to be uprooted and re-grading
Headworks	Close proximity to IEBL	Increased truck access through busy Chino Hills Pkwy
	—	Exiting through new opening near the existing intersection On Chino Hills Pkwy may pose traffic safety concerns
	—	Waste hauler personnel will enter plant
Alternative 2:	Located on existing IEUA property	Likely requires a lift station
Northeast of	Utilizing unoccupied space at RP-5	Requiring extensive piping to reach IEBL
RP-5	Relative low impact to RP-5 operations	Increased traffic at entrance from Kimball Ave
	Waste hauler personnel will not enter plant	Egress restricted to right turn only

Table 5-1: Comparison of Alternatives for the Relocation of the IEBL Discharge Station

Pre-De	INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 5: Evaluation of the Relocation of IEBL Discharge Station				
Alternative	Advantages Disadvantages				
		City of Chino may raise additional requirements			
Alternative 3:	Located on existing IEUA property	Shared pathway with other trucks			
North of SHF	Utilizing unoccupied space at RP-5	Occupying extensive space that could have been used for other purposes			
	Relative low impact to RP-5 operations	—			
	Using existing 8-in-diameter pipeline to IEBL	—			
	Waste hauler personnel will not enter plant	—			

5.1.4.2 Basis of Cost Estimate

The costs presented herein reflect an *Engineering News-Record* Construction Cost Index of 11555 (*ENR* CCI – Los Angeles, December 2016). The estimate was developed using historical costs from recent projects, proprietary cost data, and vendor quote information. The cost includes major project elements plus indirect costs (markups) associated with completion of the estimate. Project markups include contractor overhead and profit, contingency, and escalation to midpoint of construction. The contingency provides for unknown construction conditions and final design completion variations.

The construction cost estimate is referred to as Class 3 - "Budget Level Estimate" based on the cost estimate classifications by the American Association of Cost Engineers (AACE) International². The final construction costs will depend on final project scope, actual labor and material costs, market conditions, actual site conditions, implementation schedule and other factors that may impact the project costs.

5.1.4.3 Preliminary Cost Estimates

Table 5-2 provides the estimated capital costs of the three alternatives for the relocated IEBL Discharge station.

	Item	Alternative 1 West of CCWRF	Alternative 2 Northeast of RP-5	<u>Alternative 3</u> North of SHF
1	Yard Piping	\$23,000	\$260,000	\$144,000
2	Structures	\$33,500	\$36,000	\$36,000
3	Civil	\$87,000	\$89,000	\$186,000
4	Septage Station Relocation	\$10,000	\$10,000	\$10,000
5	Solar Panel Relocation	-	-	-
6	Site Security Improvements	\$11,500	\$21,000	\$17,000
7	Lift Station	-	\$113,000	-

Table 5-2: Estimated Capital Costs

² AACE Recommended Practice No. 18R-97, "Cost Estimate Classification System – as applied in Engineering, Procurement, and Construction for the Process Industries," Rev. 3/1/2016.

		<u>Alternative 1</u> West of	<u>Alternative 2</u> Northeast of	Alternative 3
	Item	CCWRF	RP-5	North of SHF
8	Sales Tax (8.0%)	\$4,400	\$17,000	\$11,000
9	Total Direct Cost	\$170,000	\$546,000	\$404,000
10	Overhead and Profit (15%)	\$25,500	\$81,900	\$60,600
11	Inflation (8%)	\$13,600	\$43,700	\$32,300
12	Bonds and Insurances (4%)	\$6,800	\$21,800	\$16,200
13	Subtotal (Items 9 through 13)	\$215,900	\$693,400	\$513,100
14	Contingency (30%)	\$64,800	\$208,000	\$153,900
15	Total Construction Cost (Sum of Items 13 and 14)	\$280,700	\$901,400	\$667,000
16	Administration and Engineering (20%)	\$56,100	\$180,300	\$133,400
17	Total Estimated Project Cost	\$340,000	\$1,080,000	\$800,000

Table 5-3 provides the project costs, operations and maintenance (O&M) costs, and BCE results of the three alternatives for the relocated IEBL Discharge Station. The O&M costs assumed that number of labor hours to maintain the system will be 80 hours per year and were based on a percentage of the equipment and structures costs. The O&M cost for Alternative 2 was calculated based on the assumption that the pumps in the lift station will be operating 12 hours a day.

Table 5-3: IEBL Discharge Station Capital and O&M Costs and BCE Results

	Item	<u>Alternative 1</u> West of CCWRF	Alternative 2 Northeast of RP-5	<u>Alternative 3</u> North of SHF
1	Capital Cost	\$340,000	\$1,080,000	\$800,000
2	Annual O&M Cost	\$8,000	\$30,800	\$9,200
3	30-year NPV	\$570,000	\$1,950,000	\$1,080,000

5.1.5 Implementation Schedule

The relocation of the discharge station could be implemented in a phased approach by relocating the existing two septage receiving stations one at a time. This sequencing will allow for the continued operation of the discharge station during transition from the existing discharge station to the new discharge station, which will occur prior to the demolition of the existing IEBL Discharge Station.

5.1.6 Conclusions and Recommendations

The recommended location for the new discharge station is the north area of the RP-5 SHF (Alternative 3) as presented in this section.

In a subsequent meeting with the Agency to discuss the IEBL discharge station relocation, it was suggested to leave the IEBL discharge station at its current location. In the future, the Agency plans to consolidate the septage and high-strength industrial waste receiving station location and operation at RP-4, which is located in Rancho Cucamonga.



APPENDIX 5-A: OTHER ALTERNATIVES CONSIDERED FOR THE RELOCATION OF IEBL DISCHARGE STATION

Eight locations were considered for the new IEBL Discharge station. These options were as follows:

- A. Chino Creek Wetlands and Education Park where trucks enter from El Prado Road and exit to Kimball Avenue
- B. West of the Chino Creek Wetlands and Education Park where trucks enter and exit from and to El Prado Road
- C. South of the Chlorine Contact Tanks at CCWRF where trucks enter and exit through a new opening to and from Telegraph Avenue
- D. North of the Solar Panels at CCWRF where trucks enter and exit through the existing entrance off Telegraph Avenue
- E. West of Existing Solar Panels at RP-5
- F. West of the Headworks at CCWRF where trucks enter through the existing entrance off Telegraph Avenue and exit through a new opening onto Chino Hills Parkway
- G. Northeast corner of RP-5 near the entrance off Kimball Avenue.
- H. West of the RP-5 Solids Handling Facility where trucks will enter and exit through existing openings off Mountain Avenue.

Options A through E were considered infeasible and were eliminated from consideration due to major concerns and design constraints. These options are discussed in detail in this section.

Options A and B locate the new Discharge Station west of IEUA's LEED certified headquarters in the area with the Chino Creek Wetlands and Educational Park. Both options will require the discharge station to be fenced and to occupy approximately 140-ft by 56-ft space. Both options will occupy and disturb the wetland and require trenching through the park for construction of electrical conduits and water utility pipelines. The electrical conduits will need to extend to the RP-5 plant control station to send and receive signals in addition to providing power to the septage receiving stations, light fixtures, and security systems.

Option A will go through the middle of the Educational Park and cover an area of approximately 16,500 square feet (Figure 5.A-1). The hauling trucks will enter the discharge station through El Prado Road and exit onto Kimball Avenue. The exit is located approximately 25 feet away from a bus pad, which serves as a LEED credit to the headquarters. The roadways to and from the discharge station will be paved with asphalt concrete, requiring existing vegetation to be removed. A new 8-inch diameter sewer pipeline will also be constructed to connect the dump station manhole to an existing manhole on the IEBL on El Prado Road.

Option B will have the new discharge station parallel to El Prado Road and cover an area of approximately 18,750 square feet (Figure 5.A-2). The hauling trucks will enter and exit the Discharge Station through El Prado Road. Most of this area currently features trees and vegetation, which will need to be removed. A new 8-inch diameter sewer pipeline will also be constructed to connect the new dump station manhole to an existing manhole on the IEBL.

Relocating the discharge station at the Chino Creek Wetlands and Education Park is unfavorable due to the site's importance to the community and purpose in preserving and restoring the Prado Basin. This project was partially funded by a grant from the State Water Resources Control Board and serves as a learning facility to visiting student groups. Both options will require the existing vegetation to be uprooted. Approximately 1,000 volunteers participated with planting and irrigation activities throughout the Park, which was opened in April 2008; therefore, impacting the Park will be undesirable to the public. The pathways in Option A will also intercept existing public trails, which could pose safety concerns to the visitors of the Park.




Figure 5.A-1: Option A overall layout



Figure 5.A-2: Option B overall layout

Option C has the new IEBL Discharge Station located south of CCWRF's existing chlorine contact tanks where the recycled water reservoir and pump station are located. Hauling trucks would enter and exit through a new opening off Telephone Avenue that would require part of the existing wall be demolished and fitted with a new entrance gate along with the demolition of some existing pipe and appurtenances (5.A-3). In addition, existing trees will be uprooted and removed, the curb will be modified, and the soiled ground will be paved with asphalt concrete to create this new entrance/exit.




Figure 5.A-3: Potential opening for option C

The trucks would travel on the roof of the existing reservoir and between existing reservoir air vents to a new discharge station, which will be located at the south corner of CCWRF (Figure 5.A-4). A new 8-inch sewer pipeline will be constructed to connect the new dump station manhole directly to an existing manhole on the 27-inch IEBL. The hauling trucks will exit the premises by

reversing into a space west of the chlorine contact tanks. This space provides the adequate turning radius required for WB-50 trucks to comfortably exit the CCWRF.




Figure 5.A-4: Option C overall layout

The major concern with this option is that the recycled water reservoir roof cannot structurally support truck traffic and the existing surrounding slopes are too steep for trucks to travel on. The design roof live load is only 400 psf, which is much less than the HS-20 live load required to support large semitrailers (WB-50 design vehicle). The roof will require major modifications to support these truck loads. In addition, the existing ground slope around the reservoir is too steep for hauling trucks to maneuver through as the slopes on the northeast and southwest sides are 5H:1V and 2H:1V, respectively. The two feet of soil that covers the reservoir's roof is part of the roof structural design, so maintaining the cover is desirable. Re-grading the surrounding area is infeasible due to the space constraints, especially on the northeast side. Locating the new Discharge Station at this location would also require demolishing and the creation of a new entrance opening.

Option D has the new IEBL Discharge Station located north of the solar panels at CCWRF. Trucks would enter and exit the premise through the existing entrance off Telegraph Avenue. Upon entering CCWRF, the trucks would follow the pathway delineated on Figure 5.A-5. Option D directs the trucks to a new discharge station located east of the existing headworks and north of the existing solar panels. Under this option, the new discharge station will encroach upon the existing curb by up to 15 feet horizontally. Therefore, the existing curb will need to be modified to accommodate the new discharge station and also to provide adequate turning radii. The existing site also contains solar panels, which would need to be relocated.

A new 8-inch diameter sewer pipeline would also be constructed to connect the new dump station manhole to a discharge manhole, which would connect to an existing manhole on the IEBL with another 8-inch diameter sewer pipeline. Under this configuration, no additional site security

measures would be required because no new opening has been created and the discharge station is within the CCWRF. However, signals would still need to be transmitted to and from the plant operations center to monitor the dumping occurring at the new discharge station.



Figure 5.A-5: Option D overall layout

Option D is considered unfavorable, however, because trucks would need to enter CCWRF and would disturb current operations and raise security concerns. Based on conversations with IEUA, allowing outside private haulers access to the plant is undesirable. Relocating the solar panels will also pose challenges because modifying the existing design could jeopardize the original electrical output projections and will require reworking of the solar panel system.

An alternate location was also considered where the private haulers would enter and exit the Discharge Station from Chino Hills Parkway through new openings in the existing wall. To isolate the Discharge Station from CCWRF, new security fencing and gates would be constructed. To achieve the necessary turning radii, this configuration would encroach upon the existing solar panels' area even more. In addition, the new pathways would require modifications to the sidewalk and vegetation along Chino Hills Parkway. Therefore, this alternate configuration is also undesirable.

Option E locates the new Discharge Station west of the existing solar panels at RP-5. Trucks would enter and exit the RP-5 through the existing entrance off Kimball Avenue. Upon entering RP-5, the trucks would follow the pathway shown on Figure 5.A-6. Under this option, the existing solar panels would be relocated and the new pathway would be paved with asphalt concrete. A new 8-inch diameter sewer pipeline would be constructed to connect the new dump station manhole to a new manhole, which would connect to an existing manhole on the IEBL with another 8-inch diameter sewer pipeline. Under this configuration, no additional site security measures would be required because the discharge station would be within the RP-5. However, signals

would need to be transmitted to and from the plant control station to monitor the dumping occurring at the new discharge station.



Figure 5.A-6: Option E overall layout

Option E is also considered undesirable because private haulers would have access to RP-5. In addition, the haulers would be sharing a pathway with maintenance trucks servicing RP-5, which would increase in number due to the future construction of solids handling facilities at RP-5. And like Option C, relocating the solar panels could jeopardize the original electrical output projections and would require reworking of the solar panel system.

Evaluation of Onsite Centrate Treatment and Offsite Recycle Flow Discharge

Predesign Report Yolume III, Chapter 6 RP-1 (RP-1) (Carbon RP-5) (P-2)

submitted by



in association with



TABLE OF CONTENTS

CHAPTER 6: EVA	ALUATIO	N OF RP-1 AND RP-5 ONSITE CENTRATE TREATMENT	
6.1	Introd	luction	6-1
	6.1.1 6.1.2	Understanding and Approach List of Alternatives	
6.2	Centra	ate Flow and Characteristics	
	6.2.1 6.2.2 6.2.3	Review of Available Data Centrate Flow Projections Estimated Centrate Characteristics	
6.3	Develo	opment of Alternatives	6-7
	6.3.1 6.3.2 6.3.3 6.3.4	Pre-Screening of Representative Centrate Treatment Technologies Principles of Operation RP-1 Alternatives RP-5 Alternatives	
6.4	Altern	atives Screening	
	6.4.1 6.4.2	Screening Screening Recommendations	
6.5	Altern	atives Comparison	6-41
	6.5.1 6.5.2 6.5.3 6.5.4	Capital Costs Operating and Maintenance Costs Repair and Replacement Costs Risks and Benefits	
6.6	Busin	ess Case Evaluation	
	6.6.1 6.6.2 6.6.3	BCE Results Food Waste Impacts Phasing Considerations for Food Waste Addition	
6.7	Concl	usions and Recommendations	
	6.7.1 6.7.2	Conclusions Recommendations	

LIST OF FIGURES

Figure 6-1: Traditional Nitrogen Removal Process in Comparison to Any Anammox Nitrogen Removal Process	6-10
Figure 6-2: ANITA [™] Mox Biofilm Growth on Media	
Figure 6-3: Paques Anammox Reactor	
Figure 6-4: Ostara Sidestream Phosphorus-Removal Process Diagram	
Figure 6-5: Struvite Produced in a Pearl Reactor	
Figure 6-6: AirPrex Process Flow Diagram	
Figure 6-7: Struvite Produced in AirPrex Reactor, and Packaged Struvite Fertilizer	
Product	6-17
Figure 6-8: General DEMON Footprint and Required Height	6-18
Figure 6-9: Typical AirPrex Configuration and Footprint	6-19
Figure 6-10: Typical AirPrex Section	6-19
Figure 6-11: Centrate Equalization Tanks and Pump Station Footprint	6-20
Figure 6-12: RP-1 Influent Flow and Treatment Capacity	6-23
Figure 6-13: RP-5 Influent Flow and Treatment Capacity	6-23
Figure 6-14: RP-1 Flow Forecast (mgd); RP-1 Alternative 1: Discharge to the NRW Line	6-24
Figure 6-15: RP-1 Flow Forecast (mgd), RP-1 Alternative 2: Treat Centrate with DEMON after 2030	6-25
Figure 6-16: RP-1 Flow Forecast (mgd), RP-1 Alternative 3: Treat Centrate with AirPrex after 2030	
Figure 6-17: RP-1 Flow Forecast (mgd), RP-1 Alternative 4: Treat Centrate with DEMON and AirPrex after 2030	6-27
Figure 6-18: RP-1 Flow Forecast (mgd), RP-1 Alternative 5: Return Centrate to RP-1 Liquids Stream after 2030	6-28
Figure 6-19: RP-1 Flow Forecast (mgd), RP-1 Alternative 6: Centrate Transfer to RP-5 after 2022	6-29
Figure 6-20: RP-1 Flow Forecast (mgd), RP-1 Alternative 7: Centrate Transfer to RP-5 after 2022 and to RP-1 DEMON after 2030	6-30
Figure 6-21: RP-1 Flow Forecast (mgd), RP-1 Alternative 8: Centrate Transfer to RP-5 after 2022 and RP-1 AirPrex after 2030	6-31
Figure 6-22: RP-1 Flow Forecast (mgd), RP-1 Alternative 9: Centrate Transfer to RP-5 after 2022 and RP-1 DEMON and AirPrex after 2030	6-32
Figure 6-23: RP-1 Flow Forecast (mgd), RP-1 Alternative 10: Centrate Transfer to RP-5 after 2030	6-33
Figure 6-24: RP-1 Flow Forecast (mgd), RP-1 Alternative 11: Centrate Transfer to RP-5 before 2022 and RP-1 after 2030.	6-34
Figure 6-25: RP-5 Flow Forecast (mgd); RP-5 Alternative 1: Discharge to the IEBL	6-35
Figure 6-26: RP-5 Flow Forecast (mgd); RP-5 Alternative 2: Centrate Recycle to RP-5	
Figure 6-27: RP-5 Flow Forecast (mgd); RP-5 Alternative 3: Centrate to RP-5 DEMON	6-37

Figure 6-28: RP-5 Flow Forecast (mgd); RP-5 Alternative 4: Centrate to RP-5 AirPrex	. 6-38
Figure 6-29: RP-5 Flow Forecast (mgd); RP-5 Alternative 5: Centrate to RP-5 DEMON	
and AirPrex	6-39

LIST OF TABLES

Table 6-1: Summary of Available Data	6-2
Table 6-2: Calculation of Centrate Production Rate Ratio	6-3
Table 6-3: Influent Characteristics, mg/L	6-4
Table 6-4: Solids Production Rate	6-4
Table 6-5: Projected Influent Flows at IEUA Facilities, mgd	6-4
Table 6-6: Projected Centrate Flows in 2045 Based on Centrate Production Rate Ratio,	(5
Table 6-7: Projected Centrate Flows in 2045 Based on Sludge Production Rate, gpd	
Table 6-8: Centrate Characteristics, mg/L	
Table 6-9: BAR Advantages and Disadvantages	6-8
Table 6-10: NSBR Advantages and Disadvantages	6-8
Table 6-11: Nitritation Advantages and Disadvantages	6-9
Table 6-12: Annamox Advantages and Disadvantages	6-12
Table 6-13: DEMON Installation List in North America	6-17
Table 6-14: Final RP-1 Centrate Handling Alternatives	6-40
Table 6-15: Final RP-5 Centrate Handling Alternatives	6-41
Table 6-16: RP-1 Centrate Handling Alternatives Capital Costs (\$1,000)	6-42
Table 6-17: RP-5 Centrate Handling Alternatives Capital Costs (\$1,000)	6-43
Table 6-18: Annual Running Unit Cost Assumptions	6-44
Table 6-19: BCE Results for RP-1 Centrate Handling	6-47
Table 6-20: BCE Results for RP-5 Centrate Handling	6-48
Table 6-21: Phasing Considerations for RP-5, Including Food Waste	6-51

THIS PAGE INTENTIONALLY LEFT BLANK.

CHAPTER 6: EVALUATION OF RP-1 AND RP-5 ONSITE CENTRATE TREATMENT

6.1 INTRODUCTION

This introductory section presents a project background, understanding and approach, and a list of alternatives considered.

6.1.1 Understanding and Approach

Centrate from Regional Water Recycling Plant 1 (RP-1) currently is discharged to the Non-Reclaimable Wastewater System (NRWS) line, but the Inland Empire Utilities Agency (IEUA) is considering alternatives because of the surcharges associated with using this brine line. The planned plant expansion at RP-1 may provide a convenient opportunity to install flexibility to treat centrate at the plant. Alternatively, the planned expansion at Regional Water Recycling Plant 5 (RP-5) may allow the opportunity to send centrate from RP-1 to RP-5, where RP-5 can be expanded to treat the additional load from RP-1 centrate. This business case evaluation (BCE) will evaluate alternatives for managing centrate treatment at RP-1.

Currently Regional Water Recycling Plant 2 (RP-2) sends recycle flows to RP-5. In relocating the solids treatment facility at RP-5, new options for managing these recycle flows may be needed. Flexibility should be provided to allow RP-5 to either treat the recycle flows or discharge these flows to the IEBL. This BCE will determine the most cost-effective approach to managing centrate treatment at RP-5. All BCE analysis are provided in Exhibit I of this Volume.

6.1.2 List of Alternatives

The following four alternatives are considered in the BCE for centrate handling at RP-1:

- Continue use of the NRW pipeline
- Recycle centrate back to RP-1 liquid treatment
- Provide separate treatment of centrate at RP-1
- Transfer centrate from RP-1 to RP-5 for combined treatment
- A combination of the above alternatives

The following three alternatives are considered in the BCE for centrate handling at RP-5:

- Recycle centrate to the RP-5 liquids treatment system
- Provide separate centrate treatment at RP-5
- Discharge centrate to the IEBL
- A combination of the above alternatives

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 6: Evaluation of RP-1 and RP-5 Onsite Centrate Treatment

6.2 CENTRATE FLOW AND CHARACTERISTICS

This section describes available data, methodologies, and assumptions used to develop centrate flow projections and centrate characteristics. This BCE was conducted during early stages of the project, and limited mass balance information was available. For this BCE, the estimation of centrate flows and characteristics uses the best information available at the time to provide an assessment of the alternatives. It is assumed that this approach will be sufficient for recommending centrate handling approaches, and selection of these technologies will allow continued development and refinement of future project mass balance efforts.

6.2.1 Review of Available Data

The following available data were used to project sludge and centrate production and characteristics at the IEUA facilities. Available data and their use for this evaluation are summarized in Table 6-1.

Data Description	Note
Daily influent flows and centrate flows at RP-1 and daily influent flows at RP-5 from 2/11/2016 to 3/9/2016	Historical centrate production rates were established for RP-1 based on ratio of centrate flow to influent flow (gallons of centrate/MG of plant influent). Because sludge from RP-4 is sent to and treated at RP-1, the ratio needs to account for RP-4 influent flows. However, RP-4 influent flow data are not provided for this period. Therefore, a flow of 10.5 mgd was assumed based on flow data given in other periods. Sludge from RP-5 and CCWRF are currently treated at RP-2. Centrate flow data at RP-2 are not available. Therefore, the same ratio was assumed for both RP-1 and RP-5.
Historical influent characteristics at RP-1, RP-5, and CCWRF from 2010 to 2015	Historical plant influent characteristics were reviewed but the plant influent concentrations used for this analysis are based on design concentrations for each facility.
RP-1 centrate characteristics data in February and March 2016	Centrate characteristics data were reviewed, but the centrate concentrations used for this analysis are based on design concentrations and are assumed to be the same at both facilities.
Solids production rates (lb of solids/MG of plant influent) at RP-5 and CCWRF	Solids production at IEUA facilities were estimated through efforts associated with Chapters 4 and 7 through preliminary mass balance modeling. Refer to these documents for details. ^a

Table 6-1: Summary of Available Data

^a Chapter 4: Evaluation of Ultimate Expansion of RP-5, and Chapter 7: BCE of RP-5 Secondary Treatment Alternatives

Table 6-1 summarizes the flow data and calculated flow ratios used to estimate centrate production rates. Historical centrate production rates from RP-1 were evaluated to develop centrate production rate to influent flow rate ratios at RP-1 from February 11 to March 9, 2016. Plant influent flow rates presented in Table 6-2 include the influent flows from both RP-1 and Regional Water Recycling Plant 4 (RP-4), because sludge from RP-4 is treated at RP-1. Based on these data, a centrate production rate ratio of 9,220 (gallons of centrate per million gallon of plant influent) was used.

Date	Plant Influent Flow ^a , mgd	Centrate Flow, gpd	Centrate Production Rate, Gallons/MG Influent
2/11/2016	34.7	368,483	10,619
2/12/2016	34.2	343,056	10,041
2/13/2016	34.6	395,555	11,433
2/14/2016	34.9	342,052	9,815
2/15/2016	34.2	333,151	9,727
2/16/2016	36.1	320,878	8,876
2/17/2016	34.8	329,769	9,479
2/18/2016	35.7	378,577	10,613
2/19/2016	35.7	386,073	10,805
2/20/2016	35.0	334,107	9,549
2/21/2016	35.9	346,548	9,661
2/22/2016	36.5	321,836	8,814
2/23/2016	35.6	328,726	9,242
2/24/2016	35.0	310,876	8,877
2/25/2016	34.6	319,280	9,223
2/26/2016	34.1	351,776	10,313
2/27/2016	33.4	337,988	10,109
2/28/2016	34.9	264,682	7,580
2/29/2016	35.1	330,905	9,423
3/1/2016	34.2	308,920	9,033
3/2/2016	34.6	304,978	8,811
3/3/2016	36.2	267,461	7,383
3/4/2016	34.3	378,901	11,057
3/5/2016	35.2	285,713	8,127
3/6/2016	34.3	307,109	8,957
3/7/2016	37.0	295,193	7,984
3/8/2016	36.7	210,594	5,736
3/9/2016	36.7	252,020	6,869
Average	35.1	323,400	9,220

Table 6-2: Calculation of Centrate Production Rate Ratio

^a RP-1 and RP-4 combined influent flow. Historical RP-4 influent flow data are not available for the period of evaluation. 10.5 mgd influent flow was assumed for RP-4.

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 6: Evaluation of RP-1 and RP-5 Onsite Centrate Treatmen

The design plant influent characteristics at RP-1 and RP-5 are summarized in Table 6-3. The influent characteristics were selected during a RP-1 and RP-5 Expansion PDR Flow and Loading Analysis meeting on March 7, 2016, which included a thorough review of historical data and previous master planning efforts. The design values were selected based on max month averages (90th percentile). The design plant influent concentrations for RP-5 include the centrate contributions (currently returned from RP-2). Since the centrate contribution is included, the actual projected influent loadings to RP-5 may be lower when RP-2 is decommissioned and sludge is treated at RP-5 (as centrate loadings are then internal to the plant).

Facility	BOD	TSS	NH3-N	TKN	VSS/TSS
RP-1	600	550	40	65	0.85
RP-5	500	400	50	65	0.85

Table	6-3:	Influent	Characteristics, mg/L	
-------	------	----------	-----------------------	--

Table 6-4 summarizes the solids production rate ratios used to calculate projected solids production rates. The ratios for RP-1 are approximately 25% higher than those for RP-5 due to the higher BOD and TSS influent concentrations.

Table 6-4: Solids Production Rate

Facility	Average Annual, lb/MG Influent		Maximum Month, lb/MG Influ	
	Primary Sludge	WAS	Primary Sludge	WAS
RP-5	1,700	800	2,500	1,500
CCWRF	2,125	1,000	3,125	1,875

6.2.2 Centrate Flow Projections

Future centrate flows were initially estimated using two different methods: from the calculated centrate flow to influent flow ratio and from estimated sludge production rates. In both cases, plant influent flows were applied to the calculated ratios. Table 6-5 summarizes the flow projections at each plant through 2050. For this analysis, flows between the given years were interpolated.

Facility	2013	2020	2030	2035	2040	2050
RP-1	24.7	26.2	30.3	32.2	33.7	32.9
RP-4	11.1	12.7	13.0	13.0	13.0	17.8
RP-5	4.3	8.9	14.7	17.1	19.7	23.6
CCWRF	7.4	7.6	7.8	7.9	8.1	8.3
Montclair Diversion	3.4	3.6	3.8	3.8	3.9	3.9
Whispering Lakes PS	1.5	1.5	1.6	1.6	1.7	1.7
Haven PS	0.1	0.1	0.2	0.2	0.3	0.3

Table 6-5: Projected Influent Flows at IEUA Facilities, mgd

6.2.2.1 Centrate Flow Projections Based on Centrate Production Rate Ratio

The following assumptions were used to project centrate production rates at RP-1 and RP-5 using the centrate production rate ratio:

- Ratios of centrate flow to plant influent flow (see Table 6-2) calculated based on data from February to March 2016 are representative of those of RP-1 and RP-5.
- The ratio of centrate flow to plant influent flow will remain the same for future flow and load conditions and solids stream treatment technologies to be used.
- Because sludge from RP-4 is sent to and treated at RP-1, the ratio needs to account for RP-4 influent flows. However, RP-4 influent flow data are not provided for this period. Therefore, a flow of 10.5 mgd was assumed based on flow data given in other periods.
- A peaking factor of 1.0 was selected for sizing centrate treatment process as flow and load attenuation is expected across the liquid-stream and solids stream processes. Additional considerations on peaking factors should be considered for the recommended centrate handling alternatives, as applicable.
- For centrate generation at RP-1, the influent flows for both RP-1 and RP-4 are used as the sludge from RP-4 is sent to RP-1.
- For centrate generation at RP-5, the influent flows for both RP-5 and Carbon Canyon Water Recycling Facility (CCWRF) are used as the sludge from CCWRF will be sent to RP-5.
- While certain flows in the service area (Montclair Diversion, Whispering Lakes Pump Station [PS], and Haven PS can be routed to either RP-1 or RP-5, and Montclair flow can also be routed to CCWRF, the centrate flows at each facility were calculated assuming that these flows are included to provide the most conservative estimate. For the centrate flow at RP-5, the Montclair Diversion flow is counted only once.
- For the design centrate flow at RP-5 (for sizing the sidestream treatment processes), a design capacity of 40 million gallons per day (mgd) was assumed for RP-5, which accounts for flows from CCWRF when it is decommissioned.

Based on the assumptions and data described above, centrate projections in 2045 based on the centrate production rate ratio were calculated and are summarized in Table 6-6

Table 6-6: Projected Centrate Flows in 2045Based on Centrate Production Rate Ratio, gpd

RP-1 + PR-4 ^a	RP-5 + CCWRF ^b		
503,400	368,800		
^a For RP-1 and RP-4, the projected 2045 flows were used to calculate the design centrate flow.			

^b For RP-5 + CCWRF, the 2035 design capacity for RP-5 with CCWRF decommissioned was used to calculate the design centrate flow.

6.2.2.2 Centrate Flow Projections Based on Sludge Production Rate

Centrate flows were also estimated by calculating the digested sludge production rates and through mass balance calculations across the dewatering process. The following assumptions were used to project centrate productions based on sludge production rate:

- Sludge production rate at RP-1 is about 25% higher than that of RP-5.
- Sludge production rates will remain the same for future flow and load conditions and solids stream treatment technologies to be used.
- Total solids contents of thickened sludge and dewatered cake are 4.5 percent and 25 percent, respectively.
- As a conservative estimate, solids capture rates of sludge thickening and dewatering processes are 100 percent.

Based on the assumptions and data presented above, centrate projections in 2045 based on sludge production rate were calculated and are summarized in Table 6-7.

Table 6-7: Projected Centrate Flows in 2045 Based on Sludge Production Rate, gpd

RP-1 + PR-4 ^a	RP-5 + CCWRF ^b		
322,200	256,000		
 ^a For RP-1 and RP-4, the projected 2045 flows were used to calculate the design centrate flow. ^b For RP-5 + CCWRF, the 2035 design capacity for RP-5 with CCWRF decommissioned was used to calculate the 			

design centrate flow.

6.2.2.3 Centrate Flow Projections Used for Centrate Treatment Evaluation

As shown in Tables 6-6- and 6-7, centrate projections calculated from the two methods are different. Those calculated from centrate production rate are significantly higher than those from sludge production.

Such discrepancy is likely due to limited available data for this evaluation. For example, centrate production rate data during a period of only approximately one month at RP-1 were used to predict centrate production rates at both RP-1 and RP-5 in the future. The results can be flawed if the influent and/or centrate flows during that limited period were not representative of typical operation. Assumptions were also made regarding the influent flows at RP-4 and the applicability of the calculated ratio at both facilities. Any deviations from these assumptions would further exacerbate the discrepancies.

The apparent discrepancy between centrate flow projections derived from two methods is not uncommon for high-level evaluations at the early stage of a project. The Parsons/Brown and Caldwell (BC) team will continue to refine centrate projections as more process data become available.

For the purpose of this analysis, the higher, more conservative centrate projections based on the centrate production ratio (Table 6-6) were used for the BCE. The BCE was conducted based on the period from 2016 to 2045.

6.2.3 Estimated Centrate Characteristics

Table 6-8 summarizes the centrate characteristics used for the centrate treatment BCE.

Table 6-8: Centrate Characteristics, mg/L

COD	TSS	NH3-N	Р
850	250	1,000	120

6.3 **DEVELOPMENT OF ALTERNATIVES**

This section describes the development of centrate treatment technology alternatives.

6.3.1 Pre-Screening of Representative Centrate Treatment Technologies

This section describes pre-screening of centrate treatment technologies.

6.3.1.1 Sidestream Nitrogen Removal Technologies

This section provides an overview of sidestream treatment technologies that could reduce centrate impact on secondary treatment processes and improve nitrogen removal. The strategies discussed in this section include the following:

- Centrate equalization
- Biological Augmentation Reactor (BAR)
- Separate Sludge Nitrification
- Nitritation
- Anammox
- Ammonia Stripping

Centrate Equalization

Centrate equalization can be implemented by plants that have intermittent thickening and dewatering operations to provide a more continuous loading of ammonia back to the main liquid stream treatment process. An equalization basin allows the plant to provide a constant centrate flow rate. For plants that thicken and dewater continuously, equalization allows the plant to return more centrate during low influent loading periods when the secondary process has available treatment capacity. Equalization does not reduce the ammonia loading treated in the secondary process, but it does provide the plant with the ability to control when the ammonia loading is returned to match the secondary process capacity.

Sizing of equalization depends on planned dewatering operation schedules, typically ranging from 24 hours of equalization for plants that dewater continuously up to 72 hours or more for plants that do not dewater on weekends or holidays.

Centrate and RAS Reaeration Basin

The BAR process combines RAS from the secondary system with centrate in an aerated reactor before entering the liquid treatment process. The BAR process offers the advantage of bioaugmentation of the nitrifier population and increases the rate of nitrification in the downstream



bioreactor. This allows operation at a comparatively lower aerobic solids retention time (SRT) for full nitrification and a lower mixed liquor suspended solids (MLSS) for reduced solids load to the clarifiers. For best performance, the centrate return flow should be equalized and introduced at a constant rate to maintain a steady source of substrate (ammonia) rather than feast/starve cycles. Advantages and disadvantages of BAR are shown in Table 6-9.

Advantages	Disadvantages
 Operational flexibility Less tankage for nitrification Can split and bypass a portion of RAS and/or centrate for operational flexibility Reduced mixed liquor recycle requirement 	 Nitrogen not fully removed; only converted to nitrate, which must be removed in the liquid treatment process May require supplemental alkalinity No reduction in total air demand
Provides bioaugmentation of nitrifying organisms	• No reduction in supplemental carbon requirements

Table 6-9: BAR Advantages and Disadvantages

Separate Sludge Nitrification

One potential sidestream treatment technology would be to nitrify the sidestream flow using a separate activated sludge system. One means often employed is a nitrifying sequencing batch reactor (NSBR), which is a fill-and-draw activated sludge system. In this system, wastewater is added to a single "batch" reactor, treated to remove pollutants, and then discharged. Equalization, aeration, and clarification can all be achieved using a single batch reactor.

To optimize the performance of the system, two or more batch reactors are used in a predetermined sequence of operations. Sequencing batch reactor (SBR) systems have been broadly used to treat both municipal and industrial wastewater. They are uniquely suited for wastewater treatment applications characterized by low or intermittent flow conditions such as for sidestreams. The NSBR would be installed to treat centrate prior to sending the flow back to the headworks. The flow leaving the NSBR would still need to denitrify in the main stream flow. Some denitrification would probably occur in the headworks and primary clarifiers, with the rest in the secondary process. Advantages and disadvantages of an NSBR are shown in Table 6-10.

Table 6-10: NSBR Advantages and Disadvantages

Advantages	Disadvantages
Established technology	Alkalinity addition required
Simple reactor vessel	• Oxygen transfer limitations result in large reactor volume
• Operational flexibility and control	• Heavy reliance on automated systems to control process
• Potential capital savings by incorporating separation/other	• Potential of washing out non-settled biomass during the decant phase
 equipment within a common basin Reduce final effluent ammonia discharge concentration 	• Nitrogen not fully removed; only converted to nitrate, which must be removed in the liquid treatment process and may result in supplemental carbon requirements

SHARON®

The Single Reactor High-Activity Ammonia Removal Over Nitrite (SHARON) process is a highrate nitritation/denitrification two-step process. In the first step, all of the ammonia is oxidized to nitrite (nitritation) and in the second step, the nitrite is reduced by denitrifiers. The second step requires an external carbon source to fuel the biological process.

Advantages and disadvantages for the nitritation reactor are summarized in Table 6-11.

Table 6-11: Nitritation Advantages and Disadvantages

Advantages	Disadvantages
 Lower oxygen demand than conventional nitrification No clarifier is required with two tanks in series Removes nitrogen from the sidestream 	 Higher oxygen demand than ANAMMOX Challenging process control New technology for operators Requires external carbon source addition Separate process that must be operated Risk of incomplete ammonia reduction A significant amount of nitrite is converted to nitrate Requires cooling water to maintain temperature

Anammox

Three treatment technologies are considered for sidestream nitrogen removal via anammox bacteria: World Water Works' DEamMONification (DEMON[®]) process, Veolia's _____ (ANITATM Mox) process, and Paques' ANaerobic AMMonia OXidation (ANAMMOX[®]) process.

DEMON Process

As opposed to traditional total nitrogen removal through nitrification and denitrification, the DEMON process uses a de-ammonification process in a suspended-growth SBR configuration for nitrogen removal. The de-ammonification process uses a special type of bacteria to convert ammonia to nitrogen gas without the need of an external carbon source and with about half of the energy compared to that typically required in a traditional total nitrogen removal process. The special bacteria used in de-ammonification are called anammox. The DEMON process involves partially nitrifying ammonia with ammonia-oxidizing bacteria (AOB), followed by anaerobic reaction involving nitrite removal by conversion to nitrogen gas carried out by anammox bacteria. Figure 6-1 shows the traditional nitrification and denitrification process in comparison to anammox processes.

In the SBR configuration, the reactor is gradually filled with the centrate and then alternatively aerated and mixed. After the aeration phase, aeration and mixing are both stopped and the sludge blanket is allowed to settle. Because the anammox bacteria are very slow growth, the DEMON process uses cyclones to separate the anammox granules from the mixed liquor.




Figure 6-1: Traditional Nitrogen Removal Process in Comparison to Any Anammox Nitrogen Removal Process

ANITA Mox Process

The ANITA Mox process is similar to the DEMON process, also using a de-ammonification process for nitrogen removal. However, ANITA Mox uses media in a moving-bed biofilm reactor (MBBR) to treat the ammonia-rich influent. In the MBBR, carriers are kept in suspension by aeration and mixing. A biofilm grows on the plastic media, with the AOB on the outer layers of the biofilm and the anammox bacteria on the inner layers of the biofilm. Thus, nitritation occurs on the outer layer, while anammox carries out nitrite oxidation in the inner layer as shown in Figure 6-2. A benefit of the use of media is that it prevents the washout of the anammox bacteria from the reactor. Other advantages to the ANITA Mox process are similar to those of DEMON.




Figure 6-2: ANITA™ Mox Biofilm Growth on Media

Source: <u>http://technomaps.veoliawatertechnologies.com/anita/en/anita_mox.htm?bu=doc</u>

ANAMMOX Process

The ANAMMOX process also uses anammox bacteria in combination with nitrification to convert ammonium directly into nitrogen gas. The ANAMMOX process uses an upflow reactor. The reactor is aerated, contains granular biomass, and is continuously fed wastewater. The reactor is aerated to provide mixing and contact with the biomass. The effluent leaves the reactor by passing through the anammox separator. The granular biomass is separated from the effluent, thus retaining the biomass in the reactor and eventually ensuring high biomass content. With such high biomass content, conversion of ammonia into nitrogen gas is efficient in a small reactor volume. Figure 6-3 shows a typical Paques ANAMMOX reactor.




Figure 6-3: Paques Anammox Reactor

Source: Paques Vendor Pamphlet

Advantages and Disadvantages of the Various Anammox Processes

In summary, the advantages and disadvantages with the anammox method for sidestream treatment are presented in Table 6-12.

Advantages Disadvantages	
 Lower aeration energy requirement (less than half) because only about half of the ammonium supplied has to be oxidized in the reactor Typically no supplemental alkalinity requirement Does not require an external organic carbon source (such as methanol) because ammonium is used the electron donor in the reactor Lower sludge output because of the low yield of the anammox bacteria Retains a smaller total footprint in comparison to what would be required in a secondary treatment expansion, assuming the sidestreams were routed New technology for operators Separate process that must be optimate of the sidestreams were routed 	erated

Table 6-12: Annamox Advantages and Disadvantages

Ammonia Stripping

Another potential alternative for sidestream nitrogen removal is ammonia stripping. In this physical/chemical process, ammonia is removed by changing the operating conditions such as temperature and/or pH to shift the liquid-gas equilibrium favoring transfer of ammonia from the

6-12

liquid to gas phase. Ammonia stripping is typically done in a packed bed column to enhance mass transfer, but that limits its applications to a low-solids stream with lower potential for fouling of the column media. Ammonia stripping is more commonly used in industrial applications and may be used in conjunction with an adsorption process to recover the ammonia as ammonium sulfate.

Anaergia Side Stream Ammonia Recovery (SBSA) Process

One example of an ammonia stripping system is the Anaergia Side Stream Ammonia Recovery (SBSA) process designed for wastewater applications. The SBSA process is a proprietary commercial process for sidestream treatment. It involves ammonia stripping from digestate centrate using waste heat and submerged aeration. After dewatering of the digested sludge, the centrate is pre-heated using heat recovered from the ammonia stripped effluent and waste heat from a combined heat and power (CHP) system. The heated filtrate then enters the first of a series of aerated tanks where carbon dioxide is stripped to increase pH. Up to 90 percent ammonia removal can be achieved at conditions where the pH is increased to above 9 and temperature is increased to above 60 deg C. The ammonia rich gas from the strippers can then be sent to an acid gas scrubber, where sulfuric acid is added to lower the pH and ammonium sulfate is generated.

The Anaergia system was designed to allow application in a municipal wastewater treatment plant by including a stripping process that does not use packed bed columns, which eliminates the need for any pre-treatment filtration process to prevent fouling of the column media. Temperature adjustment is achieved by using waste heat from a CHP process. If a CHP process is not included in the treatment facility, then the centrate stream will then need to be heated separately, which could result in significant energy requirements. Chemical addition for pH adjustment in the stripping process is not needed; however, if acid scrubbing is used in conjunction with the stripping process, addition of sulfuric acid is required. The recovered ammonium sulfate may be sold as a fertilizer product if a market can be found.

Further evaluation of this process is needed to determine its feasibility and cost-effectiveness. It is not included in the BCE analysis described below.

6.3.1.2 Struvite Removal Technologies: WASSTRIP + Ostara, AirPrex

This section describes struvite removal technologies, including Waste Activated Sludge Stripping to Remove Internal Phosphorus (WASSTRIP) combined with Ostara and AirPrex.

Ostara and WASSTRIP

Ostara markets the Pearl reactor, which produces a struvite precipitate on the dewatering filtrate or centrate stream. To maximize phosphorus release and recovery while minimizing struvite precipitation upstream of the Pearl reactor, the Pearl process will be combined with Clean Water Institute's patented process called WASSTRIP. The combined process minimizes the sidestream phosphorus load and struvite formation within the biosolids system, while also reducing sidestream ammonium loads and solids quantities for disposal. Ostara also claims that the combined processes can reclaim lost dewatering performance (which is often observed in biological phosphorus [Bio-P] facilities), increasing the dewatered biosolids concentrations and reducing polymer demand for dewatering. The resulting struvite product is purchased by Ostara and sold to the public or to other fertilizer manufacturers as Crystal Green[®]. The Ostara/WASSTRIP process has eight current

installations with another five currently under construction or design. Most projects are in the United States and Canada.

The WASSTRIP process is designed to cause a release of intracellular phosphate reserves from the waste-activated sludge (WAS). Bacteria uptake phosphorus when exposed to cyclical anaerobic and aerobic conditions, such as conditions existing in plants that perform Bio-P removal or anaerobic selectors to control filamentous bacterial growth. While the facilities at IEUA do not use either Bio-P or anaerobic selectors, the high phosphate concentrations in the digested sludge suggest that the bacteria are storing some intracellular phosphate. To validate the utility of the WASSTRIP process, pilot-scale testing is necessary.

The WASSTRIP process holds WAS for approximately 12 hours (6 to 20 hours) in an anaerobic environment while providing a form of readily biodegradable chemical oxygen demand (COD). These conditions mimic the anaerobic environment in the anaerobic selector that prompts the phosphorus-accumulating organisms (PAOs) to release internal reserves of polyphosphate. Effluent from the WASSTRIP tank is thickened to 2 to 3 percent solids using the plant's thickening process. The thickener subnatant, rich in phosphate, is then combined with centrate from the centrifuges and passed to the Pearl reactor. The thickened WAS is sent to digestion for solids stabilization.

The Pearl reactor creates an environment that promotes struvite formation in a controlled location. It does this by treating thickening and dewatering streams in a high-pH environment with added magnesium to increase the struvite precipitation potential in a location that will not cause operations and maintenance (O&M) issues. To do this, Ostara increases the pH of the treated streams (filtrate, centrate, etc.) in the Pearl reactor to approximately 9 using caustic soda (i.e., sodium hydroxide [NaOH]). Additional magnesium is also added, most commonly as magnesium chloride (MgCl₂), because magnesium is typically the limiting component (lowest concentration) for precipitating struvite. A process flow diagram for the Ostara Pearl system with WASSTRIP is presented in Figure 6-4.

The Pearl reactor operates as a fluidized bed reactor, growing the struvite crystals until they reach 0.9 to 3.0 millimeters (mm) in diameter. The large struvite crystals or "prills" (see Figure 6-5) are then harvested for use as fertilizer or to supplement a fertilizer product. Ostara claims to remove up to 88 percent of the sidestream phosphorus load.




Figure 6-4: Ostara Sidestream Phosphorus-Removal Process Diagram

Source: Ostara





0.9, 1.5, 3.0, and 4.5 mm prill size (Source: Ostara)

AirPrex

CNP markets the AirPrex reactor, which, like Ostara's Pearl system, precipitates struvite. However, where Ostara precipitates struvite on "clean" sidestreams of thickener and dewatering filtrate and centrate, the AirPrex system is designed to remove struvite from the digested sludge



stream prior to dewatering. The AirPrex system has two modes of operation: struvite "harvesting" and struvite "sequestration," which leaves the struvite in the sludge rather than separating it for sale. The AirPrex system will minimize sidestream phosphorus load and struvite formation within the dewatering system while also reducing sidestream ammonium loads and solids quantities for disposal. CNP also claims that the AirPrex system can reclaim lost dewatering performance, increasing the dewatered biosolids concentrations and reducing polymer demand for dewatering. The CNP AirPrex system has 6 European installations and 1 Chinese installation, and 28 projects in planning or design in the United States.

6.3.2 Principles of Operation

The AirPrex reactor treats anaerobically digested sludge with high phosphate and ammonium concentrations due to the breakdown of organic content. The digested sludge is transferred to the AirPrex reactor, where it is aerated using coarse-bubble diffusers to strip carbon dioxide (CO₂) and increase the pH. This is done in lieu of the chemical pH adjustment used by other systems. A supplemental source of magnesium (typically MgCl₂) is injected to increase the magnesium concentration and initiate struvite precipitation. CNP claims that the AirPrex reactor is capable of removing 90 to 95 percent of the sidestream phosphorus load. If the reactor is operated in the struvite sequestration mode (i.e., no interest in producing a fertilizer product), then the digested sludge, the struvite can enhance the nutrient value of the biosolids. If harvesting of struvite is desired, struvite-rich digested solids are removed from the bottom of the AirPrex reactor and a Huber Coanda grit washer is used to rinse the majority of organics from the struvite. See Figure 6-6 for a process flow diagram of the AirPrex system. Figure 6-7 shows the struvite product.




Figure 6-6: AirPrex Process Flow Diagram

Source: CNP



Figure 6-7: Struvite Produced in AirPrex Reactor, and Packaged Struvite Fertilizer Product

6.3.2.1 Representative Centrate Treatment Technologies

To simplify the BCE effort, a representative technology for sidestream nitrogen and struvite removal was selected as a representative technology for analysis.

For sidestream nitrogen removal, the DEMON process was selected based on its lower operating cost and footprint relative to other technologies. In addition, DEMON has a significant number of installations worldwide and in the United States. Currently, there are over 5 installations that are operational and a few under construction in the United States. For planning purposes, the footprint of a DEMON system is assumed to match Figure 6-8. In general, DEMON can be applied in a variety of different tank configurations (round, rectangular, etc.). At other utilities, DEMON was successfully adopted in existing basins to reduce the cost of installation.

Table 6-13 lists the installations of DEMON in North America as of 2015.

Year	Location	Status	Drivers
2014	Chambers Creek, Pierce County, WA	Under construction	Reduce mainstream methanol demands; reduce size of aeration basins
2015	DC Water- Blue Plains, Washington, DC	Under construction	Thermal hydrolysis recycle streams with high NH ₃
2016	Raleigh NRRRF	Planned installation	Digestion was a new component in solids treatment
2015	Greeley, CO	Operational	Reduce methanol demands
2012	HRSD, York River, VA	Operational	Recycle streams with high ammonia; Energy costs
2013	Orlando, FL	Operational	Reduce energy demand
2013	Alexandria, VA	Operational	
2016	Philadelphia, PA	100% review by client	
2015	Guelph, Ontaria	Operational	

Table 6-13: DEMON Installation List in North America




Figure 6-8: General DEMON Footprint and Required Height

For struvite removal, the AirPrex system was selected for the flexibility to either precipitate struvite in the digested sludge prior to dewatering or to recover struvite struvite for sale. AirPrex induces struvite formation in digested sludge prior to dewatering. Struvite can either be precipitated and left in the digested sludge or removed for recovery and sale. When left in the digested sludge, the struvite can enhance the nutrient value of the biosolids.

Ostara is considered by many to be the leading manufacturer in struvite recovery. For this evaluation, Ostara was not selected as the representative technology because it requires the WASSTRIP process to effectively prevent struvite formation in the dewatering equipment. While the WASSTRIP process may prove to be effective if appropriate field testing and pilot-scale demonstrations are performed, it was considered an unacceptable risk to assume its effectiveness and include it within this BCE. The Ostara process also requires additional equipment, because it always harvests struvite. This increases the O&M and capital costs creating a less favorable scenario for sidestream phosphorus removal. The Ostara reactor does have a higher struvite recovery efficiency than AirPrex, thus if struvite harvesting and sale is shown to improve the sidestream phosphorus removal alternatives then an additional BCE should be undertaken to assess the selection of AirPrex and Ostara assuming appropriate field testing is also performed.

For planning purposes, the footprint of an AirPrex system is assumed to match Figure 6-9.




Figure 6-9: Typical AirPrex Configuration and Footprint




Figure 6-10: Typical AirPrex Section

Centrate equalization was sized to store centrate during an 8-hour dewatering shift and return centrate to the plant over a 24-hour period. The following schematic illustrates the footprint of a centrate equalization considered for this BCE.




Figure 6-11: Centrate Equalization Tanks and Pump Station Footprint

6.3.3 **RP-1** Alternatives

Several alternatives were considered for centrate handling at RP-1. This section describes these alternatives in more detail.

Discharge Centrate to NRW Line

Currently RP-1 discharges centrate to the NRW line. A usage fee is assessed for this service based on the quantity and quality of centrate discharged and a constant O&M and _____(CIP) fee. The rate structure established in the current agreement between IEUA and the County Sanitation Districts of Los Angeles County for fiscal year 2015–16 was assumed to apply for calendar year 2016, with an assumed escalation rate applied for each subsequent year. It was assumed that IEUA had already paid for the necessary upfront costs for the maximum capacity units (CUs) for discharge and would not need to procure more CUs. This alternative consists of the lowest capital expenditures because centrate treatment or equalization is not required.

Recycling Centrate Back to RP-1 Liquids Treatment

Centrate from RP-1 can recycle to the secondary liquid process for treatment. Recycling centrate to the secondary process will increase the nitrogen load and thus require greater aeration volume for nitrification, higher aeration air requirements, and potentially supplemental carbon requirements for denitrification, which was assumed to be methanol requirements for this analysis. Recycling centrate back to the liquids process will require some equalization to minimize the impact of dewatering schedule on the plant load. For the purpose of this study, it is assumed that

dewatering will occur daily over an 8-hour shift, and centrate will be equalized to allow storage and return of the centrate to the liquids process over 24 hours.

Separate Treatment of Centrate at RP-1

Separate treatment of centrate can be achieved by sidestream treatment with the DEMON process. DEMON is assumed to remove 85 percent of the ammonia load in the centrate. For struvite removal, AirPrex was used for this analysis. AirPrex is capable of removing 90 percent of the phosphorus load in the digested sludge. It should be noted that AirPrex is not a centrate treatment process but it achieves phosphorus removal and provides struvite control. For both DEMON and AirPrex, equalization of the centrate is required to manage the size and cost of the centrate treatment process and reduce impact on the liquid stream process. For the purpose of this study, it is assumed that dewatering will occur daily over an 8-hour shift, and centrate will be equalized to allow storage and return of the centrate to the separate treatment process over 24 hours.

Transfer Centrate from RP-1 to RP-5 with Combined Treatment

At RP-1, the capability exists to transfer centrate into a gravity sewer line to the RP-5 headworks and the centrate will subsequently be treated in the secondary system at RP-5. The volume of centrate transfer to RP-5 will depend on the dewatering schedule. To manage the nitrogen load at RP-5 associated with the centrate, it is assumed that centrate equalization will be provided for this alternative. It is assumed that dewatering will occur daily over an 8-hour shift, and centrate will be equalized to allow storage and return of the centrate to RP-5 over 24 hours.

6.3.4 **RP-5** Alternatives

Several alternatives were considered for centrate handling at RP-5. This section describes these alternatives in more detail.

Discharge Centrate to IEBL Line

Centrate from the new solids process at RP-5 can be connected to the IEBL line for disposal. Similar to the NRW line, a usage fee is assessed for this service based on centrate quantity and quality and a constant capacity and CIP fee. The rate structure established in the current resolution by IEUA for fiscal year 2015–16 was assumed to apply for calendar year 2016, with an assumed escalation rate applied for each subsequent year. It was assumed that IEUA had already paid for the necessary upfront costs for the maximum CUs for discharge and any application and permitting fees and would not need to procure more CUs. This alternative consists of the lowest capital expenditures because centrate treatment or equalization is not required.

Recycling Centrate to RP-5 Liquids Treatment

Centrate generated at RP-5 can be recycled to the secondary liquid process for treatment. This is similar to the current operation as the recycle flows generated at RP-2 are routed to RP-5 for treatment. Compared to the option of sending the centrate to IEBL, recycling centrate back to the liquids process will require some equalization to minimize the impact of dewatering schedule on the plant load. For the purpose of this study, it is assumed that dewatering will occur daily over an 8-hour shift, and centrate will be equalized to allow storage and return of the centrate to the liquids process over 24 hours.

Separate Treatment of Centrate at RP-5


Separate treatment of centrate includes sidestream treatment with DEMON and AirPrex. As noted above, AirPrex is not a centrate treatment process but is included as an option for this alternative as it achieves some similar objectives and also provides struvite control. Separate treatment of centrate will also require some equalization of centrate to manage the size and cost of the centrate treatment process. For the purpose of this study, it is assumed that dewatering will occur daily over an 8-hour shift, and centrate will be equalized to allow storage and return of the centrate to the separate treatment process over 24 hours.

6.4 **ALTERNATIVES SCREENING**

The previously listed alternatives or a combination of these alternatives will provide the best opportunity for centrate handling at RP-1 and RP-5. The IEUA includes a complex system with several treatment plants: CCWRF, RP-1, RP-2, RP-4, and RP-5. Each treatment plant has specific capacity limitations and different plans for expansion or decommissioning. As such, the most attractive centrate handling alternatives or combination of alternatives at RP-1 and RP-5 must account for the respective flows, loads, and capacities of each reclamation plant. This section summarizes combination of centrate handling alternatives based on the projected flows, loads, and timing of planned capacity expansions at the various reclamation facilities.

6.4.1 Screening

The current understanding of the flows and projected process capacities at RP-1 and RP-5 is summarized in Figure 6-12 and Figure 6-13. Based on these flows and projected capacities, several alternatives for centrate handling at RP-1 can be developed.








Figure 6-12: RP-1 Influent Flow and Treatment Capacity

Figure 6-13: RP-5 Influent Flow and Treatment Capacity

Centrate Handling Alternatives at RP-1

This section describes centrate handling alternatives at RP-1.

Alternative 1

At RP-1, the current practice of transferring centrate to the NRW line can continue indefinitely (though there are some risks to be considered). This alternative assumes centrate will be transferred from RP-1 to the NRW line for the duration of the evaluation. Figure 6-14 shows a flow forecast for RP-1 Alternative 1.





Figure 6-14: RP-1 Flow Forecast (mgd); RP-1 Alternative 1: Discharge to the NRW Line

Alternative 2

A planned expansion at RP-1 will occur in 2030 and, during this expansion, separate centrate treatment capacity can be designed as DEMON to allow centrate treatment. Prior to 2030, it is not anticipated that RP-1 will have sufficient capacity to treat centrate and, during that period, centrate can be returned to the NRW line. While the DEMON process will remove most of the nitrogen load in centrate, a small fraction, approximately 10 to 20 percent, will be returned to the secondary process as nitrate. While this will not increase aeration demand, the secondary denitrification process should be designed to accommodate this load. The DEMON system would be designed for the centrate flows and loads corresponding to the projected 2045 plant influent flows at RP-1 and RP-4. Figure 6-15 shows a flow forecast for RP-1 Alternative 2.




RP-1 Influent Flow and Treatment Capacity



Alternative 3

A planned expansion at RP-1 will occur in 2030 and, during this expansion, separate centrate treatment capacity can be designed with AirPrex. Prior to 2030, centrate can be returned to the NRW line. The AirPrex system would be designed to remove some nitrogen and all struvite. Currently struvite accumulates at RP-1 at the dewatering process, and struvite accumulation is managed by addition of a chemical designed to control the precipitation of struvite. Removal of struvite with AirPrex will reduce operating costs associated with struvite cleaning chemicals. In addition, AirPrex will remove approximately 25 percent of the nitrogen load. The remaining nitrogen load in the centrate will be recycled to RP-1 liquids process, and the secondary system should be designed to accommodate this additional load. The AirPrex system would be designed for the digested sludge flows and loads corresponding to the projected 2045 plant influent flows at RP-1 and RP-4. Figure 6-16 shows a flow forecast for RP-1 Alternative 3.




RP-1 Influent Flow and Treatment Capacity

Figure 6-16: RP-1 Flow Forecast (mgd), RP-1 Alternative 3: Treat Centrate with AirPrex after 2030

Alternative 4

A planned expansion at RP-1 will occur in 2030 and, during this expansion, separate centrate treatment capacity can be designed with both DEMON and AirPrex. DEMON and AirPrex will provide the combined advantages presented with Alternatives 2 and 3. The systems would be designed for the centrate and digested sludge flows and loads corresponding to the projected 2045 plant influent flows at RP-1 and RP-4. Prior to 2030, centrate will continue to be discharged to the NRW line. Figure 6-17 shows a flow forecast for RP-1 Alternative 4.




RP-1 Influent Flow and Treatment Capacity

Figure 6-17: RP-1 Flow Forecast (mgd), RP-1 Alternative 4: Treat Centrate with DEMON and AirPrex after 2030

Alternative 5

A planned expansion at RP-1 will occur in 2030 and, during this expansion, additional secondary system capacity can be designed and installed to allow centrate to be recycled back to the plant. Prior to 2030, it is not anticipated that RP-1 will have sufficient capacity to treat centrate, and during that period, centrate will continue to be discharged to the NRW line. Figure 6-18 shows a flow forecast for RP-1 Alternative 5.




RP-1 Influent Flow and Treatment Capacity

Figure 6-18: RP-1 Flow Forecast (mgd), RP-1 Alternative 5: Return Centrate to RP-1 Liquids Stream after 2030

Alternative 6

A planned expansion at RP-5 will occur in 2022 and, during this expansion, additional secondary system capacity can be designed and installed to allow centrate to be transferred from RP-1 to RP-5. Transferring centrate to RP-5 will require the secondary process at RP-5 to be designed to handle the increased nitrogen load. Also, based on the influent and centrate characteristics, it is anticipated that RP-5 will require methanol addition to process the centrate from both RP-1 and RP-5. Prior to 2022, it is assumed that centrate will continue to be discharged to the NRW line. Figure 6-19 shows a flow forecast for RP-1 Alternative 6.




RP-1 Influent Flow and Treatment Capacity

Figure 6-19: RP-1 Flow Forecast (mgd), RP-1 Alternative 6: Centrate Transfer to RP-5 after 2022

Alternative 7

A planned expansion at RP-5 will occur in 2022 and, initially after this expansion, RP-5 will have excess secondary capacity to process centrate. Prior to 2022, it is assumed that centrate will continue to be discharged to the NRW line. After the 2022 RP-5 expansion, centrate can be transferred to RP-5 until 2030, when RP-1 expansion is anticipated. During the RP-1 expansion, separate centrate treatment capacity can be designed as DEMON to allow centrate treatment. Figure 6-20 shows a flow forecast for RP-1 Alternative 7.




RP-1 Influent Flow and Treatment Capacity

Figure 6-20: RP-1 Flow Forecast (mgd), RP-1 Alternative 7: Centrate Transfer to RP-5 after 2022 and to RP-1 DEMON after 2030

Alternative 8

A planned expansion at RP-5 will occur in 2022 and, initially after this expansion, RP-5 will have excess secondary capacity to process centrate. Prior to 2022, it is assumed that centrate will continue to be discharged to the NRW line. After the 2022 RP-5 expansion, centrate can be transferred to RP-5 until 2030, when RP-1 expansion is anticipated. During the RP-1 expansion, separate centrate treatment capacity can be designed as AirPrex to allow centrate treatment. Figure 6-21 shows a flow forecast for RP-1 Alternative 8.




RP-1 Influent Flow and Treatment Capacity

Figure 6-21: RP-1 Flow Forecast (mgd), RP-1 Alternative 8: Centrate Transfer to RP-5 after 2022 and RP-1 AirPrex after 2030

Alternative 9

A planned expansion at RP-5 will occur in 2022 and, initially after this expansion, RP-5 will have excess secondary capacity to process centrate. Prior to 2022, it is assumed that centrate will continue to be discharged to the NRW line. After the 2022 RP-5 expansion, centrate can be transferred to RP-5 until 2030, when RP-1 expansion is anticipated. During the RP-1 expansion, separate centrate treatment capacity can be designed as DEMON and AirPrex to allow centrate treatment. Figure 6-22 shows a flow forecast for RP-1 Alternative 9.




RP-1 Influent Flow and Treatment Capacity

Figure 6-22: RP-1 Flow Forecast (mgd), RP-1 Alternative 9: Centrate Transfer to RP-5 after 2022 and RP-1 DEMON and AirPrex after 2030

Alternative 10

A planned expansion at RP-1 will occur in 2030, and it is anticipated that footprint will be constrained at the site. Prior to 2030, it is not anticipated that RP-1 will have sufficient capacity to treat centrate and, during that period, centrate will continue to be discharged to the NRW line. Further, this alternative assumes that expansion of RP-1 will not be able to accommodate the additional load associated with centrate recycle. Therefore, it is planned that centrate will be transferred to RP-5 after 2030. Figure 6-23 shows a flow forecast for RP-1 Alternative 10.




RP-1 Influent Flow and Treatment Capacity

Figure 6-23: RP-1 Flow Forecast (mgd), RP-1 Alternative 10: Centrate Transfer to RP-5 after 2030

Alternative 11

A planned expansion at RP-5 will occur in 2022 and, initially after this expansion, RP-5 will have excess secondary capacity to process centrate. Prior to 2022, it is assumed that centrate will continue to be discharged to the NRW line. After the 2022 RP-5 expansion, centrate can be transferred to RP-5 until 2030, when RP-1 expansion is anticipated. During the RP-1 expansion, additional secondary capacity can be designed into RP-1 to process centrate. While RP-5 will have capacity to process the additional centrate from RP-1 from 2022 to 2030, it is anticipated that methanol addition at RP-5 will be required. Figure 6-24 shows a flow forecast for RP-1 Alternative 11.



RP-1 Influent Flow and Treatment Capacity

Figure 6-24: RP-1 Flow Forecast (mgd), RP-1 Alternative 11: Centrate Transfer to RP-5 before 2022 and RP-1 after 2030

Centrate Handling Alternatives at RP-5

This section describes centrate handling alternatives at RP-5.

Alternative 1

Centrate from solids processing at RP-2 is currently transferred to the RP-5 headworks along with other recycle flows from RP-2. Alternative 1 assumes this centrate will continue to be sent to RP-5 until the 2022 plant expansion. After construction and startup of the solids processing facilities at RP-5, centrate from RP-5 can be routed to the IEBL. With this approach, no additional equipment is required for centrate handling. Also, the RP-5 secondary system does not need to be expanded to accommodate the additional recycle load. Figure 6-25 shows a flow forecast for RP-5 Alternative 1.





Figure 6-25: RP-5 Flow Forecast (mgd); RP-5 Alternative 1: Discharge to the IEBL

Alternative 2

Centrate from solids processing at RP-2 is currently transferred to the RP-5 headworks along with other recycle flows from RP-2. Alternative 2 assumes this centrate will continue to be transferred to RP-5 until construction of the solids processing at RP-5. After startup of the solids processing facilities at RP-5, centrate from RP-5 can be recycled back to RP-5 for treatment. The RP-5 secondary system will need to be expanded to accommodate the additional recycle load. Centrate equalization would be provided to allow daily operation of dewatering over an 8-hour shift. The equalization volume would be sized to return this centrate to the RP-5 liquids stream over a 24-hour period. Figure 6-26 shows a flow forecast for RP-5 Alternative 2.




RP-5 Influent Flow and Treatment Capacity

Figure 6-26: RP-5 Flow Forecast (mgd); RP-5 Alternative 2: Centrate Recycle to RP-5

Alternative 3

Centrate from solids processing at RP-2 is currently transferred to the RP-5 headworks along with other recycle flows from RP-2. Alternative 3 assumes this centrate will continue to be transferred to RP-5 until construction of the solids processing at RP-5, and the expansion at RP-5 would include DEMON sidestream treatment for centrate. After startup of the solids processing facilities at RP-5 in 2022, centrate from RP-5 will be treated with DEMON. While the DEMON process will remove most of the nitrogen load in centrate, a small fraction, approximately 10 to 20 percent, will be returned to the secondary process as nitrate. While this will not increase aeration demand, the secondary denitrification process should be designed to accommodate this load. The DEMON system would be designed for centrate load corresponding to 40 mgd of plant flow capacity. Figure 6-27 shows a flow forecast for RP-5 Alternative 3.



RP-5 Influent Flow and Treatment Capacity

Figure 6-27: RP-5 Flow Forecast (mgd); RP-5 Alternative 3: Centrate to RP-5 DEMON

Alternative 4

Centrate from solids processing at RP-2 is currently transferred to the RP-5 headworks. Alternative 4 assumes this centrate will continue to be transferred to RP-5 until construction of the solids processing at RP-5, and the expansion at RP-5 would include AirPrex sidestream treatment for centrate. After startup of the solids processing facilities at RP-5 in 2022, centrate from RP-5 will be treated with AirPrex. The AirPrex system would be designed to remove some nitrogen and all struvite. Currently struvite accumulates at RP-1 at the dewatering process, and struvite accumulation is managed by addition of a chemical designed to control the precipitation of struvite. It is assumed a similar condition will exist at RP-5, and the removal of struvite with AirPrex will remove approximately 8 percent of the nitrogen load. The remaining nitrogen load in the centrate will be recycled to the RP-5 liquids process, and the secondary system should be designed to accommodate this additional load. The AirPrex system would be designed for digested sludge loads corresponding to 40 mgd of plant flow capacity. Figure 6-28 shows a flow forecast for RP-5 Alternative 4.





Figure 6-28: RP-5 Flow Forecast (mgd); RP-5 Alternative 4: Centrate to RP-5 AirPrex

Alternative 5

Centrate from solids processing at RP-2 is currently transferred to the RP-5 headworks. Alternative 4 assumes this centrate will continue to be transferred to RP-5 until construction of the solids processing at RP-5, and the expansion at RP-5 would include both DEMON and AirPrex sidestream treatment for centrate. After startup of the solids processing facilities at RP-5 in 2022, centrate from RP-5 will be treated with DEMON and AirPrex. DEMON and AirPrex will provide the combined advantages presented with Alternatives 3 and 4. These systems would be designed to accommodate the plant flow capacity of 40 mgd. Figure 6-29 shows a flow forecast for RP-5 Alternative 5.



RP-5 Influent Flow and Treatment Capacity

Figure 6-29: RP-5 Flow Forecast (mgd); RP-5 Alternative 5: Centrate to RP-5 DEMON and AirPrex

6.4.2 Screening Recommendations

Based on the alternatives presented above, the alternative combinations shown in Table 6-14 and Table 6-15 are recommended for the BCE analysis. These alternatives are summarized based on centrate time periods related to plant expansion at RP-1 and RP-5. The full BCE spreadsheets are presented in Exhibit I of this Volume.

Table 6-14: Final RP-1	Centrate Handling	Alternatives
------------------------	-------------------	--------------

	Alterr	native		Summany.		
Alternative	2016–22	2022–30	2030–45	Summary		
1	NRW	NRW	NRW	Alt 1 is based on discharge of centrate to NRW line for the duration of the project.		
2	NRW	NRW	DEMON Sidestream	Alt 2 assumes continued use of the NRW line until the 2030 RP-1 plant expansion, when sidestream nitrogen removal can be constructed.		
3	NRW	NRW	AirPrex	Alt 3 assumes continued use of the NRW line until the 2030 RP-1 plant expansion, when sidestream struvite removal can be constructed.		
4	NRW	NRW	DEMON and AirPrex Sidestream	Alt 4 assumes continued use of the NRW line until the 2030 RP-1 plant expansion, when sidestream nitrogen and struvite removal can be constructed.		
5	NRW	NRW	RP-1 Liquids	Alt 5 assumes continued use of the NRW line until the 2030 RP-1 plant expansion, when the centrate can be recycled back to a larger RP-1 secondary system designed to treat the recycle load.		
6	NRW	RP-5 Liquids	RP-1 Liquids	Alt 6 assumes continued use of the NRW line until the 2022 RP-5 plant expansion, when the centrate will be sent to RP-5. After the 2030 RP-1 plant expansion, centrate can be recycled back to a larger RP-1 secondary system designed to treat the recycle load.		
7	NRW	RP-5 Liquids	DEMON Sidestream	Alt 7 assumes continued use of the NRW line until the 2022 RP-5 plant expansion, when the centrate will be sent to RP- 5. After the 2030 RP-1 plant expansion, sidestream nitrogen removal can be constructed to treat the centrate load.		
8	NRW	RP-5 Liquids	AirPrex	Alt 8 assumes continued use of the NRW line until the 2022 RP-5 plant expansion, when the centrate will be sent to RP-5. After the 2030 RP-1 plant expansion, sidestream struvite removal can be constructed to treat the centrate load.		
9	NRW	RP-5 Liquids	DEMON and AirPrex Sidestream	Alt 9 assumes continued use of the NRW line until the 2022 RP-5 plant expansion, when the centrate will be sent to RP-5. After the 2030 RP-1 plant expansion, sidestream nitrogen and struvite removal can be constructed to treat the centrate load.		
10	NRW	NRW	RP-5 Liquids	Alt 10 assumes continued use of the NRW line until the 2030 RP-1 plant expansion, when the centrate will be sent to RP-5.		
11	NRW	RP-5 Liquids	RP-1 Liquids	Alt 11 assumes continued use of the NRW line until the 2022 RP-5 plant expansion, when the centrate will be sent to RP-5. After the 2030 RP-1 plant expansion, centrate can be recycled back to a larger RP-1 secondary system designed to treat the recycle load.		

	Alternative		Summar
Alternative	2016–22	2022–30	Summary
1	RP-5 Liquids	IEBL	Alt 1 is based on discharge of centrate to IEBL line after the 2022 RP-5 plant expansion.
2	RP-5 Liquids	RP-5 Liquids	Alt 2 assumes centrate will be recycled to the RP-5 secondary system. The RP-5 plant expansion in 2022 will include a larger secondary system to process the recycle load.
3	RP-5 Liquids	DEMON Sidestream	Alt 3 assumes centrate will be recycled to the RP-5 secondary system. After the 2022 RP-5 plant expansion, sidestream nitrogen removal can be constructed to treat the centrate load.
4	RP-5 Liquids	AirPrex Sidestream	Alt 4 assumes centrate will be recycled to the RP-5 secondary system. After the 2022 RP-5 plant expansion, sidestream struvite removal can be constructed to treat the centrate load.
5	RP-5 Liquids	DEMON and AirPrex Sidestream	Alt 5 assumes centrate will be recycled to the RP-5 secondary system. After the 2022 RP-5 plant expansion, sidestream nitrogen and struvite removal can be constructed to treat the centrate load.

Table 6-15: Final RP-5 Centrate Handling Alternatives

6.5 ALTERNATIVES COMPARISON

Capital, annual running, and repair and replacement (R&R) costs were estimated for the various centrate alternatives associated with RP-1 and RP-5.

6.5.1 Capital Costs

Capital cost estimates for the RP-1 and RP-5 alternatives are summarized in Table 6-16 and Table 6-17. Capital cost estimates are Class 4 estimates as defined by AACE International with an expected lower range accuracy of -15% to -30% and upper range accuracy of +20% to +50%.

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION

Pre-Design Report Volume III, Chapter 6: Evaluation of RP-1 and RP-5 Onsite Centrate Treatment

	Alt 1	Alt 2	Alt3	Alt 4	Alt 5	Alt 6	Alt 7	Alt 8	Alt 9	Alt 10	Alt 11
Description	NRW/	NRW/	NRW/	NRW/	NRW/	NRW/	NRW/	NRW/	NRW/	NRW/	NRW/
	NRW/	NRW/	NRW/	NRW/	NRW/	RP-5 LS/	RP-5 LS/	RP-5 LS/	RP-5 LS/	NRW/	RP-5 LS/
	NRW	DEMON	AirPrex	DEMON/	RP-1LS	RP-5 LS	DEMON	AirPrex	DEMON/	RP-5 LS	RP-1 LS
				AirPrex					AirPrex		
Centrate equalization			Х		Х	Х		Х		Х	Х
AirPrex			Х	Х				Х	Х		
DEMON		Х		Х			Х		Х		
RP-1 expansion for centrate		Х	Х	Х	Х		Х	Х	Х		Х
RP-5 expansion for centrate						Х				Х	
RP-5 methanol addition						Х	Х	Х	Х	Х	Х
Subtotal	\$0	\$8,150	\$8,200	\$10,700	\$5,600	\$4,250	\$9,250	\$9,250	\$11,800	\$6,400	\$6,700
Construction costs:											
Contractor Overhead and	l profit: 1	5%									
Inflation: 8%											
	Bond and Insurance: 4%										
Estimator's Contingency: 30%											
Allied costs:											
Design, Permitting and scope, Const. Management, Warranty, Engineering Contingency, and change order allowance: 20%											
Total	\$0	\$16,300	\$16,400	\$21,400	\$11,200	\$8,500	\$18,500	\$18,500	\$23,600	\$12,800	\$13,400
Note: X's indicated features included in the Alternative											

Table 6-16: RP-1 Centrate Handling Alternatives Capital Costs (\$1,000)

		-							
	Alt 1	Alt 2	Alt3	Alt 4	Alt 5				
Description	IEBL/	RP-5 LS/	RP-5 LS/	RP-5 LS/	RP-5 LS/				
	IEBL	RP-5 LS	DEMON	AirPrex	DEMON/ AirPrex				
Centrate equalization		Х		Х					
AirPrex				Х	Х				
DEMON			Х		Х				
RP-5 expansion for centrate		Х	Х	Х	Х				
Subtotal	\$0	\$3,350	\$5,300	\$5,600	\$7,600				
Construction costs:	ad profit: 150/								
Contractor's Overhead an Inflation: 8%	nu prom. 15%								
Bond and Insurance: 4%									
Estimator's Contingency	: 30%								
Allied costs:									
Design, Permitting and scope, Const. Management, Warranty, Engineering Contingency, and change order allowance: 20%									
Total	\$0	\$6,700	\$10,600	\$11,200	\$15,200				
Note: X's indicated features	Note: X's indicated features included in the Alternative								

Table 6-17: RP-5 Centrate Handling Alternatives Capital Costs (\$1,000)

Capital costs for the centrate handling alternatives include the following assumptions:

- Treatment performance for AirPrex and DEMON is based on data provided by the vendor and from other similar projects.
- Capital cost for the AirPrex system was based on a vendor quote for the equipment. Costs for the associated building and piping were estimated from costs developed for another similar project, with adjustment for local conditions. Capital cost for the DEMON system was estimated based on cost curves developed from other similar projects.
- The existing centrifuges at RP-1 and RP-2 operate 8 hours per day, 7 days per week. It was assumed that the dewatering systems at RP-1 and RP-5 will operate at the same schedule.
- A centrate storage tank and pump station were assumed to be required to provide flow and load equalization for all alternatives except for those where the centrate is sent to the brine pipeline. A storage tank is included in the DEMON system; therefore, a separate cost for the storage tank and pumps are not included for the alternatives involving DEMON.

6.5.2 Operating and Maintenance Costs

O&M costs were evaluated based on the unit costs shown in Table 6-18.

Item	Units	Cost	Notes
Polydyne Flowsperse	\$/gal	0.92	
Polymer (current use at site)	\$/gal	10.63	
Electrical power	\$/kWh	0.125	
Corrected FTE labor cost	\$/hr	96.33	
Current biosolids value	\$/ton	0	
Methanol (99% w/w solution)	\$/gal	2.55	Estimated from previous project in Idaho
kWh per lb of oxygen	kWh/lb O2	0.3	Based on Sanitaire diffuser reference data
MgCl ₂ (33% w/w solution)	\$/gal	0.6	Estimated from previous project in Idaho
Molar ratio	Mol Mg/Mol P	1.3	
MgCL ₂ density	lb/gal	10.7586	
Solution concentration	wt/wt	0.33	
Molar wt. of P	g/mol	30.97	
Molar wt. of Mg	g/mol	24.305	
Ratio of MgCl ₂ solution/1 lb P removed	lb/lb	10.97	

Table 6-18: Annual Running Unit Cost Assumptions

Other assumptions related to annual running costs include the following:

- The secondary systems at RP-1 and RP-5 are required to achieve an annual average total influent nitrogen (TIN) limit of 8 milligrams per liter (mg/L) based on the current National Pollutant Discharge Elimination System (NPDES) permit (could be applied on an agency-wide basis). Therefore, the need for supplemental carbon was estimated for each alternative.
- Methanol requirements were estimated based on BioWin simulations performed by Parsons for RP-5 with and without centrate from RP-1 routed to RP-5 under 2020 conditions. Based on those results, a ratio of 4.62 lb BOD/lb NO₃-N removed was calculated. This ratio was assumed to determine the need for methanol addition and, if methanol is needed, the methanol requirements.
- Capital cost for a methanol storage and feed system was extrapolated from cost estimates developed for another recent similar project, which includes a stainless-steel storage tank under a canopy roof structure, metering pumps, and associated piping and instrumentation.
- Aeration energy requirement is expressed as kilowatt-hours (kWh) per pound per day (lb/d) oxygen (O₂) required (as field oxygen requirement). Using site-specific information at RP-1 and RP-5 (in terms of elevation, existing basin depth), and assuming diffuser density (10 percent) and alpha factor (0.5), values of about 0.32 to 0.34 were calculated. A value of 0.30 was assumed for this analysis.
- Unit costs are based on data provided by Parsons, where available. These include unit labor costs (\$96.33/hr, per BCE Manual provided by IEUA accounting for estimated hours of productive work), electricity cost (\$0.125/kWh), and cost of Flowsperse for struvite control (\$102,897/yr, at RP-1 only).
- Other unit costs, including those for MgCl₂ and methanol, are based on recent cost estimates developed for similar recent projects for other treatment plants (Meridian, Idaho).
- Centrate from RP-1 is currently discharged to the NRW pipeline. The rate structure for discharge to this pipeline was based on the current agreement between IEUA and Los Angeles County for fiscal year 2015–16.
- It was assumed that IEUA had paid the upfront purchase costs for a set number of CUs previously calculated. An annual lease cost is thus not required. The assigned CU was assumed to be 1,928 based on spreadsheets provided by Parsons. It was assumed that a surcharge would not be needed because of any exceedance of this assigned CU, even though it was estimated that the actual CU would exceed the assigned CU of 1,928 after 2037 based on the projected RP-1 centrate flow and loadings.
- The annual O&M and CIP charges are assumed to be based on the assigned CU only. Therefore, the annual O&M and CIP costs are the same each year (before escalation).
- Centrate generated at RP-2, which receives sludge from RP-5 and CCWRF, is currently sent to RP-5 along with other recycle flows. It was assumed that IEUA has already established an agreement to discharge into the IEBL, which reaches the jurisdiction of the

Santa Ana Watershed Project Authority. It was thus assumed that IEUA would not need to pay the initial capacity charge, application fees, and any permit renewal fees. The assigned CU was assumed to be 16, based on the projected 2045 centrate flow for RP-5.

• Energy costs do not include cost of pumping centrate. The centrate pumping volume is similar for each plant, RP-1 and RP-5. Therefore, it is assumed the centrate pumping costs are similar and will not impact the BCE assessment.

6.5.3 Repair and Replacement Costs

R&R costs were estimated for the sidestream nitrogen and struvite removal technologies. An annual R&R cost of 0.75 percent of the capital cost for DEMON was used and an annual R&R cost of 1.65 percent of the capital cost of AirPrex was used. The R&R rate for DEMON is lower than that of AirPrex because DEMON has more concrete structures as a proportion of cost; concrete structures have longer expected life than other equipment and electrical systems. No additional R&R costs were assumed for alternatives that included expansion of the secondary process to increase capacity for nitrogen removal. The minor additional impact of this recycle stream on the R&R requirements for the secondary process equipment was considered negligible. Additionally, centrate R&R costs associated with equalization and pumping was considered minor and approximately equivalent between alternatives.

6.5.4 Risks and Benefits

No risks or benefits were included in this BCE.

6.6 **BUSINESS CASE EVALUATION**

IEUA has adopted the BCE as the structured economic analysis used to make decisions based on life-cycle costs that include community, environmental, and risk considerations. The BCE is a step-by-step process that can be performed on any size project that requires a decision to be made from policy and capital planning to operations, maintenance, refurbishment, and information systems. This is a repeatable, defensible, and quantitative process that assists IEUA in making clear, actionable decisions on facilities rehabilitation or replacement.

The life-cycle benefit/cost analysis is based on the net present value (NPV) tool included in the IEUA template. NPV analysis is the most comprehensive method to make investment decisions by considering the total cost of a project over its entire life. Because costs or revenues may occur at different times during the duration of the project, time-value of money equations can be used to calculate the present value of all costs and revenues over the life cycle of a project.

Two parameters are particularly important in this analysis:

• *Escalation rate* is the result of many factors including the overall inflation in the currency, supply/demand of certain goods, technology changes, environmental effect, political conditions, and other miscellaneous effects. In most cases, the escalation rate is different from (although greatly influenced by) the currency inflation rate. Typically, the rate of escalation is above the general level of inflation. This means that the lifetime cost is weighted toward future years, and shorter-term capital expenses are favored. The escalation rate used in this evaluation is 3 percent.

• *Discount rate* is the rate of interest (or rate of return) that is expected from an alternative investment. Examples of alternative investments are interest from a bank, stock market appreciation, or expected profits from one's own business. Selection of high discount rates indicates the belief that a large profit can be made from an alternative investment. The discount rate used in this evaluation is 2 percent.

6.6.1 BCE Results

The life-cycle benefit/cost analysis based on the NPV tool was conducted for the alternatives under evaluation in this report. Results for BCEs for centrate handling at RP-1 and RP-5 are presented in Table 6-19 and Table 6-20.

Altownativo	2016–22	2022-30	2030-45	Capital Cost	NPV	Difference from cheapest
Alternative				(\$1,000)	(\$1,000)	NPV (\$1,000)
1	NRW	NRW	NRW	\$0	(\$46,100)	(\$4,500)
2	NRW	NRW	DEMON Sidestream	\$16,300	(\$46,100)	(\$10,100)
3	NRW	NRW	AirPrex	\$16,300	(\$44,500)	(\$8,500)
4	NRW	NRW	DEMON and AirPrex Sidestream	\$21,400	(\$54,400)	(\$18,400)
5	NRW	NRW	RP-1 Liquids	\$11,200	(\$36,000)	
6	NRW	RP-5 Liquids	RP-1 Liquids	\$8,500	(\$53,900)	(\$17,900)
7	NRW	RP-5 Liquids	DEMON Sidestream	\$18,500	(\$48,500)	(\$12,500)
8	NRW	RP-5 Liquids	AirPrex	\$18,500	(\$46,300)	(\$14,800)
9	NRW	RP-5 Liquids	DEMON and AirPrex Sidestream	\$22,500	(\$56,200)	(\$10,200)
10	NRW	NRW	RP-5 Liquids	\$12,800	\$59,000	(\$20,300)
11	NRW	RP-5 Liquids	RP-1 Liquids	\$13,400	\$38,600	(\$23,100)

Table 6-19: BCE Results for RP-1 Centrate Handling

Alternative	2016–22	2022–30	Capital Cost (\$1,000)	NPV (\$1,000)	Difference from cheapest NPV (\$1,000)
1	RP-5 Liquids	IEBL	\$0	(\$13,300)	(\$4,100)
2	RP-5 Liquids	RP-5 Liquids	\$6,700	(\$9,200)	
3	RP-5 Liquids	DEMON Sidestream	\$10,600	(\$18,500)	(\$9,300)
4	RP-5 Liquids	AirPrex Sidestream	\$11,200	(\$20,500)	(\$11,300)
5	RP-5 Liquids	DEMON and AirPrex Sidestream	\$15,300	(\$29,800)	(\$20,700)

 Table 6-20: BCE Results for RP-5 Centrate Handling

Based on the BCE for RP-1, Alternative 5, returning centrate flows to RP-1 liquids process after the 2030 plant expansion represented the lowest NPV alternative. Before 2030, it is most costeffective to discharge the centrate flows to the NRW line. While RP-5 may have sufficient capacity to receive the centrate flows from RP-1 before 2030, it is anticipated that RP-5 will require methanol to process the additional nitrogen load. The additional chemical cost increases the NPV and does not represent the most cost-effective approach to centrate management.

The next-lowest NPV alternatives are Alternative 1 and Alternative 2. Alternative 1 assumes discharge of centrate to the NRW line for the duration of the project. This alternative does not require a capital cost, but there are substantial operating costs. In addition, some risks may be associated with this alternative. For example, the unit cost to discharge centrate may increase in the future, or the utilities receiving the NRW flows may increase restrictions on discharge quantity or quality.

RP-1 is a space-limited site, and if sufficient footprint is not available to expand the RP-1 secondary system to receive the centrate recycle, Alternatives 1 or 2 could be considered as the next-best approach to centrate management.

Results for BCE for centrate handling alternatives at RP-5 are presented in Table 6-20 above.

Based on the BCE for RP-5, Alternative 2, returning centrate flows to RP-5 liquids process after the 2030 plant expansion represented the lowest NPV alternative. While the site at RP-5 is limited, it is anticipated that a sufficient footprint at the site exists to accommodate increased secondary treatment capacity associated with centrate recycle.

6.6.2 Food Waste Impacts

IEUA is interested in accepting high-strength wastes for co-digestion to increase digester gas production. High-strength wastes include food processing wastes from industrial sources and food wastes currently disposed of as municipal solid wastes. It could also include fats, oil and grease (FOG). These are collectively referred to as food waste in this document. While addition of food wastes will improve digester performance and increase digester gas production, it will also increase the centrate flows and loads. The extent of the increase will depend on the quantities of food wastes (e.g., wet tons delivered per day) and the characteristics of the food wastes. For example, food wastes originating from fruits and grain products would have high organic content (as COD), while food wastes from meat processing would have high nitrogen content (as TKN). The latter would have the largest impact on centrate treatment as the additional nitrogen load is not removed in the digesters and would either increase the requirements for any sidestream treatment process or increase the aeration and potential methanol requirements in the secondary system if the centrate is returned to the liquid stream processes for treatment. In the latter case, additional aeration basin volume may also be needed to accommodate the higher centrate loadings.

Based on data given in the Draft Co-Digestion/Digester Gas Utilization Feasibility Study prepared by Carollo Engineers (dated April 2016), up to 326 wet tons per day of food wastes may be sent to IEUA for co-digestion. Assuming that this quantity of food wastes is sent to RP-5 and typical characteristics for food waste that is not excessively high in nitrogen content, the centrate flow at RP-5 could increase by about 10 to 20 percent, while the ammonia loading could increase by 20 to 30 percent, when compared to the estimated design centrate flows and ammonia loadings without food waste. The percent increases will be less if IEUA receives less than 100 percent of the available food wastes. Based on these estimates, the capital cost of the DEMON system for sidestream treatment at RP-5 is estimated to increase from \$11.0 million to approximately \$14.7 million. For alternatives considering recycle of centrate to the secondary system, the capital cost of the secondary system expansion would also increase to account for recycle ammonia loading and food waste quantity and quality for co-digestion. It is expected that the additional cost of food waste to the secondary system would be approximately \$2.5M.

A sensitivity analysis of the RP-1 and RP-5 alternatives indicated that when the recycle of centrate to the secondary process of each plant required the addition of an external carbon source such as methanol, the high operating costs associated with methanol addition resulted in alternatives that used sidestream ammonia removal through processes such as DEMON as the lowest net present value alternative. For this evaluation, it was assumed that the plant influent characteristics were sufficient that recycle of centrate to the secondary process did not require the additional of methanol. The addition of food waste at RP-5 will increase the nitrogen load in the centrate and would likely result in centrate discharge to the IEBL (Alternative 1) as the lowest net present value alternative. As previously mentioned, there are risks associated with relying upon this brine line for dedicated centrate disposal. If this option were not available, reliable, or practical for long term operation, the sidestream nitrogen removal alternative (Alternative 3) would represent the lowest net present value approach to centrate handling.

6.6.3 Phasing Considerations for Food Waste Addition

Currently is it assumed that RP-1 secondary capacity will expand in 2030 to 40 mgd. Based on the BCE findings presented in Table 6-19 above, expansion of RP-1 to include recycle of centrate to the secondary process represents the lowest net present value alternative. Prior to 2030, the centrate could be transferred to the NRW line or RP-5.

Several expansion opportunities at RP-5 exist to increase capacity at the plant over several increments. Workshop #1 review comments related to centrate handling at RP-5 included a request to consider phasing opportunities at RP-5 as it relates to centrate handling. The BCE alternatives presented above assume phasing of RP-5 in 2023 to 40 mgd secondary system capacity. Other opportunities to be considered include:

• Option 1: Install sidestream treatment in 2023 for ammonia removal

Regardless of the secondary system expansion phasing, install centrate sidestream treatment for ammonia removal in 2023, sized to treat future 2045 centrate loads and anticipated loads associated with food waste co-digestion.

• Option 2: Expand the secondary system to 22.5 mgd in 2023 and install sidestream ammonia removal in 2035

Expand secondary capacity to 22.5 mgd in 2023 and provide additional capacity in the secondary system to treat centrate recycle. While an additional carbon source such as methanol is not anticipated to be required from solids centrate alone, the inclusion of food waste co-digestion will increase the ammonia concentration in the centrate and will require provisions for methanol or another carbon source.

Expand the secondary capacity to 30 or 40 mgd in 2035 and provide additional centrate treatment capacity through the installation of sidestream ammonia removal, such as DEMON. The sidestream treatment system should be sized for 2045 solids loads and to accommodate centrate ammonia removal, including increased ammonia concentrations related to food waste co-digestion.

• Option 3: Expand the secondary system to 30 mgd in 2023 and install sidestream ammonia removal in 2035

Expand secondary capacity to 30 mgd in 2023 and provide additional capacity in the secondary system to treat recycle centrate. While an additional carbon source such as methanol is not anticipated to be required, the inclusion of food waste will likely increase the ammonia concentration in the centrate and require provisions for methanol or another carbon source.

Expand the secondary capacity to 40 mgd in 2035 and provide additional centrate treatment capacity through the installation of sidestream ammonia removal, such as DEMON. The sidestream treatment system should be sized to accommodate centrate ammonia removal, including increased ammonia concentrations related to food waste co-digestion.

• Option 4: Expand the secondary capacity to 40 mgd in 2023

Expand secondary capacity to 40 mgd in 2023 and provide additional capacity in the secondary system to treat recycle centrate. While an additional carbon source such as methanol is not anticipated to be required, the inclusion of food waste will likely increase the ammonia concentration in the centrate and require provisions for methanol to be added if needed.

Based on these alternatives, Table 6-21 outlines the anticipated schedule and anticipated capital costs.

	2023 Expansion		2030 Expansio)n
Phasing Option	Description	Anticipated Capital Cost	Description	Anticipated Capital Cost
Option 1	Install sidestream treatment ammonia removal for 2045 loads.	\$15.1M ^a	-	-
Option 2	Expand secondary capacity for 22.5 mgd, including recycle of centrate and capability for methanol addition.	\$11.2M ^b	Expand secondary capacity for 30 or 40 mgd. Install sidestream treatment ammonia removal for 2045 loads.	\$13.7M ^e
Option 3	Expand secondary capacity for 30 mgd, including recycle of centrate and capability for methanol addition.	\$12.6M ^c	Expand secondary capacity for 40 mgd. Install sidestream treatment ammonia removal for 2045 loads.	\$13.7M ^e
Option 4	Expand secondary capacity for 40 mgd, including recycle of centrate and capability for methanol addition.	\$14.3M ^d	Install sidestream treatment ammonia removal for 2045 loads	\$13.7M ^e

Table 6-21: Phasing Considerations for RP-5, Including Food Waste

^a Cost assumes \$13.7M DEMON side stream treatment with centrate from food waste co-digestion and an additional \$1.4M expansion of the secondary system to process effluent nitrogen from DEMON.

^b Cost assumes \$4.1M expansion of the secondary system for centrate recycle, an additional \$2.3M secondary expansion for nitrogen recycle associated with food waste, \$1.7M for centrate equalization, and \$3.1M for a methanol addition facility.

^c Cost assumes \$5.5M expansion of the secondary system for centrate recycle, an additional \$2.3M secondary expansion for nitrogen recycle associated with food waste, \$1.7M for centrate equalization, and \$3.1M for a methanol addition facility.

^d Cost assumes \$7.3M expansion of the secondary system for centrate recycle, an additional \$2.3M secondary expansion for nitrogen recycle associated with food waste, \$1.7M for centrate equalization, and \$3.1M for a methanol addition facility.

^e Cost assumes \$13.7M DEMON side stream treatment with centrate from food waste co-digestion. No additional costs is included for expansion of the secondary system to process effluent nitrogen from DEMON as it is assumed the capacity for centrate ammonia treatment was installed during a previous expansion (in 2023 or 2030).

6.7 CONCLUSIONS AND RECOMMENDATIONS

This section presents conclusions and recommendations resulting from the analysis.

6.7.1 Conclusions

Results for the BCE suggest the following:

• For RP-1: Alternative 5, returning centrate flows to RP-1 liquids process after the 2030 plant expansion, represented the lowest NPV alternative. The next-lowest NPV alternatives are Alternative 1 and Alternative 2. Alternative 1 assumes discharge of centrate to the NRW line for the duration of the project. Alternative 2 assumes centrate is treated with DEMON. RP-1 is a footprint-limited site, and if insufficient footprint is available to expand

the RP-1 secondary system to receive the centrate recycle, Alternatives 1 or 2 could be considered as the next-best approach to centrate management.

- For RP-5: Based on the BCE for RP-5, Alternative 2, returning centrate flows to RP-5 liquids process after the 2030 plant expansion represented the lowest NPV alternative.
- Based on current experiences at RP-1 and RP-5 and projections that future organic loads will increase, methanol is not anticipated at RP-1 and RP-5 (except when treating centrate from RP-1 at RP-5). If loads do not increase as projected, methanol may be required in the future, and operating costs associated with methanol will change the economics of centrate treatment in the liquids stream. In such cases, discharge of centrate to the brine lines will be the most cost-effective approach to centrate handling.
- Risks are associated with long-term planned use of the brine lines. If a cost is applied to alternatives associated with discharge of centrate to the brine lines, recycling of centrate to the liquids stream or sidestream nitrogen removal through DEMON (or another annamox technology) will become the next most economically attractive alternatives.
- This BCE was conducted during early stages of the project, and limited mass balance information was available. For this evaluation, the estimation of centrate flows and characteristics uses the best information available to provide an assessment of the alternatives. It is assumed the this approach will be sufficient for recommending centrate handling approaches, and selection of these technologies will allow continued development and refinement of future project mass balance efforts.
- The addition of food waste to the digestion process at RP-5 will have the impact of increasing the centrate flow and ammonia load. While the exact impact will depend on the food waste quantity and quality, it is anticipated that food waste will increase the ammonia recycle nitrogen load. If recycled to the secondary system, the need for an additional carbon source such as methanol is anticipated. Based on sensitivity analysis of BCE alternatives for RP-5, the additional of methanol will result in the Alternatives 1 (centrate discharge to IEBL) and 3 (centrate sidestream treatment with DEMON) as the lowest net present value alternatives. As previously mentioned, there are risks associated with relying upon this brine line for dedicated centrate disposal. If this option were not available, reliable, or practical for long term operation, the sidestream nitrogen removal alternative (Alternative 3) would represent the lowest net present value approach to centrate handling.
- Phasing has the potential to offset capital costs related to handling of centrate at RP-5. A summary of these anticipated costs, including the impact of food waste, are presented in Table 6-21.

6.7.2 Recommendations

Based on the analysis provided, the following preliminary recommendations are provided:

• At RP-1, expanding the secondary system in 2030 to accommodate centrate recycle is the lowest net present value alternative and is recommended. Prior to 2030, the centrate can be discharged to the NRW line or transferred to RP-5. If footprint or other factors limit the ability to expand the secondary capacity to accommodate centrate recycle, centrate

6-52

treatment can be managed with sidestream ammonia removal or transfer of centrate to RP-5.

- For this evaluation, it was assumed that the RP-1 influent characteristics were sufficient that recycle of centrate to the secondary process did not require the additional of methanol. The requirements for methanol or other carbon sources should be evaluated in more detail in later stages of the project.
- It is anticipated that the capital costs associated with operation of food waste co-digestion and recycle of centrate to the secondary process at RP-5 will range from \$12-16M, depending on the secondary capacity to be installed in 2023. Further, installation of sidestream nitrogen removal or additional secondary capacity will be required to process centrate after 2030. Installation of sidestream nitrogen removal in 2023 is expected to cost approximately \$16.2M. For budgetary purposes, it is recommended that centrate handling at RP-5 assume a sidestream nitrogen removal process at \$16.2M. The impacts of food waste can then be further evaluated during scheduled project efforts and PDR development to determine if other lower initial cost options are appropriate.
- It is recommended that if sidestream nitrogen removal is the preferred alternative, a pilot trial of the technology be conducted to allow operations staff to gain a level of familiarity with the new technology.



Evaluation of RP-5 Solids Treatment Alternative Technologies







TABLE OF CONTENTS

CHAPTER 7: EV	ALUATIO	N OF RP-5 SOLIDS TREATMENT ALTERNATIVE TECHNOLOGIES.	7-7
7.1	Introd	luction	7-7
	7.1.1	Background	7-7
	7.1.2	Understanding and Approach	
7.2	Solids	Characteristics and Production	7-7
	7.2.1	Plant Influent Flow	7-8
	7.2.2	Solids Production Rates and Peaking Factors	
	7.2.3	Projected Solids Flows and Loads	
	7.2.4	High Strength Waste for Co-digestion	7-11
7.3	Evalua	ation of RP-5 Solids Thickening Alternatives	7-12
	7.3.1	Introduction	7-12
	7.3.2	Solids Feed Characteristics and Production	7-13
	7.3.3	Solids Thickening Technology Descriptions	7-15
	7.3.4	Thickening Alternatives Screening	
	7.3.5	Alternatives Development	7-21
	7.3.6	Thickening Alternatives Business Case Evaluation	7-24
	7.3.7	Agency Decisions and Preferences for the Approved Project	
		Requirements	7-25
	7.3.8	Recommendations	7-26
7.4	Evalua	ation of RP-5 Solids Digestion Alternatives	7-26
	7.4.1	Introduction	7-26
	7.4.2	Solids Feed Characteristics and Production	7-27
	7.4.3	Digestion Technology Alternatives Descriptions	7-28
	7.4.4	Alternatives Screening	
	7.4.5	Alternatives Development	7-31
	7.4.6	Digestion Alternatives Business Case Evaluations	7-36
	7.4.7	Agency Decision and Preferences for the Approved Project	
		Requirements	7-38
	7.4.8	Recommendation	7-39
7.5	Evalua	ation of RP-5 Solids Dewatering Alternatives	7-39
	7.5.1	Introduction	7-39
	7.5.2	Solids Feed Characteristics and Production	7-39
	7.5.3	Solids Dewatering Technology Alternatives Descriptions	7-40
	7.5.4	Alternatives Screening	7-42
	7.5.5	Alternatives Development	7-43
	7.5.6	Dewatering Equipment Business Case Evaluation	7-47
	7.5.7	Agency Decisions and Preferences for the Approved Project	
		Requirements	
	7.5.8	Recommendations	7-48

7.6	Evalua	tion of RP-5 Gas Storage and Waste Gas Flares	7-49
	7.6.1	Introduction	7-49
	7.6.2	Biogas Characteristics and Production	7-50
	7.6.3	Gas Storage Purpose and Criteria	
	7.6.4	Biogas Storage Technologies	
	7.6.5	Gas Storage Alternatives Screening	
	7.6.6	Gas Storage Alternatives Comparisons	
	7.6.7	Gas Storage Summary	
	7.6.8	Waste Gas Flare Purpose and Criteria	7-58
	7.6.9	Waste Gas Flare Technologies	
	7.6.10	Waste Gas Flare Alternatives Screening	
	7.6.11	Waste Gas Flare Alternatives Comparison	
	7.6.12	Waste Gas Flare Preliminary Summary	
	7.6.13	Agency Decisions and Preferences for the Approved Project	
		Requirements	7-62
	7.6.14	Subsequent Evaluation of Waste Gas Flares	7-63
	7.6.15	Updated Description of Waste Gas Flare Alternatives	
	7.6.16	Updated BCE for Waste Gas Flares	
	7.6.17	Updated Recommendation for Waste Gas Flares	
7.7	Evalua	tion of RP-5 Odor Control Alternatives	7-69
	7.7.1	Introduction	7-69
	7.7.2	Foul Air Production and Characteristics	7-70
	7.7.3	Odor Control Technology Alternatives	7-72
	7.7.4	Odor Control Alternatives Screening	
	7.7.5	Odor Control System Alternatives Business Case Evaluation	
	7.7.6	Odor Control System Summary	
	7.7.7	Agency Decisions and Preferences for the Approved Project	
		Requirements	7-80
	7.7.8	Recommendations	

LIST OF APPENDICES

Appendix 7-A: RP-1 and RP-5 Ex	pansion Flow Validation	7-81
Appendix 7-B: RP-5 and CCWRF	Sludge Quantity Estimates	7-83

LIST OF FIGURES

Figure 7.3-1: Process Flow Diagram for Separate Thickening	. 7-13
Figure 7.3-2: Process Flow Diagram for Co-thickening	. 7-14
Figure 7.3-3: Gravity Thickener	. 7-15
Figure 7.3-4: Dissolved Air Flotation Thickener	. 7-16
Figure 7.3-5: Centrifuge Thickener	. 7-16

Figure 7.3-6: Membrane Thickener	7-17
Figure 7.3-7: Rotary Drum Thickener	7-17
Figure 7.3-8: Gravity Belt Thickener	7-18
Figure 7.4-1: MAD PFD	7-28
Figure 7.4-2: Two-Phase Anaerobic Digestion PFD	7-29
Figure 7.4-3: THP PFD	7-30
Figure 7.5-1: Dewatering Centrifuge	7-40
Figure 7.5-2: Belt Filter Press	7-41
Figure 7.5-3: Screw Press	7-42
Figure 7.6-1: Flexible-Membrane Gas Storage Configurations	7-51
Figure 7.6-2: Digester Gas-Holder Covers	7-52
Figure 7.6-3: Dry-Seal Gasholder	7-53
Figure 7.6-4: Wet-Seal Gasholder	7-53
Figure 7.6-5: High-Pressure Gas Storage	7-54
Figure 7.6-6: Candlestick Waste Gas Flares	7-59
Figure 7.6-7: Enclosed Waste Gas Burners	7-59
Figure 7.6-8: Ultra-Low Emission Enclosed Gas Flare	7-64
Figure 7.6-9: Schematic of Waste Gas Flare Alternative 1A	7-65
Figure 7.6-10: Schematic of Waste Gas Flare Alternative 1B	7-66
Figure 7.6-11: Schematic of Waste Gas Flare Alternative 2	7-67
Figure 7.6-12: Schematic of Waste Gas Flare Alternative 3	7-67
Figure 7.6-13: Schematic of Recommended Alternative 1B in More Detail	7-69
Figure 7.7-1: Biofilter Process Flow Diagram	7-74
Figure 7.7-2: Bioscrubber Process Flow Diagram	7-75
Figure 7.7-3: Activated Carbon Dual Bed Process Flow Diagram	7-76

LIST OF TABLES

Table 7.2-1: Plant Influent Flow at Maximum Month Condition, mgd	
Table 7.2-2: Sludge Production Rates at Max Month Condition, lb/MG	
Table 7.2-3: Sludge Production Peaking Factors ^a	
Table 7.2-4: Projected Sludge Productions in 2060	7-10
Table 7.2-5: Projected FOG and Food Waste Quantities for Co-Digestion in 2060	7-12
Table 7.3-1: Thickening Process Feed Solids Projections	7-15
Table 7.3-2: Pros and Cons for Thickening Technologies	7-18
Table 7.3-3: Results of Initial Screening Evaluation	7-20
Table 7.3-4: Thickening System Performance Goals	7-21
Table 7.3-5: DAFT Design Criteria	7-21

Table 7.2. 6: Contrifuge Design Critoria	7 22
Table 7.3-6: Centrifuge Design Criteria Table 7.3-7: RDT Design Criteria	
Table 7.3-8: GBT Design Criteria	
Table 7.3-9: Separate Thickening Alternatives Number of Units	
Table 7.3-10: Co-thickening Alternatives Number of Units	
Table 7.3-11: Results of the Business Case Evaluation	
Table 7.4-1: Projected Digestion Feed Characteristics	
Table 7.4-2: Digestion Solids and Hydraulic Loading Projections	
Table 7.4-3: Results of Initial Screening Evaluation	
Table 7.4-4: Digestion System Performance Requirements	
Table 7.4-5: Alternative 1- MAD Performance and Sizing Data	
Table 7.4-6: Alternative 2 - Two-Phase Digestion Performance and Sizing Data	
Table 7.4-7: Alternative 3 - THP Performance and Sizing Data	
Table 7.4-8: MAD Equipment Considerations	
Table 7.4-9: Two-Phase Equipment Considerations	
Table 7.4-10: THP Equipment Considerations	
Table 7.4-11: Comparative Summary of Digestion Alternatives	
Table 7.4-12: Results of the Anaerobic Digestion Alternative Business Case Evaluation	
Table 7.5-1: Projected Dewatering Feed Characteristics	
Table 7.5-2: Dewatering Solids and Hydraulic Loading Projections	
Table 7.5-3: Results of Initial Screening Evaluation	
Table 7.5-4: Digested Sludge Minimum Storage Requirement (3 days' storage)	
Table 7.5-5: Dewatering System Performance Requirements	
Table 7.5-6: Dewatering Equipment Performance and Equipment Data	
Table 7.5-7: Dewatering Centrifuge Equipment Number of Operating (Duty) Units	. 7-47
Table 7.6-1: Biogas System Basis of Design	. 7-50
Table 7.6-2: Gas Storage Screening Criteria	. 7-55
Table 7.6-3: Gas Storage Screening Results	
Table 7.6-4: Gas Storage Capital Cost Comparison	. 7-56
Table 7.6-5: Gas Storage O&M Considerations Comparison	. 7-56
Table 7.6-6: Waste Gas Flare Design Criteria	. 7-58
Table 7.6-7: Waste Gas Flare Configurations for Digestion Alternatives	. 7-60
Table 7.6-8: Two-Phase Waste Gas O&M Considerations	. 7-61
Table 7.6-9: Waste Gas Flare Capital Costs	. 7-61
Table 7.6-10: Waste Gas Flare Emissions Requirements	. 7-63
Table 7.6-11 Updated Biogas Design Criteria	. 7-65
Table 7.7-1: Sources of Foul Air and Design Criteria	. 7-70
Table 7.7-2: System Design Parameters for Odor Control Systems	. 7-71

Table 7.7-3: System Design Parameters for Odor Control Systems	. 7-71
Table 7.7-4: Examples of Wastewater Treatment Authorities Design Criteria	. 7-72
Table 7.7-5: Results of Initial Screening Evaluation	. 7-76
Table 7.7-6: Odor Control System Capital Cost Comparison	. 7-77
Table 7.7-7: Operations and Maintenance Parameters	. 7-78
Table 7.7-8: Results of the Business Case Evaluation	. 7-78

THIS PAGE INTENTIONALLY LEFT BLANK.

CHAPTER 7: EVALUATION OF RP-5 SOLIDS TREATMENT ALTERNATIVE TECHNOLOGIES

7.1 INTRODUCTION

7.1.1 Background

The Wastewater Facilities Master Plan (WFMP) evaluated the Regional Water Recycling Plant #5's (RP-5's) existing wastewater treatment capacity and concluded it would be exceeded by the year 2025. In addition, the solids loading from the Carbon Canyon Water Recycling Facility (CCWRF) and RP-5 already exceeds the digester capacity at RP-2, where these solids streams are currently treated. Due to the United States Army Corps of Engineers (USACE) project to raise the Prado Dam Spillway, the RP-2 solids treatment facility will need to be decommissioned and a new RP-5 solids treatment facility constructed with a design capacity to treat the projected flows.

7.1.2 Understanding and Approach

Based on the background of the project, the new solids treatment facility at RP-5 will consist of Thickening, Digestion and Dewatering. This chapter describes the approaches used to develop solids production projections and characteristics used for sizing the treatment processes and presents business case evaluations (BCEs) for each of the main solids processes.

The purpose of the BCEs is to provide sufficient comparative information on costs, benefits, and risks of the alternatives to provide a sound basis for technology selection. Sizing, loading, process configurations, layouts, and costs are based on project parameters agreed upon by the project team and Agency staff at the time of commencing the BCEs for the 2045 design year.

These evaluations of technologies (BCEs) and other important project conditions were conducted in parallel and results can impact the final configurations. Therefore, refinement of the final selected alternative and costs will be conducted after the BCEs and technology selection described in this chapter are completed. This refinement will be reflected in the Approved Project Requirements document and integrate into the final design decisions made by the Agency on project phasing, final load decisions related to food waste (FW) and fats, oils, and grease (FOG) treatment, staff layout and configuration preferences, and other decisions subsequent to the BCE evaluations.

Based on the background of the project, the new solids treatment facility at RP-5 will be sized to process future solids productions at RP-5 and CCWRF. In addition, FOG and FW are assumed to be treated at RP-5. All BCE analysis are provided in Exhibit I of this Volume. Note that subsequent decisions on handling FOG and FW will be discussed in the Approved Project Requirements section of the Pre-Design Report.

7.2 SOLIDS CHARACTERISTICS AND PRODUCTION

This introductory section presents project background as well as and understanding and approach for solids mass balance development.

Solids flows and loads were estimated based on future influent flows to RP-5 and CCWRF and solids production rates at each plant.

7.2.1 Plant Influent Flow

Projected plant influent flows at various Inland Empire Utilities Agency (IEUA) facilities through 2060 under various flow diversion scenarios were provided by the IEUA (Appendix 7-A). As instructed by the Agency, the following scenarios were selected for RP-5 Solids Treatment Alternatives Evaluation.

- RP-5: Flow to RP-5 includes gravity flow and maximum diversion flow.
- CCWRF: Flow to CCWRF includes gravity flow only.

The projected plant influent flows at RP-5 and CCWRF are summarized in Table 7.2-1.

Year	RP-5	CCWRF
2016	9.3	7.4
2020	14.2	7.6
2025	16.0	7.6
2030	20.2	7.8
2035	22.8	7.9
2040	25.5	8.1
2045	27.6	8.2
2050	29.5	8.3
2060	30.0	8.5

Table 7.2-1: Plant Influent Flow at Maximum Month Condition, mgd

7.2.2 Solids Production Rates and Peaking Factors

Sludge production values were estimated on a per million gallons' basis using the influent design pollutant concentrations decided upon on March 11, 2016. These influent design concentrations were chosen after analysis of 5 years of the existing plant data with consensus among the design team and IEUA staff. These design concentrations are provided in Appendix 7- B of this document. The design concentrations chosen were based on maximum month values. If the 90th percentile concentration was greater than the max month value, then the 90th percentile value was used. Sludge production rates are summarized in Table 7.2-2.

	Table 7.2-2: Sludge Production R	Rates at Max Month	Condition, lb/MG
--	----------------------------------	--------------------	------------------

Parameter	RP-5	CCWRF
Max Month Primary Sludge	2,335	2,919
Max Month WAS	1,297	1,633
Max Month Total Sludge	3,632	4,552

^a FOG and FW are not included in these sludge quantity estimates

Sludge productions fluctuates throughout the year as the plant influent flow and characteristics change. The solids handling facilities and associated equipment must be sized properly to be able to handle solids productions at peak events. Therefore, several peaking factors are needed, including max day, max week, max 2-week, and max month to design the solids system.

However, there is not enough data available to determine all peaking factors to this level of precision. The peaking factors were determined by reviewing the available influent data as well as using the design team's engineering judgement, knowledge, and experience. Influent data was used to develop peaking factors because there was not enough available data on primary sludge and waste activated sludge (WAS) flow and solids percentage.

The peaking factors were developed for combined sludge as well as separate primary sludge and WAS. Peaking factors for combined sludge will be used to size equipment after the two sludge streams are combined, such as combined thickening, digestion, and dewatering. Peaking factors for separate primary sludge and WAS productions will be used to size equipment for separate sludge thickening alternatives. The peaking factors for separate sludge streams are slightly higher than those of combined sludge as peak sludge productions of primary sludge and WAS typically do not occur simultaneously. The peaking factors are summarized in Table 7.2-3.

Parameter	Combined Sludge	Separate Sludge ^{b,c,d}
Max Month / Annual Average	1.40 ^a	1.60
Max 2-Week / Max Month	1.68 ^b	1.75
Max Week / Max Month	1.75 ^b	1.90
Max Day / Max Month	1.82 ^a	2.10

Table 7.2-3: Sludge Production Peaking Factors^a

^a Based on a review of existing plant data.

^b Not enough existing data to determine this precise peaking factor – value based on the judgment and experience of the design team and interpolated from influent data (See Vol. II Chapter 7)

^c Peaking factors for separate sludge streams are higher than those of combined sludge because peak primary sludge and WAS productions typically do not occur simultaneously

^d Peaking factors for PS and WAS are assumed to be the same

7.2.3 Projected Solids Flows and Loads

Solids productions at maximum month (MM) conditions were developed by multiplying plant influent flow shown in Table 7.2-1 and the unit solids production rates shown in Table 7.2-2. Solids productions at other conditions were developed based on the MM conditions solids productions and the peaking factors shown in Table 7.2-3.

Major assumptions used to project future solids flows and loads include:

- Plant influent flows projections and unit solids production rates (pounds [lbs] of solids produced per million gallon of plant influent) estimates were based on population growth projection taking into account future water conservation.
- Unit solids production rates and solids production peaking factors remain the same throughout the evaluation period.
- Peaking factors for primary sludge and WAS are the same. The peaking factors for primary sludge and WAS might not be the same in reality. However, they are assumed to be the same due to not enough existing data to determine peaking factors for separate primary sludge and WAS. Such assumption has little impact on combined sludge projections. The design team believes that the higher peaking factors assumed for separate primary sludge and WAS projections are conservative for sizing the solids handling facilities that treat separate sludge streams.

- Primary sludge will be wasted from the primary clarifiers. WAS will be wasted from the return activated sludge (RAS) line. Total solids content of the primary sludge and WAS is 0.8% based on the IEUA's preference for sludge pumping.
- Volatile solids of primary sludge are 85% of total solids. This is based on the assumption that the volatile solids of primary sludge are the same as the VSS portion of plant influent.
- Volatile solids of WAS is 88.4% of total solids. This is based on the calculations and assumptions used for solids production estimation in Appendix 7- B.

Projected solids flow and loads at 2060 are summarized in Table 7.2-4. Combined sludge flows and loads were used to size process equipment that treats combined sludge, such as combined thickening, digestion, and dewatering. Separate primary and WAS flows and loads were used to size process equipment that treat the two sludge streams separately, such as separate thickening and associated pumps and piping.

Parameter	Units	Average Annual	Max Month	Max 2- Week	Max Week	Max Day	
Combined Slu	ıdge						
Sludge Flow	gpd	1,581,000	2,213,000	2,656,000	2,766,000	2,877,000	
Total Solids	%			0.8			
Total Solids	ppd	105,000	148,000	177,000	185,000	192,000	
Volatile Solids	% of TS			86			
Volatile Solids	ppd	91,000	127,000	153,000	159,000	166,000	
Separate Slud	ge – Primar	y Sludge					
Sludge Flow	gpd	1,016,000	1,660,000	1,815,000	1,971,000	2,178,000	
Total Solids	%		0.8				
Total Solids	ppd	68,000	111,000	121,000	131,000	145,000	
Volatile Solids	% of TS			85			
Volatile Solids	ppd	58,000	94,000	103,000	112,000	124,000	
Separate Slud	ge – WAS						
Sludge Flow	gpd	565,000	924,000	1,010,000	1,097,000	1,212,000	
Total Solids	%		0.80				
Total Solids	ppd	38,000	62,000	67,000	73,000	81,000	
Volatile Solids	% of TS			88			
Volatile Solids	ppd	565,000	924,000	1,010,000	1,097,000	1,212,000	

Table 7.2-4: Projected Sludge Productions in 2060

7.2.4 High Strength Waste for Co-digestion

The IEUA is interested in accepting high-strength wastes (HSWs) for co-digestion to increase digester gas production. High-strength wastes include FOG and FWs from commercial sources.

The design team conducted an extensive literature review to identify the quantities of FOG and food waste available for co-digestion on local market and best practices in the industry to co-digest HSW at municipal wastewater treatment plants. Details of identifying quantities and qualities of HSWs are discussed in in Chapter 8 of this Volume.

In summary, the following criteria were used for the solids handling facility BCE evaluation:

- Total HSW (FOG and food waste) for co-digestion is limited to 30% of the load to the digesters on a volatile solids basis at annual average condition. The 30% limit is deemed as the best practice in the industry to maximize digester gas production without impairing normal digester operation and stability.
- Quantities of HSW at other conditions (max month, peak week, etc.) are the same as those at annual average condition for a given design year. This ensures the HSW load is always below the 30% limit and minimizes the risk of over loading the digesters.
- Dewatering equipment were sized assuming that all HSW for co-digestion is food waste. This is conservative for dewatering equipment sizing as food waste has lower volatile solids content and lower volatile solids reduction during digestion, resulting in more digested material for dewatering.

Quantities and characteristics of FOG and food waste used for the BCE evaluations are summarized in Table 7.2-5.

Parameter	Units	Value
FOG		
Flow	gpd	21,000
Total Solids	%	6
Total Solids	ppd	11,000
Volatile Solids	% of TS	90
Volatile Solids	ppd	10,000
Food Waste		
Flow	gpd	30,000
Total Solids	%	14
Total Solids	ppd	35,000
Volatile Solids	% of TS	85
Volatile Solids	ppd	29,000
Food Waste (For Dewate	ering Equipmen	t Sizing)
Sludge Flow	gpd	39,000
Total Solids	%	14
Total Solids	ppd	46,000
Volatile Solids	% of TS	85
Volatile Solids	ppd	39,000

Table 7.2-5: Projected FOG and Food Waste Quantities for Co-Digestion in 2060

7.3 EVALUATION OF RP-5 SOLIDS THICKENING ALTERNATIVES

7.3.1 Introduction

This introductory section presents a project background, understanding and approach, and a list of solids thickening alternatives evaluated using a BCE. The BCE is a life-cycle benefit/cost analysis based on the net present value (NPV). NPV analysis is the most comprehensive method to make investment decisions by considering the total cost of a project over its entire life. Because costs or revenues may occur at different times during the duration of the project, time-value of money equations can be used to calculate the present value of all costs and revenues over the life cycle of a project.

The purpose of the BCE is to provide sufficient comparative information on costs, benefits, and risks of the alternatives to provide a sound basis for technology selection. Sizing, loading, process configurations, layouts, and costs are based on project parameters agreed upon by the project team and Agency staff at the time of commencing the BCEs. Since evaluations of technologies and other important project conditions were conducted in parallel and results can impact the final configurations, refinement of the final selected alternative and costs will be conducted after the BCE and technology selection described in this chapter. This refinement will be reflected in the Approved Project Requirements document and integrated into the design final decisions made by the Agency on project phasing, final load decisions related to food waste and FOG treatment, staff layout and configuration preferences, and other decisions subsequent to the BCE.

The following are the alternatives considered for thickening sludge at the new facility:

- Gravity Thickening
- Dissolved Air Flotation Thickener (DAFT)
- Centrifuge
- Membrane Thickening
- Rotary Drum Thickener (RDT)
- Gravity Belt Thickener (GBT)

7.3.2 Solids Feed Characteristics and Production

7.3.2.1 Introduction

Thickening is used to increase the solids content and reduce the volume of sludge by removing a portion of water from the sludge feed. This reduction in volume increases the solids retention time (SRT) in a subsequent digester relative to digestion without thickening. Thickening, reduces the overall costs of sludge processing and handling.

Solids thickening is achieved through physical separation of solids particles from the liquid. The mechanism used for separation is often one of the following: centrifugal force, filtration, screening, sedimentation, or flotation. All of these are represented by the technologies being evaluated. The effectiveness of the separation mechanism depends upon hydraulic flow rate, solids loading rate, and the quantity of chemicals used for increasing particle size (e.g., polymer flocculation).

The new solids treatment facility at RP-5 will received sludge generated from the primary clarifiers (Primary Sludge) and from the secondary treatment process (WAS). The two streams can be thickened separately or blended into a homogenous mix to be co-thickened. Both, separate thickening and co-thickening, have advantages and disadvantages and will be evaluated as part of this BCE.

7.3.2.2 Separate Thickening

In the case of separate thickening, Primary Sludge and WAS are thickened independently. Prior to entering the thickening units, flow from each stream is equalized to shave off peaks and prevent solids washout. After the thickening process, the separate streams are conveyed to the sludge storage tank in the Digester Facility to be blended prior to feeding into the digesters. Figure 7.3-1 shows the main components assumed for separate thickening scenarios.




Figure 7.3-1: Process Flow Diagram for Separate Thickening

An advantage of thickening streams separately is that thickening technologies benefit from having a consistent feed. By having a consistent feed, the polymer dosage for each can be fine-tuned and would not require much adjustment to produce a consistent thickened sludge concentration.

7.3.2.3 Co-thickening

In the case of co-thickening, Primary Sludge and WAS are blended in a sludge blending tank prior to entering the thickening units. After thickening, the thickened sludge is conveyed to the Digestion Facility. Figure 7.3-2 shows the main components assumed for co-thickening scenarios.

Co-thickening helps reduces odors during the thickening process, because of the additions of WAS to Primary Sludge, which helps absorb some of the volatile fatty acids. In addition, co-thickening typically requires one less thickening unit than separate thickening because Primary Sludge and WAS peak production does not occur at the same time and, consequently, can be accommodated by the same unit.




Figure 7.3-2: Process Flow Diagram for Co-thickening

7.3.2.4 Solids Feed Characteristics

Projected maximum day and average annual flows and loads are summarized in Table 7.3-1. The development and assumptions to produce flow and loads projections are presented in Section 7.2. Because the majority of the thickening technologies evaluated are hydraulically limited, with the exception of the DAFT, the thickening facility will be sized to accommodate maximum day flows and loads.

		Design Year						
Parameter	Units	2025		20	45	2060		
	Units	Average Annual	Max Day	Average Annual	Max Day	Average Annual	Max Day	
Primary Sludg	e							
Solids loading	lb/d	42,500	89,300	63,100	132,600	67,800	145,300	
Solids flow	gpd	637,500	1,338,700	946,200	1,987,000	1,015,600	2,178,300	
Solids	%TS	0	0	0.8		0.8		
concentration	7015	0	0.8		0.8		0.8	
WAS								
Solids loading	lb/d	23,700	49,700	35,100	73,800	37,700	80,900	
Solids flow	gpd	355,000	745,600	526,600	1,105,800	565,200	1,212,200	
Solids concentration	%TS	0.8		0.	8	0.	8	
Combined Sluc	lge ^a							
Solids loading	lb/d	66,200	120,500	98,300	178,800	105,500	191,900	
Solids flow	gpd	992,500	1,806,300	1,472,800	2,680,500	1,580,700	2,876,900	
Solids concentration	%TS	0.8		0.8		0.8		

Table 7.3-1: Thickening Process Feed Solids Projections

a. Because peak production of Primary Sludge and WAS Sludge occurs at different times, two sets of peaking factors assumed to develop sludge productions at peak conditions for combined sludge.

7.3.3 Solids Thickening Technology Descriptions

7.3.3.1 Gravity Thickener

A gravity thickener, an example of which is shown on in the Figure 7.3-3 below, operates much like conventional primary or secondary clarifiers, with solids settling to the bottom of a tank via gravity. The process performs best when it receives sludge continuously to promote a stable sludge blanket. This reduces the occurrence of rising sludge by minimizing hydraulic residence time. The sludge blanket provides some means for additional sludge storage.



Figure 7.3-3: Gravity Thickener

7.3.3.2 Dissolved Air Flotation Thickener (DAFT)

A DAFT uses tiny air bubbles to separate solids from the liquid stream. A recycle stream from the DAFT subnatant is pressurized and mixed with the feed sludge just before entering the DAFT. When the recycle stream depressurizes upon entering the DAFT tank, dissolved air is released as fine bubbles attach to the sludge solids and carry them to the upper water surface, where they concentrate and are removed. Heavy solids settle out and are removed as DAFT underflow.



Figure 7.3-4: Dissolved Air Flotation Thickener

(Photo courtesy of Ovivo)

7.3.3.3 Centrifuge Thickener

Centrifuge thickeners involve separation of sludge particles and water under the influence of centrifugal forces induced through the force from high-speed rotation of a cylindrical bowl. A solid-bowl centrifuge operates as a continuous feed unit which removes solids using a scroll conveyor and discharges liquid over an end weir. The bowl is a conical-shape, which helps lift solids out of the liquid, allowing them to dry on an inclined surface before being discharged.



Figure 7.3-5: Centrifuge Thickener

(Photo courtesy of Alfa-Laval)

7.3.3.4 Membrane Thickener

Membrane thickening is a relatively new application of existing membrane bioreactor technology. Compared to a membrane bioreactor, a membrane thickening process operates with a higher solids concentration in the reactor, but at a much lower flux rate (about one third). A lower flux rate prevents the higher solids concentration from quickly fouling the membranes. The membrane thickener concentrates sludge by drawing excess water through the membranes, leaving behind the sludge solids.



Figure 7.3-6: Membrane Thickener

(Photo Courtesy of Ovivo)

7.3.3.5 Rotary Drum Thickener (RDT)

In RDTs, sludge is conditioned with polymer before being introduced into a slow rotating screen. Free water drains through the screen openings and collects in a trough underdrain. Thickened sludge is conveyed through the rotating drum and out the discharge end via a continuous internal screw or angled flights. The drum is sometimes inclined to aid in dewatering. An example of a single-drum style RDT is shown in the figure below.



Figure 7.3-7: Rotary Drum Thickener

(Photo courtesy of Parkson)

7.3.3.6 Gravity Belt Thickener (GBT)

GBTs were originally developed based on the gravity section of a belt filter press, where the majority of dewatering occurs. This process uses gravity to drain water from the polymer-conditioned sludge as it travels over a filter belt that is under tension. The water is collected beneath the belt as the concentrated sludge is carried above the belt to the discharge end of the thickener.



Figure 7.3-8: Gravity Belt Thickener

(Photo courtesy of Komline-Sanderson)

7.3.4 Thickening Alternatives Screening

7.3.4.1 Comparison of Thickening Technologies

Subjective considerations for the thickening technology alternatives were presented for consideration as part of the selection process and are provided below. The main factors considered in the pros and cons comparison are capital cost, anticipated performance, equipment footprint, potential for odors, and energy and water consumption. Table 7.3-2 lists the pros and cons for each technology.

DAFT	Centrifuge
Pros	Pros
Effective at accommodating hydraulic peaks without decrease performance.	Solids concentrations of 4% – 8%
Allows for grit removal that can damage downstream equipment.	95% – 99% solids capture
Plant staff is familiar with equipment	Odors are contained/ Reduced odor potential
	Low wash water
	Relatively small footprint smaller building requirement
	ProsEffective at accommodating hydraulic peaks without decrease performance.Allows for grit removal that can damage downstream equipment.

Table 7.3-2: Pros and Cons for Thickening Technologies

Gravity Thickener	DAFT	Centrifuge
Cons	Cons	Cons
High capital cost	Highest capital cost	High capital cost
Not well suited for WAS thickening	Not well suited for Primary Sludge thickening	Energy intensive
Odor nuisance/ Requires high volume of Odor Control	Odor nuisance/ Requires high volume of Odor Control	Complex to operate – high- rotational speed equipment, means highest O&M labor cost of the alternatives
Large footprint	Energy intensive	High noise potential
	Large footprint	
	Many pieces of equipment requiring maintenance	

Membrane Thickener	RDT	GBT
Pros	Pros	Pros
Modular design requires less space than tank alternatives.	Lowest capital cost	Low capital cost
Nearly 100% solids capture	Solids concentrations of 5% – 9%	Solids concentrations of 6% - 8%
	93% – 99% solids capture	95% – 98% solids capture
	Odors are contained/ Reduced odor potential	Odors are contained/ Reduced odor potential
	Low power consumption	Low power consumption
	Relatively small footprint smaller building requirement	Relatively small footprint smaller building requirement
Cons	Cons	Cons
Highest capital cost	Oils and greases can blind the drum filter media.	Oils and greases can blind the belt filter media
No well suited for Primary Sludge Thickening	Hydraulically limited. Largest unit is 400 gpm.	High wash water consumptions
Solids concentrations of 3% – 4%		
Energy intensive		
New technology/ unproven		
Odor nuisance/ Requires high volume of Odor Control		

7.3.4.2 Screening Criteria

The thickening technologies were screened to determine if the technologies met a minimum set of requirements. The screening process used a combination of pass/fail scoring and a high level rating

on a scale of 1 to 5 for criteria identified in the previous sections. The results of the initial screening are provided in Table 7.3-3.

Thickening Alternatives	Weight	Gravity Thickener	DAFT	Centrifuge	Membrane	GBT	RDT
Supports Treatment and End Use Objectives	Pass/Fail	Yes	Yes	Yes	Yes	Yes	Yes
MeetsRequiredPerformance5%Min(6% for 2-Phase Digestion)	Pass/Fail	Yes (No)	Yes	Yes	No	Yes	Yes
Proven Technology	Pass/Fail	Yes	Yes	Yes	No	Yes	Yes
Acceptable Complexity	Pass/Fail	Yes	Yes	Yes	No	Yes	Yes
Suitable for Separate or Co- Thickening	5%	1	4	3	1	4	4
Thickened Solids Concentration	30%	2	2	3	1	5	5
Solids Capture	20%	1	3	2	5	4	4
Footprint	10%	2	3	5	3	4	3
Polymer Usage	15%	4	3	3	5	1	2
Odor Control	10%	3	3	5	3	3	5
Power Requirements	5%	5	2	1	2	4	4
O&M Requirement	5%	5	4	2	1	3	3
Weighte	ed Average	2.5	2.8	3.1	2.9	3.7	4

Table 7.3-3: Results of Initial Screening Evaluation

7.3.4.3 Screening Results

Gravity Thickeners and Membrane Thickeners were eliminated as potential alternatives through the initial screening because they failed to meet pass/fail criteria. Membranes are still a relatively new technology as applied to thickening. In the case of gravity thickening, in addition to the potential for low thickening solids concentration, the Agency expressed additional concerns with excessive odors and maintenance. The weighted average score was highest for RDT, followed by GBT. Centrifuge had a score more than 20% lower than RDT. DAFT scored 30% lower than RDT.

Although the Agency currently uses DAFTs successfully at existing facilities to thicken WAS, DAFTs are not well suited to thicken Primary Sludge separately and pose odor and maintenance concerns similar to Gravity Thickeners. However, due to the Agency's current successful

operation and potential benefits of DAFTs, they were not screened out. DAFT, RDT, GBT and Centrifuges continued on to the more detailed evaluation.

7.3.5 Alternatives Development

7.3.5.1 Thickening System Performance Requirements

The performance goals shown in Table 7.3-4 will be used for the thickening technology evaluation only. These performance requirements are conservative and can potentially be achieved by all of the remaining four technologies. During detailed design, these can be refined based on IEUA objectives and related process selections.

Table 7.3-4: Thickening System Performance Goals

Performance Requirement	Value
Minimum thickened solids concentration	5% (6% for 2-Phase Digestion)
Minimum Solids Capture	95%

The following assumptions were made in evaluating the different thickening technology alternatives:

- Equipment sizing and facility layout are based on 2060 (build-out) projected flows and loads. Running costs, and repair and replacement are carried out to year 2045.
- Maximum day flows and loads were used to size the thickening facility to ensure facility is not hydraulically limited. If desired, during detail design, this assumption can be refined based on available equalization in upstream processes and to more closely match the Digestion facility.
- Thickening operation is assumed to be continuous, 24 hours per day/7 days per week.

7.3.5.2 Design Criteria and Equipment Sizing

Design criteria and sizing results for the four thickening alternatives are summarized in Tables 7.3-5 to 7.3-8. The design criteria for each alternative are based on the "Basis of Design Model" listed in the tables.

Design Parameter	Unit	Primary Sludge	WAN I	
Solids Loading Rate	lb/ft²/hr	2.8	1.5	2.0
Air/ Solids Ratio	%	3	3	3
Air Input	scfm	50	30	70
Recycle Flow, total	gpm	4,470	2,490	5,910
Polymer Dosage	lb/dry ton	10	5	7.5
Basis of Design/ Tank Diameter		Ovivo 30-ft	Ovivo 30-ft	Ovivo 40-ft

Table 7.3-5: DAFT Design Criteria

Design Parameter	Unit Primary Sludge		WAS	Combined Sludge
Hydraulic Loading Rate, max	gpm/unit	425	425	425
Solids Loading Rate, max	lb/hr/unit	3200	3200	3200
Polymer Dosage	lb/dry ton	3	8	5
Wash Water Requirement ^a	gpm	250	250	250
Basis of Design Model ^b		Alfa-Laval G3-125	Alfa-Laval G3-125	Alfa-Laval G3-125
Bowl Diameter	in	29	29	29

Table 7.3-6: Centrifuge Design Criteria

a. Intermittent Flow.

b. Per manufacturer's recommendation the medium size unit (G3-125) was selected over the larger unit (G3-165) because it results in lowest capital cost and is a more proven design.

Design Parameter	Unit	Primary Sludge	WAS	Combined Sludge
Hydraulic Loading Rate, max	gpm/unit	400	400	400
Polymer Dosage	lb/dry ton	5	10	8
Wash Water Requirement	gpm	50	50	50
Basis of Design Model		Parkson RDT-400	Parkson RDT-400	Parkson RDT-400
Drum Diameter	in	44	44	44

Table 7.3-7: RDT Design Criteria

Table 7.3-8: GBT Design Criteria

Design Parameter	Unit	Primary Sludge	WAS	Combined Sludge
Hydraulic Loading Rate	gpm/m	600	600	600
Solids Loading Rate	lb/hr/m	2600	2600	2600
Polymer Dosage	lb/ton	6	10	8
Wash Water Requirement	gpm	60	60	60
Basis of Design Model		Komline 3-m GBT	Komline 3-m GBT	Komline 3-m GBT

7.3.5.3 Alternatives Definition

A list of alternatives consisting of various combinations of technologies to handle Primary Sludge and Waste Activated Sludge separately or combined is presented below. As previously mentioned, DAFT was not considered for Primary Sludge thickening because of performance, odor, and maintenance concerns.

Separate Thickening:

- Alternative 1 DAFT (WAS) + Centrifuges (PS)
- Alternative 2 DAFT (WAS) + RDTs (PS)
- Alternative 3 DAFT (WAS) + GBTs (PS)
- Alternative 4 Centrifuges (Primary & WAS separately)
- Alternative 5 RDTs (Primary & WAS separately)
- Alternative 6 GBTs (Primary & WAS separately)

Co-thickening:

- Alternative 7 DAFT (Combined)
- Alternative 8 Centrifuges (Combined)
- Alternative 9 RDTs (Combined)
- Alternative 10 GBTs (Combined)

7.3.5.4 Unit Redundancy

For the DAFT alternatives, one large duty unit would be feasible, however, four smaller DAFT units that provide 33% capacity redundancy was preferred over one large duty unit and one large redundant unit, providing 100% redundancy that would sit empty most of the time. For Centrifuge, RDT and GBT alternatives, one full unit was assumed to provide redundancy in order to facilitate the thickening operations and maintain required capacity during extended maintenance events. In separate thickening alternatives for Centrifuge, RDT, and GBT, one redundant unit is setup to thicken either Primary Sludge or WAS.

Ancillary systems such as polymer, wash/spray water, conveyance and electrical will be designed to allow for operation of all thickening units (including standby) simultaneously in order to provide maximum operational flexibility.

7.3.5.5 Alternatives Sizing Results

Thickening equipment for the ten (10) BCE Alternatives are presented in Table 7.3-9. It is worth mentioning that in most cases the number of units required in 2060 did not vary from that required in 2045. This is because the population growth projection is linear up to 2045 and from 2045 to 2060 it is assumed to slow down considerably.

Total Number of Units for each Alternative	2025		2045			2060			
Separate Thickening @ Max Day	PS	WAS	Total	PS	WAS	Total	PS	WAS	Total
Alternative 1 - DAFTs (WAS) + Centrifuges (PS)	4	3	7	5	4	9	5	4	9
Alternative 2 - DAFTs (WAS) + RDTs (PS)	4	3	7	5	4	9	5	4	9
Alternative 3 - DAFTs (WAS) + GBTs (PS)	3	3	6	4	4	8	4	4	8
Alternative 4 - Centrifuges (Primary & WAS)	4	1	5	5	2	7	5	2	7

Table 7.3-9: Separate Thickening Alternatives Number of Units

Total Number of Units for each Alternative	2025		2045			2060			
Separate Thickening @ Max Day	PS	WAS	Total	PS	WAS	Total	PS	WAS	Total
Alternative 5 - RDTs (Primary and WAS)	4	2	6	5	2	7	5	2	7
Alternative 6 - GBTs (Primary and WAS)	3	1	4	4	2	6	4	2	6

a. Total number of units includes 1 standby unit. When using the same technology for the different stream, the standby unit is included in the count for Primary Sludge units.

Total Number of Units for each Alternative	2025	2045	2060
Co-Thickening @ Max Day	Total	Total	Total
Alternative 7 - DAFT	3	4	4
Alternative 8 - Centrifuge	4	6	6
Alternative 9 - RDT	4	6	6
Alternative 10 - GBT	3	4	5

Table 7.3-10: Co-thickening Alternatives Number of Units

a. Total number of units include duty units plus one standby unit.

7.3.5.6 Alternatives Layout

Layouts for each thickening alternative were developed to identify any space constraints that would rule out an alternative. No space constraints were identified. A facility layout of the selected technology, as modified to represent the Approved Project, is included in Chapter 2 of this Volume.

7.3.6 Thickening Alternatives Business Case Evaluation

Inputs and assumptions for the thickening BCE were developed in more detail in collaboration with IEUA staff. These are presented in the subsequent sections. The IEUA standard BCE template was utilized to develop comparative net present values for thickening facilities with construction starting in 2022 and operating through 2045.

7.3.6.1 Capital Costs

Capital costs for major pieces of equipment are project specific and were obtained from local manufacturer's sales representatives.

7.3.6.2 Operation and Maintenance (O&M) Costs

O&M assumptions were obtained from manufacturers and supplemented with information from previous projects.

Costs for energy consumption, water consumption, and polymer were obtained from the IEUA.

Labor costs and maintenance cost on a full-time equivalent (FTE) basis were also provided by the IEUA.



7.3.6.3 Repair and Replacement Costs

Cost for wear parts and hours for replacement were obtained from manufacturers and supplemented with information from previous projects.

One full unit was assumed to be replaced within the 23-year period for this BCE.

7.3.6.4 Risks and Benefits

No risks or benefits were included in this BCE.

7.3.6.5 Business Case Evaluation and Analysis

A summary of the results of the BCE are presented in Table 7.3-11. All costs are in 2016 dollars. The full BCE spreadsheets are presented in Exhibit I of this Volume.

DAFT and Centrifuges alternatives are cost-prohibitive due to the high cost of the equipment, high energy consumption, and high parts replacement costs. Rotary Drum and Gravity Belt Thickening are similar in terms of capital and annual O&M costs, but RDT has lower repair and replacement costs. Even though GBT alternatives require one less unit than RDTs, the units are more expensive and larger, requiring more physical space in a solids thickening facility.

Polymer consumption is not a differentiator between alternatives. The recommended polymer dosage for all equipment was within the range of 0 to 10 lb/dry ton.

The most cost-effective technology based on this BCE is co-thickening with RDTs. However, depending on the actual polymer dosage requirements established after bench scale testing of the different sludge streams, separate thickening may prove more cost-effective.

Alternative	Capital (1)	O&M (2)	R&R (2)	NPV
1 DAFT (WAS) and Centrifuges (PS)	\$32,200,000	\$25,800,000	\$2,500,000	\$(62,400,000)
2 DAFT (WAS) and RDT (PS)	\$24,200,000	\$18,800,000	\$1,400,000	\$(45,700,000)
3 DAFT (WAS) and GBT (PS)	\$25,800,000	\$19,900,000	\$2,000,000	\$(49,100,000)
4 Centrifuges Separate	\$25,000,000	\$21,600,000	\$2,100,000	\$(50,200,000)
5 Rotary Drum Thickener Separate	\$12,800,000	\$12,700,000	\$600,000	\$(26,800,000)
6 Gravity Belt Thickener Separate	\$14,500,000	\$15,900,000	\$1,400,000	\$(32,600,000)
7 DAFT Co-thickening	\$19,100,000	\$30,600,000	\$1,100,000	\$(51,900,000)
8 Centrifuges Co-thickening	\$21,500,000	\$22,400,000	\$1,700,000	\$(46,700,000)
9 Rotary Drum Thickener Co-thickening	\$11,200,000	\$14,000,000	\$600,000	\$(26,400,000)
$\begin{pmatrix} 1 \\ 0 \end{pmatrix}$ Gravity Belt Thickener Co-thickening	\$11,900,000	\$14,900,000	\$1,100,000	\$(28,500,000)

Table 7.3-11: Results of the Business Case Evaluation

(1) Capital costs shown are un-escalated 2016 dollars

(2) O&M and R&R costs shown are escalated and discounted back to 2016 dollars.

7.3.7 Agency Decisions and Preferences for the Approved Project Requirements

During the BCE workshop on August 11, 2016, IEUA provided some direction and preferences that are not part of the BCE but will be included in the Approved Project deliverable. The BCE was only updated to address comments that would have the potential for affecting the technology

selection. The impact on the selected thickening equipment size, number, layout, and cost will be evaluated at the next detailed design phase of the project.

Major items to be integrated into the final Approved Project Requirements include:

- Thickening equipment phasing.
- Thickening building layout refinements. Sufficient space around thickening units to facilitate easy maintenance and operation.
- Flexibility to separately thicken Primary Sludge and WAS or co-thicken based on the Agency's goals.
- The thickening facility sludge storage tanks (raw and thickened sludge) will be sized to allow operation of the thickening and sludge transfer equipment over all anticipated facility loading rates.
- Ranges of performance of thickening equipment (i.e., higher %TS of thickened sludge) needs to be accommodated by pumping and conveyance downstream of thickening units.
- Emulsion polymer is preferred over dry polymer systems as it provides the Agency with more polymer options based on their current contracts.

The Agency staff also expressed a desire to visit an operating RDT facility to better understand design and operational details that will help inform their ultimate design preferences leading to optimization of the design at the next stage of the project.

7.3.8 Recommendations

Based on the BCE favoring RDTs by a considerable margin for both separate thickening and cothickening scenarios, selection of RDT is recommended for solids thickening. Because the difference between separate thickening and co-thickening is small and heavily depends on the polymer dosage assumed for each stream, it is recommended that the Thickening Facility be sized for the seven (7) RDT units required for separate thickening through build-out and provide the piping arrangement required to allow for separate thickening or co-thickening. This recommendation was approved by the IEUA at the BCE workshop on August 11, 2016.

7.4 EVALUATION OF RP-5 SOLIDS DIGESTION ALTERNATIVES

7.4.1 Introduction

This introductory section presents a project background, understanding and approach, and a list of the anaerobic digestion alternatives evaluated using a BCE for evaluation of the IEUA RP-5 solids digestion facility alternatives.

Based on the background of the project, the new solids treatment facility at RP-5 would consist of Thickening, Digestion, and Dewatering. This chapter describes the BCE of three different alternatives for the digestion facility to arrive at the most cost-effective option.

The purpose of the BCE is to provide sufficient comparative information on costs, benefits, and risks of the alternatives to provide a sound basis for technology selection. Sizing, loading, process



configurations, layouts, and costs are based on project parameters agreed on by the project team and Agency staff at the time of commencing the BCEs for the 2045 design year. Because evaluations of technologies and other important project conditions were conducted in parallel and results can impact the final configurations, refinement of the final selected alternative and costs will be conducted after the BCE and technology selection described in this chapter are completed. This refinement will be reflected in the Approved Project Requirements document and integrate into the design final decisions made by the Agency on project phasing, final load decisions related to FW and FOG treatment, staff layout and configuration preferences, and other decisions subsequent to the BCE.

The following are the three alternatives considered for the digestion facility:

- Mesophilic Anaerobic Digestion (MAD)
- Two-Phase Anaerobic Digestion (2-Phase)
- Thermal Hydrolysis Process Anaerobic Digestion (THP)

7.4.2 Solids Feed Characteristics and Production

This section describes solids feed characteristics Projections for the solids flows and loads to the digestion facility.

7.4.2.1 Solids Feed Characteristics

The solids feed characteristics that will impact digestion are summarized in Table 7.4-1.

Sludge Characteristic	Average Value
Nominal Sludge Composition, Total Dry Solids Weight Basis	Anaerobically digested blend of primary sludge, WAS, FW, and FOG
Primary sludge and WAS feed, %volatile solids (%VS) dry mass basis	70
Food waste and FOG to digester feed, %VS dry mass basis	30
Total solids concentration, %TS, MAD, 2-Phase	5
Total solids concentration, %TS, THP ^a	16.5
Volatile solids (VS), % dry mass basis	86
Temperature, deg F	65 - 85
Average pH	7

Table 7.4-1: Projected Digestion Feed Characteristics

a. After pre-dewatering facility

7.4.2.2 Solids Flows and Loads

Projections for the solids flows and loads to the digestion facility following solids thickening for both the maximum day and maximum 2-week conditions have been developed. Table 7.4-2 provides a summary of these solids loads for 2025, 2045, and 2060. The values shown in Table 7.4-2 are for overall combined sludge which includes food waste, FOG and combined sludge (Primary Sludge and WAS). Sludge projections are based on the plant influent flow of both RP-5 and CCWRF.

Performance	Parameter	2025	2045	2060
Influent Flow, mgd ^a (R	RP-5 and CCWRF)	23.6	35.8	38.5
Solida Looding andb	Max Day	149,400	221,700	237,900
Solids Loading, ppd ^b	Max 2-Week	140,100	207,900	223,100
VS Looding and	Max Day	128,500	190,600	204,600
VS Loading, ppd	Max 2-Week	120,500	178,800	191,800
Hydraulic Loading,	Max Day	313,800	465,600	499,700
gpd ^c	Max 2-Week	291,500	432,600	464,300
Sludge VS, % VS			86	

Table 7.4-2	: Digestior	ι Solids and	Hydraulic	Loading Projections
-------------	-------------	--------------	-----------	---------------------

a. million gallons per day

b. pounds per day

c. gallons per day

7.4.3 Digestion Technology Alternatives Descriptions

7.4.3.1 Mesophilic Anaerobic Digestion (MAD)

The majority of MAD systems currently in use at municipal wastewater treatment plants (WWTPs) for solids stabilization are configured as conventional mesophilic anaerobic digesters. The mesophilic temperature range is approximately 36°C–38°C where heating and mixing are provided to maintain uniform conditions in the digester. In a conventional mesophilic digestion operation, storage tanks are normally included for digested sludge prior to dewatering. Properly configured, a storage tank can also function as a digester in the event that the primary digester is out of service, provided the necessary heating and mixing equipment is installed. MAD is the industry standard for anaerobic digestion and represents the base case for the BCE. A process flow diagram (PFD) for the MAD process is provided in Figure 7.4-1.




Figure 7.4-1: MAD PFD



7.4.3.2 Two-Phase Anaerobic Digestion (2-Phase)

Two-phase Acid/Gas (2-Phase) digestion is a two-stage digestion process comprising acid and gas phase digesters. The first digester in the series is operated with a short SRT of 1.5 days to 2 days, during which the substrates are hydrolyzed to produce volatile fatty acids (VFAs). Methanogens require a longer SRT and are thus excluded from this acid-phase digester (aka acid silo), which can be at either thermophilic or mesophilic temperature. The VFAs are then used by methanogens in the second digester. This separation in phases has been demonstrated through long-term operation by the IEUA to improve solids reduction and increase gas production. A PFD for 2-Phase digestion process is provided in Figure 7.4-2.




Figure 7.4-2: Two-Phase Anaerobic Digestion PFD

7.4.3.3 Thermal Hydrolysis Process (THP)

Thermal hydrolysis is a high-heat, high-pressure anaerobic digestion pretreatment system that results in enhanced solids processing and energy production and has the benefit of reducing pathogens to Class A levels through pasteurization/sterilization and improved dewaterability. THP is an evolving technology that uses steam to put solids under high temperature and pressure conditions, which lyse bacterial cells and promote the release and solubilization of particulate organic material. THP also tends to hydrolyze large biological macromolecules, carbohydrates, and long-chain fatty acids to lower molecular weight intermediates, making them more amenable to digestion, improving volatile solids reduction and biogas production. To make the process efficient, raw feed solids are pre-dewatered before the THP process and the anaerobic digesters are operated at a higher solids concentration than other digestion processes such as MAD and 2-Phase. A process flow schematic is provided in Figure 7.4-3.




Figure 7.4-3: THP PFD

7.4.4 Alternatives Screening

7.4.4.1 Screening Criteria

The following digestion technologies were initially screened to determine if all technologies meet IEUA minimum requirements using a pass/fail approach:

- Mesophilic Anaerobic Digestion (MAD)
- 2-Phase Anaerobic Digestion (2-Phase)
- 3-Phase Anaerobic Digestion
- Temperature-Phased Anaerobic Digestion (TPAD)
- Thermal Hydrolysis Process (THP)

A high level rating on a scale of 1 to 5 (with 5 being the most favorable score) was also provided for criteria considered important and weighted averages computed. The results are provided in Table 7.4-3.

Parameters	Weight	MAD	3-Phase	2-Phase	TPAD	THP
Supports Treatment and End Use Objectives	Pass/Fail	YES	YES	YES	YES	YES
Meets Required Performance	Pass/Fail	YES	YES	YES	YES	YES
Proven Technology	Pass/Fail	YES	YES	YES	YES	YES
Acceptable Complexity	Pass/Fail	YES	YES	YES	YES	YES
Performance (VSR ^a , Gas Production)	15%	3	4	4	4	4

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 7: Evaluation of RP-5 Solids Treatment Alternative Technologies						
Energy/Resource Recovery	10%	3	4	4	4	4
O&M Impacts	10%	5	3	4	3	1
Safety Impacts	10%	4	4	4	4	2
Environmental Impacts – Cake Stability, Pathogens	5%	3	4	3	4	5
Potential Odor Impacts	5%	4	3	3	3	2
Flexibility	10%	4	4	4	4	2
Site Space Utilization	15%	4	3	3	3	5
Food Waste Compatibility	5%	3	5	4	5	2
Relative Cost	15%	5	3	4	3	3
Weighted Ave	3.9	3.6	3.8	3.6	3.1	

a. volatile solids reduction

b. Note: higher weighted average scores are most favorable

The IEUA desires that the digestion facility is provided with the ability to operate at either mesophilic or thermophilic temperatures. Given this preference, both the 3-Phase and TPAD alternatives were removed from further evaluation. Either the mesophilic digestion or 2-Phase options could be operated as either TPAD or 3-phase given the ability to operate at either mesophilic or thermophilic temperatures. THP was included for consideration due to the ability of this technology to reduce footprint requirements and provide a desirable Class A product.

7.4.4.2 Screening Recommendation

All digestion technology alternatives met the pass/fail criteria and advanced. Three technologies were carried forward for the BCE analysis: MAD, 2-Phase, and THP alternatives. The 3-Phase and TPAD technologies were not carried forward as these processes could be easily accommodated by either the Mesophilic or 2-Phase technologies given the ability to operate the digesters at either mesophilic or thermophilic temperatures (assumption for thermophilic option would include installation of higher capacity heat exchangers, comprehensive thermal insulation of tanks and covers, and other necessary improvements).

7.4.5 Alternatives Development

This section describes the development of the digestion technology alternatives.

7.4.5.1 Digestion System Performance Requirements

The performance requirements shown in Table 7.4-4 will be used for the digestion technology evaluation only. These design performance requirements will be refined based upon IEUA objectives and related process selections during detailed design.

Performance Requirement ^a		MAD	2-Phase		THP
		MAD	Acid	Gas	
Solids retention Time, days	Max ^d 2-Week	15	-	14	12
	Max Day	-	1	-	-
Organic Loading Rate,	Max 2-Week	0.18	-	0.2	0.35
lb ^b VS/ft ^{3c} -day	Max Day	0.24	3	0.27	0.5

Table 7.4-4: Digestion System Performance Requirements

a. Values based on WEF MOP 8 and Industry Standard Design Practices.

b. Pound

c. Cubic foot

d. Maximum

The following assumptions were used in evaluating the digester alternatives:

Digesters sizing and site layouts are based on year 2060 (build-out). BCE will be carried out to year 2045.

- Max 2-week flows and loads are used to size digestion facility for Mesophilic, 2-Phase, and THP facility digesters.
- Acid reactors sized for max day.

7.4.5.2 IEUA Digestion Technology Preferences

IEUA defined several preferences for the digestion technology, as follows:

- Proven 2-phase digestion to maximize digestion performance and gas production
- Redundant digester
- Continuous digester feeding
- Fixed digester cover
- Ability to operate in thermophilic mode
- Digested Solids (DS) storage tank(s) to operate as digester if needed in the future
- FOG and FW digestion; design impacts without FW and FOG will be evaluated as part of the approved project
- Future treatment of digestate from RP-5 solids handling facility (SHF) may be required
- All indoor equipment and galleries
- Operator familiarity with equipment
- Equipment repair downtime must be low; facilities requiring manufacturer services facilities must be capable of quick response with spare primary and critical equipment components stocked at the facility or quickly available through a manufacturer exchange program
- Capable of fully automatic operation with limited operator observation
- Preference towards fewer equipment items to limit maintenance requirements and complexity
- Low equipment repair/component replacement frequency
- Low daily maintenance and housekeeping requirement

7-32

7.4.5.3 Alternatives Performance and Sizing

The performance and sizing results for the three digestion alternatives are summarized in Tables 7.4-5 to 7.4-7 and were used as the basis for developing the digestion technology BCE.

Note that for the MAD and THP processes the controlling condition is the 2060 VS load. For the Two-Phase process the controlling condition is the 2060 SRT for the acid reactor at one tank out of service and the VS load for the methane reactor.

Design Condition	2025	2045	2060	
Digester tank volume and number				
Digester Feed Tank Volume, mgal each	0.13	0.13	0.13	
Digester Feed Tank Number	2	2	2	
Digester Volume, mgal each ^a	1.6	1.6	1.6	
Digester Tank Number	4	6	6	
Digester SRT, day				
Max 2-week, all in service	21.9	22.1	20.6	
Max 2-week, one tank out of service	16.4	18.4	17.3	
Digester VS Loading, lb/ft ³				
Max 2-week, all in service	0.14	0.14	0.15	
Max 2-week, one tank out of service	0.19	0.17	0.18	

Table 7.4-5: Alternative 1- MAD Performance and Sizing Data

a. At one tank out of service.

	•		•			
Design Condition	2025	2045	2060			
Digester Tank Volume and Number						
Acid Tank Volume, mgal ^a	0.25	0.25	0.25			
Acid Feed Tank Number	2	3	3			
Digester Volume, mgal ^a	1.44	1.44	1.44			
Digester Tank Number	4	6	6			
Acid Digester SRT, day						
Max Day, all in service	2.4	1.6	1.5			
Max Day, one tank out of service	1.6	1.1	1.0			
Gas Digester SRT, day						
Max 2-week, all in service	19.7	19.9	18.6			
Max 2-week, one tank out of service	14.8	16.6	15.5			
Acid Digester VS Loading, lb/ft ³						
Max Day, all in service	1.3	1.9	2.0			
Max Day, one tank out of service	1.9	2.8	3.0			
Gas Digester VS Loading, lb/ft ³						
Max 2-week, all in service	0.16	0.16	0.17			
Max 2-week, one tank out of service	0.2	0.19	0.2			

Table 7.4-6: Alternative 2 - Two-Phase Digestion Performance and Sizing Data

a. At one tank out of service.

Table 7.4-7: Alternative 3 - THP Performance and Sizing Data

Design Condition	2025	2045	2060			
Digester tank volume and number						
Digester Volume, mgal ^a	1.37	1.37	1.37			
Digester Tank Number	3	4	4			
Digester SRT, day						
Max 2-week, all in service	25.9	23.3	21.7			
Max 2-week, one tank out of service	17.3	17.5	16.3			
Digester VS Loading, lb/ft ³						
Max 2-week, all in service	0.22	0.24	0.26			
Max 2-week, one tank out of service	0.33	0.33	0.35			

a. At one tank out of service.

7.4.5.4 Subjective Equipment Considerations

Subjective considerations for the three digestion technology alternatives were presented for consideration as part of the selection process and are provided below.

The advantages and disadvantages of the MAD, 2-Phase, and THP digestion alternatives are summarized in Table 7.4-8 through Table 7.4-10.

Advantages	Disadvantages
 Longest operational history of all the processes under consideration. Most supporting operational data. Produces class B solids with minimal amount of additional testing or processing. Digester performance and gas production rates can be easily predicted from MAD systems. Process can easily be upgraded to an advanced digestion process, such as 2-Phase, 3-phase, or THP. 	 Degradation rates are relatively low. Foaming potential. Process upset potential (temperature and loading rate sensitive). Lower VS destruction, low gas production, more tankage volume required. Additional mass of solids for disposal relative to two other processes.

Table 7.4-8: MAD Equipment Considerations

Table 7.4-9: Two-Phase Equipment Considerations

Advantages	Disadvantages
 Higher loading rate allows for slightly smaller digesters For class A biosolids, 2-Phase can be run as TPAD by operating acid reactor at thermophilic temperatures. Improved VSR and gas production. Process can easily be upgraded to an advanced digestion process, such as 3-phase or THP. 	 Gas from acid phase reactor requires more extensive treatment than not blended with methane phase gas. Excessive retention times in the acid phase may increase odorous compounds including Hydrogen Sulfide (H₂S) gas. These compounds impact the life or performance of gas utilization equipment and may generate odors at flares. Biogas produced in Acid Phase reactor is of low quality and requires either a thermal oxidizer flare or bending with higher quality biogas from mesophilic digester gas

Table 7.4-10: THP Equipment Considerations

Advantages	Disadvantages
 Highest wastewater solids processing capacity and greatest VSR. THP also increases extent of VSR and gas production. 	• Ancillary systems & equipment such as steam boilers, pre-dewatering centrifuges, raw cake storage and sludge cooling systems impact the total cost, complexity and footprint.

• THP decreases viscosity of digester feed sludge allowing the feed solids range from 9%-12% thereby allowing for a reduced	• Increased concentration of ammonia in digester with potential inhibition of digestion and impacts from high ammonia
 digester residence time. Volumetric solids loading rate to the digestion process is increased and SRT decreased, increasing the solids handling capacity of a given digester volume or reducing number of new digesters installed. 	 concentrations in dewatering recycles. Formation of recalcitrant dissolved organic nitrogen (rdoN) may occur under certain operation conditions.
 Solids from THP exhibit improved dewaterability, less odorous cake and Class A biosolids. 	

The comparative summary of the three digestion alternatives is provided in Table 7.4-11.

Alternatives	Footprint	Biogas	Utilities	Odor	Biosolids	Cos	sts	Experience
7 Hiter Hutives	rootprint	Production	C thrues	Potential	Quality	Capex	Opex	Experience
MAD	Avg ^a	Avg	Avg	Avg	Avg	Avg	Avg	High
2-Phase	Avg	Above Avg	Above Avg	High	Avg	Above Avg	Abo ve Avg	IEUA standard
ТНР	Below Avg	Avg	High	High	High	High	High	Limited in USA, strong growth

Table 7.4-11: Comparative Summary of Digestion Alternatives

a. Average

7.4.5.5 Redundancy Discussion

In order to provide redundancy for digestion alternatives, the following options are provided:

- Additional digester tank for all options.
- Additional acid phase tank for 2-Phase digestion process
- Redundant mixing provided by standby pump and HEX recirculation pump for all options
- Dedicated or shared standby pumps for all options
- Additional heat exchanger (HEX) capacity and tank insulation will allow either alternative to operate in TPAD mode
- Digested sludge storage tank can be sized/configured to operate as a standby anaerobic digester

7.4.6 Digestion Alternatives Business Case Evaluations

7.4.6.1 Cost Estimates

Capital, annual running (O&M), repair and replacement (R&R), and risk and benefit costs were estimated collaboratively with IEUA staff for the three digestion alternatives described in this

chapter. The IEUA standard BCE template was used to develop comparative NPVs for digestion facilities constructed in 2022 and operating through 2045. Capital costs were developed for 2045 but also represents for 2060 costs since the number and size of equipment are the same for both 2045 and 2060 due to only a modest increase in solids loadings between 2045 and 2060.

The results of the BCE are based on the following assumptions:

- Capital cost for major equipment components were obtained from manufacturers.
 - MAD, 2-Phase: Covers recent quotes for 85-ft Tank. Digester mixing pumps based on a Vaughan Rotamix equipment quotation. Other equipment based on separate vendor data and past projects.
 - THP: Based on vendor data and recent/ongoing projects; Centrifuges based on Andritz quote for D7LL unit.
- O&M Costs:
 - Maintenance and operation assumptions were obtained from manufactures and previous projects.
 - Costs for energy consumption, water consumption, and polymer were obtained from the IEUA.
 - Labor costs and maintenance cost on an FTE basis were also provided by the IEUA.
- R&R Costs: Cost for repair and replacement were calculated based on service life of each equipment:
 - Valves: 10 years
 - Pumps, piping, and other small equipment: 20 years
 - Large equipment (digester covers, flares): 30 years
- Risk and Benefit: Benefits of dewatering from THP, and dewatering and gas production from 2-Phase digestion were included in this BCE.
- Life-Cycle Benefit/Cost Analysis: Based on NPV, which included an escalation rate = 3% and discount rate = 2%.

7.4.6.2 Business Case Evaluation Results and Analysis

Results of the BCE for the digestion alternatives under evaluation in this report are provided below in Table 7.4-12. All costs are in 2016 dollars. The full BCE spreadsheets are presented in Exhibit I of this Volume.

Alternatives	Capital (1)	O&M (2)	R & R (2)	Risk and (Benefit)	NPV
1 MAD	\$70,300,000	\$65,512,000	\$11,661,000	-	\$152,480,000
2 Two-Phase	\$61,100,000	\$72,986,000	\$12,947,000	(\$13,060,000)	\$135,010,000
3 THP	\$116,500,000	\$142,557,000	\$29,072,000	(\$26,136,000)	\$274,250,000

Table 7.4-12: Results of the Anaerobic Digestion Alternative Business Case Evaluation

(3) Capital costs shown are un-escalated 2016 dollars

(4) O&M and R&R costs shown are escalated and discounted back to 2016 dollars.

Alternative 1, MAD, represents the base case for VSR efficiency and biogas production and is historically the lowest case capital option but at higher operating costs compared to advanced digestion alternatives discussed previously in this report. Alternative 2, Two-Phase digestion, has a higher capital cost (by 5.5% compared to MAD) but which is offset by benefits of improved biosolids dewatering resulting in lower hauling costs and improved VSR and biogas production. Operational data collected by the IEUA indicates 2-Phase digestion has higher biogas production (16 ft³ per lb for VSR compared to 15 for MAD) and higher VSR (58% compared to 55% for MAD). The combination of these two factors resulted in a 12.1% increase in biogas production over MAD and resulted in NPV equivalent to MAD. Alternative 3, THP, has the highest capital and operating cost but with benefits including better dewaterability leading to less sludge being hauled to disposal. A sensitivity analysis was performed and determined that BCE results are not sensitive to typical variables across digestion technology alternatives.

7.4.7 Agency Decision and Preferences for the Approved Project Requirements

The purpose of this section is to document recent IEUA direction/preferences provided during the BCE workshop on August 11, 2016. These preferences will not impact the comparative decision making process provided through the BCE analysis.

Major items to be integrated into the final Approved Project Requirements include:

- Determine feasibility (capital and operating costs) of feeding FOG or FW to digesters.
- Evaluate digester facility phasing options to reduce capital expenditures for the initial project.
- Develop site layout alternatives for potential addition of future food waste, FOG, and SHF digestate.
- Determine phasing of thermophilic digestion capability; for example, determine if inclusion of equipment for thermophilic operation should be installed for the initial project or phased into a future project.
- Evaluate impact of configuring DS storage tank(s) as anaerobic digesters on the number and size of anaerobic digesters required for the initial project while meeting the 2060 buildout requirements.
- Evaluate the potential to optimize digester size and/or performance (i.e., longer SRTs, VSR exceeding 0.18 lb/ft³ loading criteria) by increasing thickening performance using RDTs to increase feed solids concentration to digestion (i.e., 5.5% instead of 5%, or potentially higher %TS).
- Evaluate digester mixing systems other than jet mixing system, including draft tube and gas mixing to determine the optimal mixing system for the 2-Phase anaerobic digestion process.
- Evaluate egg-shaped digester as an option to either silo or pancake shapes in terms of impacts to site layout, and capital and O&M costs. Include the potential effect of the high-voltage power lines running along the eastern boundary of the site. Safety issues for working near the power lines may present important constraints for using construction

7-38

cranes necessary for constructing tall digestion tanks, and their maintenance if/when cranes are needed.

• Evaluate surface withdrawal and additional cover options to address foaming issues.

7.4.8 Recommendation

Because of the IEUA's favorable experience with 2-Phase digestion, the improved biogas production and increased digestion efficiency, and the BCE results show 2-Phase equal to MAD, 2-Phase digestion is recommended. This recommendation was approved by the IEUA at the BCE workshop on August 11, 2016. To provide ability for future 3-Phase operation, the digestion system should be designed to be capable of either mesophilic or thermophilic operation.

7.5 EVALUATION OF RP-5 SOLIDS DEWATERING ALTERNATIVES

7.5.1 Introduction

This introductory section presents a project background, understanding and approach, and a list of solids dewatering alternatives evaluated using a BCE.

Based on the background of the project, the new solids treatment facility at RP-5 would consist of Thickening, Digestion, and Dewatering.

This section describes the BCE of three different alternatives for digested solids dewatering to arrive at the most cost-effective option.

The purpose of the BCE is to provide sufficient comparative information on costs, benefits, and risks of the alternatives to provide a sound basis for technology selection. Sizing, loading, process configurations, layouts, and costs are based on project parameters agreed on by the project team and Agency staff at the time of commencing the BCEs. Since evaluations of technologies and other important project conditions were conducted in parallel and results can impact the final configurations, refinement of the final selected alternative and costs will be conducted after the BCE and technology selection described in this chapter. This refinement will be reflected in the Approved Project Requirements document and integrated into the design final decisions made by the Agency on project phasing, final load decisions related to FW and FOG treatment, staff layout and configuration preferences, and other decisions subsequent to the BCE.

The following are the alternatives considered for dewatering:

- Centrifuge
- Belt Filter Press (BFP)
- Screw Press

7.5.2 Solids Feed Characteristics and Production

7.5.2.1 Solids Feed Characteristics

The solids feed characteristics from anaerobic digestion that may impact dewaterability are summarized in Table 7.5-1. Projected average values are provided to facilitate comparison of dewatering technologies.

Sludge Characteristics	Value
Nominal Sludge Composition, Total Dry Solids Weight Basis	Anaerobically digested blend of primary sludge, WAS, FW, and FOG
Total solids concentration, %TS	2.8
Volatile solids (VS), % dry mass basis	69
Temperature, deg F	85-100
Average pH	7

Table 7.5-1: Projected Dewatering Feed Characteristics

7.5.2.2 Solids Flows and Loads

Projections for the solids flows and loads from anaerobic digestion to dewatering for both the maximum month and annual average conditions have been developed. Table 7.5-2 provides a summary of these solids loads for 2025, 2045, and 2060.

Table 7.5-2: Dewatering Solids and Hydraulic Loading Projections

Loading Condition	2025	2045	2060
Maximum month solids loading, dry lb TS/day	56,700	84,200	90,400
Maximum month hydraulic loading, gpd @ 2.8 %TS	247,400	367,100	394,000
Annual average solids loading, dry lb TS/day	42,800	63,500	68,200
Annual average hydraulic loading, gpd @ 2.8 %TS	183,300	272,100	292,000

7.5.3 Solids Dewatering Technology Alternatives Descriptions

7.5.3.1 Centrifuge

A centrifuge is composed of two cylinders, rotating at slightly different speeds. In the outer cylinder, centrifugal force propels the heavier digested solids to the wall of the outer cylinder at accelerations of approximately 3,000 gravitational units (G's). Centrate, the remaining residual liquid, accumulates along the axis of rotation and is discharged over a concentric weir. The inner cylinder has a scroll encircling its outer surface. Because the inner cylinder rotates at a slightly slower rotational speed than the outer cylinder (the differential), the scroll moves along the inner surface of the outer cylinder, conveying the dewatered solids to a dewatering beach, and then to its discharge. The liquid centrate is conveyed via an overflow weir to a liquid drain. A picture of a dewatering centrifuge is presented below in Figure 7.5-1.



Figure 7.5-1: Dewatering Centrifuge Image courtesy of Alfa Laval



7.5.3.2 Belt Filter Press (BFP)

A BFP is a dewatering device that applies mechanical pressure to chemically conditioned sludge slurry sandwiched between two tensioned belts by passing those belts through a serpentine of decreasing-diameter rolls. The machine can be divided into three zones:

- Gravity zone: free-draining water is drained by gravity through a porous belt
- Wedge zone: solids are prepared for pressure application
- Pressure zone: medium and then high pressure is applied to the conditioned solids

The serpentine pathway of the belts also imparts shear to the compressed solids, further aiding in dewatering. A photograph of a typical BFP is shown in Figure 7.5-2.

Following conditioning with polymers, the sludge is first discharged onto a gravity section (analogous to a gravity belt thickener), where the free liquid drains through the filter cloth. In Figure 7.5-2, this section is located along the top of the BFP. The gravity belt can be a separate cloth with different porosity from the other belts (in a three-belt design), or it becomes either the top or bottom belt (two-belt design). The top and bottom belts envelop the gravity-drained sludge and feed it into a series of rollers that gradually compress the sludge, displacing the water.



Figure 7.5-2: Belt Filter Press

Image courtesy of Komline-Sanderson

The gravity belt section discharges thickened sludge into the wedge section, where the sludge is captured between the top and bottom belts prior to entering the wedge section. The belt/sludge/belt sandwich is then fed to the high-pressure zones. Multiple drive rollers, belt washers, and belt steering (tracking) rollers are provided within the BFP. Operational adjustments include feed rate, belt speed, belt tension, belt type, and wedge adjustment.

Polymer addition and polymer/sludge mixing also critical factors. Excessive turbulence downstream of polymer/sludge mixing can deflocculate the conditioned sludge, resulting in degraded solids capture and increased solids in the recycle stream. A flocculation tank is typically provided (see Figure 7.5-2) immediately upstream of the BFP gravity drainage section.

7.5.3.3 Screw Press

The screw press forces flocculated digested sludge through a porous drum with a flighted expanding shaft diameter screw. The screw press may be horizontal or inclined and works according to the dewatering principles of gravity and mechanical compression. The screw press drum is provided with opening spacing and sizing that can vary by manufacturer. The screw conveys the sludge slowly through the drum exerting increasing mechanical pressure as the screw shaft diameter increases. The screw speed is adjustable for operational flexibility. Back-pressure may be added by an adjustable discharge zone to further increase dewatering performance. An image of a typical screw press is presented in Figure 7.5-3.




Figure 7.5-3: Screw Press

Figure courtesy of FKC Co., Ltd.

7.5.4 Alternatives Screening

7.5.4.1 Screening Criteria

The dewatering technologies were initially screened to determine if all technologies meet IEUA minimum requirements using a pass/fail approach. A high level rating on a scale of 1 to 5 was also provided for criteria considered important and weighted averages computed. The results are provided in Table 7.5-3.

Dewatering Alternatives	Weight	Centrifuge	Belt Filter Press	Screw Press
Supports Treatment and End Use Objectives	Pass/Fail	YES	YES	YES
Meets Required Performance	Pass/Fail	YES	YES	YES
Proven Technology	Pass/Fail	YES	YES	YES
Acceptable Complexity	Pass/Fail	YES	YES	YES
Number of Units Required	5%	5	3	1

Table 7.5-3: Results of Initial Screening Evaluation

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 7: Evaluation of RP-5 Solids Treatment Alternative Technologies				
Record of US Municipal Installations for Similar Size Unit	5%	5	5	2
Cake Solids Concentration	15%	5	3	4
Solids Capture	10%	5	5	4
Polymer Dose	15%	2	4	4
Power Requirement	10%	1	3	5
Footprint	10%	5	3	2
Operations and Maintenance Impacts	10%	4	3	5
Operator Exposure (noise, sound, process)	10%	4	2	5
Odor Control	5%	4	2	4
Washwater Requirements – Impact to Secondary Treatment Process	5%	5	2	4
Wei	ghted Average	4	3.2	3.9

7.5.4.2 Screening Recommendation

All dewatering technology alternatives met the pass/fail criteria and advanced. The weighted average score was highest for centrifuge with screw press nearly equal and BFP about 20% lower.

7.5.5 Alternatives Development

7.5.5.1 Operating Schedule

The IEUA has requested that the initial BCE consider a dewatering operating schedule of 8 hours per day, 5 days per week. After Agency staff reviewed and provided feedback on the initial BCE results, the screw presses' operation was revised to 24 hours per day, 5 days per week. Operation of centrifuges and BFPs was not altered and assumed to be 8 hours per day, 5 days per week.

It is important that equipment availability is maximized with limited downtime for routine cleaning and maintenance of dewatering equipment. It is also important to have a redundant dewatering unit to ensure processing capacity during extended machine downtime for maintenance.

7.5.5.2 Digested Sludge Holding Tank

A minimum of 3 days of maximum month digested sludge storage will be provided upstream of dewatering to provide operational flexibility and eliminate the need for dewatering over holiday weekends. An additional benefit of dedicated digested sludge storage volume is the ability to help accommodate a digester volume expansion event if properly configured.

Digested sludge storage tank mixing will be provided to keep solids in suspension and digested sludge storage will be connected to the low-pressure digester gas management system. Minimum total digested sludge storage requirements are shown in Table 7.5-4 to provide 3 days of storage.

Loading Condition	2025	2045	2060
Maximum month	742	1,101	1,182
Average annual	550	816	876

Table 7.5-4: Digested Sludge Minimum Storage Requirement (3 days' storage)

a. Storage requirements are shown in 1,000 gallons.

Digested sludge storage configuration should consider redundancy in order to maintain storage during tank cleaning and maintenance. Two options are proposed for consideration and incorporation into the approved project requirements.

- Construction of 2 dedicated digested sludge storage tanks Storage tank diameter would
 match digester diameter with sidewall height adequate to provide a total combined storage
 of 3 days' maximum month digested sludge production. When additional digestion
 capacity is required, storage tank sidewall height could be raised to convert storage tank(s)
 to digestion service and new digested sludge storage could be constructed.
- Construction of 1 dedicated digested sludge storage tank Storage tank construction would match digester construction to provide a digester volume of storage, which exceeds the minimum digested sludge storage requirement. An adjacent digester would be configured to serve as back-up digested sludge storage during cleaning and maintenance of the digested sludge storage tank. When additional digestion capacity is required, the digested sludge storage tank could be converted and new digested sludge storage could be constructed.

7.5.5.3 Dewatering System Performance Requirements

The performance requirements shown in Table 7.5-5 will be used for the dewatering technology evaluation only. These design performance requirements will be refined based on IEUA objectives and related process selections during detailed design. Maximum month digested sludge was selected for the design basis with the understanding that 3 days of upstream digested sludge storage will be provided, the operating schedule may be extended slightly during peak digested sludge production and a full standby unit will be provided.

Performance Requirement	Value
Dewatering system solids processing capacity ^a , dry lb TS/hour	14,735
Dewatering system hydraulic processing capacity ^a , gpm	1,070
Desired minimum cake solids, %TS	24
Desired minimum solids capture efficiency, %	95

Table 7.5-5: Dewatering System Performance Requirements

a. Based on maximum month projection for 2045 and 8 hours/day, 5 day/week operating schedule.

7.5.5.4 IEUA Dewatering Technology Preferences

The IEUA defined several preferences for the dewatering technology, as follows:

- Minimum 95% solids capture favoring capability for higher solids capture. This is important to avoid recycling solids back through the plant and the associated costs and potential risks to secondary process performance and stability.
- Strong record of municipal installations of the same equipment model or similar in North America.
- Operator familiarity with equipment.



- Equipment repair downtime must be low. Manufacturer services facilities must be able to respond quickly and spare primary equipment components should be stocked at the facility or quickly available through a manufacturer exchange program.
- Capable of fully automatic operation with limited operator observation.
- Preference towards fewer dewatering units to limit maintenance requirements and complexity.
- Low equipment repair/component replacement frequency.
- Low daily maintenance and housekeeping requirement.
- Low operator exposure to odors and contact with biosolids.
- Low wash water requirements. High wash water flows would have negative impacts on the overall secondary treatment process; a criterion that is incompatible with process treatment objectives.

7.5.5.5 Alternatives Performance and Equipment Data

The performance and equipment data summarized in Table 7.5-6 was used as the basis for developing the dewatering technology BCE. It should be noted that the BFP and Screw Press do not meet the desired performance parameters. This is not considered a fatal flaw and the impacts of lesser performance will be evaluated as cost impact in the BCE.

Parameter	Centrifuge	Belt Filter Press	Screw Press
Operation Schedule	8 hour/day, 5 day/week	8 hour/day, 5 day/week	24 hour/day, 5 day/week
Number of units for year 2045, duty + standby	5+1	8+1	3+1
Unit Size	30-in bowl	2 meter	Dual 1,250-mm screws
Maximum Solids loading rate, lb/hr	3,500	2,000	2,000
Maximum Hydraulic loading rate, gpm	300	200	200
Cake solids concentration, %TS	24	18	20
Solids capture rate, %	95	95	90
Polymer dose, active lbs APS/dry ton solids	35	15	25
Washwater requirement, gpd per unit	5,000	60,000	17,000
Connected Power, hp per unit	250	20	15

Table 7.5-6: Dewatering Equipment Performance and Equipment Data

7.5.5.6 Subjective Equipment Considerations

Subjective considerations for the three dewatering technology alternatives were presented for consideration as part of the selection process and are provided below.

Centrifuge

Pros:

• Typically provides highest cake solids and solids capture of considered alternatives

- Enclosed process minimizes odors, room humidity, and housekeeping
- Moderate operator attention requirements (highly automated)
- High installed capacity to building area ratio
- Operator familiarity

Cons:

- Relatively high energy requirement
- Equipment vibration may require building structural additions
- Relatively high noise level
- Relatively high polymer use
- High rotational speed (> 2,500 revolutions per minute [rpm]) \rightarrow increased wear and maintenance particularly with high grit

Belt Filter Press

Pros:

- Relatively simple operation
- Relatively low energy requirement
- Relatively low polymer use
- High cake solids relative to alternatives when coupled with thermal hydrolysis

Cons:

- Relatively high housekeeping requirement
- Higher odor control flow requirement relative to other alternatives
- Higher wash water requirement relative to other alternatives and may require booster pumps
- Relatively high room humidity results in accelerated building wear
- Increased risk of sludge contact
- Higher potential operator health concerns
- Manual machine adjustment/optimization
- Increased safety risk due to exposed machine parts
- Lower cake solids concentration relative to other considered alternatives

Screw Press

Pros:

- Slow operational speed results in less wear and maintenance
- Relatively low polymer use
- Relatively low energy requirement
- Enclosed process minimizes odors, room humidity, and housekeeping
- Low operator attention requirements (highly automated)

Cons:

- Fewer municipal installations relative to centrifuges and BFPs
- Low hydraulic flow capacity relative to alternatives
- Lower solids capture than other considered alternatives

7-46

7.5.5.7 Redundancy Discussion

In order to provide redundancy for dewatering operations to maintain required capacity during extended maintenance events, one full standby dewatering unit along with all ancillary equipment will be provided. Supporting systems such as polymer, wash/spray water, conveyance and electrical will be designed to allow for operation of all dewatering units (including standby) to operate simultaneously in order to provide maximum operational flexibility in the event that plant operators decided to temporarily operate at a higher dewatering system throughput than the design basis.

A minimum of 3 days of upstream digested sludge storage is provided to eliminate the need for dewatering shifts during three day weekends and also to provide additional operational flexibility for the dewatering system.

7.5.5.8 Alternatives Sizing Results

Dewatering equipment for the three alternatives was selected and the number of units required was determined based on the design information presented in this chapter. Although the recommended number of units for 2045, digested sludge production is indicated in Table 7.5-6, fractional units are shown below to facilitate project phasing discussions. Results for centrifuge sizing are presented in Table 7.5-7 based on the IEUA's preliminary selection of this dewatering technology.

Table 7.5-7: Dewatering Centrifuge Equipment Number of Operating (Duty) Units

Parameter	2025	2045	2060
Maximum month loading	2.8	4.2	4.5
Average annual loading	2.1	3.2	3.4

7.5.5.9 Facility Layout

A centrifuge-based facility preliminary layout is provided in Chapter 2 of this volume. Dewatering facility preferences were summarized by IEUA staff and carefully considered during development of this layout.

7.5.6 Dewatering Equipment Business Case Evaluation

This section presents the evaluation of dewatering equipment, including a summary of BCE results.

7.5.6.1 Evaluation Process

In addition to the screening step described previously, inputs and assumptions for evaluation of dewatering equipment were developed collaboratively with IEUA staff. The IEUA standard BCE template was used to develop comparative NPVs for dewatering facilities constructed in 2022 and operating through 2045.

7.5.6.2 Business Case Evaluation Results and Analysis

Results of the BCE are provided below in Table 7.5-8. All costs are in 2016 dollars. The full BCE spreadsheets are presented in Exhibit I of this Volume.

Alternative	Capital (1)	O&M (2)	R & R (2)	NPV
Centrifuge	\$64,300,000	\$104,419,000	\$2,060,000	\$174,860,000
Belt Filter Press	\$72,000,000	\$84,277,000	\$2,116,000	\$192,880,000
Screw Press	\$57,500,000	\$113,039,000	\$3,488,000	\$177,640,000

Updated Table 7.5-8: Results of the Business Case Evaluation

(5) Capital costs shown are un-escalated 2016 dollars

(6) O&M and R&R costs shown are escalated and discounted back to 2016 dollars.

Centrifuge dewatering has the lowest O&M and R&R costs and results in the overall lowest NPV. Screw press dewatering has the lowest capital, the highest R&R costs, and results in the marginally higher NVP when compared to the centrifuge dewatering alternative. Given the accuracy of the BCE at this level of design, centrifuge and screw press dewatering alternatives can be considered equivalent.

A sensitivity analysis was performed and determined that BCE results are not sensitive to typical variables across dewatering technology alternatives. Significant changes to power, polymer, and dewatered sludge disposal costs will not result in a significant change to the BCE outcome.

The primary BCE influencers were:

- Dewatered sludge disposal cost of \$53/wet ton at composting facility plus hauling costs
- Higher capacity per unit of centrifuges results in fewer units required and lower space requirement
- Higher capacity-to-space requirement of centrifuges results in lower space requirement

7.5.7 Agency Decisions and Preferences for the Approved Project Requirements

The purpose of this section is to document recent IEUA direction/preferences provided during the BCE workshop on August 11, 2016. These preferences will not affect the comparative decision-making process provided through the BCE analysis. The impact on the dewatering equipment size, number, layout, and cost will be evaluated at the next detailed design phase of the project.

Major items to be integrated into the final Approved Project Requirements include:

- Determination of FOG or FW feed to digesters
- Evaluation of digester facility phasing to manage capital expenditures
- Site planning for potential addition of future FW, FOG, and SHF digestate
- Evaluation of digested sludge storage tanks as one larger tank that could be used as sludge storage or serve as a future digester
- Dewatering building layout refinements, such as moving the polymer system to the second floor, to accommodate Agency preferences
- Integration of a long term maintenance agreement into the procurement process
- Consideration of alternative cake conveyance systems

7.5.8 Recommendations

Based on the BCE results and further discussion of non-cost-related considerations with the Agency, it is recommended to make a selection between centrifuge and screw press dewatering alternatives. A few potential considerations are outlined below.

Centrifuges:

- IEUA staff is familiar with centrifuge equipment
- Centrifuges are sized based on 8-hour operation; however, they can operate longer hours in a given day if required during higher loading periods
- Relatively high noise level for centrifuges

Screw presses:

- Using a 24-hour-per-day operating schedule may require more upstream digested sludge storage, more dewatering units, or more dewatering hours during periods of high solids production
- Since units are sized for 24-hour operation, there is less flexibility to "catch up" on sludge inventories during higher loading periods
- Fewer municipal installations relative to centrifuges
- Lower solids capture than centrifuge
- Potential struvite buildup may degrade performance of the screws overtime and will require additional maintenance

7.6 EVALUATION OF RP-5 GAS STORAGE AND WASTE GAS FLARES

7.6.1 Introduction

This introductory section presents project background as well as and understanding and approach for digester gas storage and waste gas flare alternatives.

Biogas generated by the anaerobic digestion process at RP-5 will be captured, conveyed, and used beneficially for energy recovery and reduction of greenhouse gas (GHG) emissions. The digester gas management system is composed of gas piping, controls, storage, conditioning, utilization, and safety equipment. This section focuses on the gas storage and waste gas flare components of the gas management system.

Digester gas production is variable depending on changes in organic loading and operating conditions. The role of gas storage is to help facilitate smooth operation of gas system equipment and to maximize conversion of digester gas to energy. When digester gas production exceeds what can be used or stored, or if utilization equipment is out of service, waste gas flares are used to combust excess gas to reduce GHG emissions and meet air permit requirements.

7.6.1.1 Digester Gas Storage

This section includes a comparison of gas storage technologies, screening of candidate options, and capital cost comparison for a range of gas storage volumes. Design of biogas storage is integral to the evaluation of gas utilization alternatives. Therefore, the design gas storage volume and complete life-cycle cost considerations for gas storage are to be incorporated into the BCE for the digester gas utilization BCE (Chapter 9). This evaluation was conducted before the gas utilization evaluation was completed. Therefore, the exact volume of gas storage needed to optimize gas utilization equipment operation was not available. A range of gas storage volumes was considered for the comparison. It is assumed this approach will be sufficient for preliminary recommendations on gas storage volumes and technology selection.

7.6.1.2 Waste Gas Flares

Waste gas flares are required ancillary anaerobic digestion equipment used for safely wasting excess digester gas and to meet air permitting regulations. The type of flare required is dependent on the selected anaerobic digestion process configuration, which impacts the characteristics of the digester gas. This section includes a comparison of flare technologies that cover all of the digester process configuration alternatives being considered in Section 7.4: conventional MAD, 2-Phase, and THP. Because the type of flare(s) required will depend on the selected digestion alternative, the life-cycle costs of the flares are incorporated into the digestion BCE (Section 7.4).

7.6.2 Biogas Characteristics and Production

Table 7.6-1 contains the biogas system basis of design criteria. This is based on the plant solids, FW, and FOG loadings established in the solids mass balance. The design capacity for waste gas assumes all of the gas produced has to be sent to the flares. A peaking factor of 1.5 is applied to the peak day gas production to account for instantaneous peaks.

Table 7.6-1: Biogas System Basis of Design

Parameter	Unit	Value
Biogas Production (average day, 2045)	scfm	950
Biogas Production (peak day, 2045)	scfm	1,400
Gas Peaking Factor (waste gas)	-	1.5
Max Design Biogas to Flares (2045)	scfm	2,100

7.6.3 Gas Storage Purpose and Criteria

7.6.3.1 Introduction

Biogas storage is one component of the digester gas management system. The purpose of gas storage is to help facilitate smooth operation of gas utilization equipment and to maximize conversion of digester gas to energy. Digester gas production is variable, but utilization equipment operates best with a steady supply of gas. Storage effectively dampens the variation in the digester gas production rate. Gas storage can also provide a control signal from which the entire gas handling and utilization systems can be operated.

As an alternative to (or in addition to) gas storage, variations in digester gas production can be accounted for by blending with natural gas to achieve a steady supply to the gas utilization equipment.

7.6.3.2 Design Criteria for Biogas Storage

The design criteria for sizing biogas storage are set by the functional requirements of the gas utilization equipment. These criteria include typical diurnal gas production values, target percentage of biogas captured for utilization (not flared), gas system operating pressure, and the operating philosophy/method for controlling the gas utilization equipment. These criteria are still under development and will be covered in the digester gas utilization and BCE in Chapter 9. The technology evaluation in this chapter is based on typical gas system operating pressures. A range of storage volumes are considered.

7-50

7.6.4 Biogas Storage Technologies

7.6.4.1 Flexible Membrane

Dual-membrane gas holding systems have been used in the industry for nearly 20 years. These systems hold biogas at low pressures, between 6 inches water column (inches w.c.) to 16 inches w.c. The dual-membrane systems consist of an outer membrane that maintains a consistent dome shape, while the inner membrane moves depending on gas storage requirements. The space between the inner and outer membranes is kept pressurized using small, ambient air blowers in conjunction with pressure-release valves.

Dual-membrane gas holders can be installed on top of a digester tank or directly on the ground. A ground-mounted gas holder has a third ground membrane that provides a gas-tight connection along the bottom of the holder. The ground membrane is typically positioned on top of a concrete slab or in some installations directly on compacted fill.





Left – Ground-Mounted Dual Membrane Storage Schematic / Right – Photo of Digester Cover Mounted Membrane Storage

Membranes installed on top of digester tanks are at an increased risk of failure due to rapid volume expansion or foaming events which can plug gas piping and lead to over-pressurizing the membrane. Installing the membrane on a separate slab mitigates this risk by completely decoupling the gas storage from the operation of the digestion system. Alternatively, the membrane can be installed on a digested sludge storage tank. These tanks store biosolids that have already been stabilized by the digestion process and are therefore much less likely to experience a foaming event that could plug gas piping.

7.6.4.2 Floating Gas-Holder Digester Cover

The floating gasholder cover is ballasted to balance the buoyant forces of the digester fluid, the cover weight, and the gas dome pressure. This cover is similar to the standard floating cover with the addition of an extended skirt to permit digester gas storage within the void created by the added skirt length.

This type of system has several major disadvantages: the gas/liquid interface is across the entire surface area of the digester; it has a high internal corrosion potential; it has a high capital cost relative to other cover types; and the volume of space to be purged to take the digester out of service is higher than that of other systems. The taller dome makes safe sampling of the digester contents and maintenance of the pressure/vacuum relief devices difficult. Gasholder covers do not allow use of roof-mounted mechanical draft tube mixers. These covers can also require additional wind load protection.




Figure 7.6-2: Digester Gas-Holder Covers

Left - Photo of Floating Gas-Holder Covers / Right - Cutaway Schematic of Floating Gas-Holder Cover

7.6.4.3 Dry-Seal Gasholder

The dry-seal "Wiggins" type gasholder uses an internal membrane to contain the stored biogas. The main elements of this gas holder are the foundation, the main tank, the piston and the sealing membrane. The gas enters the holder from beneath the piston which floats on the internal gas pressure. The gas holder piston moves up and down inside the tank as gas enters and exits. The weight of the piston produces the pressure at which the gas holder is designed to operate. A mechanical counterbalance system of weights and pulleys works to ensure that the pistons moments are kept in equilibrium. The level of the piston/membrane provides a reliable control signal for management of the digester gas system. The maximum operating pressure for a dry-seal gasholder is typically limited to 14 inches w.c.




Figure 7.6-3: Dry-Seal Gasholder

7.6.4.4 Wet-Seal Gasholder

Wet-seal digester gas holders consist of an outer shell, inner piston, water seal, and stabilizing system. It operates on the same principle as a floating gas-holder digester cover; as gas enters/leaves the headspace of the tank, the ballasted cover rises and falls to accommodate the change in gas volume while maintaining a constant gas pressure. Wet-seal gasholders are generally larger than a dry seal with equivalent active gas storage because of the volume of water in the tank. The wet-seal gasholders have the ability to operate at slightly higher pressures than the dry-seal gasholders.




Figure 7.6-4: Wet-Seal Gasholder

7.6.4.5 High Pressure Gas Storage

High-pressure gas storage consists of a steel structure designed for storing high-pressure gas downstream of blowers to provide buffering to downstream gas utilization equipment. Typically, these are either spheres or cylindrical tanks. A standard design is constructed with ¹/₄-in-thick ASTM SA516 A36 steel material, which is suitable for operating pressures at up to 75 pounds per square inch gage (psig). Digester gas spheres can be designed for higher pressures at higher costs.

Storing at high pressure does nothing to address the variability in digester gas production upstream of gas blowers. Other disadvantages of high-pressure gas storage include corrosion concerns, higher energy demand, and safety issues with pressurized gas.



Figure 7.6-5: High-Pressure Gas Storage

Left – Photo of Storage Sphere / Right – Photo of Horizontal Cylinder Storage Tanks

7.6.5 Gas Storage Alternatives Screening

7.6.5.1 Introduction

The technologies described above were evaluated at a high level and given quantitative scores and weighting factors in order to screen the alternatives for more detailed analysis.

7.6.5.2 Screening Criteria

Screening criteria for digester gas storage alternatives included four pass/fail criteria and five quantitative criteria and are included in Table 7.6-2.

Criteria	Туре	Description
Supports Treatment and End-Use Objectives	Pass/Fail	Contributes to the objective of providing an adequately steady supply of gas for beneficial use.
Meets Desired Performance	Pass/Fail	Proven ability to reliably store biogas within the digester gas pressure operating range (for low pressure) or compressed at up to 75 psig (for high pressure).
Provides Proven Technology	Pass/Fail	Technology has been proven reliable for more than 10 years in plants of comparable size - not emerging, research, or pilot technologies.
Provides Acceptable Complexity	Pass/Fail	Technology does not require extraordinary expertise or resources unreasonably beyond traditional operations and maintenance resources currently employed.
Capital Cost	Quantitative $(1-5)$	Relative capital cost of alternatives. 5 is least expensive and 1 is most expensive.
O&M Requirements	Quantitative $(1-5)$	Ease of O&M, cost of O&M, frequency of replacement/maintenance. 5 has lowest O&M impact/cost, 1 has the highest.
Footprint	Quantitative $(1-5)$	Impact on site layout. 5 is lowest impact and 1 is greatest impact.
Safety Impacts	Quantitative $(1-5)$	Impacts to safety including safe access to equipment for O&M, reliability of gas seals, pressurized gas, etc. 5 has the lowest impact to safety, 1 has the highest.
Process Control	Quantitative $(1-5)$	Ability to produce a reliable control signal for digester gas management. 5 has the most reliable/robust control, 1 has the least.

Table 7.6-2: Gas Storage Screening Criteria

7.6.5.3 Screening Results

The results for the gas storage screening are included in Table 7.6-3.

Gas Storage Alternatives	Weight	Membrane (Digester)	Membrane (Ground)	Gas-holder Cover	Dry Seal	Wet Seal	High Pressure
Supports End-Use Objectives	Pass/Fail	YES	YES	YES	YES	YES	YES
Meets Required Performance	Pass/Fail	YES	YES	YES	YES	YES	YES
Proven Technology	Pass/Fail	YES	YES	YES	YES	YES	YES
Acceptable Complexity	Pass/Fail	YES	YES	YES	YES	YES	YES
Relative Capital Cost	25%	5	5	3	2	1	2
O&M Requirements	25%	2	2	2	4	4	1
Footprint	15%	4	2	4	2	2	3
Safety Impacts	20%	1	3	2	4	4	2
Process Control	15%	2	2	4	5	5	3
Weighte	d Average	2.9	3.0	2.9	3.4	3.1	2.1

Table 7.6-3: Gas Storage Screening Results

7.6.5.4 Screening Recommendation

Based on the scores of the screening criteria for the digester gas storage alternatives, we recommend comparing the dry-seal gasholder (which received the highest score) with the slabmounted flexible membrane (the lowest-cost option). The digester cover options (membrane and floating gasholder cover) are not compatible with the type of covers being considered for the digestion system, and the wet-seal gasholder is more expensive than the dry seal for the same amount of storage volume. The flexible membrane cover is also an option if installed on digested sludge storage tanks, as foaming/volume expansion impacts are of less concern.

7.6.6 Gas Storage Alternatives Comparisons

7.6.6.1 Capital Costs

Capital costs for four different storage volumes are presented in Table 7.6-4.

Volume of Gas Storage (ft ³)	Dry-Seal Gasholder	Slab-Mounted Membrane
30,000	\$2,800,000	-
50,000	\$3,800,000	\$1,000,000
90,000	\$5,300,000	\$1,300,000
250,000	-	\$2,000,000

Table 7.6-4: Gas Storage Capital Cost Comparison

7.6.6.2 Operating and Maintenance Considerations

Operation and maintenance considerations for the dry-seal gasholder and membrane gas storage options are presented in Table 7.6-5.

Table 7.6-5: Gas Storage O&M Considerations Comparison

O&M Consideration	Dry-Seal Gasholder	Membrane (slab-mounted)
Operation – pressure control	Provides inherent constant pressure through ballast of internal piston	Blowers/controls used to maintain a pressure setpoint
Operation – control signal for gas management	Provides reliable/simple control signal via gasholder level	Membrane manufacturers use ultrasonic, infrared, or mechanical gauge to calculate estimated volume of stored gas
Energy	No power requirements	Blowers required to pressurize space between membranes
Maintenance	Inspect once/5 yrs – requires nitrogen purge Recoat or repair seals as needed	Inspect annually Blower maintenance Membrane repairs Periodic purging of methane between membranes
Replacement Costs	Recoating of tank and repairs/replacement of internal seal Long life for steel tank	Replacement cost is usually almost equal to the cost of a new installation Lifespan 10 years to 15 years (failures have occurred sooner)
Safety	Robust steel tank	Membrane failure possible

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 7: Evaluation of RP-5 Solids Treatment Alternative Technologies			
O&M Consideration	Dry-Seal Gasholder	Membrane (slab-mounted)	
	Headspace above piston is atmospheric conditions Gas monitor for leak detection	Methane accumulation between membranes requires purge to prevent explosive conditions	

7.6.7 Gas Storage Summary

7.6.7.1 Conclusions

The comparison of gas storage alternatives suggests the following:

- Dry-seal gasholders received the highest score of the gas storage technologies evaluated on a screening-level basis.
- Dry-seal gasholders were compared to flexible membranes on capital cost and O&M considerations:
 - Flexible membrane gas storage has the lowest capital cost on a \$/ft³ basis.
 - Dry-seal gasholders offer superior O&M characteristics over membranes, including constant gas pressure, reliable and simple control of the gas system using gasholder level, and no power requirements for blowers.
- This evaluation was conducted before the gas utilization evaluation was completed. Thus, the exact volume of gas storage needed for gas utilization equipment operation was not available. A range of gas storage volumes was considered for the comparison of dry-seal gasholder and flexible-membrane storage options. It is assumed this approach will be sufficient for preliminary recommendations on gas storage volumes and technology selection.

7.6.7.2 Gas Storage Recommendations

Based on the evaluation provided, the following preliminary recommendations are provided:

- At RP-5, installation of one small dry-seal gasholder for low pressure gas storage is recommended to set a constant gas pressure on the gas system and to provide a reliable control signal (gasholder level) for gas system operation. This tank will have approximately 30,000 ft³ of gas storage and a 35-ft diameter.
- At RP-5, installation of one large slab-mounted flexible membrane is recommended for additional gas storage volume required beyond what is provided by the dry-seal gasholder. The dry-seal gasholder is more expensive on a \$/ft³ basis, but can provide better O&M characteristics even with a relatively small volume. Additional gas storage volume will be provided with the more cost-effective flexible membrane. Preliminary recommendation is for approximately 90,000-ft³ membrane with an outside base diameter of 60 ft.
- The total capital cost in 2016 dollars for these gas storage recommendations at RP-5 is \$4.1 million.
- Once the gas utilization evaluation has been completed, it is recommended that the volumes of gas storage are revisited and optimized.

7.6.8 Waste Gas Flare Purpose and Criteria

Waste gas flares are required ancillary anaerobic digestion equipment used for safety wasting excess digester gas and to meet air permitting regulations. The type of flare required is dependent on the selected anaerobic digestion process configuration, which impacts the characteristics of the digester gas. This section includes a comparison of flare technologies that cover all of the digester process configuration alternatives being considered: conventional MAD, 2-Phase, and THP. Because the type of flare(s) required will depend on the selected digestion alternative, the life-cycle costs of the flares are incorporated into the digestion BCE (Section 7.4).

The design criteria for the waste gas flares are presented in Table 7.6-6.

Parameter	Unit	Value
Biogas Production (average day, 2045)	scfm	950
Biogas Production (peak day, 2045)	scfm	1,400
Gas Peaking Factor (waste gas)	-	1.5
Max Design Biogas to Flares (2045)	scfm	2,100
Flare Basis of Design Model	-	Varec 244E (Enclosed Type)
Flare Size (gas inlet connection)	in	12
Number of Flares	-	2
Flare Capacity, each (11-in w.c. inlet pressure)	scfm	1,050
Destruction Efficiency	%	> 99.0
Max Design Acid-Gas to Thermal Oxidizer (2045) (for 2-Phase option only)	scfm	110
Number of Acid-Gas Thermal Oxidizers (for 2-Phase option only)	-	1
H ₂ S Concentration at Flare/Thermal Oxidizer	ppm	40

Table 7.6-6: Waste Gas Flare Design Criteria

The flares must be sized to handle the peak gas production when all utilization equipment is out of service, but also to handle small amounts of gas when production exceeds utilization and storage capacities (aka: "trim"). For this reason, two flares are needed to turn down for the lower trim gas flows while still meeting the maximum case capacity.

The 40 ppm H₂S concentration to the flares is a universal requirement that will be achieved by an H₂S removal system for each process configuration/flare technology discussed.

7.6.9 Waste Gas Flare Technologies

7.6.9.1 Candlestick

Candlestick flares are very common at WWTPs. They are an older technology and are the least efficient combustion technology among flares and thermal oxidizers. See Figure 7.6-6 for a photo of candlestick flares. Of all options they have the greatest loss of unburned digester gas (up to 10% in high wind conditions) and contribute a large GHG emission.



Figure 7.6-6: Candlestick Waste Gas Flares

7.6.9.2 Enclosed

Enclosed flares are becoming more prevalent at WWTPs. Enclosed flares have no visible flame and have very low emissions relative to open/candlestick flares. Because these flares are enclosed they are protected from wind and maintain a stable flame. Combustion efficiencies are generally 98% to 99%. See Figure 7.6-7 for photos of enclosed flares.



Figure 7.6-7: Enclosed Waste Gas Burners

7.6.9.3 Thermal Oxidizer

Thermal oxidizers are the most complex option for combusting a waste gas stream. These are typically only considered at WWTPs for extremely low quality gas streams with high volatile organic compounds (VOCs) and hazardous air pollutants (HAPs). Thermal oxidizers maintain a high temperature in a designed combustion chamber. Some configurations of thermal oxidizers include heat recovery systems to increase the efficiency of the efficiency of the system and reduce auxiliary fuel consumption. Thermal oxidizers may also require a combustion air blower to get enough oxygen into the combustion reactor.

Thermal oxidizers will only be considered as a feasible option for the 2-Phase digestion process alternative, which generates a low British thermal unit (BTU), high H₂S waste gas from the first-stage acid reactors.

7.6.10 Waste Gas Flare Alternatives Screening

Candlestick flares are not a modern technology and may have issues meeting California Air Quality Standards/permit requirements in the South Coast Air Quality Management District (SCAQMD). It is sensible to screen out candlestick flares from further evaluation given industry trends and to mitigate the risk of permitting/compliance issues.

7.6.11 Waste Gas Flare Alternatives Comparison

The type/configuration of the waste gas flares is dependent on the selected digestion process alternative. For this reason, the flare configurations are assigned to specific digester process options as shown in Table 7.6-7.

Flare Configuration	MAD or THP	2-Phase
2 Enclosed Flares	YES	YES (if acid and gas phase reactor gas streams are combined or an assist gas is used)
1 Thermal Oxidizer + 2 Enclosed Flares	NO	YES

Table 7.6-7: Waste Gas Flare Configurations for Digestion Alternatives

Two enclosed flares will be the basis of design for the MAD and THP digestion alternatives (Chapter 8). This will require a single H_2S removal system for the digester gas with a target outlet concentration of 40 ppm. The basis for this system will be iron sponge, which is what is used at other IEUA digestion facilities.

For the 2-Phase alternative there are three possible options:

- 1. Two enclosed flares combine the acid-phase and second-stage gas streams so that they can be combusted together in an enclosed flare when needed.
- 2. Two enclosed flares designate one enclosed flare for the acid phase waste gas and use an assist gas to allow continuous combustion of the low-BTU acid gas.
- 3. One thermal oxidizer and two enclosed flares the thermal oxidizer will be designated for the acid phase waste gas. A combustion air blower will be required.

Each of the options for the 2-Phase alternative will require an H_2S removal system. For the first alternative where the gases are combined, a single iron sponge system is required. For the second and third alternatives, two separate H_2S systems will be needed – one for the acid-phase gas and one for the second-stage gas. These systems will be both be based on iron sponge, which are used at other IEUA digestion facilities.

The O&M considerations for each of these alternatives are summarized in Table 7.6-8.

O&M Consideration	Two Enclosed Flares	Two Enclosed Flares (one with assist gas)	One Thermal Oxidizer and Two Enclosed Flares
Complexity	Low – standard enclosed flare operation with no assist gas needed	Low – digester or natural gas needed to assist in combustion of acid-phase gas	High – more mechanical complexity. Combustion air blower and heat recovery equipment
Maintenance	Few components requiring maintenance	Few components requiring maintenance	More maintenance needed for combustion blower and additional H ₂ S removal system.
Operating Cost	Low – low maintenance, no electrical loads, no assist gas	High – natural gas purchase or use of gas- phase gas to combust the acid-phase in an enclosed flare	Medium – low/no assist gas needed, but electrical load for combustion air blower and increased maintenance costs.
Other Considerations	Feasibility concerns with achieving blend of acid/gas phase. Peaks of high H ₂ S gas from acid- phase may impact gas blowers and H ₂ S removal equipment.	Separate combustion of acid-phase gas improves quality of second-stage gas for conditioning and utilization.	Separate combustion of acid-phase gas improves quality of second-stage gas for conditioning and utilization.

Table 7.6-8: Two-Phase Waste Gas O&M Considerations

7.6.12 Waste Gas Flare Preliminary Summary

For the purposes of evaluating the digestion alternatives (Chapter 8), the THP and MAD alternatives will assume two enclosed flares, and the 2-Phase alternative will assume two enclosed flares with a thermal oxidizer to handle the acid-phase gas. The capital cost of these flare configurations are provided in Table 7.6-9.

Two Enclosed Flares	Two Enclosed Flares + Thermal Oxidizer (2-
(MAD and THP)	Phase)
\$2,000,000	\$2,700,000

Table 7.6-9: Waste Gas Flare Capital Costs

7.6.12.1 Waste Gas Flare Preliminary Conclusions

The comparison of waste gas flare alternatives suggests the following:

- Two enclosed flares are the basis of design for waste gas combustion. Open flares are not suitable for the permit requirements in the SCAQMD.
- The acid-gas produced in the 2-Phase digestion alternative can be handled with an additional thermal oxidizer, by combusting it in an enclosed flare with an assist gas, or by combining it with the second-stage gas system. The digestion evaluation assumes a thermal oxidizer will be provided in addition to the two enclosed flares.
- An H₂S treatment system is required to reduce concentrations to 40 ppm at the flares/thermal oxidizers. A single system will be required for MAD and THP digestion alternatives. Two separate systems will be needed if the acid-gas from the 2-Phase alternative is kept separated.

7.6.12.2 Waste Gas Flare Preliminary Recommendations

Based on the evaluation provided, the following preliminary recommendations are provided:

- At RP-5, installation of two enclosed flares to handle the digester gas is recommended. This will meet both the peak waste gas condition and trimming of small gas volumes that exceed the utilization and storage capacities. The capital cost in 2016 dollars for these flares is \$2 million.
- If 2-Phase is the selected digestion alternative for RP-5, additional considerations are required for the acid-phase gas. Installation of an additional thermal oxidizer is the preliminary recommendation to flare the acid-phase gas, but the options discussed in Section 7.6.7.5 for handling this gas should be evaluated in greater detail during detailed design. The capital cost in 2016 dollars for the thermal oxidizer with the enclosed flares is \$2.7 million.
- At RP-5, installation of H2S removal upstream of flares will be required to meet SCAQMD Title V air permit requirements. Iron sponge is suitable and is recommended based on IEUA's experience with the technology, but additional investigation will be required once the digestion alternative and handling of the acid-gas are decided upon.

7.6.13 Agency Decisions and Preferences for the Approved Project Requirements

The purpose of this section is to document recent IEUA direction/preferences provided during the BCE workshop on August 11, 2016, that are not included in this evaluation but deferred to the approved project. This evaluation would only be updated to address minor comments that would have the potential for affecting the technology selection. The impact on the gas storage and flare equipment size, number, layout, and cost will be evaluated at the next detailed design phase of the project.

Major items to be integrated into the final Approved Project Requirements include:

• Evaluation of safety impacts on location of high-voltage power lines in proximity to digester gas storage site location for the approved project

7-62

- Evaluation of iron sponge, carbon-based, and biological removal technologies to meet H₂S requirements for waste gas flares and gas utilization
- Selection of final gas utilization alternative and gas storage volume optimization as part of final sizing and configuration
- Evaluation of flexible-membrane gas storage mounted on top of a digested sludge storage tank instead of separate slab for conserving site layout
- Elimination of FOG or FW feed to digesters
- Digester phasing and appropriate gas system sizing to match phases
- Potential addition of food waste, FOG, and SHF digestate in the future
- Thermophilic and mesophilic digestion flexibility, including inclusion of equipment for thermophilic operation and the potential need for gas chilling and moisture removal with thermophilic operation

7.6.14 Subsequent Evaluation of Waste Gas Flares

Following the preliminary waste gas flare screening above, a more detailed evaluation of the available flaring options was performed. Additional data was gathered in regard to regulatory emissions requirements and gas production data was updated following subsequent meetings and workshops with the Client.

7.6.14.1 Regulatory Emissions Requirements

The RP-5 facility is under the jurisdiction of the SCAQMD, the air pollution control agency for the IEUA. Prior to construction, biogas elimination and the resulting emissions must be reviewed and approved by the SCAQMD.

With the expected quantity of biogas production of the RP-5 solids digestion method, the facility is defined as a "Major Source" according to Title V as adopted and modified by the SCAQMD from the EPA.

As a Major Source the waste gas process emissions will need to meet either the Best Available Control Technology (BACT) or the Lowest Achievable Emission Rate (LAER). BACT or LAER determination is on a case-by-case basis by the SCAQMD. For the purpose of this evaluation, it was determined that the flares at the RP-5 facility must meet LAER for criteria pollutants as defined below.

Criteria Pollutant	Emission Factor (lb/MMBTU)	Emission Factor (ppm)
NOx	0.025	19
СО	0.06	75
VOC Destruction Efficiency	> 99%	N/A

Table 7.6-10: Waste Gas Flare Emissions Requirements

Due to the stringent criteria pollutant limits of LAER, a standard enclosed flare will not meet emissions requirements. Ultra-low emissions enclosed flares were the next flaring technology evaluated against the expected emissions requirements and thermal oxidizers.

7.6.14.2 Description of Approved Waste Gas Flare Technology

Ultra-low emissions enclosed flares have a similar configuration to standard enclosed combustion flares in regard to the flaring section with an enclosed tower that promotes flame stability. Where the ultra-low emissions flare differs is the addition of specialized combustion air blowers and an extended fuel/air pre-mixing section upstream of the flare to ensure a consistent homogenous air/fuel mixture. These blowers bring in additional air that is blended with the biogas prior to combustion resulting in lower emissions of criteria pollutants.



Figure 7.6-8: Ultra-Low Emission Enclosed Gas Flare

Image courtesy of John Zink

7.6.14.3 Updated Design Criteria for Waste Gas Flares

Design criteria for flare type and sizing are set by calculated biogas production and regulatory emissions requirements. The flares are sized to handle the peak design gas production when all other utilization equipment is out of service, but also to handle small amounts of gas when production minimally exceeds utilization. For this reason, two independent flares, of differing sizes and capacities, are needed to turn down for the lower gas flows while still meeting the maximum case capacity.

Updated biogas design criteria for the waste gas flares are presented below in Table 7.6-11. Note that these criteria supersede the data in Table 7.6-6 and were refined from subsequent meetings and discussions with the Client.



Table 7.6-11 Updated Biogas Design Criteria

Parameter	Unit	Value
Biogas Production, average day (2045)	scfm	530
Biogas Production, peak day (2045)	scfm	965
Gas Peaking Factor (waste gas)		1.5
Design Biogas to Flares, maximum (2045)	scfm	1,450
Design Acid-Phase Gas, maximum (2045)	scfm	100
Treated Biogas H ₂ S Concentration to the Flares	ppmv	40
Methane Concentration in Thermophilic Gas	% mole	~60
Methane Concentration in Acid-Phase Gas	% mole	13-25

The 40-ppm H_2S concentration to the flares is a plant-wide air quality requirement that will be achieved by an H_2S removal system for each process alternative discussed.

7.6.15 Updated Description of Waste Gas Flare Alternatives

7.6.15.1 Introduction

A further analysis of waste gas flare alternatives given updated criteria has ultimately four alternative methods for the burning of waste gas. These various configurations included: H_2S removal, gas pressurization, and the waste gas burning technology. The evaluated alternatives are as follows.

7.6.15.2 Alternative 1A: Combined Acid-Phase and Digester Gas Streams with Duplex Treatment

This alternative mixes or combines both gas streams prior to H_2S removal and flaring. Under normal operating conditions, the acid-phase gas will be flared as needed with a small amount of digester gas as a supplement to meet the flare's stable fuel combustion requirements.




Figure 7.6-9: Schematic of Waste Gas Flare Alternative 1A

7.6.15.3 Alternative 1B: Combined Acid-Phase and Digester Gas Streams with Merged Treatment

This is similar to the above except that the gas streams mix prior to a H₂S removal system. Flares only operate if there are excess gas flows or if gas utilization is out of service. Under normal operating conditions, the blended gas, containing acid-phase, and digester gas will be beneficially utilized.




Figure 7.6-10: Schematic of Waste Gas Flare Alternative 1B

7.6.15.4 Alternative 2: Separate Gas Streams - Acid-Phase Gas to Thermal Oxidizer and Excess Digester Gas to Flares

The acid-phase gas will be piped to and eliminated by a thermal oxidizer. To protect various operating components of the thermal oxidizer, including the combustion air recuperator or heat exchanger, a siloxane removal system is included. As a prerequisite for this, a moisture removal system with a chiller is included to protect the siloxane removal media. Natural gas will supplement the thermal oxidizer both to pre-heat and maintain heat in the combustion chamber, as needed.

The digester gas flares are used only when there is excess gas flow or if the gas utilization system is out of service.




Figure 7.6-11: Schematic of Waste Gas Flare Alternative 2

7.6.15.5 Alternative 3: Separate Gas Streams - Acid-Phase and Excess Digester Gas to Separate Flares

Acid-phase gas will be combusted by a single flare. The digester gas flares only operate to combust excess gas flows or if the gas utilization system is out of service. H₂S removal and gas pressurization is provided as required.




Figure 7.6-12: Schematic of Waste Gas Flare Alternative 3

7.6.16 Updated BCE for Waste Gas Flares

A BCE was performed on ultimately four alternative methods for the burning of waste gas. These various configurations included: H_2S removal, gas pressurization, and the waste gas burning technology. This evaluation took into account the initial capital cost of each alternative and the expected O&M costs resulting in a NPV over a span of 23 years for each. Capital costs are inputted for year 2022 and the O&M costs are annualized from 2023 to 2045. A summary of the results of this updated BCE is included in the table below.

Alternative	Description	Capital Costs	NPV
1A	Flare Combined Streams; Duplex Treatment	\$7,160,000	\$13,440,000
1B	Flare Combined Streams; Merged Treatment	\$4,630,000	\$6,920,000
2	Flare and Thermal Oxidizer	\$8,030,000	\$13,630,000
3	Flare Separate Streams	\$6,370,000	\$11,645,000

Table 7.6-12: Summary of Updated BCE for Waste Gas Flares

(1) Capital costs shown are un-escalated 2016 dollars

(2) O&M and R&R costs shown are escalated and discounted back to 2016 dollars.

7.6.17 Updated Recommendation for Waste Gas Flares

As a result of the BCE, the recommended gas elimination and configuration is Alternative 1B. With the lowest capital costs total and NPV, this configuration maximizes the beneficial utilization of all biogas methane produced by the digesters, both acid-phase and digester gas. As opposed to all other alternatives, the flares will only operate when needed to eliminate excess gas flows or when the gas utilization is out of service. The recommended alternative also reduces the number of H_2S removal systems and gas booster blowers, further simplifying operation and maintenance.

Below is the recommended preliminary waste gas flaring schematic in slightly more detail. Redundancy is recommended for both the H₂S removal system and the gas booster blowers, both of which are critical components in the waste gas flaring process. As previously mentioned there are two independent flares, of differing sizes and capacities, needed to turn down for the lower gas flows while still meeting the maximum case capacity.




Figure 7.6-13: Schematic of Recommended Alternative 1B in More Detail

7.7 EVALUATION OF RP-5 ODOR CONTROL ALTERNATIVES

7.7.1 Introduction

This introductory section presents a project background, understanding and design approach, for several odor control alternatives applicable to the RP-5 project. Each alternative is considered from a performance, operating, and BCE perspective. The BCE is a life-cycle benefit/cost analysis based on the NPV. NPV analysis is the most comprehensive method to make investment decisions by considering the total cost of a project over its entire life. Because costs or revenues may occur at different times during the duration of the project, time-value of money equations can be used to calculate the present value of all costs and revenues over the life cycle of a project.

The purpose of this BCE this to provide sufficient comparative information on costs, benefits, and risks of the alternatives to provide a sound basis for technology selection. Sizing, loading, process configurations, layouts, and costs are based on project parameters agreed on by the project team and Agency staff at the time of commencing the BCEs. Since evaluations of technologies and other important project conditions were conducted in parallel and results can impact the final configurations, refinement of the final selected alternative and costs will be conducted after the BCE and technology selection described in this chapter. This refinement will be reflected in the Approved Project Requirements document and integrate into the design final decisions made by the Agency on project phasing, final load decisions related to FW and FOG treatment, staff layout and configuration preferences, and other decisions subsequent to the BCE.

Based on the background of the project, the new solids treatment facility at RP-5 would consist of Thickening, Digestion, and Dewatering. It is recommended that odor control be added to the Thickening and Dewatering processes since these have the most potential for fugitive odorous air emissions. Gas produced in the Digestion process is treated using a dedicated gas storage and treatment system.

This BCE will evaluate three different technologies for odor control and arrive at the most costeffective option for selecting a technology. Following are the alternatives we considered for odor control:

• Chemical scrubbing

- Bioscrubbing
- Biofiltration
- Activated carbon

7.7.2 Foul Air Production and Characteristics

7.7.2.1 Foul Air Sources

The odor control systems will treat foul air that is collected from the thickening and dewatering equipment, and truck loadout operations. Equipment that can be hooded or totally enclosed will contain and capture odorous air with relatively low airflow. This approach treats foul air from the equipment only, as opposed to treating the entire room volume. This allows the odor control system capacity to be reduced, significantly decreasing the size and cost of the system.

The BCEs for Thickening and Dewatering included evaluating different technologies, each with slightly different air flow requirements. The odor control systems will be sized to accommodate the air flow from the selected technologies based on the results of those BCEs. The air flow rates and design criteria are summarized below in Table 7.7-1.

Location	Source	Design Criteria	Air Flow Rate per unit	Total Air Flow
Location	Source	Design Criteria	cfm	cfm
	RDT	Per Manufacturer	430	3,000
Thickoning	Sludge Blend Tanks	Leakage Rate, 0.5 cfm/ft ²	300	300
Thickening Building	Thickened Sludge Tanks	Leakage Rate, 0.5 cfm/ft ²	50	50
	Filtrate Tanks	Leakage Rate, 0.5 cfm/ft ²	50	50
			TOTAL	3,400
	Centrifuge	Per manufacturer	400	1,000
	Conveyors	5 cfm/ft	200	1,000
Dewatering Building	Cake Bins	Leakage Rate, 1 cfm/ft ²	500	1,000
Dunung	Truck Load Out Room	12 ACH	8,500 (per bay)	17,000
	Centrate Storage Tanks	Leakage Rate, 1 cfm/ft ²	1,000	2,000
			TOTAL	22,000

Table 7.7-1: Sources of Foul Air and Design Criteria

7.7.2.2 Foul Air Characteristics and Design Parameters

Table 7.7-2 summarizes the foul air characteristics and performance criteria. Since the solids processes are not existing, sampling and testing for common odor constituents cannot be conducted, therefore, assumed values typical for these processes should be used for designing the

odor control systems. It is recommended that sampling be conducted after construction and startup of the facilities to obtain actual data relevant to RP-5.

Constituent	Average Concentration	Peak Concentration	System Removal Efficiency
Hydrogen Sulfide, ppm	2	6	97%
Other Reduced Sulfur Compounds	0.5	2	90%

Table 7.7-2: System Design Parameters for Odor Control Systems

7.7.2.3 Odor Control System Design Criteria

Table 7.7-3 lists the assumed design parameters for the different technologies.

Item	Biofilter	Bioscrubber	Activated Carbon
System Type	Open Bed	Tower	Dual Bed
Empty Bed Contact Time, sec	45	15	2.5
Pressure Drop Across Media, inches w.c.	8	4	8
Design Approach Velocity, ft/min	< 5	50-70	< 60

Table 7.7-3: System Design Parameters for Odor Control Systems

7.7.2.4 Accepted Odor Removal Goals

A quantitative odor limit of 5 dilutions-to-threshold (D/T) at the fence line represents the regulatory standard that can be applied by the SCAQMD if triggered by complaints. As the term implies, the detection threshold (dilution to threshold) is a measure of odor strength for any given odor sample. The olfactometry test to determine odor strength is relatively complicated in its test apparatus and methods. But the results (simply put) is the number of fresh-air dilutions to a sample that renders the sample "non-odorous to an odor panel of at least eight individuals." High D/T samples reflect strongly odorous samples requiring considerable amounts of dilution air to render a sample non-odorous. A similar value is the recognition threshold which is defined as the lowest concentration where the odorant can be specifically identified, instead of broadly quantified as a noticeable odor. In low concentrations, H₂S roughly correlates to approximately 2 D/T for part per billion of H₂S in a sample. Ammonia produces much less of an odor impact. Concentrations above 1 ppm ammonia are usually required to produce a measureable D/T value.

The 5 D/T fence line value with a 1-hour averaging period and 99% compliance has been adopted as a design requirement consistent with the Agency's goal of no detectable odors at the fence line. This is normally the D/T concentration that is considered "zero odor," since normal urban atmospheres usually test at least 5 D/T to 10 D/T, in the absence any known odor source contributors.

The fence line criteria of 5 D/T is consistent with several wastewater treatment authorities in California and elsewhere as shown below in Table 7.7-4 below.

Facility/Agency	Standard	Averaging Time	Compliance
BAAQMD, San Francisco, CA.	5 D/T	-	-
Cincinnati WWTP, OH	7 D/T	3 minutes	90%
Dublin San Ramon Services District, Dublin, CA	4 D/T	1 hour	99%
East Bay Municipal Utility District, Oakland, CA	5 D/T	1 hour	99%
Fairfax, VA	7 D/T	1 hour	100%
Hampton Roads Sanitation District, VA	5 D/T	1 hour	99%
Orange County Sanitation District, CA	15 D/T	3 minutes	
San Diego WWTP, CA	5 D/T	5 minutes	99.5%
Sacramento County Regional Sanitation District, CA	10 D/T	1 hour (assumed)	
Wilsonville, OR	5 D/T	1 hour	
Spokane, WA	7 D/T	1 hour	

Table 7.7-4: Examples of Wastewater Treatment Authorities Design Criteria

The averaging time indicated in the table, is also an important factor for the odor goal. For dispersion modeling, the level of refinement of results is usually one hour, since the models typically rely on hourly meteorological data records. Shorter time frames can be considered, but they usually much higher than the hourly average and represent transient conditions, not representative of routine odor conditions from a source. Based on the above reasons, a 1-hour averaging time for modeling evaluations of compliance with the 5 D/T criterion and 95% compliance is recommended. It should be noted that 95% compliance is considered realistic to allow for operations activities including short-term opened doors/hatches and unplanned plant upsets. It is also appropriate to note, that control equipment does not require exhaust concentrations at these values, since the exhaust from any odor control unit will achieve additional air dilution prior to reaching the fence line. Dilution factors of at least 10 and as much as 50 can be experienced, depending on specific site factors.

7.7.3 Odor Control Technology Alternatives

Several techniques are used to treat odors. A combination of control measures is often used to achieve effective and economical control. H_2S is the main constituent in many wastewater odors. Therefore, most treatment processes focus on removing H_2S to reduce odors.

Some odor control treatments are significantly more effective on H₂S than on other odorants. Since H₂S is ionic in nature, gas scrubbing and absorption systems are effective for gas phase control. Dry biofilters, or wet bioscrubbers are also very effective H₂S removal systems and have the significant advantage of not requiring chemicals for absorption and oxidation of H₂S. Activated carbon adsorption is a dry technology relying on the adsorption affinity of H₂S and other VOCs, by activated carbon. It is a superior technology for conditions in which non-H₂S compounds are prevalent and difficult to remove by conventional biological or chemical means. Sulfide precipitation with liquid phase chemicals can help reduce the odor emissions levels from the wastewater if H₂S concentrations become overly high. This is usually considered a collections systems. Reduced sulfur compounds and VOCs often require a different treatment technique than

that needed for H₂S control. Air streams with these odor constituents normally are treated with activated carbon after H₂S removal. Processes requiring sludge treatment and handling usually present a more complex mixture of odorous compounds, and should consider multistage processes combining different control technologies.

7.7.3.1 Chemical Scrubbing

Wet chemical scrubbers treat odorous air by using oxidizing chemicals in a counter-current packed bed tower. Foul air is conveyed from different processes into a vessel, where it flows countercurrent to the chemical liquid. Sodium hypochlorite and caustic soda are commonly used in wet chemical scrubbers to oxidize the H₂S and other reduced sulfur compounds. The caustic soda maintains high pH to ionize the H₂S and drive the sulfide into solution and the sodium hypochlorite oxidizes the dissolved sulfide, converting it into dissolved sulfate and elemental sulfur. Chemical scrubbers consist of a liquid sump, recirculation pump, gas inlet, packed bed media, spray nozzles and a demister and gas outlet. In addition to the scrubber towers, a chemical storage facility is also required to store and convey the chemical to the packed tower.

One advantage of chemical scrubbing is the capacity to treat high air flow volumes and high gas loadings. Also, because chemicals are used to raise the pH of the fluid within the vessel, the chemical reaction between the gas and liquid phases only requires a 1 second to 2 second contact time. Thus, relatively small vessels can handle high air flows. Another advantage is that chemical scrubbers require no acclimation time and can achieve 98% to 99% efficiency almost immediately after startup. Contrary to the biological treatments, chemical scrubbers do not require any lead time for biological growth and foul air may be treated in a separate vessel simply by transferring the air flow to the redundant vessel.

The disadvantages to chemical scrubbing are that it can be very costly and complex to operate. Chemical usage is one of the significant costs associated with chemical scrubbing. The chemicals also require handling and storage, which is another added expense. Maintaining the system chemistry within the scrubber and the components required to monitor system chemistry add to high maintenance hours required to operate the system and add complexity to the system. Any problem condition such as pump failure, air binding in chemical lines, or pH or oxidation reduction potential measuring errors, almost immediately causes a significant drop in performance.

7.7.3.2 Biofiltration

Biofiltration is an odor control technique that uses a bed of porous and moist medium that support micro-organisms that absorb and oxidize odorous constituents. Biofilters can be constructed either as open systems exposed to atmosphere or packaged enclosed aboveground systems. Space requirements for biofilters is significant as the air through-put velocity is normally between 3 ft and 5 ft per minute. Influent air is typically spray-humidified prior to the biofiltration process to maintain adequate moisture in the media. Media sprinklers are also used for moisture maintenance, although total water use is relatively low. An organic biofilter requires somewhat high residence times (45 seconds to 90 seconds) and low velocities to effectively treat the odorous compounds. Newer inorganic media manufactured by vendors can reduce residence times to 30 seconds. These medias produce lower pressure drop, longer life, and greater ability to flush and clean the system. They do require a considerable cost premium as they are an "engineered media." Figure 7.7-1 illustrates a process flow diagram of a biofiltration system.




Figure 7.7-1: Biofilter Process Flow Diagram

7.7.3.3 Bioscrubbing

Similar to biofiltration, bioscrubbing is another environmentally friendly odor control treatment that also treats foul air using biological micro-organisms. However, a bioscrubber appears similar to a normal vertical chemical scrubber, operating at much higher throughput than a biofilter. The differentiator between the bioscrubber and the biofilter is that in addition to biodegradation, the bioscrubber also utilizes absorption, adsorption and condensation to treat the contaminants in the foul air. In bioscrubbers, highly soluble compounds are transferred from the gas phase into the aqueous phase (H₂S is highly soluble in water) and the compounds with low water solubility may be physically adsorbed into the biological flocs. Odorous gas will also condense when it is contacted with an aqueous medium at a lower temperature. Bioscrubbing is essentially a liquid process whereas biofiltration is considered a dry process.

Bioscrubbers may consist of counter-current packed towers that are comprised of a liquid sump, recirculation pump, gas inlet, packed bed media, spray nozzles and a demister and gas outlet. The influent air enters the packed tower and flows counter-current to the liquid. The packed bed is filled with randomly placed low-pressure, high-efficiency plastic packing. A custom designed bioscrubber such as a concrete tower structure may be a viable option to allow a decrease in the system footprint and greater air flow. A bioscrubber has the capacity to withstand higher loading rates in a smaller space requirement. Where biofilters are loaded at 3 ft³ to 4 ft³ per minute per square foot (cfm/ft²) of area and have 45 seconds to 90 seconds of residence time, bioscrubbers are loaded to 50 cfm/sf to 100 cfm/sf and operate with 5 seconds to 10 seconds residence. The disadvantage to a bioscrubber is that treatment is limited to water soluble compounds and H₂S removal efficiency is less (< 95%), unless residence time is increased beyond 10 seconds. Systems

needing to achieve 99% or greater removal efficiency should be followed by activated carbon for polishing.

Figure 7.7-2 illustrates a process flow diagram of a bioscrubber system.




Figure 7.7-2: Bioscrubber Process Flow Diagram

7.7.3.4 Activated Carbon

Activated carbon is used to reduce odorous air by using the adsorption process. Odorous air is passed through a packed bed of activated carbon and the H₂S, as well as other odorous reduced sulfur compounds, are adsorbed into the pores of the carbon. Activated carbons that are the most effective on typical wastewater odors include coal and coconut-based carbons and catalytically enhanced carbon. Activated carbon is capable of treating volatile organic compounds and low to moderate levels of H₂S. The general rule of thumb for using activated carbon as a treatment option is in applications where H₂S concentrations are less than 10 ppm. Activated carbon is often used as a second stage, polishing step to another technology. An activated carbon system consists of a fan, vessel and exhaust stack. Vessel configurations can be vertical, horizontal or radial and can consist of a single bed or dual beds. An example of a process flow diagram for a vertical dual bed is shown in Figure 7.7-3 below.




Figure 7.7-3: Activated Carbon Dual Bed Process Flow Diagram

7.7.4 Odor Control Alternatives Screening

7.7.4.1 Screening Criteria

The odor control technologies were initially screened to determine if all technologies meet IEUA minimum requirements using a pass/fail approach. A high level rating on a scale of 1 to 5 was also provided for criteria considered important and weighted averages computed. The results are provided in Table 7.7-5.

Odor Control Alternatives	Weight	Chemical Scrubbing	Bioscrubbers	Biofilters	Activated Carbon
Supports Treatment and End Use Objectives	Pass/Fail	YES	YES	YES	YES
Meets Required Performance	Pass/Fail	YES	YES	YES	YES
Proven Technology	Pass/Fail	YES	YES	YES	YES
Acceptable Complexity	Pass/Fail	YES	YES	YES	YES
Capital Costs	10%	3	4	3	4
Power and Operating Costs	20%	2	4	4	3
H ₂ S and Odor Removal Efficiency	25%	5	4	5	4
Response to High Odor Loads	10%	5	4	3	1
Operating Complexity	10%	1	5	5	5
Space Requirement	10%	3	4	2	4
Chemical Storage and Handling Requirement	10%	1	5	5	5
O&M Requirement	5%	1	5	5	4
Weighted Average		3.0	4.3	4.1	3.7

7.7.4.2 Screening Recommendation

Based on the scores of the screening criteria for the odor control alternatives, BC recommends comparing biofiltration, activated carbon and combined system comprising of bioscrubbing (1st stage) and activated carbon (2nd stage). Chemical scrubbing received the lowest score mostly due to operational complexity, the requirement to store and handle hazardous chemicals and the O&M requirements to maintain chemical deliveries and system components for proper performance. Due to the high sensitivity of the surrounding area and goal of little to no odors at the fence line, it is recommended that bioscrubbing be analyzed as a two-stage system with activated carbon as a polishing step. Bioscrubbers typically maintain a 90% to 95% H₂S removal efficiency with very little reduced sulfur compound removal. Thus, a restrictive fence line odor requirement will benefit from the second stage activated carbon polishing.

In all cases, the screening level recommendations assume that some systems may operate intermittently, such as dewatering presses, and airflow from tank headspaces, wet wells, and truck bays, to provide some level of continuous odorous air to the odor control system. This enables biological systems to maintain a minimum level of biological activity. This airflow may be reduced due by variable airflow fans, based on dewatering operating schedules.

7.7.5 Odor Control System Alternatives Business Case Evaluation

This section presents an equipment evaluation and comparison of the odor control technologies, including a summary of BCE results. The IEUA standard BCE template was used to develop comparative net present values for odor control facilities constructed in 2022 and operating through 2045.

7.7.5.1 Capital Costs

The capital costs for the odor control technologies are presented in Table 7.7-6. The systems used for analysis are biofiltration, activated carbon and bioscrubbing plus activated carbon. Also, the assumed capacity for analysis was 36,000 cfm.

Technology	Capital Cost
Biofilter	\$4,800,000
Activated Carbon	\$3,000,000
Bioscrubber plus Activated Carbon	\$6,300,000

Table 7.7-6: Odor Control System Capital Cost Comparison

7.7.5.2 Operations and Maintenance Considerations

Table 7.7-7 lists the parameters used for comparison of the odor control alternatives. Conversations with Agency staff indicate that the existing biofilter media requires change out approximately every 5 years or less. Also, it is assumed that carbon will only need to be replaced every 5 years because it is a polishing step. Another potential operational approach is to only operate the activated carbon when the thickening and dewatering processes are operational. When they are not operational, the foul air would only be treated through the bioscrubber. This would require some motor operated dampers on the duct interlocked such that they would open and close to direct foul

air to the appropriate treatment system. This would reduce the frequency of carbon media replacement and ultimately save O&M cost.

Parameter	Biofilter	Bioscrubber	Carbon
Media Replacement Cycle, yrs	5	20	5
Power Cost, \$/kWh	\$0.125	\$0.125	\$0.125
Power Usage, kW	24	48	48
Water Cost, \$/1,000 gal	\$2.20	\$2.20	\$2.20
Water Usage, gph/cfm	0.012	0.008	0
Operating Hours per Year	8,000	8,000	8,000
Labor Rate Per Hour	\$96.33	\$96.33	\$96.33
Labor Requirement, hours/mo	12	6	6

Table 7.7-7: Operations and Maintenance Parameters

7.7.5.3 Business Case Evaluation Results and Analysis

Results of the BCE are provided below in Table 7.7-8. All costs are in 2016 dollars. The full BCE spreadsheet is presented in Exhibit I of this Volume.

Table 7.7-8: Results of the Business Case Evaluation

Alternative	Capital (1)	O&M (2)	NPV
Biofiltration	\$4,800,000	\$8,408,000	\$13,200,000
Activated Carbon	\$3,000,000	\$4,234,000	\$6,600,000
Bioscrubbing with Carbon Polishing	\$6,330,000	\$3,142,000	\$12,000,000

(1) Capital costs shown are un-escalated 2016 dollars

(2) O&M costs shown are escalated and discounted back to 2016 dollars.

7.7.6 Odor Control System Summary

7.7.6.1 Screening Level Odor Control System Factors

An initial screening was completed to compare the major features of various odor control alternatives. The comparison of the odor control alternatives suggests the following:

- Bioscrubbers received the highest score of the odor control technologies evaluated on a screening-level basis. The screening level evaluation factored in capital cost, odor removal efficiency, footprint, and ease of operation.
- Bioscrubbers with activated carbon as a polishing step result in a significantly higher capital cost but provide greater odor removal, improved operating flexibility, and no loss of odor treatment if either system is off-line. O&M costs and overall NPV are slightly lower than a biofilter costs assuming relatively frequent biofilter media replacement.
- Activated carbon as a single stage odor control option, results in the lowest NPV value. Activated carbon is an appropriate technology for low H₂S applications (less than 10 ppm). However, activated carbon has an implied carbon cost for each pound of odorant removed.

7-78

Biological processes do not have this cost as the processes rely on biological assimilation of the odorants. Thus, higher H_2S and odor loads skew the costs benefits to a biological option. The odor control system used to treat foul air from the dewatering building may be a good candidate for activated carbon depending on the actual concentrations. Experience elsewhere has shown that dewatering odors have low H_2S concentrations, but overall D/T odor concentrations that are somewhat high. Treating that source in single stage activated carbon is a viable alternative.

Providing one centralized odor control system to treat all areas has also been evaluated. Centralizing odor control has obvious cost benefits, but may also produce more consistent odor loads to a biological process. More details regarding the size the potential locations for a centralized system are provided in Volume II, Chapter 7: Evaluation of RP-5 Liquid Treatment Alternative Technologies (specifically Chapter 7.5 Odor Control).

7.7.6.2 Odor Control System Operating Conditions

Based on conversations with IEUA staff, there are operating conditions that can affect the inlet H₂S concentrations and the performance of the odor control system.

- 1. Ferric chloride addition to the influent typically reduces H_2S odors at virtually all downstream plant processes. Decreased H_2S emissions from the primary clarifiers and from digestion processes is the main odor benefit of ferric chloride.
- 2. Sludge dewatering occurs intermittently. At this time, it is anticipated that the dewatering processes will operate 5 days a week, 8 hours per day. Therefore, odor control effectiveness is best accomplished by blending the dewatering odor sources with other foul airstreams: (centralized concept), or to systems such as activated carbon, that can be on-line and effective within minutes.

7.7.6.3 Dedicated Odor Control System for Dewatering

Inconsistent H_2S loading to the odor control system will occur under intermittent sludge dewatering operation. Intermittent odor loads to a bioscrubber may produce variations in odor removal efficiency, as the bioscrubber may not respond quickly to large changes in loads. There are a couple of provisions that can be made and should be evaluated further during the design phase. One is to add a bypass duct to the dewatering foul air duct to allow the option to treat directly in the carbon system. Another option would be to add provisions to the duct to allow the foul air from the thickening processes to combine with the foul air from the dewatering to provide consistent source of H_2S .

It is recommended that samples be collected after the system is operational. This will help to determine the concentrations and odor constituents prior to treating it solely with activated carbon. Activated carbon may be an economical and appropriate technology for low H_2S applications (less than 10 ppm). If the concentrations are greater than 10 ppm, it could lead to frequent media replacement and increase the O&M costs. The higher costs would likely justify a biological scrubber for pretreatment of the odorous air prior to carbon polishing.

7.7.7 Agency Decisions and Preferences for the Approved Project Requirements

The purpose of this section is to document recent IEUA direction/preferences provided during the BCE workshop on August 11, 2016, that are not included in this evaluation but deferred to the approved project deliverable. This evaluation would only be updated to address minor comments that would have the potential for affecting the technology selection. The impact on odor control equipment size, number, layout, and cost will be evaluated at the next detailed design phase of the project.

Major items to be integrated into the Approved Project Requirements include:

- Evaluation of one centralized treatment system to treat foul air from all foul air sources from the primaries, thickening, and dewatering processes through conveyance of foul air across site. Items include further evaluation on average and peak odor concentrations, physical size of the system, possible locations and cost differences between conveyance of air across the site compared to dedicated systems at each area.
- Further analysis of system redundancy to ensure compliance during a system failure or during an outage due to routine maintenance.
- Review options to ensure a negative pressure is maintained in equipment and structures and provide cost for increased levels of reliability.
- Understanding process operations and how they would affect the performance on the odor control system by changing the assumed design H₂S concentrations. This may include rapid sludge withdraw, adding ferric chloride upstream of the plant, and combining foul air sources or keeping them separate. Provide flexibility in the design to allow for slight changes in concentrations.

7.7.8 Recommendations

Based on the assumed design parameters, the overall recommendation for a centralized odor control system for the primary, thickening, and dewatering processes at the RP-5 facility is a 2-stage system consisting of bioscrubbing with activated carbon polishing system.

- The BCE is supportive of this option. The BCE was evaluated using a media replacement frequency of 5 years for biofilters because the IEUA historically has had to change out the media every 5 years or less. Inorganic media has a longer life expectancy but at somewhat greater cost. IEUA has experienced operational and performance issues with their organic media biofilters. This suggests that this technology may not be sufficiently reliable and produce the level of odor removal and ease of operation that is essential for the odor control system.
- This recommendation provides two stages of treatment which will help the IEUA to meet the target odor concentration goal at the fence line. Two stages of treatment also provide inherent redundancy such that if one system needs to be maintained, the other system can be used for treatment during the maintenance period.

Bioscrubber with carbon was selected as the preferred alternative by the IEUA at the August 11, 2016, BCE workshop. Having the solids thickening and dewatering follow this approach, provides consistency with odor control on the liquid treatment processes.



APPENDIX 7-A: RP-1 AND RP-5 EXPANSION FLOW VALIDATION

THIS PAGE INTENTIONALLY LEFT BLANK.

> APPENDIX 7-B: RP-5 AND CCWRF SLUDGE QUANTITY ESTIMATES

THIS PAGE INTENTIONALLY LEFT BLANK.

RP-1& RP-5 Expansion Flow Validation Project Nos. EN16025 & EN16028 April 2016



Inland Empire Utilities Agency

A MUNICIPAL WATER DISTRICT

A-2

Jason Marseilles, P.E., Senior Engineer

Agency Flow Forecast


	Tributary Areas	2013 Flow (MGD)	2020 Flow (MGD)	2030 Flow (MGD)	2035 Flow (MGD)	2040 Flow (MGD)	2050 Flow (MGD)	2060 Flow (MGD)
le contra de la cont	The second second			1000				
Gravity Flow	CW-07,CW-07BT, CW-A, F-17, F-18, & F-1	6.5	7.0	8.2	8.6	8.9	9.6	10.4
San Bernardino Lift Station Flow	F-1SB & F-SB_A	4.6	4.7	5.3	5.4	5.5	5.7	6.0
Converted Septic Flow ¹	F-1SB_B, F-SB_B, F-9FT	0.0	1.0	1.5	1.8	2.0	2.5	3.0
RP-4 Max Flow ²		11,1	12,7	15.0	15,8	16.4	17.8	19,4
L.			100	114.55			-	
Gravity Flow	C-13, C-15, CW-01BT, CW-02BT, CW-08,)	19.4	20.3	21.9	22.7	23,4	25.5	25.7
Gravity Flow (Potential RP-4 Trunk)	RP4-1T & RP4-2T	5.3	5.4	5.4	5.4	5.4	5.4	5.4
Converted Septic Flow	Parcel Count (8,679 x 5 c/parcel x 55 gpc	0.0	0.5	1.0	1.3	1.5	2.0	2.5
RP-4 Bypass ³	Bypass at Headworks or SBLS	0.0	0.0	2.0	2.8	3.4	0.0	0.0
Montclair Diversion Flow	M-1 & P-U3	3.4	3.6	3.8	3.8	3.9	3.9	3.9
Whispering Lakes PS Flow	OA-1B	1.5	1.5	1.6	1.6	1.7	1.7	1.7
Haven PS Flow ⁴	0-31, 0-32, 0-33A, 0-42, 0-43, & 0-48	0.1	0.1	0.2	0.2	0.3	0.3	0.3
RP-1 Max Flow ⁵		29.7	31.4	35.9	37.8	39.5	38.7	39.4
RF								
Gravity Flow	C-1N, C-3A:C-9, C-12, C-14, C-16:C20, & (7.4	7.6	7.8	7.9	8.1	8.3	8.5
Montclair Diversion Flow	M-1 & P-U3	3.4	3.6	3.8	3.8	3.9	3.9	3.9
CCWRF Max Flow		10.8	11.2	11.6	11.7	11.9	12.2	12.4
5								
Gravity Flow	C-1B:C-2, C-10, C-11, C-21, CA-1:CA-3, CH	3.8	6.4	11.5	13.7	16.0	19.3	19.6
Preserve Lift Station Flow	CA-4, CIW_A & CIW_B	0.2	1.3	2.0	2.2	2.5	3.0	3.3
RP-2 Lift Station Flow (No Recycle)	C-1D, CH-5, CH-7, SB-6A, & SB-6B	0.3	0.3	0.3	0.3	0.3	0.4	0.4
Montclair Diversion Flow	M-1 & P-U3	3.4	3.6	3.8	3.8	3.9	3.9	3.9
Whispering Lakes PS Flow	OA-1B	1.5	1.5	1.6	1.6	1.7	1.7	1.7
Haven PS Flow	0-31, 0-32, 0-33A, 0-42, 0-43, & 0-48	0.1	0.1	0.2	0.2	0.3	0.3	0.3
CIM Flow		0.0	0.9	0.9	0.9	0.9	0.9	0.9
Additional Buffering Capacity		0.0	0.0	0.0	0.0	0.0	0.0	0.0
CCWRF Base Flow	C-1N, C-3A:C-9, C-12, C-14, C-16:C20, & (7.4	7.6	7.8	7.9	8.1	8.3	8.5
RP-5 Base Flow		5.8	8.1	13.7	16.3	18.8	22.7	23.2
RP-5 with Max. Diversion		9.3	14.2	20.2	22.8	25.5	29.4	29.9
RP-5 Max Flow with CCWRF Flow		16.7	21.8	28.0	30.7	33.6	37.8	38.4

Inland Empire Utilities Agency

A MUNICIPAL WATER DISTRICT


RP-4 Flow Forecast

RP-4 Influent Flow and Treatment Capacity




RP-1 Flow Forecast

RP-1 Influent Flow and Treatment Capacity




CCWRF Flow Forecast

CCWRF Influent Flow and Treatment Capacity




RP-5 Flow Forecast

RP-5 Influent Flow and Treatment Capacity




CCWRF Decommissioning Alternatives



CCWRF Influent Flow Treatment Cost

Agency Running Cost to Treat CCWRF Influent Flow





Proposed Facility Expansions (Tentative)



Inland Empire Utilities Agency

RP-5 AND CCWRF SLUDGE QUANTITY ESTIMATES

Sludge production values were estimated on a per million gallons basis using the influent design pollutant concentrations decided upon on March 11, 2016. These influent design concentrations were chosen after analysis of five years of the existing plant data with consensus among Parsons and IEUA staff. These design concentrations are provided in Attachment 1 of this document. The design concentrations chosen were based on maximum month values. If the 90th percentile concentration was greater than the max month value, then the 90th percentile value was used.

These *max month* influent design concentrations were used to calculate the *max month* sludge production quantities (calculations provided in Attachment 2). Table 1 below presents the sludge quantity estimates. Parsons is recommending the sludge quantities used for design purposes should be the values calculated from the design influent concentrations (Table 1 columns 2 and 3) for two reasons:

- The design values have already been agreed upon by IEUA staff after extensive analysis of 5 years of data; and
- 2) Sludge quantities calculated based on these values are realistic, representing years of experience of the Parsons team. For example, 70 percent removal of TSS in primary clarifiers (the chosen design value) is reasonable and in line with literature and our experience. Sludge yield used for secondary sludge calculations is in line with our experience for plants with similar SRT values in the range of 15 to 20 days.

Two important points should be recognized when considering the information presented in the table below. First, food waste and FOG have not been included in these sludge quantities and will need to be considered when the biosolids system is sized. Second, several peaking factors may be needed in the design of the biosolids system, including max day, max week, max 2-weeks, and max month. Not enough data were available to determine peaking factors to this level of precision. The peaking factors presented in Table 1 were determined by reviewing the available data as well as using the Parsons team engineering judgment, knowledge, and experience.

Suggested factors for solids train sizing:

- Use max month average values for mesophilic digester sizing. For options that require shorter HRT, such as acid phase reactors, maximum day peaking factor may be used. Peaking Factor may be adjusted when the largest single unit of process is out of service for cleaning, repair, etc. Operational constraints must be considered such as not taking a digester down during peak loading periods or seasons.
- 2. Use a PF of 1.3 on the max month values for sizing of thickeners.
- 3. Use average annual values for O&M cost determination and BCE's.
- 4. For pumping sludges and pipe sizing, a PF of as high as 1.5 to 2.0 (not in the table) may be used. Primary and secondary sludge concentrations entering the thickening process will be in the range of 0.8 to 1 percent. Thickened sludge concentrations used for sizing the digesters should be no more than 5%, to account for variability in thickener performance.

RP-5 AND CCWRF SLUDGE QUANTITY ESTIMATES

Parameter	RP-5 values based on design concentrations	CCWRF values based on design concentrations	
Ultimate (year 2060) Projected Influent Flow (mgd)	30	8.5	
Max Month Primary Sludge (Ib/MG)	2335	2919	
Max Month WAS (lb/MG)	1297	1633	
Max Month Total Sludge (Ib/MG)	3632	4552	
Max Month Peaking Factor ^b (max month average/annual average)	1.4	1.4	
Max 2-Weeks Peaking Factor ^c (max 2-weeks average/max month average)	1.2	1.2	
Max Week Peaking Factor ^c (max week average/max month average)	1.25	1.25	
Max Day Peaking Factor ^b (max day/max month average)	1.3	1.3	
Annual Average Total Sludge	2594	3251	
Max Total Sludge (lb/MG)	4722	5918	

Table 1: Sludge Quantity Estimates^a

^a FOG and food waste are not included in these sludge quantity estimates

^b Based essentially on a review of existing plant data

^c Not enough existing data to determine this precise peaking factor – value based on the judgment and experience of the Parsons team and interpolated from existing data

Parsons 03/11/2016 ATTACHMENT 1: INFLUENT DATA – PROPOSED DESIGN VALUES

<u>RP-1</u>

Influent Design Concentrations:

tBOD = 600 mg/L (for design, cBOD will be assumed to be 10% less than tBOD until more data is available) TSS = 550 mg/LNH3-N = 40 mg/LTKN = 65 mg/LVSS/TSS = 0.85 **Primary Treatment:** BOD Removal = 45% TSS Removal = 65% **Peaking Factors:** Process peaking factor (for tankage) = 1.12 (Max month average flow: annual average flow) Max Day Flow peaking factor (for filters and disinfection) = 1.30 (Max day during max month: annual average) Aeration system load peaking factor = 1.25 (Max day BOD load during the max month: Max month avg. BOD load) Hydraulic system peaking factor = 2.1 (Maximum instantaneous flow: annual average flow) Centrate: NH3-N = 1000 mg/LCOD = 850 mg/L TSS = 250 mg/LP = 120 mg/LAnnual Average Flow = 230 gpm; Max Month Average Flow = 260 gpm (2014-2015 data) RP-5 **Influent Design Concentrations:** BOD = 500 mg/L (for design, cBOD will be assumed to be 10% less than tBOD until more data is available) TSS = 400 mg/L NH3-N = 50 mg/LTKN = 65 mg/LVSS/TSS = 0.85**Primary Treatment:** BOD Removal = 45% TSS Removal = 70% **Peaking Factors:** Process peaking factor (for tankage) = 1.18 (Max month average flow: annual average flow) Max Day Flow peaking factor (for filters and disinfection) = 1.32 (Max day during max month: annual average) Aeration system load peaking factor = 1.4 (Max day BOD load during the max month: Max month avg. BOD load) Hydraulic system peaking factor = 3.0 (Maximum instantaneous flow: annual average flow) **RP-2 Centrate Concentrations:** NH3-N = 1000 mg/L COD = 850 mg/L TSS = 250 mg/LP = 120 mg/L**CCWRF Influent Design Concentrations:** BOD = 630 mg/L (for design, cBOD will be assumed to be 10% less than tBOD until more data is available) TSS = 500 mg/LNH3-N = 40 mg/LTKN = 57 mg/LVSS/TSS = 0.85**Peaking Factors:** Process peaking factor (for tankage) = 1.3 (Max month average flow: annual average flow)

Max Day Flow peaking factor (for filters and disinfection) = 1.35 (*Max day during max month: annual average*) Aeration system load peaking factor = 1.3 (*Max day BOD load during the max month: Max month avg. BOD load*) Hydraulic system peaking factor = 2.1 (*Maximum instantaneous flow: annual average flow*)

ATTACHMENT 2: SLUDGE QUANTITY ESTIMATES – CALCULATIONS

RP-5:

Design Influent BOD (max month average) = 500 mg/L Design Influent TSS (max month average) = 400 mg/L Design Primary BOD removal = 45% Design Primary TSS removal = 70% Design VSS/TSS = 0.85

Primary Sludge Estimate:

Primary Sludge = $400 mg/L TSS \times 0.7 = 280 mg/L TSS$

Primary Sludge (max month average) = 280 mg/L TSS × 8.34 $\frac{lb/MG}{mg/L}$ = 2335 $\frac{lb}{MG}$

WAS Estimate:

 $PE BOD = 500 \ mg/L \times (1 - 0.45) = 275 \ mg/L$

Yield = 0.5 mg VSS/mg BOD

$$nVSS = PE TSS \times \left(1 - \frac{VSS}{TSS}\right) = 120 mg/L \times 0.15 = 18 mg/L$$

 $WAS = PE BOD \times Yield + nVSS = 275 mg/L \times 0.5 + 18 mg/L = 155.5 \frac{mg}{L}$

WAS (max month average) = 155.5 mg/L × 8.34 $\frac{lb/MG}{mg/L}$ = 1297 lb/MG

ATTACHMENT 2: SLUDGE QUANTITY ESTIMATES – CALCULATIONS

CCWRF:

Design Influent BOD (max month average) = 630 mg/L Design Influent TSS (max month average) = 500 mg/L Design Primary BOD removal (kept the same as RP-5) = 45% Design Primary TSS removal (kept the same as RP-5) = 70% Design VSS/TSS (kept the same as RP-5) = 0.85

Primary Sludge Estimate:

Primary Sludge = $500 mg/L TSS \times 0.7 = 350 mg/L TSS$

Primary Sludge (max month average) = 350 mg/L TSS × 8.34 $\frac{lb/MG}{mg/L}$ = 2919 $\frac{lb}{MG}$

WAS Estimate:

 $PE BOD = 630 \ mg/L \times (1 - 0.45) = 346.5 \ mg/L$

Yield = 0.5 mg VSS/mg BOD

$$nVSS = PE TSS \times \left(1 - \frac{VSS}{TSS}\right) = 150 mg/L \times 0.15 = 22.5 mg/L$$

 $WAS = PE BOD \times Yield + nVSS = 346.5 mg/L \times 0.5 + 22.5 mg/L = 195.75 \frac{mg}{L}$

WAS (max month average) = 195.75 mg/L × 8.34 $\frac{lb/MG}{mg/L}$ = 1633 lb/MG



Evaluation of RP-5 Food Waste Treatment System





in association with



TABLE OF CONTENTS

CHAPTER 8: EVA	UATION OF RP-5 FOOD WASTE TREATMENT SYSTEM	. 8-1
8.1	Introduction	. 8-1
	 8.1.1 Background 8.1.2 Regulatory and Environmental Drivers and Considerations 8.1.3 Current Practice at IEUA 8.1.4 Food Waste and FOG Potential within IEUA's Service Area 	8-1 8-2
8.2	Pre-Processed Food Waste from IEUA's Service Area	8-4
	 8.2.1 Engineered BioSlurry (EBS) 8.2.2 Design Criteria – Quantity and Quality 	
8.3	Food Waste Co-Digestion: Development of Alternatives	. 8-4
	 8.3.1 Alternative 1: Base Case – Biosolids Only at RP-5 8.3.2 Alternative 2: Co-Digestion at RP-5 8.3.3 Alternative 3: Digestate from RP-5 SHF to RP-5 	. 8-6
8.4	Impact of Food Waste on Treatment Processes at RP-5	8-13
	 8.4.1 Option 1: Treat centrate in liquid stream processes 8.4.2 Option 2: Sidestream Centrate Treatment (DEMON) 8.4.3 Recommendations for Handling Increased Ammonia Load 	8-14
8.5	Business Case Evaluation (BCE)	8-14
8.6	Conclusions and Recommendations	8-15

LIST OF FIGURES

Figure 8-1: RP-5 SHF Process Flow Schematic	. 8-2
Figure 8-2: Alternative 1 Schematic	. 8-5
Figure 8-3: Alternative 2 Schematic	. 8-7
Figure 8-4: Food Waste Receiving Station Preliminary Process Schematic	. 8-7
Figure 8-5: FOG Receiving Station Preliminary Process Schematic	. 8-8
Figure 8-6: Preliminary Layout for Food Waste and FOG Receiving Station	. 8-8
Figure 8-7: Alternative 3 Schematic	8-11

LIST OF TABLES

Table 8-1: Market Available Quantities of Commercial Food Waste and FOG	8-3
Table 8-2: Design Quality of Food Waste and FOG	8-4
Table 8-3: Alternative 1 Capital Costs*	8-6

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 8: Evaluation of RP-5 Food Waste Treatment System

Table 8-4: Alternative 1 – 2045 O&M Costs and Savings	
Table 8-5: Food Waste and FOG Co-Digestion Design Quantities	
Table 8-6: Alternative 2 Capital Costs*	
Table 8-7: Alternative 2 – 2045 O&M Costs and Savings	
Table 8-8: Food Waste/Digestate Quantity Projections	
Table 8-9: Alternative 3 Capital Costs*	8-12
Table 8-10: Alternative 3 – 2045 O&M Costs and Savings	8-13
Table 8-11: Food Waste Alternatives BCE Results	8-15

CHAPTER 8: EVALUATION OF RP-5 FOOD WASTE TREATMENT SYSTEM

8.1 INTRODUCTION

8.1.1 Background

California has long been a pioneer in innovative and groundbreaking legislation to advance environmental protection. With the recent passing of State Assembly Bills (ABs) 341 and 1826 in California, the state is requiring diversion of solid waste streams away from landfills. One of those waste streams that needs to be diverted is organic waste, which includes food waste. Food waste is generated in many different types and forms, including expired food from groceries, food scraps from cafeterias, food scraps and expired food from residential homes, and waste products from industrial food processing plants. In California, anaerobic digestion at water resource recovery facilities is rapidly gaining momentum as the means to divert food waste from landfills, which will result in production of digester gas that can be used to generate power and recover heat. For these reasons, Inland Empire Utilities Agency (IEUA), together with Parsons as its consultant, would like to evaluate the best way to utilize the available food waste in the IEUA service area.

8.1.2 Regulatory and Environmental Drivers and Considerations

With the passing of AB 341, California established a goal of 75% diversion or reduction of solid waste by 2020. One of the facets of this overarching goal is the diversion of organic waste from landfills to composting or digestion facilities. This goal will reduce waste disposal loads at California landfills and will generate beneficial byproducts such as bio-fertilizer and/or biogas for renewable energy.

A subsequent assembly bill, AB 1826, provides the framework and tools to meet the organics recycling mandate of 75% reduction/diversion of waste from landfills. According to this bill, businesses, including public entities and multifamily complexes of 5 units or more are required to recycle organic waste if they produce:

- 8 cubic yards per week of organic waste as of 4/1/16
- 4 cubic yards per week of organic waste as of 1/1/17
- 4 cubic yards per week of solid waste as of 1/1/19

Organic waste includes the following:

- Food waste,
- Green waste,
- Landscape and pruning waste,
- Nonhazardous wood waste,
- And food-soiled paper waste

Prior to the above deadlines, every City/local jurisdiction is required to implement an organic waste recycling program. Cities must find alternative end-uses for organic waste. IEUA's regional wastewater treatment plants can serve as potential solutions for recycling organic waste within its service area by treating organic waste along with biosolids generated at these plants. This will accomplish the following two beneficial goals:

- 1) Help cities within its service area to comply with AB 1826 and AB 341
- 2) Increase digester gas production and thereby additional renewable power generation towards energy self-sufficiency.

8.1.3 Current Practice at IEUA

Currently, IEUA is accepting some food waste for digestion and beneficial use at the Regional Water Recycling Plant #5 (RP-5) Solids Handling Facility (SHF), which is operated by Inland Bioenergy (IBE). Food waste delivered to SHF comes in three different forms:

- 1) Pre-Processed Slurry this includes food waste (mostly fruits and vegetables) from grocery stores that are sent to the West Valley Material Recovery Facility (WVMRF) to be processed into a slurry prior to deliver to SHF via trucks.
- Dissolved Air Flotation Thickener (DAFT) Sludge this includes products such as expired coffee creamer that are sent to an off-site DAFT to be thickened before delivery to RP-5 SHF.
- 3) Liquid Food Waste this includes syrups and other high-strength liquid waste products from industrial processing plants such as Coca-Cola.

Based on 2015 data from SHF, the current quantity of food waste being received is approximately 169 wet tons per day on average, or 41,000 gallons per day (gpd). The process flow at SHF is described below and is also shown in Figure 8-1.




Figure 8-1: RP-5 SHF Process Flow Schematic

IBE operates two 1.2 million gallon (MG) digesters separately – one for "high solids" food waste including items (1) and (2) above with about 13% to 18% solids, and one for "low solids" food waste which consists of the liquid waste (item 3, about 2% to 3% solids). Liquid waste is fed to the "low solids" digester from two small storage tanks; the pre-processed slurry is sent to a 2-millimeter (mm) screw press and then mixed with the DAFT sludge in an underground storage tank before being fed to the "high-solids" digester. Digested sludge is then sent to a centrifuge and/or dissolved air flotation (DAF). Dewatered solids are sent to a composting facility and

centrate (or underflow) is sent to the Inland Empire Brine Line (IEBL). Digester gas is sent to an iron sponge for hydrogen sulfide removal, then compressed for high-pressure gas storage before being sent to the internal combustion engines at RP-5 Renewable Energy Efficiency Project (REEP).

Current power production from the digester gas at SHF ranges between 800 kilowatts (kW) and 1,200 kW, based on 2015 data.

8.1.4 Food Waste and FOG Potential within IEUA's Service Area

IEUA has provided Parsons with a feasibility study report (draft dated June 2016) that analyzed the market-availability of food waste within IEUA's service area. CalRecycle data and population data of the seven cities within IEUA's service area (Chino, Chino Hills, Fontana, Montclair, Ontario, Rancho Cucamonga, and Upland) were used to estimate the quantity of food waste available for digestion. However, this study only estimated the quantity available until 2016, so Parsons extended the projections to 2060 based on population data from Southern California Association of Governments (SCAG).

The study's projections included two sources: residential and commercial food waste. Residential food waste comes from residential households in the service area while commercial food waste derives from large-scale commercial enterprises such as grocery stores, restaurants, and cafeterias. Through the course of Parsons' review of the study, the Agency has decided to exclude residential food waste from consideration for this pre-design report due to anticipated lack of regulatory enforcement and infrastructure for collection of residential food waste.

A separate report provided by IEUA (draft dated March 2016), estimated availability of Fat, Oil, and Grease (FOG) within the IEUA service area. This analysis for FOG availability extended to 2025, so Parsons projected these quantities to 2060 based on population growth data from SCAG. Commercial food waste and FOG projections are presented in Table 8-1 below.

	2016	2020	2025	2030	2035	2040	2045	2060
Commercial Food Waste Available (gal/day)	20,300	21,300	22,500	23,700	24,800	26,000	27,200	31,300
FOG Available (gal/day)	13,700	14,400	15,200	16,000	16,800	17,600	18,400	21,100
Total Food Waste & FOG Available	34,000	35,700	37,700	39,700	41,600	43,600	45,600	52,400

8.2 PRE-PROCESSED FOOD WASTE FROM IEUA'S SERVICE AREA

8.2.1 Engineered BioSlurry (EBS)

There are several methods of accepting food waste for co-digestion at WWTPs. One method is to accept all organic waste as is, process it onsite at the WWTP, and feed to the digesters. East Bay Municipal Utilities District (EBMUD) has a practice similar to this, and has experienced some process stability and operational issues. Another method is to source-separate the organic waste and process into a slurry, which is then trucked to the WWTP and fed directly to the digesters. This method is currently being practiced by Los Angeles County Sanitation Districts (LACSD) in a pilot program and they have not experienced any major issues thus far. LACSD wrote a specification for the bioslurry that must be met by waste haulers before it is accepted at the plant. This step provided predictability of the quality of food waste and eased concerns of potential digester upsets due to "bad" loads of food waste. IEUA and parsons staff visited the pilot plant at the Joint Water Pollution Control Plant (JWPCP) (owned by LACSD). Subsequently, IEUA has decided that food waste in the form of EBS should be pursued at RP-5 due to its simplicity and relatively fewer operational problems. IEUA will develop a specification similar to LACSD for food waste slurry to be accepted for co-digestion at RP-5.

8.2.2 Design Criteria – Quantity and Quality

Design criteria will be based on the food waste and FOG quantity projections described in Section 8.1.4. The relevant characteristics based on the LACSD specification as well as other literature sources for food waste and FOG are shown in Table 8-2 below. Design quantities for each were taken from Table 8-1, shown in Section 8.1.4.

Parameter	Food Waste (EBS)	FOG
Total Solids (%)	14	6
Volatile Solids (% of TS)	85	90
Solids Volatile Solids Reduction (%)	-	95%
Gas Production (cu. ft./wet ton)	3,200	-

Table 8-2: Design Quality of Food Waste and FOG

8.3 FOOD WASTE CO-DIGESTION: DEVELOPMENT OF ALTERNATIVES

The following three alternatives were developed in cooperation with the Agency and will be discussed in detail under this section.

- 1. Alternative 1: Base Case Biosolids Only at RP-5
- 2. Alternative 2: Co-Digestion at RP-5
- 3. Alternative 3: Digestate from RP-5 SHF to RP-5

8.3.1 Alternative 1: Base Case – Biosolids Only at RP-5

8.3.1.1 Description of Alternative

Alternative 1 is the base case for biosolids treatment at RP-5, in which only the biosolids generated from the wastewater treatment process are treated; no food waste or FOG would be accepted at RP-5. This alternative was developed to provide a baseline for facilities, site layout, and costs. A schematic describing this alternative is presented in Figure 8-2 below.




Figure 8-2: Alternative 1 Schematic

8.3.1.2 Design Criteria

Design criteria for Alternative 1 does not differ from the design criteria developed in *Chapter* 7 - Solids *Treatment Alternatives* because there will be no addition of food waste in this alternative.

8.3.1.3 Capital and O&M Costs

Costs for facilities required for 2035 as well as for the ultimate build-out period of 2060 were developed. The hinge point, when additional facilities or equipment are required, was between 2033 and 2036 for most processes; therefore 2035 was chosen as a representative hinge point. Capital costs for the 2035 and 2060 systems are presented below in Table 8-3.

	20	2060		
System Components	System Size	System Cost	System Size	System Cost
Acid Phase Digestion	1 Acid (0.37 MG)	\$3,041,000	2 Acid (0.4 MG)	\$4,100,000
Gas Phase Digestion - Thermophilic/Mesophilic	3 Thermo (1.52 MG)	\$19,287,000	5 Thermo (1.5 MG)	\$28,500,000
Digested Sludge Storage/Backup Digester	1 Storage (1.52 MG)	\$6,000,000	1 Storage (1.52 MG)	\$6,000,000
Dewatering, Cake Storage, and Truck Loadout	3 centrifuges @ 300 gpm Cake storage, 2 x 5,500 ft ³	\$24,400,000	4 centrifuges @ 300 gpm (4+1) Cake storage, 2 x 5,500 ft ³	\$26,700,000
Centrate Handling	Centrate EQ tanks & pumps	\$720,000	Centrate EQ tanks & pumps	\$720,000
Digester Gas Conditioning at RP-5	H ₂ S & Siloxane Removal	\$1,845,000	H ₂ S & Siloxane Removal	\$1,845,000
Base Cost		\$55,293,000		\$67,865,000
Overhead & Profit, Inflation, Bonds & Insurances, Contingency (30%)		\$36,000,000		\$44,200,000
Total Biosolids Construction Cost		\$91,300,000		\$112,100,000
Design & Administration (20%)		\$18,300,000		\$22,400,000
Total Project Cost		\$109,600,000		\$134,500,000

Table 8-3: Alternative 1 Capital Costs*

*Note: only includes facilities that would be impacted by food waste

Operations and maintenance (O&M) costs as well as potential savings from beneficial use of digester gas for the year 2045 (chosen as a midpoint) are presented below in Table 8-4.

Table 8-4: Alternative 1 – 2045 O&M Costs and Savings

Item	Cost
O&M – includes labor, power (includes parasitic loads), and chemicals	\$7,454,000
Repair and replacement of equipment parts	\$663,000
Savings - beneficial use of digester gas (power and heat)	(\$2,238,000)
Net Annual Costs	\$5,878,000

8.3.2 Alternative 2: Co-Digestion at RP-5

8.3.2.1 Description of Alternative

In Alternative 2, food waste and FOG would be received at RP-5 for co-digestion. Both food waste and FOG would be received at an onsite receiving station, then pumped directly to the digesters for co-digestion. This process is shown below in Figure 8-3.




Figure 8-3: Alternative 2 Schematic

As shown in the above figure, food waste and FOG receiving station is required at RP-5 under this alternative. Preliminary process schematics for the food waste portion and FOG portion of the receiving station are shown in Figures 8-4 and 8-5, respectively. While the equipment required for the receiving station is slightly different between the two (i.e. heat exchangers are only required for the FOG portion), the receiving station would be combined in one central location. The planned location of the food waste and FOG receiving station in relation to the other solids handling processes is shown in Figure 8-6.




Figure 8-4: Food Waste Receiving Station Preliminary Process Schematic

8-7

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 8: Evaluation of RP-5 Food Waste Treatment System




Figure 8-5: FOG Receiving Station Preliminary Process Schematic




Figure 8-6: Preliminary Layout for Food Waste and FOG Receiving Station

8.3.2.2 Design Criteria

The amount of food waste and FOG that can be accepted into the digestion system at RP-5 is limited by the organic solids ratio between food waste and biosolids. To maintain reliability in the digestion process and maximize gas production, previous studies and operating data at other facilities indicate that food waste and FOG should only be co-digested up to 30% of the total volatile solids (VS) load, resulting in a 30:70 ratio of food waste/FOG VS to biosolids VS.

Therefore, the amount of food waste and FOG that can be co-digested at RP-5 is tied to the biosolids projections that were presented in Chapter 7. The quantity of organic waste for co-digestion thus calculated is slightly below the market-available quantity of food waste and FOG. In this analysis, Parsons assumed that all the market-available FOG would be accepted at RP-5 due to its high volatility and substantial benefit to gas production. The remaining portion of the

capacity for organic waste up to the 30:70 ratio would consist of EBS. The quantities of food waste and FOG estimated for co-digestion are shown below in Table 8-5.

2025	2030	2035	2040	2045	2050	2055	2060
6,848	7,206	7,549	7,907	8,283	8,676	9,088	9,520
17,593	21,497	23,764	26,231	27,986	29,432	29,427	29,407
24,442	28,703	31,313	34,138	36,269	38,108	38,516	38,927
15,207	16,001	16,761	17,557	18,391	19,265	20,180	21,138
17,727	21,660	23,945	26,430	28,199	29,656	29,651	29,631
32,933	37,661	40,706	43,988	46,590	48,921	49,831	50,769
	6,848 17,593 24,442 15,207 17,727	6,8487,20617,59321,49724,44228,70315,20716,00117,72721,66032,93337,661	6,8487,2067,54917,59321,49723,76424,44228,70331,31315,20716,00116,76117,72721,66023,945	6,8487,2067,5497,90717,59321,49723,76426,23124,44228,70331,31334,13815,20716,00116,76117,55717,72721,66023,94526,430	6,8487,2067,5497,9078,28317,59321,49723,76426,23127,98624,44228,70331,31334,13836,26915,20716,00116,76117,55718,39117,72721,66023,94526,43028,199	6,8487,2067,5497,9078,2838,67617,59321,49723,76426,23127,98629,43224,44228,70331,31334,13836,26938,10815,20716,00116,76117,55718,39119,26517,72721,66023,94526,43028,19929,656	6,8487,2067,5497,9078,2838,6769,08817,59321,49723,76426,23127,98629,43229,42724,44228,70331,31334,13836,26938,10838,51615,20716,00116,76117,55718,39119,26520,18017,72721,66023,94526,43028,19929,65629,65132,93337,66140,70643,98846,59048,92149,831

Table 8-5: Food Waste and FOG Co-Digestion Design Quantities

8.3.2.3 Capital and O&M Costs

Similar to Alternative 1, costs were developed for facilities required to reach the 2035 capacity and the 2060 capacity for Alternative 2. These costs are presented below in Table 8-6.

	2035	2060			
System Components	System Size	System Cost	System Size	System Cost	
Acid Phase Digestion	1 Acid (0.37 MG)	\$3,041,000	2 Acid (0.4 MG)	\$4,100,000	
Gas Phase Digestion - Thermophilic/Mesophilic	4 Thermo (1.52 MG)	\$23,900,000	6 Thermo (1.5 MG)	\$33,100,000	
Digested Sludge Storage/Backup Digester	1 Storage (1.52 MG)	\$6,000,000	1 Storage (1.52 MG)	\$6,000,000	
Dewatering, Cake Storage, and Truck Loadout	atering, Cake Storage,4 centrifuges @ 300gpm\$27,450,000		5 centrifuges @ 300 gpm (4+1) Cake storage, 2 x 6,000 ft ³	\$29,750,000	
Centrate Handling	Centrate EQ tanks & pumps	\$800,000	Centrate EQ tanks & pumps	\$800,000	
Digester Gas Conditioning at RP-5	H ₂ S & Siloxane Removal	\$1,845,000	H ₂ S & Siloxane Removal	\$1,845,000	
HSW Receiving Station	~50,000 gal/day of pre-processed slurry	\$2,000,000	~50,000 gal/day of pre- processed slurry	\$2,000,000	
Base Cost		\$65,036,000		\$77,595,000	
Overhead & Profit, Inflation, Bonds & Insurances, Contingency (30%)		\$42,300,000		\$50,500,000	
Total Construction Cost		\$107,300,000		\$128,100,000	
Design & Administration (20%)		\$21,500,000		\$25,600,000	
Total Project Cost		\$128,800,000		\$153,700,000	

Table 8-6: Alternative 2 Capital Costs*

*Note: only includes facilities that would be impacted by food waste

O&M costs and savings from beneficial use of digester gas for Alternative 2 are provided in Table 8-7 below.

Item	Cost
O&M – includes labor, power (includes parasitic loads), and chemicals	\$9,230,000
Repair and replacement of equipment parts	\$710,000
Savings - beneficial use of digester gas (power and heat)	(\$3,900,000)
Net Annual Cost	\$6,040,000

Table 8-7: Alternative 2 – 2045 O&M Costs and Savings

8.3.3 Alternative 3: Digestate from RP-5 SHF to RP-5

8.3.3.1 Description of Alternative

This alternative considers that all food waste and FOG are accepted at SHF for digestion, and all digestate from SHF will be sent to the RP-5 digesters. Currently, digestate at SHF is dewatered and the centrate is sent to the IEBL. By proposing to send centrate to RP-5 instead of discharging to IEBL, the SHF benefits from avoided centrate disposal fees as well as an option not to operate capacity-limited digestate dewatering processes (existing centrifuge and DAF at SHF).

In light of the above benefits, IBE would like to send digestate produced at SHF to RP-5. The digestate can either be sent to the digesters or to the digested sludge holding tank for dewatering. The goal of sending the digestate to the digesters would be to increase gas production. However, after technical review and discussions with food waste digestion experts, Parsons recommends sending the digestate downstream of the digesters because there is very little gas that can be generated from the digestate that has been fully digested already. This analysis considers the digestate being sent to the digested sludge holding tank at RP-5 because the gas production potential of the digestate from SHF is minimal. A schematic describing this alternative is shown in Figure 8-7.




Figure 8-7: Alternative 3 Schematic

8.3.3.2 Design Criteria

As stated in the previous section, this alternative considers all food waste being sent to SHF and all digestate being sent to dewatering at RP-5. No reliable data was available with projections for industrial food waste currently being received at SHF, so this quantity was assumed to remain constant from now until 2060. The food waste quantity projections are shown in Table 8-8 below.

	2025	2030	2035	2040	2045	2060
Pre-Processed Slurry						
(gal/day)	22,500	23,700	24,800	26,000	27,200	31,300
FOG (gal/day)	15,200	16,000	16,800	17,600	18,400	21,100
Industrial (gal/day)	40,500	40,500	40,500	40,500	40,500	40,500
Total digester feed (gal/day)	78,000	80,000	82,000	84,000	86,000	93,000
Total Digestate (gal/day)	78,000	80,000	82,000	84,000	86,000	93,000

Table 8-8: Food Waste/Digestate Quantity Projections

Note: Based on discussions with the Agency, FOG may not be received at SHF. For design purposes, approximately 50,000 gallons/day of pre-processed slurry in 2060 is considered.

8.3.3.3 Capital and O&M Costs

The capital costs for Alternative 3 for a 2035 and a 2060 system are presented in Table 8-9 below.

	2035	5	2060			
System Components	System Size	System Cost	System Size	System Cost		
Acid Phase Digestion	1 Acid (0.37 MG)	\$3,041,000	2 Acid (0.4 MG)	\$4,100,000		
Gas Phase Digestion - Thermophilic/Mesophilic	3 Thermo (1.52 MG)	\$19,287,000	5 Thermo (1.5 MG)	\$28,500,000		
Digested Sludge Storage/Backup Digester	1 Storage (1.52 MG)	\$6,000,000	1 Storage (1.52 MG)	\$6,000,000		
Dewatering, Cake Storage, and Truck Loadout	4 centrifuges @ 300 gpm Cake storage, 2 x 6,000 ft ³ (SHF centrifuge below)	\$27,450,000	5 centrifuges @ 300 gpm (5+1) Cake storage, 2 x 6,000 ft ³	\$29,750,000		
Centrate Handling	Centrate EQ tanks & pumps	\$800,000	Centrate EQ tanks & pumps	\$800,000		
Digester Gas Conditioning at RP-5	H ₂ S & Siloxane Removal	\$1,845,000	H ₂ S & Siloxane Removal	\$1,845,000		
HSW Receiving Station at SHF	~50,000 gal/day of pre-processed slurry	\$2,000,000	~50,000 gal/day of pre-processed slurry	\$2,000,000		
Transfer Pumps & Piping from SHF to Digested Sludge Storage		\$296,000		\$296,000		
RP-5 SHF Digester Gas Conditioning		\$654,000		\$654,000		
Base Cost		\$61,373,000		\$73,945,000		
Overhead & Profit, Inflation, Bonds & Insurances, Contingency (30%)		\$40,000,000		\$48,100,000		
Total Construction Cost		\$101,400,000		\$122,000,000		
Design & Administration (20%)		\$20,300,000		\$24,400,000		
Total Project Cost		\$121,700,000		\$146,400,000		

Table 8-9: Alternative 3 Capital Costs*

*Note: only includes facilities that would be impacted by food waste

The 2045 O&M costs and savings from beneficial use of digester gas for Alternative 3 are presented below in Table 8-10.

Item	Cost
O&M – includes labor, power (includes parasitic loads), and chemicals	\$9,870,000
Repair and replacement of equipment parts	\$830,000
Savings – beneficial use of digester gas (power and heat)	(\$3,400,000)
Savings – Diversion of IEBL Discharge	(\$400,000)
Net Annual Cost	\$6,900,000

Table 8-10: Alternative 3 – 2045 O&M Costs and Savings

8.4 IMPACT OF FOOD WASTE ON TREATMENT PROCESSES AT RP-5

Accepting food waste at RP-5, whether it is food waste slurry for co-digestion or digestate from SHF, will have impacts on the liquid treatment processes at RP-5. For Alternatives 2 and 3, the ammonia concentration in the centrate will increase significantly compared to centrate from the treatment of biosolids only in case of Alternative 1. Based on over a year worth of data on centrate at SHF, the max month ammonia concentration was determined to be approximately 500 milligrams/liter (mg/L). The current practice at SHF is to discharge centrate to IEBL, which will remain as an option for centrate disposal at RP-5. However, it is the Agency's preference to minimize discharges to IEBL thereby realizing savings on disposal fees. Therefore, the following two options for treating centrate are considered and discussed in detail in this section:

- 1. Send centrate to RP-5 headworks and treat increased ammonia load in secondary treatment.
- 2. Sidestream treatment process for centrate (DEMON).

Centrate treatment options are discussed in more detail in *Volume I, Chapter 5/Volume II Chapter 6 – Evaluation of Onsite Centrate Treatment and Offsite Recycle Flow Discharge.*

8.4.1 Option 1: Treat centrate in liquid stream processes

The centrate from food waste will increase the overall ammonia load on the RP-5 secondary treatment system, resulting in increased air demand and requirement for supplemental carbon (methanol). For this analysis, an ammonia concentration of 500 mg/L in food waste centrate was used based on the 92nd percentile ammonia concentration in the centrate at SHF. Based on this concentration and the projected food waste quantities, the ammonia load at RP-5 would increase by approximately 6% by accepting food waste centrate (shown in Figure 8-8 below). BioWinTM was used to model the RP-5 secondary treatment system with the increased ammonia load. The modeling results indicated that the proposed secondary system (MBR retrofit, described in *Vol II, Chapter 7*) can handle the increased ammonia load but will require methanol addition during periods where the BOD:TKN ratio drops below 3.6:1. With max month TKN loads and annual average BOD loads, BioWinTM predicted a required methanol usage of 1000 gpd. Methanol injection is described in *Vol II, Chapter 7*.

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 8: Evaluation of RP-5 Food Waste Treatment System

8.4.2 Option 2: Sidestream Centrate Treatment (DEMON)

The driver for sidestream centrate treatment is the cost of methanol addition and increased power demand for aeration. However, there is a high capital expenditure required to construct a sidestream treatment process such as DEMON. Additionally, installing sidestream centrate treatment requires operators to learn how to operate a new process and will require additional time, energy, and maintenance. Based on preliminary analysis, the methanol requirement in Option 2 would need to be as high as approximately 1,800 gpd to make sidestream treatment more cost-effective.

8.4.3 Recommendations for Handling Increased Ammonia Load

Parsons team recommends treating the increased ammonia load from the food waste/digestate centrate in the secondary treatment system. The cost of methanol required is not enough to justify construction of a sidestream treatment process.

8.5 **BUSINESS CASE EVALUATION (BCE)**

The BCE results are presented in Table 8-11 below for the *2060 ultimate costs* for Alternatives 1, 2, and 3 (for processes impacted by food waste only). The full BCE spreadsheets are attached in Exhibit I of this Volume. It is important to note that the benefits of combined heat and power (CHP) were capped to 3-megawatt (MW) production due to the current capacity of the RP-5 REEP engines. Any gas produced that cannot be utilized in the engines can be used in the boilers or in a future renewable gas utilization facility, such as CNG or RNG.

Table 8-11: Food Waste Alternatives BCE Results

	nd Empire			
Agency:	Inland Empire Utilities Agency	F	Results (\$000s)	
Project/Problem:		Capital Cost	30-year NPV	Benefit over 'Do Nothing'
Alternative 1	FW Alt 1	\$134,500,000	(\$283,824,619)	
Alternative 2	FW Alt 2	\$153,700,000	(\$303,508,513)	(\$19,683,894)
Alternative 3	FW Alt 3	\$146,400,000	(\$331,463,251)	(\$47,638,632)
Alternative 4				
Alternative 5				
Alternative 6				
Alternative 7				
Alternative 8				
Alternative 9				
Alternative 10				
Alternative 11				
Alternative 12				
Year of analysis:	2016			
Escalation rate:	3.00%			
Discount rate:	2.00%			

8.6 CONCLUSIONS AND RECOMMENDATIONS

While Alternative 1 provides the lowest cost alternative, the Agency would like to be able to accept all of the food waste digestate from SHF, providing the following benefits:

- Elimination of dewatering facilities at SHF
- Avoidance of costs associated with disposing of SHF centrate to IEBL
- Economies of scale associated with dewatering both digested solids streams together (food waste digestate from SHF and biosolids digestate from RP-5)

The Agency's goal is to construct some of the facilities required to handle food waste, while minimizing the capital expenditure. Additionally, the project construction can be phased to further reduce costs. Upon review of the alternatives, the Parsons team recommends Alternative 3, which consists of receiving and digesting food waste at RP-5 SHF and sending digestate to digested sludge storage and dewatering at RP-5. The cost for the recommended system falls in-between the capital costs for Alternatives 1 and 2.

Some key features to note include the following:

• 50,000-gpd receiving station at RP-5 SHF included for pre-processed food waste slurry

- Thickening for 2035 biosolids quantity an additional RDT can be added in 2035 if needed
- 5 digesters required for 2035 biosolids quantity; equipment is provided to convert these digesters to thermophilic; two digesters will be capable of digested sludge storage
- Dewatering provided for 2035 biosolids quantity plus digestate from SHF; an additional centrifuge can be added in 2035 if needed
- Cake storage provided to accommodate increased cake from SHF digestate
- Recommended to only provide centrate equalization tanks and pumps (rather than sidestream centrate treatment) and methanol injection system
- No digester gas storage recommended. Fluctuations in digester gas production from RP-5 can be balanced by varying the gas flow from SHF. There are existing low- and high-pressure storage vessels for the SHF gas, which can be used to control gas flow. In later years, gas storage can be added to maximize energy production.
- Digester gas conditioning provided for RP-5 biogas and RP-5 SHF gas
- Use existing internal combustion engines and expand REEP in the future or explore other beneficial use of excess gas



Evaluation of Beneficial Use Of RP-5 Digester Gas



in association with



TABLE OF CONTENTS

CHAPTER 9: EVA	LUATIO	N OF BENEFICIAL USE OF RP-5 DIGESTER GAS	9-1
9.1	Introd	uction	9-1
	9.1.1 9.1.2 9.1.3	Background and Purpose Description of Current Sources of Digester Gas Description of Existing REEP Facility and Solids Handling Facility	9-1
9.2	Regula	atory and environmental drivers and considerations	9-3
9.3	Digest	er gas generation potential	9-3
	9.3.1	Digester Gas Estimates	9-3
9.4	Digest	er Gas Conditioning	9-4
9.5	Develo	opment of Alternatives	9-4
	9.5.1 9.5.2	Alternative 1: Use Existing REEP Capacity Alternative 2: New Cogeneration System at RP-5	
	9.5.3	(Microturbines) Alternative 3: Centralized Cogeneration – Transfer DG from RP-1 to RP-5	
	9.5.4 9.5.5	Alternative 4: Convert DG to Pipeline-Quality Natural Gas Alternative 5: Convert DG to Compressed Natural Gas (CNG) for Vehicular Fuel	
9.6	Digest	er Gas Storage Evaluation	
9.7	Busine	ess Case Evaluation (BCE)	9-20
	9.7.1 9.7.2	Introduction BCE Results	
9.8	Conclu	usions and Recommendations	9-21
	9.8.1 9.8.2	Conclusions Recommended Alternative	

LIST OF FIGURES

Figure 9-1: Sources of Digester Gas	. 9-1
Figure 9-2: One of Two Existing Caterpillar Internal Combustion Engines	. 9-2
Figure 9-3: Digester Gas Utilization Alternatives	. 9-5
Figure 9-4: Preliminary Schematic of the Modified Heat Recovery System at RP-5 REEP	. 9 - 6
Figure 9-5: Alternative 1 Process Flow Schematic	. 9 - 6
Figure 9-6: Alternative 1 – Proposed Site Layout	. 9-8
Figure 9-7: Alternative 2 Process Flow Schematic	. 9-9

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 9: Evaluation of Beneficial Use of RP-5 Digester Gas

Figure 9-8: Alternative 2 – Proposed Site Layout	9-10
Figure 9-9: RP-1 to RP-5 Gas Pipeline – Potential Alignment	9-12
Figure 9-10: Alternative 3 Process Flow Schematic	9-13
Figure 9-11: Alternative 3 – Proposed Site Layout	9-14
Figure 9-12: Alternative 4 Process Flow Schematic	9-15
Figure 9-13: Alternative 4 - Proposed Site Layout	9-17
Figure 9-14: Alternative 5 Process Flow Schematic	9-18
Figure 9-15: Alternative 5 – Proposed Site Layout	9-19
Figure 9-16: Recommended Alternative Gas Utilization Schematic	9-22
Figure 9-17: Preliminary Gas Conditioning System Layout	9-23

LIST OF TABLES

Table 9-1: Digester Gas Estimates	
Table 9-2: Alternative 1 Power and Heat Production Potential Estimates	
Table 9-3: Alternative 1 Capital Costs	
Table 9-4: Alternative 1 – 2045 O&M Costs and Savings	
Table 9-5: Alternative 2 Power and Heat Production Potential Estimates	
Table 9-6: Alternative 2 Capital Costs	
Table 9-7: Alternative 2 – 2045 O&M Costs and Savings	
Table 9-8: Alternative 3 Power and Heat Production Potential Estimates	
Table 9-9: Alternative 3 Capital Costs	
Table 9-10: Alternative 3 – 2045 O&M Costs and Savings	
Table 9-11: Alternative 4 Gas Quantity Projections	
Table 9-12: Alternative 4 Capital Costs	
Table 9-13: Alternative 4 – 2045 O&M Costs and Savings	
Table 9-14: Alternative 5 Gas Quantity Projections	
Table 9-15: Alternative 5 Capital Costs	
Table 9-16: Alternative 5 – 2045 O&M Costs and Savings	
Table 9-17: BCE Results Summary	

CHAPTER 9: EVALUATION OF BENEFICIAL USE OF RP-5 DIGESTER GAS

9.1 INTRODUCTION

9.1.1 Background and Purpose

In order to develop the basic framework of alternatives for digester gas utilization, gas production from the Regional Water Recycling Plant #5 (RP-5), RP-1, and RP-5 Solids Handling Facility (SHF) was investigated. The purpose of this chapter is to describe existing and potential digester gas sources, and provide recommendations for beneficial use of digester gas at RP-5. This chapter also includes a preliminary evaluation of improvements to the existing 1.5-megawatt (MW) engines at RP-5 Renewable Energy Efficiency Project (REEP) to meet new emission standards, per South Coast Air Quality Management District (SCAQMD).

9.1.2 Description of Current Sources of Digester Gas

Three main sources of digester gas are being considered for the analysis presented in this chapter – gas from RP-5 (digestion of municipal biosolids only), gas from RP-1 (digestion of municipal biosolids only) and gas from RP-5 SHF (digestion of food waste and fat, oil, and grease [FOG]). Because the gas from RP-5 SHF will be from dedicated digestion of food waste/FOG, the gas produced is expected to free of siloxanes and requires only hydrogen sulfide (H₂S) removal. Gas from RP-1 and RP-5 will require siloxane removal in addition to H₂S removal due to the digestion of municipal biosolids. These potential digester gas sources and the 2060 projected gas quantities are shown below in Figure 9-1.




Figure 9-1: Sources of Digester Gas

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 9: Evaluation of Beneficial Use of RP-5 Digester Gas

9.1.3 Description of Existing REEP Facility and Solids Handling Facility

Digester gas produced from the two dedicated food waste digesters at RP-5 SHF is sent to two iron sponge vessels to reduce H₂S concentration. Digester gas is then boosted through low-pressure storage units prior to gas compression and high-pressure storage. Currently, the SHF digesters are producing about 260 standard cubic feet per minute (scfm) of digester gas (annual average). Not all gas from RP-5 SHF is sent to the RP-5 REEP; a portion of the gas is sent to the SHF boilers for digester heating and excess gas is flared.

The cogeneration facility at RP-5 is currently leased to a third party, Inland Bioenergy (IBE). This facility utilizes digester gas from the RP-5 SHF to generate electricity via two 1.5-MW Caterpillar internal combustion engines as shown in Figure 9-2, operating at approximately 1 MW output (currently only operating one engine at a time) on an average. There are two additional concrete pads inside the REEP building for installing future engines. However, Pad No. 4 is reportedly too close to the equipment near the stairway going to the mezzanine floor; hence, only one engine may be installed in the future. These concrete pads are built to be demolished easily in case the future engine needs a different size of concrete pad for installation. There is a natural gas blending tank installed at the REEP facility, but it is not currently used to supplement digester gas. All the power produced is primarily used to meet the on-site power demand at RP-5. The facility is enrolled in a Net Energy Metering (NEM) agreement with Southern California Edison (SCE) for exporting any excess power back to the grid.



Figure 9-2: One of Two Existing Caterpillar Internal Combustion Engines

The major components of the cogeneration system include engine generators, exhaust heat recovery system, an organic Rankine cycle (ORC) system designed to generate 200 kilowatts (kW) of power from exhaust heat, and an absorption chiller system. Currently, the heat recovery system, including ORC and absorption chiller system, are not in use. A new electric chiller system has been recently installed to meet the cooling loads for the Agency's Headquarters (HQ) Buildings A and B.

9.2 **REGULATORY AND ENVIRONMENTAL DRIVERS AND CONSIDERATIONS**

There are various regulatory and environmental drivers and considerations that need to be evaluated in the digester gas beneficial use analysis. For the alternatives geared towards cogeneration, regulations must be met to comply with emission standards for the specific cogeneration technology being considered. SCAQMD rule 1110.2 stipulates the emission limits for nitrogen oxides (NOx), Volatile Organic Compounds (VOCs) and Carbon Monoxide (CO) from internal combustion engines. These emission limits are considered to be quite stringent and would most likely require catalytic exhaust treatment, such as Selective Catalytic Reducers (SCRs) and/or oxidation catalysts (OxiCat). For the alternatives focused on generating renewable fuel, such as Renewable Natural Gas (RNG) for pipeline injection or producing Compressed Natural Gas (CNG) for vehicular fuel, regulations play a crucial role as they also provide the desired incentives to make these alternatives more economically feasible.

9.3 DIGESTER GAS GENERATION POTENTIAL

9.3.1 Digester Gas Estimates

Digester gas from each of the three sources listed above has been estimated and projected until the buildout year of 2060. For RP-5 and RP-1, these estimates are based on the biosolids quantity projections presented in Volume III, Chapter 7 (RP-5) and Volume I, Chapter 7 (RP-1) along with an assumed volatile solids reduction (VSR) achieved in the digesters (60%) and gas production ratio (15 ft³/lb VS destroyed). For RP-5 SHF, the gas production was estimated using the food waste quantity projections presented in Volume III, Chapter 8 and the following assumed gas production ratios:

- $3,200 \text{ ft}^3 \text{ per wet ton of EBS}$
 - Based on OCSD pilot study and operational data from EBMUD
- 2,230 ft³ per wet ton of industrial food waste
 - Based on operational data from RP-5 SHF
- Gas production from digestion of FOG was calculated using a VSR of 95%
 - Based on Hyperion FOG study

The gas production estimates from each source are presented in Table 9-1 below.

Table 9-1: Digester Gas Estimates

	Year					
Digester Gas Source	2025	2030	2035	2040	2045	2060
Digester Gas from RP-5 Biosolids Only (annual average)	360	420	460	500	530	570
Digester Gas from RP-5 SHF (annual average)	590	600	620	640	660	700
Digester Gas from RP-1 Biosolids Only (annual average)	600	650	760	730	740	800

9.4 DIGESTER GAS CONDITIONING

Digester gas conditioning will vary depending on the gas utilization alternative selected. For the cogeneration alternatives (described below in Section 9.5), gas conditioning will include the following:

- 1) Hydrogen sulfide (H₂S) removal with iron sponges or other media such as SulfaTreatTM: will remove the H₂S from the digester gas to prevent corrosion in the gas utilization equipment.
- 2) Refrigeration: accomplishes two goals partial removal of siloxanes through condensation and removal of moisture.
- 3) Adsorption: uses activated carbon or silica gel to accomplish the remainder of the siloxane removal.

For the renewable fuel alternatives (described below in Section 9.5), gas conditioning will include the processes above followed by carbon dioxide (CO_2) removal. This process will "upgrade" the digester gas to a quality similar to natural gas, making it usable for CNG or RNG applications upon further compression.

9.5 DEVELOPMENT OF ALTERNATIVES

Five alternatives have been developed for the beneficial use of digester gas. These can be divided into two general categories: cogeneration and production of renewable fuel.

Cogeneration Alternatives

There are three cogeneration alternatives that involve production of power and heat at RP-5. These alternatives include:


- 1) Modification of the existing REEP facility to meet SCAQMD emission regulations
- 2) Add a new microturbine system in addition to the existing REEP
- 3) Add a gas turbine system for combined gas from RP-1 and RP-5 in addition to the existing REEP

Renewable Fuel Alternatives

There are two alternatives that involve the production of renewable fuel with biogas from RP-5 biosolids. These include the following:

- 1) Production of RNG for injection into SoCal Gas pipeline
- 2) Production of CNG for vehicle fuel

All five alternatives are outlined below in Figure 9-3.





9.5.1 Alternative 1: Use Existing REEP Capacity

This alternative considers using the existing capacity of the two 1.5-MW internal combustion engines to consume digester gas from RP-5 biosolids and RP-5 SHF food waste. Any excess gas beyond the capacity of the two REEP engines will be used at the boiler facility to heat the digesters.

9.5.1.1 Description of Alternative

As described in Section 9.1.3, there are two 1.5-MW internal combustion engines currently installed inside the REEP building at RP-5. In order to comply with stricter NOx emissions per SCAQMD Rule 1110.2, this alternative considers the installation of two SCR units, one for each of the two internal combustion engines, including required gas conditioning upstream.

This alternative also includes modifications to the existing REEP heat recovery system to make it operational. This includes using the existing heat recovery silencer, adding heat exchangers, and pumps. A preliminary schematic of the proposed modifications is shown in Figure 9-4 below.

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 9: Evaluation of Beneficial Use of RP-5 Digester Gas




Figure 9-4: Preliminary Schematic of the Modified Heat Recovery System at RP-5 REEP

In addition, the food waste projections indicate that the gas quantity at SHF will increase in the coming years. Therefore, additional equipment is required to handle the increased digester gas produced at SHF. It is estimated that two additional iron sponge vessels of similar capacity to existing will be required for H₂S removal. Based on the information available, the compressors, gas storage, and the flare at SHF are adequate for the increased gas quantities. A process flow schematic for Alternative 1 is shown below in Figure 9-4.




Figure 9-5: Alternative 1 Process Flow Schematic

9.5.1.2 Design Criteria

Power and heat production and estimates were calculated based on the following data from REEP operations:

- Internal combustion engine electrical efficiency = 37%
- Internal combustion engine thermal efficiency = 38%
- Digester gas has energy content of 580 British thermal units (BTUs)/ ft³.

The heat generation and power production potential estimates based on the gas availability are shown below in Table 9-2.

		2025	2030	2035	2040	2045	2060
Power (kW)	RP-5 Biosolids Only	1,342	1,576	1,720	1,875	1,992	2,138
	RP-5 SHF food waste + FOG	2,217	2,281	2,342	2,407	2,474	2,642
Heat (MMBTU/hr)	RP-5 Biosolids Only	4.7	5.5	6.0	6.6	7.0	7.5
	RP-5 SHF food waste + FOG	7.8	8.0	8.2	8.4	8.7	9.3
Totals	Power: RP-5 + SHF (kW)	3,559	3,857	4,062	4,282	4,466	4,780
	Heat: RP-5 + SHF (MMBTU/hr)	12.5	13.5	14.2	15.0	15.7	16.8

Table 9-2: Alternative 1 Power and Heat Production Potential Estimates

The power production and heat generation estimates are based on projections of food waste, FOG, and biosolids. Due to the inherent uncertainty of these projections, it is prudent to delay the installation of a third internal combustion engine until the actual availability of the digester feedstocks is determined. In case of excess digester gas availability, gas could be used in a new boiler facility at RP-5 to heat the digesters to thermophilic temperatures. Average heat demand for the digesters is estimated to range from 2.8 million BTU (MMBTU)/hour (hr) in 2023 to 4.9 MMBTU/hr in 2060, which is less than the projected heat recovery from the internal combustion engines. Thus, in the business case evaluation (BCE) calculations credit has only been taken for offsetting natural gas purchases up to the annual average digester heating requirement. Furthermore, in BCE calculations, credit for power production has only been taken up to the installed capacity of REEP – 3 MW.

Parsons recommends using the capacity of the existing REEP engines until the food waste program is mature and the quantities of food waste and FOG received at RP-5 SHF require the installation of a third internal combustion engine. Alternatively, digester gas beyond the capacity of the existing REEP engines could be used to explore renewable fuel alternatives, which will be described in more detail in Sections 9.5.4 and 9.5.5.

9.5.1.3 Site Layout

A proposed site layout for Alternative 1 is shown in Figure 9-6. The proposed location of the gas conditioning system is tentative.

INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 9: Evaluation of Beneficial Use of RP-5 Digester Gas




Figure 9-6: Alternative 1 – Proposed Site Layout

9.5.1.4 Capital and Operations and Maintenance (O&M) costs

Capital and O&M costs were calculated based on preliminary quotes from vendors and experience from past projects with the following assumptions:

- 1. Unit cost for operation and maintenance on internal combustion engines is assumed to be 2.5 cents per kilowatt-hour (kWh).
- 2. Power production offsets electricity costs at 12.5 cents per kWh.
- 3. Heat production offsets natural gas costs at 50 cents per therm.
- 4. Uptime for cogeneration technologies is assumed to be 90%.

Table 9-3 shows the capital cost estimate and Table 9-4 shows the O&M cost estimate associated with this alternative.

Table 9-3: Alternative 1	Capital Costs
--------------------------	---------------

Item	Cost
Two (2) Selective Catalytic Converters	\$1,002,000
Gas Conditioning System at RP-5	\$1,845,000
Gas Conditioning System at SHF	\$645,000
Existing REEP Heat Recovery System Modifications	\$505,000
Alternative 1 Base Cost	\$4,006,000
Overhead & Profit, Inflation, Bonds & Insurances, Contingency	\$2,604,000
Total Construction Cost	\$6,610,000
Design & Administration (20%)	\$1,322,000
Total Project Cost	\$7,932,000

Item	Savings		
O&M – includes labor, power (including parasitic loads), and chemicals	(\$802,000)		
Repair and replacement of equipment parts	(\$70,000)		
Savings – beneficial use of digester gas (power and heat)	\$3,156,000		
Net Annual Savings	\$2,284,000		

Table 9-4: Alternative 1 – 2045 O&M Costs and Savings

9.5.2 Alternative 2: New Cogeneration System at RP-5 (Microturbines)

This alternative considers a new cogeneration system using microturbines at RP-5. Microturbines were considered as the cogeneration technology of choice for this alternative because they are modular in nature and could potentially meet SCAQMD emission regulations without any exhaust treatment.

9.5.2.1 Description of Alternative

For this alternative, a new cogeneration system (microturbines) is proposed for the gas from RP-5 biosolids only. The gas from RP-5 SHF will continue to be sent to the existing two internal combustion engines at the REEP facility. A process flow schematic for Alternative 2 is shown below in Figure 9-7.




Figure 9-7: Alternative 2 Process Flow Schematic

9.5.2.2 Design Criteria

Power and heat production estimates were calculated based on the following assumptions:

• Microturbine electrical efficiency = 30%.

- Microturbine thermal efficiency = 35%.
- Internal combustion engine electrical efficiency = 37%.
- Internal combustion engine thermal efficiency = 38%.
- Digester gas has energy content of 580 BTU/ft³.

The power and heat production potential estimates based on the gas availability are shown below in Table 9-5 for Alternative 2 which considers the installation of seven 250 kW microturbines.

		2025	2030	2035	2040	2045	2060
Power (kW)	RP-5 Biosolids Only (microturbines)	1,088	1,278	1,394	1,520	1,615	1,734
	SHF food waste + FOG (internal combustion engines)	2,217	2,281	2,342	2,407	2,474	2,642
Heat (MMBTU/hr)	RP-5 Biosolids Only (microturbines)	4.3	5.1	5.6	6.1	6.4	6.9
	SHF food waste + FOG (internal combustion engines)	7.8	8.0	8.2	8.4	8.7	9.3
Totals	Power: RP-5 + SHF (kW)	3,305	3,559	3,737	3,927	4,089	4,375
	Heat: RP-5 + SHF (MMBTU/hr)	12.1	13.1	13.8	14.5	15.1	16.2

Table 9-5: Alternative 2 Power and Heat Production Potential Estimates

9.5.2.3 Site Layout

The proposed location for the microturbines is shown in Figure 9-8 below. The microturbines can be located outdoors on a concrete pad, possibly with a canopy, but do not have to be located within a building.



Figure 9-8: Alternative 2 – Proposed Site Layout

9.5.2.4 Capital and O&M costs

Capital and O&M costs were calculated based on preliminary quotes from vendors and experience from past projects with the following assumptions.

- 1. O&M cost for microturbines is assumed to be 3 cents per kWh.
- 2. Uptime for both cogeneration technologies is assumed to be 90%.
- 3. Power production offsets electricity costs at 12.5 cents per kWh.
- 4. Heat production offsets natural gas costs at 50 cents per therm.

Table 9-6 shows the capital cost estimate and Table 9-7 shows the O&M cost estimate associated with this alternative.

Item	Cost
Seven (7) 250 kW microturbines and associated equipment	\$10,329,000
Gas Conditioning System at RP-5	\$1,845,000
Microturbines Compression Station	\$738,000
Two (2) Selective Catalytic Converters	\$1,002,000
Existing REEP Heat Recovery System Modifications	\$505,000
Gas Conditioning at SHF	\$654,000
Alternative 2 Base Cost	\$15,073,000
Overhead & Profit, Inflation, Bonds & Insurances, Contingency	\$9,797,000
Total Construction Cost	\$24,870,000
Design & Administration (20%)	\$4,974,000
Total Project Cost	\$29,844,000

Table 9-6: Alternative 2 Capital Costs

Table 9-7: Alternative 2 – 2045 O&M Costs and Savings

Item	Savings		
O&M – includes labor, power (including parasitic loads), and chemicals	(\$1,156,000)		
Repair and replacement of equipment parts	(\$140,000)		
Savings – beneficial use of digester gas (power and heat)	\$4,229,000		
Net Annual Savings	\$2,933,000		

9.5.3 Alternative 3: Centralized Cogeneration – Transfer DG from RP-1 to RP-5

In this alternative, a centralized cogeneration facility is proposed to use gas from both RP-1 and RP-5. At the proposed scale, gas turbines are offer the most efficient combined heat and power system.

9.5.3.1 Description of Alternative

This alternative includes the installation of an interconnecting biogas pipeline between RP-1 and RP-5, as shown in Figure 9-9 below. It is assumed that the easement for the existing primary effluent sewer line between RP-1 and RP-5 will be used to install the proposed digester gas pipeline.



INLAND EMPIRE UTILITIES AGENCY RP-1 REHABILITATION AND RP-5 EXPANSION Pre-Design Report Volume III, Chapter 9: Evaluation of Beneficial Use of RP-5 Digester Gas



Figure 9-9: RP-1 to RP-5 Gas Pipeline – Potential Alignment

Potential constraints for this pipeline include permitting from the California Environmental Quality Act (CEQA), local businesses, public and private easements and increased O&M activities involving booster stations, purge stations, condensate traps, and leak detection. Figure 9-10 shows the proposed process flow schematic for this Alternative. RP-1 gas must be treated onsite before being sent to RP-5 to minimize corrosion and condensate accumulation in the cross-country pipeline.




Figure 9-10: Alternative 3 Process Flow Schematic

9.5.3.2 Design Criteria

Power and heat production estimates were calculated based on the following assumptions:

- Gas turbines electrical efficiency = 38%.
- Gas turbines thermal efficiency = 35%.
- Internal combustion engines electrical efficiency = 37%.
- Internal combustion engines thermal efficiency = 38%.
- Digester gas has energy content of 580 BTU/ft³.

The power production potential projections based on the gas availability are shown below in Table 9-8.

		2025	2030	2035	2040	2045	2060
Power (kW)	RP-1 + RP-5 Biosolids (gas turbines)	3,714	4,119	4,703	4,743	4,929	5,275
	RP-5 SHF food waste + FOG (internal combustion engines)	2,217	2,281	2,342	2,407	2,474	2,642
Heat (MMBTU/hr	RP-1 + RP-5 Biosolids (gas turbines)	11.7	13.0	14.8	14.9	15.5	16.6
)	RP-5 SHF food waste + FOG (internal combustion engines)	7.8	8.0	8.2	8.4	8.7	9.3
Totals	Power: RP-1 + RP-5 + SHF (kW)	5,930	6,400	7,045	7,150	7,403	7,917
	Heat: RP-1 + RP-5 + SHF (MMBTU/hr)	19.4	20.9	23.0	23.4	24.2	25.9

Table 9-8: Alternative 3 Power and Heat Production Potential Estimates

The projected power production potential in 2045 is approximately 4.9 MW. The only commercially available gas turbine on the market that can meet the SCAQMD emissions is a Solar Mercury Turbine at 4.6 MW capacity. Thus, only one 4.6 MW gas turbines is recommended in this alternative, with room for one additional turbine in the future. Any excess gas beyond the capacity of one gas turbine can be used in boilers.

9.5.3.3 Site Layout

The proposed site layout for Alternative 3 is shown in Figure 9-11 below.



Figure 9-11: Alternative 3 – Proposed Site Layout

9.5.3.4 Capital and O&M costs

Capital and O&M costs were calculated based on preliminary quotes from vendors and experience from past projects with the following assumptions:

- 1. O&M cost for 4.6 MW gas turbine is \$25,000 per month.
- 2. Uptime for both cogeneration technologies is assumed to be 90%.
- 3. Power production offsets electricity costs at 12.5 cents per kWh.
- 4. Heat production offsets natural gas costs at 50 cents per therm.

Estimated capital costs for Alternative 3 are shown in Table 9-9 and estimated O&M costs and savings for the year 2045 are shown in Table 9-10.

Table 9-9: Alternative 3 Capital Costs

Item	Cost
One (1) 4.6 MW Gas Turbines and associated equipment	\$12,912,000
RP-5 Gas Conditioning System	\$1,845,000
RP-1 Gas Conditioning System	\$2,767,000
Gas Turbines Compression Station	\$1,845,000
RP-1 to RP-5 Gas Pipeline (8 miles, 12-inch diameter)	\$12,100,000
RP-1 Compression Station	\$461,000
Two (2) Selective Catalytic Converters	\$1,002,000
Existing REEP Heat Recovery System Modifications	\$505,000
Gas Conditioning at SHF	\$654,000
Alternative 3 Base Cost	\$34,091,000
Overhead & Profit, Inflation, Bonds & Insurances, Contingency	\$22,159,000
Total Construction Cost	\$56,250,000
Design & Administration (20%)	\$11,250,000
Total Project Cost	\$67,500,000

Item	Savings
O&M – includes labor, power (including parasitic loads), and chemicals	(\$2,253,000)
Repair and replacement of equipment parts	(\$215,000)
Savings - beneficial use of digester gas (power and heat)	\$7,171,000
Net Annual Savings	\$4,703,000

Table 9-10: Alternative 3 – 2045 O&M Costs and Savings

9.5.4 Alternative 4: Convert DG to Pipeline-Quality Natural Gas

In Alternative 4, digester gas will be converted to high-quality natural gas that can be directly injected into the available SoCal gas pipeline in the vicinity of the treatment plant.

9.5.4.1 Description of Alternative

Alternative 4 considers the conversion of digester gas generated at RP-5 to RNG. In addition to moisture, H_2S , and siloxane removal required for cogeneration, the biogas will undergo CO_2 stripping before compression and injection to a SoCal Gas pipeline. The CO_2 stripping process will reduce the quantity of gas available for injection by approximately 40%. This alternative considers the continuation of the current REEP operation with gas from RP-5 SHF. Figure 9-12 shows the proposed schematic for this alternative.




Figure 9-12: Alternative 4 Process Flow Schematic

9.5.4.2 Applicable Incentives

One of the primary market drivers to produce RNG is the applicable incentives. There are two incentive programs applicable to this project: Renewable Fuel Standards (RFS) by the US Environmental Protection Agency (EPA) and Low Carbon Fuel Standard (LCFS) by the California Air Resources Board (CARB).

Renewable Fuel Standards (RFS) Program: This program, administered by the EPA, encourages the production of renewable fuel such as CNG as transportation fuel or indirect renewable fuel consumption due to pipeline injection. RFS credits are calculated based on the Renewable Identification Numbers (RINs) generated. In other words, RINs are the currency for the RFS program.

Low Carbon Fuel Standard (LCFS) Program: The LCFS program is part of a statewide California rule enacted in 2007. The program involves a market-based cap and trade system in which producers of low-carbon renewable fuels can sell or trade credits based on the quantity of the fuel produced.

While these incentives have the potential to make the economics of renewable fuel alternatives favorable, the current incentive market is volatile. It was noted that these incentives have dropped significantly in the recent past, and this volatility will affect the economics of these alternatives accordingly.

Both RFS and LCFS incentives are intended to promote renewable fuels in the transportation industry. Therefore, for pipeline injection, it is estimated that the available incentives will be approximately half of the incentives for production of CNG for vehicle fuel.

9.5.4.3 Design Criteria

Alternative 4 gas quantity projections are shown below in Table 9-11. Methane content in digester gas is approximately 60% and methane recovery in the CO₂ removal process is about 90%.

	Year							
RP-5 Digester Gas	2025	2030	2035	2040	2045	2060		
Digester Gas before CO ₂ Removal (scfm)	360	420	460	500	530	570		
RNG (scfm)	190	230	250	270	290	310		
RNG (therms/year)	1,010,000	1,186,000	1,294,000	1,411,000	1,499,000	1,609,000		

Table 9-11: Alternative 4 Gas Quantity Projections

9.5.4.4 Site Layout

The proposed site layout for Alternative 4 is shown in Figure 9-13 below.



Figure 9-13: Alternative 4 - Proposed Site Layout

9.5.4.5 Capital and O&M costs

In addition to gas treatment, this alternative considers the cost of a 1-mile pipeline extension to the nearest SoCal Gas pipeline with adequate capacity. The estimated interconnection fee charged by SoCal Gas is also included. The following assumptions are made in estimating the costs:

- 1. RNG sale = 0.50 per therm.
- 2. RIN Incentive = \$0.665 per gallon of gas equivalent (GGE)
- 3. LCFS Incentive = \$4.415 per MMBTU.
- 4. Uptime for cogeneration technologies is assumed to be 90%.
- 5. Power production offsets electricity costs at 12.5 cents per kWh.
- 6. Heat production offsets natural gas costs at 50 cents per therm.

Capital costs for Alternative 4 are shown in Table 9-12 and O&M costs and savings in 2045 are shown in Table 9-13.

Item	Cost
RP-5 Gas Conditioning System (H ₂ S and Siloxane Removal)	\$1,845,000
CO ₂ Removal System	\$2,213,000
Low Pressure Compression Station	\$922,000
Pipeline Extension (1 mile)	\$968,000
Point of Receipt Fee	\$2,420,000
Two (2) Selective Catalytic Converters for existing internal combustion engines	\$1,002,000
Existing REEP Heat Recovery System Modifications	\$505,000
Gas Conditioning at SHF	\$654,000
Alternative 4 Base Cost	\$10,529,000
Overhead & Profit, Inflation, Bonds & Insurances, Contingency	\$6,844,000
Total Construction Cost	\$17,373,000
Design & Administration (20%)	\$3,474,600
Total Project Cost	\$20,847,600

Table 9-12: Alternative 4 Capital Costs

Item	Savings
O&M – includes labor, power (including parasitic loads), and chemicals	(\$861,000)
Repair and replacement of equipment parts	(\$34,000)
Power and Heat Production – Existing REEP Engines	\$2,438,000
RNG sale	\$675,000
RIN Incentives	\$787,000
LCFS Incentives	\$596,000
Net Annual Savings	\$3,601,000


Table 9-13: Alternative 4 – 2045 O&M Costs and Savings

9.5.5 Alternative 5: Convert DG to Compressed Natural Gas (CNG) for Vehicular Fuel

In this alternative, digester gas will be used to produce CNG for vehicular fuel.

9.5.5.1 Description of Alternative

In addition to CO_2 removal, a high pressure storage and filling station for vehicles will be required under this alternative. Economic viability of this alternative depends on the applicable incentives as well as utilizing all the produced CNG as vehicular fuel, which requires a large fleet of CNG vehicles (see Table 9-14 below). Figure 9-14 shows the proposed schematic for Alternative 5.





9.5.5.2 Applicable Incentives

The same incentive programs for RNG fuel discussed in the previous section (RFS and LCFS) apply to production of CNG fuel. However, CNG production receives the full credits under both programs, while RNG receives only half of the credit.

9.5.5.2.1 Design Criteria

As in Alternative 4, methane content of digester gas is 60% and methane recovery is about 90%. The gas quantities for Alternative 5 are shown in Table 9-14 below.

	Year							
RP-5 Digester Gas	2025	2030	2035	2040	2045	2060		
Digester Gas before CO2 Removal (scfm)	360	420	460	500	530	570		
CNG (scfm)	190	230	250	270	290	310		
CNG (GGE/year)	886,000	1,041,000	1,135,000	1,238,000	1,315,000	1,411,000		

Table 9-14: Alternative 5 Gas Quantity Projections

9.5.5.2.2 Site Layout

The proposed site layout for Alternative 5 is shown in Figure 9-15 below.



Figure 9-15: Alternative 5 – Proposed Site Layout

9.5.5.2.3 Capital and O&M costs

For this alternative a high-pressure compression station as well as CNG storage and filling station were considered in addition to the gas treatment and CO₂ removal systems. The assumptions used to estimate costs are as follows:

- 1. Sale of CNG = \$1.50 per GGE
- 2. RIN Incentives = \$1.33 per GGE
- 3. LCFS Incentives = \$8.83 per MMBTU
- 4. Uptime for cogeneration technologies is assumed to be 90%.
- 5. Power production offsets electricity costs at 12.5 cents per kWh.
- 6. Heat production offsets natural gas costs at 50 cents per therm.

The estimated capital costs for Alternative 5 are shown in Table 9-15 and the 2045 O&M costs and savings are shown in Table 9-16.

Item	Cost
RP-5 Gas Conditioning System (H ₂ S and Siloxane Removal)	\$1,845,000
CO ₂ Removal System	\$2,213,000
High Pressure Compression Station	\$1,845,000
CNG Filling Station/Storage	\$1,845,000
Two (2) Selective Catalytic Converters	\$1,002,000
Existing REEP Heat Recovery System Modifications	\$505,000
Gas Conditioning at SHF	\$654,000
Alternative 5 Base Cost	\$9,909,000
Overhead & Profit, Inflation, Bonds & Insurances, Contingency	\$6,441,000
Total Construction Cost	\$16,350,000
Design & Administration (20%)	\$3,270,000
Total Project Cost	\$19,620,000

Table 9-15: Alternative 5 Capital Costs

Table 9-16: Alternative 5 – 2045 O&M Costs and Savings

Item	Savings
O&M – includes labor, power, and chemicals	(\$961,000)
Repair and replacement of equipment parts	(\$64,000)
Power Production – Existing REEP Engines	\$2,438,000
Savings – RNG sale	\$1,775,000
RIN Incentives	\$1,574,000
LCFS Incentives	\$1,191,000
Net Annual Savings	\$5,954,000

9.6 DIGESTER GAS STORAGE EVALUATION

Digester gas production varies depending on changes in organic loading parameters and operating conditions. Gas storage is important because it provides equalization of gas flows, hence facilitating smooth operation of gas conditioning equipment as well as maximizing the cogeneration potential of digester gas. For the digester gas produced in excess of the amount that can be stored or utilized beneficially, waste gas flares are provided to burn the excess gas. For details regarding digester gas storage, refer to Chapter 7.5 on Digester Gas Storage and Flares.

9.7 **BUSINESS CASE EVALUATION (BCE)**

9.7.1 Introduction

A BCE was performed to determine the alternative with the lowest life-cycle cost. The following assumptions were used in the analysis.

• Internal combustion engine electrical efficiency = 37%.

- Internal combustion engine thermal efficiency = 38%.
- Microturbines electrical efficiency = 30%.
- Microturbines thermal efficiency = 35%.
- Gas turbines electrical efficiency = 38%.
- Gas turbines thermal efficiency = 35%.
- Cogeneration system uptime = 90%.
- Power produced offsets electricity costs at \$0.125/kWh.
- Heat recovered offsets natural gas costs at \$0.50/therm.
- Benefits from heat recovery were only considered up to the annual average heat demand of the digesters.
- Power production from internal combustion engines was limited to the existing capacity (3 MW) for the BCE.
- Gas from RP-5 SHF is sent to the existing RP-5 REEP engines in all alternatives, however, not all gas generated can be used in the engines in Alternative 1.

9.7.2 BCE Results

BCE results are summarized below in Table 9-17.

Table 9-17: BCE Results Summary

Inland Empire Utilities Agency									
UTILITIES AGENCY Alternatives Net Present Value Analysis									
Agency:	Inland Empire Utilities Agency		R	esults (\$000s)					
Project/Problem:			Capital Cost	30-year NPV	Benefit over 'Do Nothing'				
Alternative 1	DG Alt 1 - Existing IC Engines		\$7,932,000	\$17,994,618					
Alternative 2	DG Alt 2 - Microturbines		\$29,844,000	\$40,984,453	\$22,989,836				
Alternative 3	DG Alt 3 - Centralized Cogen w/ Gas Turbines		\$67,500,000	\$49,994,494	\$31,999,876				
Alternative 4	DG Alt 4 - RNG for Pipeline Injection		\$20,847,600	\$2,418,047	(\$15,576,571)				
Alternative 5	DG Alt 5 - CNG for Vehicle Fuel		\$19,620,000	\$57,917,283	\$39,922,665				
Year of analysis: Escalation rate: Discount rate:	2016 3.00% 2.00%								

9.8 CONCLUSIONS AND RECOMMENDATIONS

9.8.1 Conclusions

This analysis is subject to some level of uncertainty, especially regarding the food waste quantities. The collection program is not yet mature, so the projected food waste quantities may not be fully realized for several years. Due to uncertainty in the quantity of food waste that will actually be collected and digested at RP-5 SHF, it is prudent to utilize the capacity of the existing REEP facility to its fullest before installing additional energy recovery facilities. Therefore, Parsons

recommends the Agency pursue Alternative 1 in this project while exploring alternative digester gas utilization technologies in the future, such as conversion to RNG/CNG.

9.8.2 Recommended Alternative

Parsons recommends Alternative 1, which includes installing new SCR units on each of the existing internal combustion engines, a new gas conditioning system (H_2S and siloxane removal) to treat RP-5 digester gas, an expanded H_2S removal system for RP-5 SHF gas, and modifications to the RP-5 REEP heat recovery system. The schematic for this alternative is shown below in Figure 9-16. A preliminary layout for the new gas conditioning system at RP-5 is shown in Figure 9-17 below.




Figure 9-16: Recommended Alternative Gas Utilization Schematic




Figure 9-17: Preliminary Gas Conditioning System Layout

THIS PAGE INTENTIONALLY LEFT BLANK.



RP-5 Solids Treatment Facility Business Case Evaluations and Detailed Cost Estimates



submitted by



in association with



	Mountain Ave. Lift Station - Pre-packaged							
		Estimate			•			
Item No.	Description	No. of Items	Units	Quantity		Unit Cost (\$)		Cost (\$)
	EQUIPMENT							
1	Pre-packaged Lift Station			1	\$	112,000	\$	112,000
2	Excavation			1	\$	14,000	\$	14,000
	Equipment Installation		%			15%		\$16,800
	Electrical & Instrumentation, SCADA interface		%			15%		\$16,800
	FITTINGS, VALVES, FLOW METER							
3	8"x6" Reducer			2	\$	239	\$	500
4	8-inch 90-degree elbow			4	\$	350	\$	1,400
5	8-inch tee			1	\$	521	\$	521
6	Quick disconnect			1	\$	1,200	\$	1,200
	Equipment Installation		%			45%		\$1,629
	PIPELINE							
7	8-inch Pipeline	50	ft	1	\$	192	\$	10,000
8	10-inch Pipeline	40	ft	1	\$	200	\$	8,000
9	8-inch Pipeline	3100	ft	1	\$	192	\$	595,000
	MANHOLE MODIFICATIONS							
10	Connect to Kimball manhole, add diversion manhole			1	\$	20,000	\$	20,000
	SITE IMPROVMENTS							
11	Block Wall			1	\$	9,700	\$	9,700
12	AC Pavement			1		\$22,000	\$	22,000
13	Slide Gate			2	\$	9,000	\$	18,000
14	Security Gate			1		\$3,200	\$	3,200
15	Fence			1	\$	7,425	\$	7,425
	Total Equipment and Structures Cost							\$858,000
3.1	Sales Tax		%			9%		\$28,400
	Unit Cost Estimate							\$886,000




Inland Empire Utilities Agency IEBL Discharge Station Relocation Alternatives Net Present Value Analysis


Agency:	Inland Empire Utilities Agency	Results (\$000s)				
Project/Problem:			Capital Cost	30-year NPV	Benefit over 'Do Nothing'	
Alternative 1	Alternative 1 - West of CCWRF Headworks	\$	340,000	(\$568,958)		
Alternative 2	Alternative 2 - Northeast of RP-5	\$	1,080,000	(\$1,949,540)	(\$1,380,582)	
Alternative 3	Alternative 3 - North of SHF	\$	800,000	(\$1,084,643)	(\$515,685)	
Alternative 4					\$568,958	
Alternative 5					\$568,958	
Year of analysis:	2016					
Escalation rate:	3.00%					

Make entries in yellow cells only.


Discount rate: 2.00%



Total risk-stjusted capital outlay: \$340,000 Alemañve: 1 Row: 1 SummarvA8 Alemañve: SummarvA8 Alemañve: SummarvA8 Alemañve: SummarvA8 Benefit sens: SummarvA8 Benefit sens: SummarvA8 Benefit sens: SummarvA8 Benefit sens:



Total risk-stjusted capital outlay: \$1,080,000 Alemañve: 1 Row: 8 SummarvA8 Alemañve: SummarvA8 Alemañve: SummarvA8 Alemañve: SummarvA8 Alemañve: SummarvA8 Benefit sens: SummarvA8 Benefit sens: SummarvA8 Benefit sens:



Totel risk-sdjusted capital outlays: \$800,000 Alternative: 1 Rov: 8 Summar/A8 Summar/A

		West of CCWR Cost Estimate	F Head	works		
ltem No.	Description	No. of Items	Units	Quantity	Unit Cost (\$)	Cost (\$)
	Piping					
1	8-inch Pipeline	120	ft	1	\$ 192	\$23,000
	STRUCTURES					
2	New IEBL Structures			1	\$ 11,300	\$11,300
3	Manhole			1	\$ 4,800	\$4,800
4	Excavation			1	\$ 15,000	\$15,000
5	Installation		%		15%	\$2,415
	EQUIPMENT					
6	Equipment Relocation		LS	1	\$10,000	\$10,000
	CIVIL WORK					
7	Wall Demolition			1	\$ 1,400	\$1,400
8	Asphalt Paving			1	\$ 68,000	\$68,000
9	Restoration Driveway			1	\$ 7,400	\$7,400
10	Vegetation Removal			1	\$ 10,500	\$10,500
	SITE IMPROVEMENTS					
11	Security gate, card reader, bollards			1	\$ 10,000	\$10,000
12	Electrical & Instrumentation		%		15%	\$1,500
	Total Equipment Cost					
	Subtotal of above items					\$165,000
3.1	Sales Tax		%		9%	\$4,400
	Construction Cost Estimate					\$170,000

	Alternative 2 -	• Northeast	of RP-	5		
	Cost	Estimate				
Item No.	Description	No. of Items	Units	Quantity	Unit Cost (\$)	Cost (\$)
	Equipment					
1	4-inch Pipeline	2100	ft	1	\$ 96	\$202,000
2	8-inch Pipeline	300	ft	1	\$ 192	\$58,000
	LIFT STATION					
3	Lift Station - Pumps and Control Panel			2	\$14,000	\$28,000
	Equipment Installation			1	45%	\$12,600
4	Wet well			1	\$ 17,000	\$17,000
	Excavation			1	\$21,000	\$21,000
	CONTROL PANEL					
5	Control Panel			1	\$ 30,000	\$ 30,000
	Installation		%		15%	\$4,500
	STRUCTURES					
6	IEBL Structures			1	\$ 11,300	\$11,300
7	Manhole			1	\$ 5,000	\$5,000
	Installation			1	15%	\$2,445
	Excavation			1	\$ 17,000	\$17,000
	CIVIL WORK					
8	Asphalt Paving			1	\$ 89,000	\$89,000
	SECURITY					
9	Security gate, card reader, bollards			1	\$ 18,000	\$18,000
10	Electrical & Instrumentation		%		15%	\$2,700
	EQUIPMENT					
11	Equipment Relocation		LS	1	\$10,000	\$10,000
	Total Equipment Cost					
	Total Equipment and Structures Cost					\$529,000
3.1	Sales Tax		%		9.000%	\$17,100
	Construction Cost Estimate					\$546,000

	Alternative Cost	3 - North o Estimate	f SHF				
Item No.	Description	No. of Items	Units	Quantity	Un	it Cost (\$)	Cost (\$)
	Piping						
1	8-inch Pipeline	750	ft	1	\$	192	\$144,000
	STRUCTURES						
2	IEBL Structures			1	\$	11,300	\$11,300
3	Manhole			1	\$	7,000	\$7,000
	Installation			1		15%	\$2,745
	Excavation			1	\$	15,000	\$15,000
	CIVIL WORK						
4	Asphalt Paving			1	\$	186,000	\$186,000
	SECURITY						
6	Security gate, card reader, bollards			1	\$	15,000	\$15,000
	Electrical & Instrumentation		%			15%	\$2,250
	EQUIPMENT						
7	Equipment Relocation		LS	1		\$10,000	\$10,000
	Total Equipment Cost						
	Subtotal of above items						\$393,000
3.1	Sales Tax		%			9.000%	\$11,000
	Construction Cost Estimate						\$404,000

	IEU	A - Alt	ernativ	/e 1 -	O&M Co	osts			
ltem No.	Description	No. of Duty	Power I	Demand	Operating			Unit Cost	Annual Cost
1	Power	Units	hp	kW	Hours/ year	kW-Hrs	Units	(\$)	(\$)
	Total power cost								\$-
Item No.	Description								
								Unit Cost	Annual Cost
3	Major Equipment Replacement						Units	(\$)	(\$)
3.1	General Repair and Replacement						LS		1,200
	Total equipment replacement cost								\$ 1,200
Item No.	Description				Labor				
					Hours /				Annual Cost
4	Labor				year		Units	Unit Cost	(\$)
4.1					80		\$/hr	85	6,800
	Total labor cost								\$ 6,800
	TOTAL ANNUAL COST								\$ 8,000

	IEU	A - Alt	ernativ	/e 2 - (O&M Co	osts			
Item No.	Description	No. of Duty	Power [Demand	Operating			Unit Cost	Annual Cost
1	Power	Units	hp	kW	Hours/ year	kW-Hrs	Units	(\$)	(\$)
1.1	Influent Pumps	1	5.179674	3.86	4,380	16,924	\$/kW-hr	0.125	2,116
	Total power cost								\$ 2,100
Item No.	Description								
3	Major Equipment Replacement						Units	Unit Cost (\$)	Annual Cost (\$)
3.1	General Repair and Replacement						LS		21,869
	Total equipment replacement cost								\$ 21,900
ltem No. 4	Description Labor	-			Labor Hours / year		Units	Unit Cost	Annual Cost (\$)
4.1					80		\$/hr	85	6,800
	Total labor cost								\$ 6,800
	TOTAL ANNUAL COST								\$ 30,800

	IEU	A - Alt	ernativ	/e 3 -	O&M Co	osts			
ltem No.	Description	No. of Duty	Power I	Demand	Operating			Unit Cost	Annual Cost
1	Power	Units	hp	kW	Hours/ year	kW-Hrs	Units	(\$)	(\$)
	Total power cost								\$-
Item No.	Description								
3	Major Equipment Replacement						Units	Unit Cost (\$)	Annual Cost (\$)
3.1	General Repair and Replacement						LS		2,400
	Total equipment replacement cost								\$ 2,400
Item No.	Description				Labor				
4	Labor				Hours / year		Units	Unit Cost	Annual Cost (\$)
4.1					80		\$/hr	85	6,800
	Total labor cost								\$ 6,800
	TOTAL ANNUAL COST								\$ 9,200

RP-5 Thickening

	-						
nd Empire R	P-5 (2016-2	2, 22-30,	30-45)				
TIES AGENCY Alterna	itives Net Pr	esent Va	lue Ana	lysis			
Inland Empire Utilities Agency		Sensitivi	ty Adjustm	ients (%)		Results (\$)	
RP-5 (2016-22, 22-30, 30-45)	Risk Premium	Benefits	Capital Costs	Running Costs	Capital Cost	20-year NPV	Difference from Highest NPV
DAFT (WAS) and Centrifuges (PS)					\$32,188,778	(\$62,353,741)	(\$35,971,238)
DAFT (WAS) and RDT (PS)					\$24,188,123		
DAFT (WAS) and GBT (PS)					\$25,747,922	(\$49,119,992)	
Centrifuges Separate					\$25,012,381	(\$50,211,462)	(\$23,828,958)
Rotary Drum Thickener Separate					\$12,784,464	(\$26,827,336)	(\$444,832)
Gravity Belt Thickener Separate					\$14,523,769	(\$32,591,733)	(\$6,209,230)
DAFT Co-thickening					\$19,047,354	(\$51,859,560)	(\$25,477,057)
Centrifuges Co-thickening					\$21,469,777	(\$46,737,780)	(\$20,355,277)
Rotary Drum Thickener Co-thickening					\$11,212,164	(\$26,382,504)	\$0
Gravity Belt Thickener Co-thickening					\$11,850,933	(\$32,591,733)	(\$6,209,230)
2016							
3.00%							
2.00%							
	Ind EmpireRInland Empire Utilities AgencyRP-5 (2016-22, 22-30, 30-45)DAFT (WAS) and Centrifuges (PS)DAFT (WAS) and RDT (PS)DAFT (WAS) and GBT (PS)Centrifuges SeparateRotary Drum Thickener SeparateGravity Belt Thickener SeparateDAFT Co-thickeningCentrifuges Co-thickeningRotary Drum Thickener Co-thickeningGravity Belt Thickener Co-thickening20163.00%	Ad EmpireRP-5 (2016-22)Inland Empire Utilities AgencyInland Empire Utilities AgencyRP-5 (2016-22, 22-30, 30-45)Risk PremiumDAFT (WAS) and Centrifuges (PS)IndextDAFT (WAS) and Centrifuges (PS)IndextDAFT (WAS) and GBT (PS)IndextCentrifuges SeparateIndextRotary Drum Thickener SeparateIndextDAFT Co-thickeningIndextCentrifuges Co-thickeningIndextCentrifuges Co-thickeningIndextCatary Drum Thickener Co-thickeningIndext <tr< th=""><th>RP-5 (2016-22, 22-30, Alternatives Net Present VaInland Empire Utilities AgencySensitivitRP-5 (2016-22, 22-30, 30-45)Risk PremiumBenefitsDAFT (WAS) and Centrifuges (PS)DAFT (WAS) and Centrifuges (PS)DAFT (WAS) and GBT (PS)Centrifuges SeparateRotary Drum Thickener SeparateDAFT Co-thickeningCentrifuges Co-thickeningCatry Drum Thickener Co-thickeningContrifuges Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeni</th><th>Inland Empire Utilities Agency Sensitivity Adjustm RP-5 (2016-22, 22-30, 30-45) Risk Premium Benefits Capital Costs DAFT (WAS) and Centrifuges (PS) Image: Cost Cost Cost Cost Cost Cost Cost Cost</th><th>RP-5 (2016-22, 22-30, 30-45)Alternatives Net Present Value AnalysisInland Empire Utilities AgencySensitivity Adjustments (%)RP-5 (2016-22, 22-30, 30-45)Risk PremiumBenefitsCapital CostsRunning CostsDAFT (WAS) and Centrifuges (PS)<!--</th--><th>RP-5 (2016-22, 22-30, 30-45)Alternatives Net Present Value AnalysisInland Empire Utilities AgencySensitivity Adjustments (%)RP-5 (2016-22, 22-30, 30-45)Risk PremiumCapital BenefitsRunning CostsCapital Capital CostsCapital CostsDAFT (WAS) and Centrifuges (PS)<!--</th--><th>RP-5 (2016-22, 22-30, 30-45)Alternatives Net Present Value AnalysisInland Empire Utilities AgencySensitivity Adjustments (%)Results (\$)RP-5 (2016-22, 22-30, 30-45)Risk PremiumCapital CostsRunning CostsCapital Cost20-year NPVDAFT (WAS) and Centrifuges (PS)Emeritian Costs\$32,188,778(\$62,353,741) \$44,188,123\$45,720,340) \$45,720,340)DAFT (WAS) and GBT (PS)Emeritian Costs\$25,747,922(\$49,119,992) \$425,101,381\$26,211,462) \$425,747,922Centrifuges SeparateEmeritian Costs\$12,784,464(\$26,827,336) \$14,523,769\$14,523,769\$32,591,733) \$14,523,769DAFT Co-thickeningEmeritian CostsEmeritian Costs\$11,212,164\$46,737,780) \$14,523,769Rotary Drum Thickener SeparateEmeritian CostsS11,212,164\$46,737,780) \$11,850,933\$11,850,933\$32,591,733) \$11,850,9332016 3.00%S10,0%S11,850,933\$11,850,933\$11,850,933\$12,781,733) \$11,850,933</br></br></th></br></th></th></tr<>	RP-5 (2016-22, 22-30, Alternatives Net Present VaInland Empire Utilities AgencySensitivitRP-5 (2016-22, 22-30, 30-45)Risk PremiumBenefitsDAFT (WAS) and Centrifuges (PS)DAFT (WAS) and Centrifuges (PS)DAFT (WAS) and GBT (PS)Centrifuges SeparateRotary Drum Thickener SeparateDAFT Co-thickeningCentrifuges Co-thickeningCatry Drum Thickener Co-thickeningContrifuges Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeningContributer Co-thickeni	Inland Empire Utilities Agency Sensitivity Adjustm RP-5 (2016-22, 22-30, 30-45) Risk Premium Benefits Capital Costs DAFT (WAS) and Centrifuges (PS) Image: Cost Cost Cost Cost Cost Cost Cost Cost	RP-5 (2016-22, 22-30, 30-45)Alternatives Net Present Value AnalysisInland Empire Utilities AgencySensitivity Adjustments (%)RP-5 (2016-22, 22-30, 30-45)Risk PremiumBenefitsCapital CostsRunning CostsDAFT (WAS) and Centrifuges (PS) </th <th>RP-5 (2016-22, 22-30, 30-45)Alternatives Net Present Value AnalysisInland Empire Utilities AgencySensitivity Adjustments (%)RP-5 (2016-22, 22-30, 30-45)Risk PremiumCapital BenefitsRunning CostsCapital Capital CostsCapital CostsDAFT (WAS) and Centrifuges (PS)<!--</th--><th>RP-5 (2016-22, 22-30, 30-45)Alternatives Net Present Value AnalysisInland Empire Utilities AgencySensitivity Adjustments (%)Results (\$)RP-5 (2016-22, 22-30, 30-45)Risk PremiumCapital CostsRunning CostsCapital Cost20-year NPVDAFT (WAS) and Centrifuges (PS)Emeritian Costs\$32,188,778(\$62,353,741) \$44,188,123\$45,720,340) \$45,720,340)DAFT (WAS) and GBT (PS)Emeritian Costs\$25,747,922(\$49,119,992) \$425,101,381\$26,211,462) \$425,747,922Centrifuges SeparateEmeritian Costs\$12,784,464(\$26,827,336) \$14,523,769\$14,523,769\$32,591,733) \$14,523,769DAFT Co-thickeningEmeritian CostsEmeritian Costs\$11,212,164\$46,737,780) \$14,523,769Rotary Drum Thickener SeparateEmeritian CostsS11,212,164\$46,737,780) \$11,850,933\$11,850,933\$32,591,733) \$11,850,9332016 3.00%S10,0%S11,850,933\$11,850,933\$11,850,933\$12,781,733) \$11,850,933</br></br></th></br></th>	RP-5 (2016-22, 22-30, 30-45)Alternatives Net Present Value AnalysisInland Empire Utilities AgencySensitivity Adjustments (%)RP-5 (2016-22, 22-30, 30-45)Risk PremiumCapital BenefitsRunning CostsCapital Capital CostsCapital 	RP-5 (2016-22, 22-30, 30-45)Alternatives Net Present Value AnalysisInland Empire Utilities AgencySensitivity Adjustments (%)Results (\$)RP-5 (2016-22, 22-30, 30-45)Risk

From Summary Sheet:		Risk adjustme	nts (+/- percent)	:									Inland Em	pire Utilities A	gency														
Year of analysis	2016		Benefits	0%										16-22, 22-30, 3	• •														
Escalation rate	3.00%		Capital costs									L	•	ernative Cost A															
Discount rate	2.00%		Running costs	0%										-															
AFT (WAS) and Centrifuges (PS)														Year															
pressed in 2016 dollars, unescalated	2016	2017	2018	2019	2020	2021 2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
pital Outlays																													
Fotal Capital						32,188,3	78																						
Total capital outlays	0	C	0	0	0	0 32,188,	78 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
enefits:																													
																					0								
Other Other																													
Total benefits	0	0	0	0	0	0	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
nnual Running Costs:																													
Energy Cost (\$/year)							\$246,90	3 \$246,903	\$373,001	\$373,001	\$373,001	\$373,001	\$373,001	\$493,805	\$493,805	\$493,805	\$493,805	\$493,805	\$493,805	\$493,805	\$493,805	\$493,805	\$493,805	\$493,805	\$493,805	\$493,805	\$493,805	\$493,805	
Total Polymer Cost (\$/year)							\$176,45		\$181,496	\$187,847	\$194,198	\$200,549	\$206,900	\$213,251	\$217,084	\$220,916	\$224,749	\$228,581	\$232,414	\$236,630	\$240,845	\$245,061	\$249,277	\$253,493	\$256,668	\$259,844	\$263,019	\$266,195	
Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year)							\$26,31 \$64,21		\$29,493 \$77,367	\$29,493 \$77,367	\$29,493 \$77,367	\$29,493 \$77,367	\$29,493 \$77,367	\$35,276 \$128,436															
Operational Labor Cost (\$/year)							\$43.32		\$69,619	\$69.619	\$69.619	\$69,619	\$69.619	\$86.642	\$86,642	\$86.642	\$86,642	\$86,642	\$86,642	\$86,642		\$86,642	\$86.642	\$86.642	\$86,642	\$86,642	\$86,642	\$86,642	
Odor Control							\$33,00		\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000		\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	
Other																													
Other Total running costs	0	0	0	0	0	0	0 590,213	592,732	763,977	770,328	776,679	783,030	789,381	990,411	994,243	998,076	1,001,908	1,005,741	1,009,573	1,013,789	1,018,005	1,022,220	1,026,436	1,030,652	1,033,827	1,037,003	1,040,178	1,043,354	1,046,52
-	U	U	U	U	U	U	0 090,213	592,752	103,911	110,328	110,019	183,030	109,301	990,411	994,243	998,070	1,001,908	1,005,741	1,009,573	1,013,789	1,018,000	1,022,220	1,020,430	1,030,052	1,033,827	1,037,003	1,040,178	1,043,354	1,040,02
R&R Costs: Total Annual Repair and Replacement Cost							10,970	12,245	31,312	20,636	40,155	28,017	29,774	31,870	41,008	29,489	48,389	26,215	36,439	93,146	33,989	98,989	36,870	33,627	31,870	46,008	24,489	1,142,137	23,21
Other							10,010	12,210	01,012	20,000	10,100	20,011	20,111	01,010	11,000	20,100	10,000	20,210	00,100	55,115	00,000	00,000	00,010	00,021	01,010	10,000	21,100	1,112,101	20,210
Other																													
Other																													
Other Total refurbishments		0	0	0	0	0	0 10.970	12.245	31.312	20.636	40.155	28.017	29.774	31.870	41.008	29.489	48.389	26.215	36,439	93,146	33.989	98.989	36.870	33.627	31.870	46.008	24.489	1.142.137	23,21
Net Benefit/(cost)	0			-		0 (32,188,7	,	,	,	(790,964)	(816,834)	,	,	(1,022,281)	,	,	,	,	,	,	(1,051,994)	,	,	,	,	,	(1,064,667)	, ,	,
	0		U	U	U	0 (32,188,1	76) (001,184	(004,970)	(195,269)	(790,904)	(010,034)	(011,047)	(019,100)	(1,022,201)	(1,050,251)	(1,027,505)	(1,000,297)	(1,031,950)	(1,040,012)	(1,100,955)	(1,001,994)	(1,121,210)	(1,003,300)	(1,004,279)	(1,005,097)	(1,003,011)	(1,004,007)	(2,105,490)	(1,009,744
Expressed in escalated dollars with sensitivit	tv adiustments																												
Capital Outlays																													
Total Capital	0	C	0	0	0	0 38,435,0	85 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	(
Total capital outlays	0	0	0	0	0	0 38,435,0	85 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Benefits:																													
0	0	0	0	0	0	0	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	(
Other Other	0		0	0	0	0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Total benefits	0	0	0	0	0	0	0 0	0	Ŭ	0	0	0	0	0	0	0	Ŭ	0	0	0	0	0	0	0	0	0	0	0	(
Annual Running Costs:																													
Energy Cost (\$/year)	0	C	0	0	0	0	0 303,659		486,682	501,283	516,321	531,811	547,765	746,925	769,333	792,413	816,185	840,671	865,891	891,868	918,624	946,182	974,568	1,003,805	1,033,919	1,064,937	1,096,885	1,129,791	1,163,685
Total Polymer Cost (\$/year)	0	0	0	0	0	0	0 217,023	· · ·	236,811	252,451	268,816	285,935	303,840	322,562	338,209	354,506	371,475	389,144	407,539	427,379	448,043	469,562	491,969	515,298	537,406	560,376	584,241	609,034	634,788
Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year)	0		0	0	0	0	0 32,361 0 78,980	33,332 81,349	38,482 100,946	39,637 103,975	40,826 107,094	42,050 110,307	43,312 113,616	53,359 194,270	54,959 200,098	56,608 206,101	58,306 212,284	60,056 218,653	61,857 225,213	63,713 231,969	65,624 238,928	67,593 246,096	69,621 253,479	71,710 261,083	73,861 268,916	76,077 276,983	78,359 285,293	80,710 293,851	83,131 302,667
Operational Labor Cost (\$/year)	0	0	0	0	0	0	0 70,900		90,837	93,562	96,369	99,260	102,238	131,054	134,985	139,035	143,206	147,502	151,927	156,485	230,920	166,015	170,996	176,125	200,910	270,965	192,457	198,231	204,178
Odor Control	0	0	0	0	0	0	0 40,586		43,058	44,349	45,680	47,050	48,462	49,915	51,413	52,955	54,544	56,180	57,866	59,602	61,390	63,231	65,128	67,082	69,095	71,168	73,303	75,502	
Other	<u>0</u>	Q	<u>0</u>	<u>0</u>	<u>0</u>	0	0 0	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>(</u>
Other	0	0	0	0	0	0	0 0	750.055	006.047	1 025 256	0	0	0	0	0	0 1,601,618	0	0	1 770 202	1 834 045	1 002 700	1 050 600	2 025 764	2 005 402	0 2,164,605	0	0 340 537	0 2 207 440	0 466 044
Total running costs	U	L U	0	U	Ŭ	U	0 725,888	750,855	996,817	1,035,256	1,075,105	1,110,413	1,109,200	1,490,080	1,046,998	1,001,018	1,000,001	1,112,200	1,770,293	1,031,010	1,893,788	1,908,080	2,020,701	2,090,103	2,104,000	2,230,391	2,310,537	2,307,118	2,400,218
R&R Costs: Total Annual Repair and Replacement Cost	0	ſ	0	0	0	0	0 13,492	15,511	40,855	27,733	55,584	39,945	43,724	48,206	63,889	47,321	79,979	44,629	63,896	168,232	63,230	189,674	72,766	68,357	66,728	99,220	54,397	2,613,126	54,707
Other	0	0	0	0	0	ő	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	(
Other	0	C	0	0	0	0	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	(
Other Other	0	0	0	0	0	0	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	(
Other Total refurbishments	0	0	0	0	0	0	0 0 0 13,492	0 15.511	0 40,855	27,733	0 55,584	0 39,945	0 43,724	0 48,206	0 63,889	0 47,321	0 79,979	0 44,629	0 63,896	0 168.232	0 63,230	0 189,674	0 72,766	0 68,357	0 66,728	0 99.220	0 54 307	0 2.613,126	54,70
let escalated benefit/(cost)	0		-			0 (38,435,0	,	,	,	,	,	'	,	,	'		,	(1,756,835)	,	'	,	,	,		,	,	,	, ,	,
	U		U	U	v	0 (38,435,	(133,360	(100,000)	(1,007,071)	(1,002,303)	(1,100,009)	(1,100,009)	(1,202,001)	(1,040,201)	(1,012,000)	(1,040,340)	(1,700,901)	(1,100,000)	(1,004,103)	(1,000,240)	(1,007,010)	(2,140,004)	(2,000,020)	(2,100,400)	(2,201,000)	(2,000,012)	(2,004,304)	(0,000,244)	(2,020,92
ife cycle cost analysis																													
Vs in 2016	0	ſ	0	0	0	0 (34,129,2	(643.675	(654.086)	(868 277)	(872 021)	(000 371)	(911 781)	(920 025)	(1 171 805)	(1 198 300)	(1 201 163)	(1 230 773)	(1,230,065)	(1 259 043)	(1.345.436)	(1 201 103)	(1 380 630)	(1.330.703)	(1.345.070)	(1 360 067)	(1 395 713)	(1 385 525)	(2 872 013)	(1 /10 563

From Summary Sheet:		Risk adjustmen	nts (+/- percent):											Inland Em	npire Utilities A	aencv														
From Summary Sneet: Year of analysis	2016	uujusunet	Benefits		ł)16-22, 22-30, 3															
Escalation rate	3.00%		Capital costs		ļ								I		ernative Cost /															
Discount rate	2.00%		Running costs										`	joio Aitt	-															
					t																									
DAFT (WAS) and RDT (PS)															Year															
	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
Expressed in 2016 dollars, unescalated																														
Capital Outlays							04.400.400														-	L								
Total Capital Total capital outlays	0	0	- n	0		1	24,188,123 0 24,188,123	0	0	0	0	0						0	0	0	0	0	0		0		0	0	0	
Benefits:	U	U	U	Ŭ	<u> </u>	- <u>-</u>					J	V	U	U	U		U	U	V		U				J	U	U	U	U	
Sonona.																						0								
Other																														
Other																														
Total benefits	0	0	0	0	0	<u>י</u> נ	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Annual Running Costs:								6404 mm		A401-0-	6404.00	6404 or 1	\$404 ac.	MAD 4 00 1	0000 100	ADEE 100	ADEE 105	055 IN-	4055 to-	0055 VC-	0055 155	0055 100	0000 to 1	ADER 100	ADD C COL	6055 (SS	0055 155	POEE IE-	0055 105	0055 105
Energy Cost (\$/year) Total Polymer Cost (\$/year)								\$134,634 \$176,459	L 1 1				\$134,634 \$176,459	\$134,634 \$176,459	\$255,438 \$176,459	\$255,438 \$176,459	\$255,438 \$176,459	\$255,438 \$176,459	\$255,438 \$176,459								\$255,438 \$176,459	\$255,438 \$176,459		\$255,438 \$176,459
Annual Water Cost (\$/year)								\$176,459 \$52,047	L				\$176,459 \$52,047	\$176,459 \$52,047	\$176,459	\$176,459	\$176,459	\$176,459 \$57,830	\$176,459									\$176,459 \$57,830		\$176,459 \$57,830
Maintenance Labor Cost (\$/year)								\$77,367	\$77,367	7 \$77,367	\$77,367	\$77,367	\$77,367	\$77,367	\$128,436	\$128,436	\$128,436	\$128,436	\$128,436	\$128,436	6 \$128,436	5 \$128,436					\$128,436	\$128,436	\$128,436	\$128,436
Operational Labor Cost (\$/year)								\$69,619	\$69,619	\$69,619	\$69,619	\$69,619	\$69,619	\$69,619	\$86,642	\$86,642	\$86,642	\$86,642	\$86,642	\$86,642	2 \$86,642	2 \$86,642	2 \$86,642	\$86,642	\$86,642	\$86,642	\$86,642	\$86,642		\$86,642
Odor Control								\$33,000	\$33,000	0 \$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	0 \$33,000	5 \$33,000	0 \$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000	\$33,000
Other Other																														
Other Total running costs	0	0	0	0	0	0 0	0 0	543,126	543,126	543,126	543,126	543,126	543,126	543,126	737,805	737,805	737,805	737,805	737,805	737,805	737,805	737,805	737,805	737,805	737,805	737,805	737,805	737,805	737,805	737,805
R&R Costs:	•	J				<u> </u>		,	,120			,.=•		,				,		,	,000	,	,500			,			,	
Total Annual Repair and Replacement Cost								10,754	10,754	10,754	10,754	13,754	10,754	10,754	14,607	14,607	19,607	14,607	17,607	14,607	14,607	50,802	14,607	19,607	14,607	14,607	19,607	14,607	673,355	14,607
Other																														
Other																														
Other Other																														
Other Total refurbishments		0	0	0	0	1 0	0 0	10,754	10,754	10,754	10,754	13,754	10,754	10,754	14,607	14.607	19.607	14,607	17.607	14.607	14.607	50.802	14.607	19.607	14.607	14,607	19.607	14.607	673,355	14,607
Net Benefit/(cost)	0						0 (24,188,123)		· · · ·	· · · ·	,	,	(553,881)	(553,881)	(752,412)	,	,	,	,	,	,	,	,	,	,	,	,	,	,	(752,412)
	U	U	J	U	<u> </u>	<u> </u>		. (000,001)	(000,001)	, (000,001)	(000,001)	(000,001)	(000,001)	(000,001)	(102,412)	(102,412)	(101,412)	(102,412)	(100,412)	(102,412)	(102,412)	, (,00,007)	, (192,412)	(101,412)	(102,412)	(172,412)	(101,412)	(102,912)	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	(102,412)
Expressed in escalated dollars with sensitivi	ity adjustments																									+				
Capital Outlays																														
Total Capital	0	•		•	0		0 28,881,884	0		0	•	0	0	0	0	0	0	0	0	0	0	0		-	0	0	0	0	0	0
Total capital outlays	0	0	0	0	0	ן נ	0 28,881,884	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Benefits:																														
0 Other	0	0	0	0	I 0) <u>(</u>	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other Other	0	0			0		0 v v		0		0		0	0	0	0	0	0	0	0						0	0	0	0	0
Total benefits	0	0	0	0	+ <u> </u>	0 0	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			0	0	0	0
Annual Running Costs:						<u> </u>			t – Ť													+	+							
Energy Cost (\$/year)	0	0	0	0	0	0 0	0	165,583	170,551	175,667	180,937	186,365	191,956	197,715	386,373	397,964	409,903	422,200	434,866	447,912	461,350	475,190	489,446	504,129	519,253	534,831	550,876	567,402	584,424	601,957
Total Polymer Cost (\$/year)	0	0	0	0	0) (0 0	217,023	223,533	230,239	237,146	244,261	251,589	259,136	266,910	274,918	283,165	291,660	300,410	309,422	318,705	328,266	338,114	348,258	358,705	369,466	380,550	391,967	403,726	415,838
Annual Water Cost (\$/year)	0	0	0	0	0	<u>ງ</u> ເ	0 0	64,011	65,932	67,910	,	72,045	74,207	76,433	87,473	90,097	92,800	95,584	98,452	101,405	,	,			,	121,083	124,716	128,457	132,311	136,280
Maintenance Labor Cost (\$/year)	0	0	0	0	0	v (v 0	95,151 85,623	98,006 88,191	100,946 90,837	103,975 93 562	107,094 96 369	110,307 99.260	113,616	194,270 131,054	200,098	206,101 139,035	212,284 143,206	218,653 147,502	225,213 151,927						268,916 181,409	276,983 186,851	285,293 192,457	293,851 198,231	302,667 204,178
Operational Labor Cost (\$/year) Odor Control	0	0	0	0	μ <u></u> 0		v 0 1 01	85,623 40,586	88,191 41,803		93,562 44,349	96,369 45,680	99,260 47,050	102,238 48,462	131,054 49,915	134,985 51,413	139,035 52,955	143,206 54,544	147,502 56,180	151,927 57,866							186,851	192,457 73,303	198,231 75,502	204,178
Other	0	0	0	0	t0	י ס	ו <mark>ס ו</mark>	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	00,120	01,002	0	0	0	0	0
Other	0	0	0	0	0	י <u></u> נ	ו <u>ס</u>	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total running costs	0	0	0	0	0	ີ	0 0	667,977	688,016	708,657	729,917	751,814	774,368	797,599	1,115,996	1,149,476	1,183,961	1,219,479	1,256,064	1,293,746	1,332,558	1,372,535	1,413,711	1,456,122	1,499,806	1,544,800	1,591,144	1,638,878	1,688,045	1,738,686
R&R Costs:																														
Total Annual Repair and Replacement Cost	0	0	0	0	0	y (0	13,226	13,623	14,032	14,453	19,039	15,333	15,793	22,095	22,758	31,464	24,144	29,975	25,614	26,383	94,507	27,989	38,697	29,694	30,585	42,285	32,447	1,540,588	34,423
Other Other	0	0			μ <u></u> 0		ν 0 1 01		0				0	0	0	0	0	0	0	0							0	0	0	0
Other	0	0	0	0		1 0	- 0 1 01	0	0	0	0	0	0	0	0	0	0	0	0	0		+ 01					0	0	0	0
Other		0	0	0	0	ט	ו 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total refurbishments	0	Q	0	0	0	0 0	0 0	13,226	13,623	14,032	14,453	19,039	15,333	15,793	22,095	22,758	31,464	24,144	29,975	25,614	26,383	94,507	27,989	38,697	29,694	30,585	42,285	32,447	1,540,588	34,423
Net escalated benefit/(cost)	0	0	0	0	0	<u>ו</u> נ	0 (28,881,884)) (681,203)	(701,639)) (722,689)	(744,369)	(770,853)	(789,701)	(813,392)	(1,138,091)	(1,172,234)	(1,215,425)	(1,243,623)	(1,286,039)	(1,319,360)	(1,358,941)	(1,467,042)) (1,441,700)	(1,494,819)	(1,529,500)	(1,575,385)	(1,633,429)	(1,671,326)	(3,228,632)	(1,773,109)
								-																						
Life cycle cost analysis			[_]									·																		/
Life cycle cost analysis PVs in 2016	0	v	0	0	0) (0 (25,646,287)) (593,028)	(598,842)) (604,713)	(610,642)	(619,969)	(622,674)	(628,779)	(862,531)	(870,987)	(885,371)	(888,149)	(900,432)	(905,649)) (914,528)) (967,919)	(932,548)	(947,948)	(950,923)	(960,246)	(976,103)	(979,166)	(1,854,444)	(998,460)
	0 (45,720,340)	v	0	0	0) <u>(</u>	(25,646,287)	(593,028)	(598,842)	(604,713)	(610,642)	(619,969)	(622,674)	(628,779)	(862,531)	(870,987)	(885,371)	(888,149)	(900,432)	(905,649)	(914,528)	(967,919)	(932,548)	(947,948)	(950,923)	(960,246)	(976,103)	(979,166)	(1,854,444)	(998,460)

om Summary Sheet:		Risk adjustments (+/- percent): Benefits 0% RP-5 (2016-22, 22-30, 30-45)																												
Year of analysis	2016	Benefits 0% RP-5 (2016-22, 22-30, 30-45)																												
Escalation rate	3.00%		Capital costs	0%									L																	
Discount rate	2.00%		Running costs	0%										•	-															
			_																											
T (WAS) and GBT (PS)																fear														
	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
ressed in 2016 dollars, unescalated																														
ital Outlays																														
otal Capital							25,747,922																							
Total capital outlays		0) 0	0	0	0	25,747,922	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
nefits:																														
Other Other	-																													
Other																														
Total benefits		0) 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
nual Running Costs:																														
Energy Cost (\$/year)								\$130,567	\$130,567	\$130,567	\$130,567	\$130,567	\$130,567	\$130,567	\$251,371	\$251,371	\$251,371	\$251,371	\$251,371	\$251,371	\$251,371	\$251,371	\$251,371	\$251,371	\$261,133	\$261,133	\$261,133	\$261,133	\$261,133	\$261,
Total Polymer Cost (\$/year)								\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,459	\$176,4
Annual Water Cost (\$/year)								\$60,722	\$60,722	\$60,722		\$60,722		\$60,722			\$66,505	\$66,505	\$66,505	\$66,505	1 A A A A A A A A A A A A A A A A A A A		\$66,505	\$66,505	\$104,094	\$104,094	\$104,094		\$104,094	\$104,0
Maintenance Labor Cost (\$/year)								77,367	77,367	77,367	77,367	77,367	77,367	77,367	128,436		128,436	128,436	128,436	128,436	128,436	128,436	128,436	128,436	154,734	154,734	154,734	154,734	154,734	154,73
Operational Labor Cost (\$/year) Odor Control								69,619 33,000	69,619 33,000	69,619 33,000	69,619 33,000	69,619 33,000	69,619 33,000	69,619 33,000	86,642 33,000	86,642 33,000	86,642 33,000	86,642 33,000	86,642 33,000	86,642 33,000	86,642 33,000	86,642 33,000	86,642 33,000	86,642 33,000	139,238 33,000	139,238 33,000	139,238 33,000	139,238 33,000	139,238 33,000	139,2 33,0
								33,000	33,000	33,000	33,000	33,000	55,000	33,000	55,000	33,000	33,000	33,000	33,000	33,000	55,000	55,000	55,000	33,000	33,000	33,000	55,000	55,000	33,000	55,0
Total running costs			0	0	0	0	0	547,733	547,733	547,733	547,733	547,733	547,733	547,733	742,412	742,412	742,412	742,412	742,412	742,412	742,412	742,412	742,412	742,412	868,658	868,658	868,658	868,658	868,658	868,6
R Costs:																														
Total Annual Repair and Replacement Cos	s <mark>t</mark>				0	0	0	26,965	26,965	31,886	26,965	34,886	26,965	31,886	30,818	35,739	35,818	40,206	33,818	35,739	30,818	45,239	30,818	40,739	30,818	35,739	35,818	35,739	807,533	35,73
Other																														
Other	_																													
Other	_																													
Other Total refurbishments) 0	0	0	0	0	26,965	26,965	31,886	26,965	34,886	26,965	31,886	30,818	35,739	35,818	40,206	33,818	35,739	30,818	45,239	30,818	40,739	30,818	35,739	35,818	35,739	807,533	35,73
) 0	0	0	•	-	(574,698)	(574,698)	(579,619)		(582,619)	'	(579,619)			(778,230)	(782,618)	(776,230)	(778,151)	,	,			,	(904,397)			(1,676,191)	(904,39
et Benefit/(cost)		U	0	U	U	v	(20,141,922)	(574,096)	(574,096)	(579,019)	(574,096)	(562,019)	(074,096)	(579,019)	(773,230)	(778,151)	(110,230)	(702,010)	(770,230)	(110,101)	(113,230)	(787,051)	(773,230)	(703,131)	(899,470)	(904,397)	(904,470)	(904,397)	(1,070,191)	(904,3
pressed in escalated dollars with sens	eitivity ediyetm	ante																												
	Silivity aujustine	51118																												
apital Outlays Total Capital		0) 0	0	0	0	30,744,365	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Total capital outlays		0) 0	0	0	0		0	0	0	0	0	0	0	0	0	0	0	0	0			0	0	0	0	0	0	0	
enefits:		-	-	-	_	-		-	-	-	-	-	-	-	-		-	-		-	-		-	-		-	-	-	-	
Other		0) 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Other		0) 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Other		0) 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Total benefits		0) 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
nual Running Costs:																														
Energy Cost (\$/year)		0) 0	0	0	0	0	160,580	165,398	170,360	175,470	180,735	186,157	191,741	380,220	391,627	403,376	415,477	427,942	440,780	454,003	467,623	481,652	496,101	530,830	546,755	563,157	580,052	597,453	615,37
Total Polymer Cost (\$/year)		0		0	0	0	0	217,023	223,533	230,239	237,146	244,261	251,589 86,574	259,136	266,910	274,918	283,165 106,720	291,660	300,410	309,422	318,705 120,115	328,266	338,114	348,258	358,705	369,466	380,550	391,967 231,223	403,726	415,83
Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year)		0		0	0	0	0	74,680 95,151	76,920 98,006	79,228 100,946	81,605 103,975	84,053 107,094	86,574 110,307	89,172 113,616	100,594 194,270	103,612 200,098	206,101	109,922 212,284	113,220 218,653	116,616 225,213	231,969	123,718 238,928	127,430 246,096	131,253 253,479	211,602 314,542	217,950 323,978	224,488 333,697	231,223	238,160 354,019	245,30
Operational Labor Cost (\$/year)		0	0	0	0	0	0	85,623	88,191	90,837	93,562	96,369	99,260	102,238		134,985	139,035	143,206	147,502	151,927	156,485	161,180	166,015	170,996	283,043	291,534	300,280	309,288	318,567	328,12
Ddor Control		0) 0	0	0	0	0	40,586	41,803	43,058	44,349	45,680	47,050	48,462	49,915	51,413	52,955	54,544	56,180	57,866	59,602	61,390	63,231	65,128	67,082	69,095	71,168	73,303	75,502	77,70
		0	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	
0				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
0		0	0			0	0	673,643	693,852	714,668	736,108	758,191	780,937	804,365	1,122,965	1,156,654	1,191,353	1,227,094	1,263,907	1,301,824	1,340,879	1,381,105	1,422,538	1,465,214	1,765,803	1,818,777	1,873,341	1,929,541	1,987,427	2,047,08
0 0 Total running costs		0 0) 0	0	0	U	•													00.000										
0 0 Total running costs R Costs:		0		0	0	v										55,680	57,478	66,454	57,573	62,668	55,661	84,157	E0.0E1	80,401	62 647					
0 0 Total running costs R Costs: otal Annual Repair and Replacement Cost		0 0 0		0	0	0	0	33,163	34,158	41,603	36,239	48,290	38,446	46,825	46,615	33,000	· •	<u>^</u>	•	<u>^</u>	~		59,051	00,401	62,647	74,829	77,245	79,386	1,847,577	84,2
0 0 Total running costs R Costs: Total Annual Repair and Replacement Cost Other		0 0 0 0		0	0		0	33,163 0	34,158 0	41,603 0	36,239 0	48,290 0	38,446 0	46,825	46,615	0	0	0	0	0	0	0	0	0	02,047	0	0	79,386	1,847,577 0	84,2
0 0 Total running costs R Costs: Total Annual Repair and Replacement Cost Other Other		0 0 0 0 0 0) 0 0 0 0 0 0 0 0	0 0 0 0	0 0 0 0 0 0 0 0		0 0 0 0 0	33,163 0 0	34,158 0 0	41,603 0 0	36,239 0 0	48,290 0 0	38,446 0 0	46,825 0 0	46,615 0 0	0	0	0	0	0 0	0 0	0	0	0	02,047	0 0 0	0 0 0	79,386 0 0	1,847,577 0 0	84,2
0 0 Total running costs R Costs: Total Annual Repair and Replacement Cost Other Other Other		0 0 0 0 0 0 0	j 0 j 0 j 0 j 0 j 0 j 0 j 0 j 0 j 0 j 0 j 0 j 0 j 0	0 0 0 0 0 0	0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0	33,163 0 0 0 0	34,158 0 0 0 0	41,603 0 0 0 0	36,239 0 0 0 0	48,290 0 0 0 0	38,446 0 0 0 0	46,825 0 0 0 0	46,615 0 0 0	0 0 0 0 0	0 0 0 0	0 0 0 0	0 0 0 0 0	0 0 0	0 0 0 0	0 0 0 0 0 0	0 0 0 0	0 0 0 0 0	02,047	0 0 0 0	0 0 0 0	79,386 0 0 0 0	1,847,577 0 0 0 0	84,2
0 Total running costs Costs: Cotal Annual Repair and Replacement Cost Cost Cost Cost Cost Cost Cost Cost	2	0 0 0 0 0 0 0 0	j j	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	33,163 0 0 0 0 0 33,163	34,158 0 0 0 0 34,158	41,603 0 0 0 0 41,603	36,239 0 0 0 0 36,239	48,290 0 0 0 48,290	38,446 0 0 0 0 38,446	46,825 0 0 0 46,825	0 0 0 0	0 0 0 0 55,680	0 0 0 0 57,478	0 0 0 66,454	0 0 0 57,573	0 0 0 62,668	0 0 0 0 55,661	0 0 0 0 0 84,157	0 0 0 59,051	0 0 0 0 80,401	02,047 0 0 0 0 62,647	74,829 0 0 0 0 74,829	77,245 0 0 0 0 77,245	79,386 0 0 0 0 79,386	0 0 0 0	
0 0 Total running costs R Costs: otal Annual Repair and Replacement Cost ther ther ther ther Total refurbishments		0 0 0 0 0) 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0	0 0 0	0 0 0 0 41,603	0 0 0 0 36,239	0 0 0 0 48,290	0 0 0 0 38,446	0 0 0 46,825	0 0 0 46,615	0 0 0 0 55,680	0 0 0 0 57,478	,				0 0 0 0	0 0 0 59,051	0 0 0 0 80,401	0 0 0 0 62,647	0 0 0 74,829	0 0 0 0 77,245	0 0 0 0 79,386	0 0 0 0 1,847,577	84,2
0 0 Total running costs R Costs: otal Annual Repair and Replacement Cost ther ther Other O		0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 33,163	0 0 0 34,158	0 0 0 0 41,603	0 0 0 0 36,239	0 0 0 0 48,290	0 0 0 0 38,446	0 0 0 46,825	0 0 0 46,615	0 0 0 0 55,680	0 0 0 0 57,478	,				0 0 0 0 84,157	0 0 0 59,051	0 0 0 0 80,401	0 0 0 0 62,647	0 0 0 74,829	0 0 0 0 77,245	0 0 0 0 79,386	0 0 0 0 1,847,577	84,2
0 0 1 0 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 33,163	0 0 0 34,158	0 0 0 0 41,603	0 0 0 0 36,239	0 0 0 0 48,290	0 0 0 0 38,446	0 0 0 46,825	0 0 0 46,615	0 0 0 0 55,680	0 0 0 0 57,478	,				0 0 0 0 84,157	0 0 0 59,051	0 0 0 0 80,401	0 0 0 0 62,647	0 0 0 74,829	0 0 0 0 77,245	0 0 0 0 79,386	0 0 0 0 1,847,577	84,2
0 0 Total running costs R Costs: otal Annual Repair and Replacement Cost ther ther ther ther ther Total refurbishments		0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 33,163 (706,806)	0 0 0 34,158 (728,010)	0 0 0 41,603 (756,271)	0 0 0 36,239 (772,346)	0 0 0 48,290 (806,481)	0 0 0 38,446 (819,382)	0 0 0 46,825 (851,190)	0 0 0 46,615 (1,169,580)	0 0 0 55,680 (1,212,333)	0 0 0 57,478 (1,248,831)	(1,293,548)		(1,364,492)	(1,396,540)	0 0 0 0 84,157	0 0 0 59,051 (1,481,589)	0 0 0 80,401 (1,545,616)	0 0 0 0 62,647	0 0 0 74,829 (1,893,606)	0 0 0 77,245 (1,950,586)	0 0 0 79,386 (2,008,927)	0 0 0 1,847,577 (3,835,004)	

From Summary Sheet:		Risk adjustme	ents (+/- percent):											Inland Em	pire Utilities Ag	iencv														
Year of analysis	2016	Then aujacan	Benefits	0%	í ————————————————————————————————————										16-22, 22-30, 30															
Escalation rate	3.00%	í	Capital costs	0%	1								I		rnative Cost Ar															
Discount rate	2.00%	i	Running costs	0%	Í									,	-															
Centrifuges Separate															Year															
	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
Expressed in 2016 dollars, unescalated																														
Capital Outlays Total capital							25.012.381																							
Total capital outlays	0	0) 0	0	0	0	25,012,381	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Benefits:			+		F		, ,																							
																						0								
Other																														
Other Tatal herefite						<u> </u>												2	2	<u>^</u>										
Total benefits	0	0) 0	0	U) 0	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Annual Running Costs:								1050 407	A050 407	#070.00G	200.000	1070 006	4070.006	A070.006	A070.000	1070.000	070 00G	A070.000	1070.000	1070 00C	\$070.00C	1070 00G	1070.000	2010 0100	2070.006	2070.006	A070.006	6070 006	0070.006	0070-006
Energy Cost (\$/year) Total Polymer Cost (\$/year)								\$252,197 \$239,586	\$252,197 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586		\$378,296 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586	\$378,296 \$239,586		\$378,296 \$239,586	
Annual Water Cost (\$/year)								\$239,586 \$29,493	\$239,586 \$29,493	\$239,586 \$35,565	\$239,586 \$35,565	\$239,586 \$35,565			\$239,586 \$35,565	\$239,586 \$35,565	\$239,586 \$35,565	\$239,586 \$35,565	\$239,586 \$35,565	\$239,586 \$35,565	\$239,586 \$35,565	\$239,586 \$35,565	\$239,586 \$35,565	\$239,586 \$35,565	\$239,586	\$239,586 \$35,565	\$239,586 \$35,565		\$239,586 \$35,565	
Maintenance Labor Cost (\$/year)								\$30,681	\$30,681	\$43,830	\$43,830	\$43,830			\$43,830	\$43,830 \$43,830	\$43,830	\$43,830	\$43,830 \$43,830	\$43,830	\$43,830	\$43,830	\$43,830	\$43,830	\$43,830	\$43,830	\$43,830		\$43,830	
Operational Labor Cost (\$/year)								\$52,596	\$52,596	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894	\$78,894
Odor Control								\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500
Other																														
Other Total running costs	0	0) 0	0	0		0 0	628.054	628.054	799,672	799,672	799,672	799,672	799,672	799.672	799,672	799.672	799,672	799.672	799.672	799,672	799,672	799,672	799,672	799.672	799,672	799,672	799.672	799.672	799,672
Total running costs				v) 0	v	020,004	020,004	199,012	199,012	199,012	193,012	199,012	199,012	199,012	199,012	/99,012	199,012	199,012	199,012	/99,012	199,012	199,012	199,012	199,012	199,012	199,012	199,012	199,012
R&R Costs: Total Annual Repair and Replacement Cost								21,352	25,174	61,024	25,174	38,881	47.317	38 881	25,174	61.024	25,174	61,024	21,352	25,174	234,968	25,174	38,881	47,317	38,881	25,174	61,024	25.174	688,336	21,352
Other								21,002	23,114	01,024	23,114	30,001	41,011	30,001	25,114	01,024	23,114	01,024	21,002	23,114	234,500	23,114	30,001	41,511	30,001	23,114	01,025	20,114	000,000	21,002
Other																														
Other																														
Other																														
Total refurbishments	Ē]	0	0	0				21,352	25,174	61,024	25,174	38,881	47,317	38,881	25,174	61,024	25,174	61,024	21,352	25,174	234,968	25,174	38,881	47,317	38,881	25,174	61,024	25,174	688,336	21,352
Net Benefit/(cost)	0	0) 0	0	0	0	0 (25,012,381)	(649,406)	(653,228)	(860,696)	(824,846)	(838,553)	(846,989)	(838,553)	(824,846)	(860,696)	(824,846)	(860,696)	(821,024)	(824,846)	(1,034,640)	(824,846)	(838,553)	(846,989)	(838,553)	(824,846)	(860,696)	(824,846)	(1,488,008)	(821,024)
			++																											
Expressed in escalated dollars with sensitivity	y adjustments																													
Capital Outlays												0				0	0	2	2	0										0
Total capital outlaws	0	0		0			29,866,091	0	0	0	0	U	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		0	
Total capital outlays	.	v		0	v		29,866,091	0	0	0	V	v	V	0	0	U	U	U	U	U	U	U	0	U		U	0	U	0	0
Benefits:	0	0			0																						0			0
0 Other	0	0	/ VI	v	<u> </u>	U ·	- I		0	0	0	0	0	0		0	0	0	n	٥	0	0	0		0		V j		V	
Other	i õ	·	0	0	· 0 ·	0	, 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.
Total benefits	· · · · · · · · · · · · · · · · · · ·	0	0	0	0	`0	0	0	0	0	0	0	0 0 0	0	0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0	0	0	0	0	0	0	0
	0	0	0	0 0 0	0	0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0	0 0 0	0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0	0 0 0 0	0 0 0	0 0 0	0 0 0 0	0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0	0 0 0	0
Annual Running Costs:	0	0	0	0 0 0	0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0
Annual Running Costs: Energy Cost (\$/year)	0	0 0 0	0	0 0 0	0 0 0	0 0 0		310,171	319,476	493,591	508,398	0 0 0 523,650	539,360	555,541	572,207	589,373	0 0 0 607,054	625,266	644,024	663,345	683,245	703,742	724,854	746,600	768,998	0 0 0 0 792,068	815,830	0 0 0 840,305	865,514	891,480
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year)	0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0	0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0	310,171 294,661	319,476 303,500		508,398 321,984	331,643	539,360 341,592	555,541 351,840	572,207 362,395	589,373 373,267	384,465	625,266 395,999	644,024 407,879	663,345 420,116	683,245 432,719	703,742 445,701	724,854 459,072	•	768,998 487,029	0 0 0 792,068 501,640	815,830 516,689	0 0 0 840,305 532,190	865,514 548,155	891,480 564,600
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year)	0 0 0 0	0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0	0 0 0 0 0		0 0 0 0 0 0 0 0 0 0	310,171 294,661 36,273	319,476 303,500 37,361	493,591 312,605 46,405	508,398 321,984 47,797	331,643 49,231	539,360 341,592 50,708	555,541 351,840 52,229	572,207 362,395 53,796	589,373 373,267 55,410	384,465 57,072	625,266 395,999 58,784	644,024 407,879 60,548	663,345 420,116 62,364	683,245 432,719 64,235	703,742 445,701 66,162	724,854 459,072 68,147	746,600 472,844 70,192	768,998 487,029 72,297	501,640 74,466	815,830 516,689 76,700	532,190 79,001	865,514 548,155 81,371	891,480 564,600 83,812
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year)			0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0		0 0 0 0 0 0 0 0 0 0 0 0	310,171 294,661 36,273 37,734	319,476 303,500 37,361 38,866	493,591 312,605 46,405 57,188	508,398 321,984 47,797 58,904	331,643 49,231 60,671	539,360 341,592 50,708 62,491	555,541 351,840 52,229 64,366	572,207 362,395 53,796 66,297	589,373 373,267 55,410 68,286	384,465 57,072 70,335	625,266 395,999 58,784 72,445	644,024 407,879 60,548 74,618	663,345 420,116 62,364 76,856	683,245 432,719 64,235 79,162	703,742 445,701 66,162 81,537	724,854 459,072 68,147 83,983	746,600 472,844 70,192 86,503	768,998 487,029 72,297 89,098	501,640 74,466 91,771	815,830 516,689 76,700 94,524	532,190 79,001 97,359	865,514 548,155 81,371 100,280	891,480 564,600 83,812 103,289
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year)	0 0 0 0 0 0 0 0 0		0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0			310,171 294,661 36,273 37,734 64,687	319,476 303,500 37,361 38,866 66,627	493,591 312,605 46,405 57,188 102,939	508,398 321,984 47,797 58,904 106,027	331,643 49,231 60,671 109,208	539,360 341,592 50,708 62,491 112,484	555,541 351,840 52,229 64,366 115,859	572,207 362,395 53,796 66,297 119,335	589,373 373,267 55,410 68,286 122,915	384,465 57,072 70,335 126,602	625,266 395,999 58,784 72,445 130,400	644,024 407,879 60,548 74,618 134,312	663,345 420,116 62,364 76,856 138,342	683,245 432,719 64,235 79,162 142,492	703,742 445,701 66,162 81,537 146,767	724,854 459,072 68,147 83,983 151,170	746,600 472,844 70,192 86,503 155,705	768,998 487,029 72,297 89,098 160,376	501,640 74,466 91,771 165,187	815,830 516,689 76,700 94,524 170,143	532,190 79,001 97,359 175,247	865,514 548,155 81,371 100,280 180,504	891,480 564,600 83,812 103,289 185,920
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control	0 0 0 0 0 0 0 0 0 0 0		0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	310,171 294,661 36,273 37,734	319,476 303,500 37,361 38,866	493,591 312,605 46,405 57,188	508,398 321,984 47,797 58,904	331,643 49,231 60,671	539,360 341,592 50,708 62,491 112,484	555,541 351,840 52,229 64,366	572,207 362,395 53,796 66,297	589,373 373,267 55,410 68,286	384,465 57,072 70,335	625,266 395,999 58,784 72,445	644,024 407,879 60,548 74,618	663,345 420,116 62,364 76,856	683,245 432,719 64,235 79,162	703,742 445,701 66,162 81,537	724,854 459,072 68,147 83,983	746,600 472,844 70,192 86,503	768,998 487,029 72,297 89,098	501,640 74,466 91,771	815,830 516,689 76,700 94,524	532,190 79,001 97,359	865,514 548,155 81,371 100,280	891,480 564,600 83,812 103,289
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year)				0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		310,171 294,661 36,273 37,734 64,687	319,476 303,500 37,361 38,866 66,627	493,591 312,605 46,405 57,188 102,939	508,398 321,984 47,797 58,904 106,027	331,643 49,231 60,671 109,208	539,360 341,592 50,708 62,491 112,484	555,541 351,840 52,229 64,366 115,859	572,207 362,395 53,796 66,297 119,335	589,373 373,267 55,410 68,286 122,915	384,465 57,072 70,335 126,602	625,266 395,999 58,784 72,445 130,400	644,024 407,879 60,548 74,618 134,312	663,345 420,116 62,364 76,856 138,342	683,245 432,719 64,235 79,162 142,492	703,742 445,701 66,162 81,537 146,767	724,854 459,072 68,147 83,983 151,170	746,600 472,844 70,192 86,503 155,705	768,998 487,029 72,297 89,098 160,376	501,640 74,466 91,771 165,187	815,830 516,689 76,700 94,524 170,143	532,190 79,001 97,359 175,247	865,514 548,155 81,371 100,280 180,504	891,480 564,600 83,812 103,289 185,920
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control Other	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0		310,171 294,661 36,273 37,734 64,687	319,476 303,500 37,361 38,866 66,627	493,591 312,605 46,405 57,188 102,939	508,398 321,984 47,797 58,904 106,027 31,582 <u>0</u> 0	331,643 49,231 60,671 109,208	539,360 341,592 50,708 62,491 112,484 33,505 <u>0</u> 0	555,541 351,840 52,229 64,366 115,859 34,511 <u>0</u> 0	572,207 362,395 53,796 66,297 119,335	589,373 373,267 55,410 68,286 122,915 36,612 <u>0</u> 0	384,465 57,072 70,335 126,602 37,711 <u>0</u> 0	625,266 395,999 58,784 72,445 130,400	644,024 407,879 60,548 74,618 134,312 40,007 <u>0</u> 0	663,345 420,116 62,364 76,856 138,342 41,207 <u>0</u> 0	683,245 432,719 64,235 79,162 142,492 42,444 <u>0</u> 0	703,742 445,701 66,162 81,537 146,767 43,717 <u>0</u> 0	724,854 459,072 68,147 83,983 151,170	746,600 472,844 70,192 86,503 155,705 46,379 <u>0</u> 0	768,998 487,029 72,297 89,098 160,376	501,640 74,466 91,771 165,187	815,830 516,689 76,700 94,524 170,143	532,190 79,001 97,359 175,247 52,200 <u>0</u> 0	865,514 548,155 81,371 100,280 180,504	891,480 564,600 83,812 103,289 185,920 55,379 <u>0</u> 0
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control Other Other Total running costs R&R Costs:	0 0 0 0 0 0 0 0 0 0 0 0		0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		310,171 294,661 36,273 37,734 64,687 28,902 <u>0</u> 0	319,476 303,500 37,361 38,866 66,627 29,769 <u>0</u> 0	493,591 312,605 46,405 57,188 102,939 30,662 <u>0</u> 0	508,398 321,984 47,797 58,904 106,027 31,582 <u>0</u> 0	331,643 49,231 60,671 109,208 32,529 <u>0</u> 0	539,360 341,592 50,708 62,491 112,484 33,505 <u>0</u> 0	555,541 351,840 52,229 64,366 115,859 34,511 <u>0</u> 0	572,207 362,395 53,796 66,297 119,335 35,546 <u>0</u> 0	589,373 373,267 55,410 68,286 122,915 36,612 <u>0</u> 0	384,465 57,072 70,335 126,602 37,711 <u>0</u> 0	625,266 395,999 58,784 72,445 130,400 38,842 <u>0</u> 0	644,024 407,879 60,548 74,618 134,312 40,007 <u>0</u> 0	663,345 420,116 62,364 76,856 138,342 41,207 <u>0</u> 0	683,245 432,719 64,235 79,162 142,492 42,444 <u>0</u> 0	703,742 445,701 66,162 81,537 146,767 43,717 <u>0</u> 0	724,854 459,072 68,147 83,983 151,170 45,028 <u>0</u> 0	746,600 472,844 70,192 86,503 155,705 46,379 <u>0</u> 0	768,998 487,029 72,297 89,098 160,376 47,771 <u>0</u> 0	501,640 74,466 91,771 165,187 49,204 <u>0</u> 0	815,830 516,689 76,700 94,524 170,143 50,680 <u>0</u> 0	532,190 79,001 97,359 175,247 52,200 <u>0</u> 0	865,514 548,155 81,371 100,280 180,504 53,766 <u>0</u> 0	891,480 564,600 83,812 103,289 185,920 55,379 <u>0</u> 0
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control Other Other Other Total running costs R&R Costs: Total Annual Repair and Replacement Cost	0 0 0 0 0 0 0 0 0 0 0 0		0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		310,171 294,661 36,273 37,734 64,687 28,902 <u>0</u> 0	319,476 303,500 37,361 38,866 66,627 29,769 <u>0</u> 0	493,591 312,605 46,405 57,188 102,939 30,662 <u>0</u> 0	508,398 321,984 47,797 58,904 106,027 31,582 <u>0</u> 0	331,643 49,231 60,671 109,208 32,529 <u>0</u> 0	539,360 341,592 50,708 62,491 112,484 33,505 <u>0</u> 0 1,140,141	555,541 351,840 52,229 64,366 115,859 34,511 <u>0</u> 0	572,207 362,395 53,796 66,297 119,335 35,546 <u>0</u> 0	589,373 373,267 55,410 68,286 122,915 36,612 <u>0</u> 0	384,465 57,072 70,335 126,602 37,711 <u>0</u> 0	625,266 395,999 58,784 72,445 130,400 38,842 <u>0</u> 0	644,024 407,879 60,548 74,618 134,312 40,007 <u>0</u> 0	663,345 420,116 62,364 76,856 138,342 41,207 <u>0</u> 0	683,245 432,719 64,235 79,162 142,492 42,444 <u>0</u> 0	703,742 445,701 66,162 81,537 146,767 43,717 <u>0</u> 0	724,854 459,072 68,147 83,983 151,170 45,028 <u>0</u> 0	746,600 472,844 70,192 86,503 155,705 46,379 <u>0</u> 0	768,998 487,029 72,297 89,098 160,376 47,771 <u>0</u> 0	501,640 74,466 91,771 165,187 49,204 <u>0</u> 0	815,830 516,689 76,700 94,524 170,143 50,680 <u>0</u> 0	532,190 79,001 97,359 175,247 52,200 <u>0</u> 0 1,776,303	865,514 548,155 81,371 100,280 180,504 53,766 <u>0</u> 0	891,480 564,600 83,812 103,289 185,920 55,379 <u>0</u> 0 1,884,479
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control Other Other Total running costs R&R Costs: Total Annual Repair and Replacement Cost Other	0 0 0 0 0 0 0 0 0 0 0 0		0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		310,171 294,661 36,273 37,734 64,687 28,902 <u>0</u> 0 772,427	319,476 303,500 37,361 38,866 66,627 29,769 <u>0</u> 0 795,600	493,591 312,605 46,405 57,188 102,939 30,662 <u>0</u> 1,043,391	508,398 321,984 47,797 58,904 106,027 31,582 <u>0</u> 0 1,074,692	331,643 49,231 60,671 109,208 32,529 <u>0</u> 0 1,106,933	539,360 341,592 50,708 62,491 112,484 33,505 <u>0</u> 0 1,140,141	555,541 351,840 52,229 64,366 115,859 34,511 <u>0</u> 0 1,174,345	572,207 362,395 53,796 66,297 119,335 35,546 0 1,209,576	589,373 373,267 55,410 68,286 122,915 36,612 <u>0</u> 0 1,245,863	384,465 57,072 70,335 126,602 37,711 <u>0</u> 0 1,283,239	625,266 395,999 58,784 72,445 130,400 38,842 0 0 1,321,736	644,024 407,879 60,548 74,618 134,312 40,007 0 1,361,388	663,345 420,116 62,364 76,856 138,342 41,207 <u>0</u> 1,402,230	683,245 432,719 64,235 79,162 142,492 42,444 <u>0</u> 0 1,444,297	703,742 445,701 66,162 81,537 146,767 43,717 <u>0</u> 0 1,487,625	724,854 459,072 68,147 83,983 151,170 45,028 <u>0</u> 0 1,532,254	746,600 472,844 70,192 86,503 155,705 46,379 <u>0</u> 0 1,578,222	768,998 487,029 72,297 89,098 160,376 47,771 <u>0</u> 0 1,625,569	501,640 74,466 91,771 165,187 49,204 <u>0</u> 0 1,674,336	815,830 516,689 76,700 94,524 170,143 50,680 0 0 1,724,566	532,190 79,001 97,359 175,247 52,200 <u>0</u> 0 1,776,303	865,514 548,155 81,371 100,280 180,504 53,766 <u>0</u> 0 1,829,592	891,480 564,600 83,812 103,289 185,920 55,379 <u>0</u> 0 1,884,479
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control Other Other Total running costs R&R Costs: Total Annual Repair and Replacement Cost Other Other	0 0 0 0 0 0 0 0 0 0 0 0		0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		310,171 294,661 36,273 37,734 64,687 28,902 <u>0</u> 0 772,427	319,476 303,500 37,361 38,866 66,627 29,769 <u>0</u> 0 795,600	493,591 312,605 46,405 57,188 102,939 30,662 <u>0</u> 1,043,391	508,398 321,984 47,797 58,904 106,027 31,582 <u>0</u> 0 1,074,692	331,643 49,231 60,671 109,208 32,529 <u>0</u> 0 1,106,933	539,360 341,592 50,708 62,491 112,484 33,505 <u>0</u> 0 1,140,141	555,541 351,840 52,229 64,366 115,859 34,511 <u>0</u> 0 1,174,345	572,207 362,395 53,796 66,297 119,335 35,546 0 1,209,576	589,373 373,267 55,410 68,286 122,915 36,612 <u>0</u> 0 1,245,863	384,465 57,072 70,335 126,602 37,711 <u>0</u> 0 1,283,239	625,266 395,999 58,784 72,445 130,400 38,842 0 0 1,321,736	644,024 407,879 60,548 74,618 134,312 40,007 0 1,361,388	663,345 420,116 62,364 76,856 138,342 41,207 <u>0</u> 0 1,402,230	683,245 432,719 64,235 79,162 142,492 42,444 <u>0</u> 0 1,444,297	703,742 445,701 66,162 81,537 146,767 43,717 <u>0</u> 0 1,487,625	724,854 459,072 68,147 83,983 151,170 45,028 <u>0</u> 0 1,532,254	746,600 472,844 70,192 86,503 155,705 46,379 <u>0</u> 0 1,578,222	768,998 487,029 72,297 89,098 160,376 47,771 <u>0</u> 0 1,625,569	501,640 74,466 91,771 165,187 49,204 <u>0</u> 0 1,674,336	815,830 516,689 76,700 94,524 170,143 50,680 0 0 1,724,566	532,190 79,001 97,359 175,247 52,200 <u>0</u> 0 1,776,303	865,514 548,155 81,371 100,280 180,504 53,766 <u>0</u> 0 1,829,592	891,480 564,600 83,812 103,289 185,920 55,379 <u>0</u> 0 1,884,479
Annual Running Costs: Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Operational Labor Cost (\$/year) Odther Other Other Other Total running costs R&R Costs: Total Annual Repair and Replacement Cost Other Other	0 0 0 0 0 0 0 0 0 0 0 0		0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		310,171 294,661 36,273 37,734 64,687 28,902 <u>0</u> 0 772,427	319,476 303,500 37,361 38,866 66,627 29,769 <u>0</u> 0 795,600	493,591 312,605 46,405 57,188 102,939 30,662 <u>0</u> 1,043,391	508,398 321,984 47,797 58,904 106,027 31,582 <u>0</u> 0 1,074,692	331,643 49,231 60,671 109,208 32,529 <u>0</u> 0 1,106,933	539,360 341,592 50,708 62,491 112,484 33,505 <u>0</u> 0 1,140,141	555,541 351,840 52,229 64,366 115,859 34,511 <u>0</u> 0 1,174,345	572,207 362,395 53,796 66,297 119,335 35,546 0 1,209,576	589,373 373,267 55,410 68,286 122,915 36,612 <u>0</u> 0 1,245,863	384,465 57,072 70,335 126,602 37,711 <u>0</u> 0 1,283,239	625,266 395,999 58,784 72,445 130,400 38,842 0 0 1,321,736	644,024 407,879 60,548 74,618 134,312 40,007 0 1,361,388	663,345 420,116 62,364 76,856 138,342 41,207 <u>0</u> 0 1,402,230	683,245 432,719 64,235 79,162 142,492 42,444 <u>0</u> 0 1,444,297	703,742 445,701 66,162 81,537 146,767 43,717 <u>0</u> 0 1,487,625	724,854 459,072 68,147 83,983 151,170 45,028 <u>0</u> 0 1,532,254	746,600 472,844 70,192 86,503 155,705 46,379 <u>0</u> 0 1,578,222	768,998 487,029 72,297 89,098 160,376 47,771 <u>0</u> 0 1,625,569	501,640 74,466 91,771 165,187 49,204 <u>0</u> 0 1,674,336	815,830 516,689 76,700 94,524 170,143 50,680 0 0 1,724,566	532,190 79,001 97,359 175,247 52,200 <u>0</u> 0 1,776,303	865,514 548,155 81,371 100,280 180,504 53,766 <u>0</u> 0 1,829,592	891,480 564,600 83,812 103,289 185,920 55,379 <u>0</u> 1,884,479
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Image: Cost (\$/year) Annual Water Cost (\$/year) Image: Cost (\$/year) Maintenance Labor Cost (\$/year) Image: Cost (\$/year) Operational Labor Cost (\$/year) Image: Cost (\$/year) Odor Control Image: Cost (\$/year) Other Image: Cost (\$/year) Total running costs Image: Cost (\$/year) Total Annual Repair and Replacement Cost Image: Cost (\$/year) Other Image: Cost (\$/year) Image: Cost (\$/year) Image: Cost (\$/year)	0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	310,171 294,661 36,273 37,734 64,687 28,902 0 0 772,427 26,260 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	319,476 303,500 37,361 38,866 66,627 29,769 0 795,600 31,890 0 0 0 0 0 0 0	493,591 312,605 46,405 57,188 102,939 30,662 0 0 1,043,391 79,622 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	508,398 321,984 47,797 58,904 106,027 31,582 0 0 1,074,692 33,832 0 0 0 0 0 0 0 0 0 0 0 0 0 0	331,643 49,231 60,671 109,208 32,529 0 0 1,106,933 53,820 0 0 0 0 0 0 0 0	539,360 341,592 50,708 62,491 112,484 33,505 0 0 1,140,141 67,462 0 0 0 0 0 0 0 0 0 0 0 0	555,541 351,840 52,229 64,366 115,859 34,511 0 0 1,174,345 57,098 0 0 0 0 0 0 0	572,207 362,395 53,796 66,297 119,335 35,546 0 0 1,209,576 	589,373 373,267 55,410 68,286 122,915 36,612 0 0 1,245,863 95,073 0 0 0 0 0 0 0	384,465 57,072 70,335 126,602 37,711 0 1,283,239 40,397 0 0 0 0 0 0 0	625,266 395,999 58,784 72,445 130,400 38,842 0 0 1,321,736 100,863 0 0 0 0 0 0 0 0 0 0 0 0 0	644,024 407,879 60,548 74,618 134,312 0 0 0 1,361,388 36,350 0 0 0 0 0 0 0 0	663,345 420,116 62,364 76,856 138,342 41,207 <u>0</u> 0 1,402,230	683,245 432,719 64,235 79,162 142,492 42,444 0 0 1,444,297 424,377 0 424,377 0 0 0 0 0	703,742 445,701 66,162 81,537 146,767 43,717 0 0 1,487,625 46,831 0 0 0 0 0	724,854 459,072 68,147 83,983 151,170 45,028 0 0 1,532,254 74,500 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	746,600 472,844 70,192 86,503 155,705 46,379 0 0 1,578,222 93,383 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	768,998 487,029 72,297 89,098 160,376 47,771 0 1,625,569 79,037 0 0 0 0 0 0 0 0 0	501,640 74,466 91,771 165,187 49,204 0 0 1,674,336 52,709 0 0 0 0 0 0	815,830 516,689 76,700 94,524 170,143 50,680 0 0 1,724,566	532,190 79,001 97,359 175,247 52,200 0 0 1,776,303 55,919 0 0 0 0 0 0	865,514 548,155 81,371 100,280 180,504 53,766 0 1,829,592 1,574,862 0 0 0 0 0 0 0 0 0 0 0 0 0	891,480 564,600 83,812 103,289 185,920 55,379 0 1,884,479 50,317 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Image: Cost (\$/year) Annual Water Cost (\$/year) Image: Cost (\$/year) Operational Labor Cost (\$/year) Image: Cost (\$/year) Odor Control Image: Cost (\$/year) Other Image: Cost (\$/year) Total Annual Repair and Replacement Cost Image: Cost (\$/year) Other Image: Cost (\$/year) Image: Cost (\$/year) Image: Cost (\$/year)	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	310,171 294,661 36,273 37,734 64,687 28,902 0 0 772,427 26,260 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	319,476 303,500 37,361 38,866 66,627 29,769 0 0 795,600 795,600 0 0 0 0 0 0 0 0 0 0 0 0	493,591 312,605 46,405 57,188 102,939 30,662 0 0 1,043,391 79,622 0 0 0 0 0 0 0 0 0 0 0 0 0	508,398 321,984 47,797 58,904 106,027 31,582 0 0 1,074,692 33,832 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	331,643 49,231 60,671 109,208 32,529 0 0 1,106,933 53,820 0 0 0 0 0 0 0 53,820	539,360 341,592 50,708 62,491 112,484 33,505 0 0 1,140,141 67,462 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	555,541 351,840 52,229 64,366 115,859 34,511 0 0 1,174,345 57,098 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	572,207 362,395 53,796 66,297 119,335 35,546 0 0 1,209,576 	589,373 373,267 55,410 68,286 122,915 36,612 0 0 1,245,863 95,073 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	384,465 57,072 70,335 126,602 37,711 0 0 1,283,239 40,397 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	625,266 395,999 58,784 72,445 130,400 38,842 0 0 1,321,736 100,863 0 0 0 0 0 100,863	644,024 407,879 60,548 74,618 134,312 0 0 0 1,361,388 36,350 0 0 0 0 0 0 0 0 0 0 36,350	663,345 420,116 62,364 76,856 138,342 41,207 0 0 1,402,230 44,143 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	683,245 432,719 64,235 79,162 142,492 42,444 0 0 1,444,297 424,377 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	703,742 445,701 66,162 81,537 146,767 43,717 0 0 1,487,625 46,831 0 0 0 0 0 46,831	724,854 459,072 68,147 83,983 151,170 45,028 0 0 1,532,254 74,500 0 0 0 0 0 0 0 0 74,500	746,600 472,844 70,192 86,503 155,705 46,379 0 0 1,578,222 93,383 0 0 0 0 0 0 0 93,383	768,998 487,029 72,297 89,098 160,376 47,771 0 0 1,625,569 79,037 0 0 0 0 0 0 0 79,037	501,640 74,466 91,771 165,187 49,204 0 0 1,674,336 52,709 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	815,830 516,689 76,700 94,524 170,143 50,680 0 0 1,724,566 131,603 0 0 0 0 131,603	532,190 79,001 97,359 175,247 52,200 0 1 1,776,303 55,919 0 0 0 0 0 0 0 55,919	865,514 548,155 81,371 100,280 180,504 53,766 0 0 1,829,592 1,574,862 0 0 0 0 0 0 0 0 0 1,574,862	891,480 564,600 83,812 103,289 185,920 55,379 0 0 1,884,479 50,317 0 0 0 0 0 0 0 50,317
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Image: Cost (\$/year) Annual Water Cost (\$/year) Image: Cost (\$/year) Maintenance Labor Cost (\$/year) Image: Cost (\$/year) Operational Labor Cost (\$/year) Image: Cost (\$/year) Odor Control Image: Cost (\$/year) Other Image: Cost (\$/year) Total running costs Image: Cost (\$/year) Total Annual Repair and Replacement Cost Image: Cost (\$/year) Other Image: Cost (\$/year) Image: Cost (\$/year) Image: Cost (\$/year)	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	310,171 294,661 36,273 37,734 64,687 28,902 0 0 772,427 26,260 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	319,476 303,500 37,361 38,866 66,627 29,769 0 0 795,600 795,600 0 0 0 0 0 0 0 0 0 0 0 0	493,591 312,605 46,405 57,188 102,939 30,662 0 0 1,043,391 79,622 0 0 0 0 0 0 0 0 0 0 0 0 0	508,398 321,984 47,797 58,904 106,027 31,582 0 0 1,074,692 33,832 0 0 0 0 0 0 0 0 0 33,832	331,643 49,231 60,671 109,208 32,529 0 0 1,106,933 53,820 0 0 0 0 0 0 0 53,820	539,360 341,592 50,708 62,491 112,484 33,505 0 0 1,140,141 67,462 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	555,541 351,840 52,229 64,366 115,859 34,511 0 0 1,174,345 57,098 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	572,207 362,395 53,796 66,297 119,335 35,546 0 0 1,209,576 	589,373 373,267 55,410 68,286 122,915 36,612 0 0 1,245,863 95,073 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	384,465 57,072 70,335 126,602 37,711 0 0 1,283,239 40,397 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	625,266 395,999 58,784 72,445 130,400 38,842 0 0 1,321,736 100,863 0 0 0 0 0 0 0 0 0 0 0 0 0	644,024 407,879 60,548 74,618 134,312 0 0 0 1,361,388 36,350 0 0 0 0 0 0 0 0 0 0 36,350	663,345 420,116 62,364 76,856 138,342 41,207 0 0 1,402,230 44,143 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	683,245 432,719 64,235 79,162 142,492 42,444 0 0 1,444,297 424,377 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	703,742 445,701 66,162 81,537 146,767 43,717 0 0 1,487,625 46,831 0 0 0 0 0 46,831	724,854 459,072 68,147 83,983 151,170 45,028 0 0 1,532,254 74,500 0 0 0 0 0 0 0 0 74,500	746,600 472,844 70,192 86,503 155,705 46,379 0 0 1,578,222 93,383 0 0 0 0 0 0 0 93,383	768,998 487,029 72,297 89,098 160,376 47,771 0 0 1,625,569 79,037 0 0 0 0 0 0 0 79,037	501,640 74,466 91,771 165,187 49,204 0 0 1,674,336 52,709 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	815,830 516,689 76,700 94,524 170,143 50,680 0 0 1,724,566 131,603 0 0 0 0 131,603	532,190 79,001 97,359 175,247 52,200 0 1 1,776,303 55,919 0 0 0 0 0 0 0 55,919	865,514 548,155 81,371 100,280 180,504 53,766 0 0 1,829,592 1,574,862 0 0 0 0 0 0 0 0 0 1,574,862	891,480 564,600 83,812 103,289 185,920 55,379 0 0 1,884,479 50,317 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Image: Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control Odor Control Other Other Total running costs Total Annual Repair and Replacement Cost Other Other Other	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	310,171 294,661 36,273 37,734 64,687 28,902 0 0 772,427 26,260 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	319,476 303,500 37,361 38,866 66,627 29,769 0 0 795,600 795,600 0 0 0 0 0 0 0 0 0 0 0 0	493,591 312,605 46,405 57,188 102,939 30,662 0 0 1,043,391 79,622 0 0 0 0 0 0 0 0 0 0 0 0 0	508,398 321,984 47,797 58,904 106,027 31,582 0 0 1,074,692 33,832 0 0 0 0 0 0 0 0 0 33,832	331,643 49,231 60,671 109,208 32,529 0 0 1,106,933 53,820 0 0 0 0 0 0 0 53,820	539,360 341,592 50,708 62,491 112,484 33,505 0 0 1,140,141 67,462 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	555,541 351,840 52,229 64,366 115,859 34,511 0 0 1,174,345 57,098 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	572,207 362,395 53,796 66,297 119,335 35,546 0 0 1,209,576 	589,373 373,267 55,410 68,286 122,915 36,612 0 0 1,245,863 95,073 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	384,465 57,072 70,335 126,602 37,711 0 0 1,283,239 40,397 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	625,266 395,999 58,784 72,445 130,400 38,842 0 0 1,321,736 100,863 0 0 0 0 0 100,863	644,024 407,879 60,548 74,618 134,312 0 0 0 1,361,388 36,350 0 0 0 0 0 0 0 0 0 0 36,350	663,345 420,116 62,364 76,856 138,342 41,207 0 0 1,402,230 44,143 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	683,245 432,719 64,235 79,162 142,492 42,444 0 0 1,444,297 424,377 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	703,742 445,701 66,162 81,537 146,767 43,717 0 0 1,487,625 46,831 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	724,854 459,072 68,147 83,983 151,170 45,028 0 0 1,532,254 74,500 0 0 0 0 0 0 0 0 74,500	746,600 472,844 70,192 86,503 155,705 46,379 0 0 1,578,222 93,383 0 0 0 0 0 0 0 93,383	768,998 487,029 72,297 89,098 160,376 47,771 0 0 1,625,569 79,037 0 0 0 0 0 0 0 79,037	501,640 74,466 91,771 165,187 49,204 0 0 1,674,336 52,709 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	815,830 516,689 76,700 94,524 170,143 50,680 0 0 1,724,566 131,603 0 0 0 0 131,603	532,190 79,001 97,359 175,247 52,200 0 1 1,776,303 55,919 0 0 0 0 0 0 0 55,919	865,514 548,155 81,371 100,280 180,504 53,766 0 0 1,829,592 1,574,862 0 0 0 0 0 0 0 0 0 1,574,862	891,480 564,600 83,812 103,289 185,920 55,379 0 0 1,884,479 50,317 0 0 0 0 0 0 0 0 0 0 0 0 0
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control Other Other Other Total running costs R&R Costs: Total Annual Repair and Replacement Cost Other Othe	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0	310,171 294,661 36,273 37,734 64,687 28,902 0 0 772,427 26,260 0 0 0 0 0 0 0 26,260 (798,687)	319,476 303,500 37,361 38,866 66,627 29,769 0 0 795,600 31,890 0 0 0 0 0 31,890 0 0 0 0 0 0 0 0 0 0 0 0 0	493,591 312,605 46,405 57,188 102,939 30,662 0 0 1,043,391 79,622 0 0 0 0 0 0 79,622 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	508,398 321,984 47,797 58,904 106,027 31,582 0 0 1,074,692 33,832 0 0 0 0 0 33,832 (1,108,524)	331,643 49,231 60,671 109,208 32,529 0 0 1,106,933 53,820 0 0 0 0 0 0 53,820 (1,160,754)	539,360 341,592 50,708 62,491 112,484 33,505 0 0 1,140,141 67,462 0 0 0 0 0 0 67,462 (1,207,603)	555,541 351,840 52,229 64,366 115,859 34,511 <u>0</u> 0 1,174,345 57,098 0 0 0 0 0 0 0 0 0 0 0 0 0	572,207 362,395 53,796 66,297 119,335 35,546 0 0 1,209,576 38,078 0 0 0 0 0 0 1,209,576 (1,247,653)	589,373 373,267 55,410 68,286 122,915 36,612 0 0 1,245,863 95,073 0 0 0 0 0 0 95,073 (1,340,936)	384,465 57,072 70,335 126,602 37,711 0 0 1,283,239 40,397 0 0 0 0 0 0 0 0 0 0 0 0 0	625,266 395,999 58,784 72,445 130,400 38,842 0 0 1,321,736 100,863 0 0 0 0 0 0 100,863 (1,422,599) (644,024 407,879 60,548 74,618 134,312 40,007 0 0 1,361,388 36,350 0 0 0 0 0 0 0 0 36,350 1,397,738)	663,345 420,116 62,364 76,856 138,342 41,207 0 0 1,402,230 44,143 0 0 0 0 44,143 (1,446,372)	683,245 432,719 64,235 79,162 142,492 42,444 0 0 1,444,297 424,377 0 0 0 0 0 0 0 0 424,377 (1,868,674)	703,742 445,701 66,162 81,537 146,767 43,717 0 0 1,487,625 46,831 0 0 0 0 46,831 0 0 0 0 (1,534,456)	724,854 459,072 68,147 83,983 151,170 45,028 0 0 1,532,254 74,500 0 0 0 0 0 0 0 0 74,500 (1,606,754)	746,600 472,844 70,192 86,503 155,705 46,379 0 0 1,578,222 93,383 0 0 0 93,383 0 0 0 93,383 (1,671,605)	768,998 487,029 72,297 89,098 160,376 47,771 0 1,625,569 79,037 0 0 0 0 0 79,037 (1,704,606)	501,640 74,466 91,771 165,187 49,204 0 0 1,674,336 52,709 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	815,830 516,689 76,700 94,524 170,143 50,680 0 0 1,724,566 131,603 0 0 0 0 131,603 0 0 0 0 131,603 (1,856,169)	532,190 79,001 97,359 175,247 52,200 0 17,776,303 55,919 0 0 0 0 0 0 0 0 0 55,919 0 0 0 0 0 (1,832,221)	865,514 548,155 81,371 100,280 180,504 53,766 <u>0</u> 0 1,829,592 1,574,862 0 0 0 0 1,574,862 (3,404,454)	891,480 564,600 83,812 103,289 185,920 55,379 0 0 1,884,479 50,317 0 0 0 0 0 (1,934,796)
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Image: Cost (\$/year) Annual Water Cost (\$/year) Image: Cost (\$/year) Annual Water Cost (\$/year) Image: Cost (\$/year) Operational Labor Cost (\$/year) Image: Cost (\$/year) Odor Control Image: Cost (\$/year) Other Image: Cost (\$/year) Total Annual Repair and Replacement Cost Image: Cost (\$/year) Other Image: Cost (\$/year) If e cycle cost analysis Image: Cost (\$/year) PVs in 2016 Image: Cost (\$/year)	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	310,171 294,661 36,273 37,734 64,687 28,902 0 0 772,427 26,260 0 0 0 0 0 0 0 26,260 (798,687)	319,476 303,500 37,361 38,866 66,627 29,769 0 0 795,600 31,890 0 0 0 0 0 31,890 0 0 0 0 0 0 0 0 0 0 0 0 0	493,591 312,605 46,405 57,188 102,939 30,662 0 0 1,043,391 79,622 0 0 0 0 0 0 79,622 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	508,398 321,984 47,797 58,904 106,027 31,582 0 0 1,074,692 33,832 0 0 0 0 0 33,832 (1,108,524)	331,643 49,231 60,671 109,208 32,529 0 0 1,106,933 53,820 0 0 0 0 0 0 53,820 (1,160,754)	539,360 341,592 50,708 62,491 112,484 33,505 0 0 1,140,141 67,462 0 0 0 0 0 0 67,462 (1,207,603)	555,541 351,840 52,229 64,366 115,859 34,511 <u>0</u> 0 1,174,345 57,098 0 0 0 0 0 0 0 0 0 0 0 0 0	572,207 362,395 53,796 66,297 119,335 35,546 0 0 1,209,576 	589,373 373,267 55,410 68,286 122,915 36,612 0 0 1,245,863 95,073 0 0 0 0 0 0 95,073 (1,340,936)	384,465 57,072 70,335 126,602 37,711 0 0 1,283,239 40,397 0 0 0 0 0 0 0 0 0 0 0 0 0	625,266 395,999 58,784 72,445 130,400 38,842 0 0 1,321,736 100,863 0 0 0 0 0 100,863	644,024 407,879 60,548 74,618 134,312 40,007 0 0 1,361,388 36,350 0 0 0 0 0 0 0 0 36,350 1,397,738)	663,345 420,116 62,364 76,856 138,342 41,207 0 0 1,402,230 44,143 0 0 0 0 44,143 (1,446,372)	683,245 432,719 64,235 79,162 142,492 42,444 0 0 1,444,297 424,377 0 0 0 0 0 0 0 0 424,377 (1,868,674)	703,742 445,701 66,162 81,537 146,767 43,717 0 0 1,487,625 46,831 0 0 0 0 46,831 0 0 0 0 (1,534,456)	724,854 459,072 68,147 83,983 151,170 45,028 0 0 1,532,254 74,500 0 0 0 0 0 0 0 0 74,500 (1,606,754)	746,600 472,844 70,192 86,503 155,705 46,379 0 0 1,578,222 93,383 0 0 0 93,383 0 0 0 93,383 (1,671,605)	768,998 487,029 72,297 89,098 160,376 47,771 0 1,625,569 79,037 0 0 0 0 0 79,037 (1,704,606)	501,640 74,466 91,771 165,187 49,204 0 0 1,674,336 52,709 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	815,830 516,689 76,700 94,524 170,143 50,680 0 0 1,724,566 131,603 0 0 0 0 131,603 0 0 0 0 131,603 (1,856,169)	532,190 79,001 97,359 175,247 52,200 0 1 1,776,303 55,919 0 0 0 0 0 0 0 55,919	865,514 548,155 81,371 100,280 180,504 53,766 <u>0</u> 0 1,829,592 1,574,862 0 0 0 0 1,574,862 (3,404,454)	891,480 564,600 83,812 103,289 185,920 55,379 0 0 1,884,479 50,317 0 0 0 0 0 (1,934,796)
Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control Other Other Other Total running costs R&R Costs: Total Annual Repair and Replacement Cost Other Othe	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0	310,171 294,661 36,273 37,734 64,687 28,902 0 0 772,427 26,260 0 0 0 0 0 0 0 26,260 (798,687)	319,476 303,500 37,361 38,866 66,627 29,769 0 0 795,600 31,890 0 0 0 0 0 31,890 0 0 0 0 0 0 0 0 0 0 0 0 0	493,591 312,605 46,405 57,188 102,939 30,662 0 0 1,043,391 79,622 0 0 0 0 0 0 79,622 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	508,398 321,984 47,797 58,904 106,027 31,582 0 0 1,074,692 33,832 0 0 0 0 0 33,832 (1,108,524)	331,643 49,231 60,671 109,208 32,529 0 0 1,106,933 53,820 0 0 0 0 0 0 53,820 (1,160,754)	539,360 341,592 50,708 62,491 112,484 33,505 0 0 1,140,141 67,462 0 0 0 0 0 0 67,462 (1,207,603)	555,541 351,840 52,229 64,366 115,859 34,511 <u>0</u> 0 1,174,345 57,098 0 0 0 0 0 0 0 0 0 0 0 0 0	572,207 362,395 53,796 66,297 119,335 35,546 0 0 1,209,576 38,078 0 0 0 0 0 0 1,209,576 (1,247,653)	589,373 373,267 55,410 68,286 122,915 36,612 0 0 1,245,863 95,073 0 0 0 0 0 0 95,073 (1,340,936)	384,465 57,072 70,335 126,602 37,711 0 0 1,283,239 40,397 0 0 0 0 0 0 0 0 0 0 0 0 0	625,266 395,999 58,784 72,445 130,400 38,842 0 0 1,321,736 100,863 0 0 0 0 0 0 100,863 (1,422,599) (644,024 407,879 60,548 74,618 134,312 40,007 <u>0</u> 0 1,361,388 36,350 0 0 0 0 0 0 36,350 1,397,738)	663,345 420,116 62,364 76,856 138,342 41,207 0 0 1,402,230 44,143 0 0 0 0 44,143 (1,446,372)	683,245 432,719 64,235 79,162 142,492 42,444 0 0 1,444,297 424,377 0 0 0 0 0 0 0 0 424,377 (1,868,674)	703,742 445,701 66,162 81,537 146,767 43,717 0 0 1,487,625 46,831 0 0 0 0 46,831 0 0 0 0 (1,534,456)	724,854 459,072 68,147 83,983 151,170 45,028 0 0 1,532,254 74,500 0 0 0 0 0 0 0 0 74,500 (1,606,754)	746,600 472,844 70,192 86,503 155,705 46,379 0 0 1,578,222 93,383 0 0 0 93,383 0 0 0 93,383 (1,671,605)	768,998 487,029 72,297 89,098 160,376 47,771 0 1,625,569 79,037 0 0 0 0 0 79,037 (1,704,606)	501,640 74,466 91,771 165,187 49,204 0 0 1,674,336 52,709 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	815,830 516,689 76,700 94,524 170,143 50,680 0 0 1,724,566 131,603 0 0 0 0 131,603 0 0 0 0 131,603 (1,856,169)	532,190 79,001 97,359 175,247 52,200 0 17,776,303 55,919 0 0 0 0 0 0 0 0 0 55,919 0 0 0 0 0 (1,832,221)	865,514 548,155 81,371 100,280 180,504 53,766 <u>0</u> 0 1,829,592 1,574,862 0 0 0 0 1,574,862 (3,404,454)	891,480 564,600 83,812 103,289 185,920 55,379 0 0 1,884,479 50,317 0 0 0 0 0 0 0 (1,934,796)

From Summary Sheet:		Risk adiustme	ents (+/- percent):	:										Inland Em	pire Utilities	Agencv														
Year of analysis	2016		Benefits	0%											16-22, 22-30,															
Escalation rate	3.00%		Capital costs										L		ernative Cost															
Discount rate	2.00%		Running costs												-	,														
Rotary Drum Thickener Separate															Yea	r														
	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
Expressed in 2016 dollars, unescalated																														
Capital Outlays																														
Total							12,784,464									<u> </u>														
Total capital outlays	0	0) 0	0	0 0	U	0 12,784,464	0	0	0	U	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	U
Benefits:																						0								
Other																						0								
Other																														
Total benefits	0	0) 0	0) 0	0	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Annual Running Costs:																														
Energy Cost (\$/year)								\$20,745	\$20,745	\$20,745		\$20,745	\$20,745	\$20,745	\$20,745	\$20,745	\$20,745	\$20,745	\$20,745	\$20,745	\$20,745	\$20,745	\$20,745	\$20,745	\$20,745	\$20,745	\$20,745	\$20,745		
Total Polymer Cost (\$/year)								\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	\$239,586	· · · · · ·
Annual Water Cost (\$/year)								\$46,264	\$46,264	\$60,722	\$60,722 \$39,447	\$60,722	\$60,722	\$60,722 \$39,447	\$60,722 \$39,447	\$60,722 \$39,447	\$60,722 \$39,447	\$60,722 \$39,447	\$60,722	\$60,722	\$60,722	\$60,722	\$60,722	\$60,722	\$60,722	\$60,722	\$60,722	\$60,722		
Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year)							-	\$39,447 \$78,894	\$39,447 \$78.894	\$39,447 \$78,894																				
Odor Control								\$78,894 \$23,500	\$23,500	\$78,894		\$78,694 \$23,500	\$78,694	\$78,894	\$78,894 \$23,500	\$78,894	\$78,894 \$23,500	\$78,894 \$23,500	\$78,894 \$23,500	\$78,894	\$78,694	\$78,694 \$23,500	\$70,094	\$23,500	\$78,894	\$23,500	\$78,894	\$78,894	\$70,094 \$23,500	\$78,694
Other								420,000	423,000	423,000	423,000	420,000	420,000	420,000	420,000	423,000	420,000	420,000	420,000	420,000	420,000	423,000	420,000	420,000	120,000	420,000	420,000	¥23,000	420,000	<i>q</i> 20,000
Other																														
Total running costs	0	0	0	0) 0	0	0 0	448,437	448,437	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894	462,894
R&R Costs:																														
Total Annual Repair and Replacement Cos	st							10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	50,394	10,351	10,351	10,351	10,351	10,351	10,351	202,663	10,351
Other																														
Other Other																														
Other																														
Total refurbishments		0) 0	0) 0	0	0 0	10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	10,351	50,394	10,351	10,351	10,351	10,351	10,351	10,351	202,663	10,351
Net Benefit/(cost)	0	0) 0	0) 0	0	0 (12,784,464)	(458,788)	(458,788)	(473,246)	(473,246)	(473,246)	(473,246)	(473,246)	(473,246)	(473,246)	(473,246)	(473,246)	(473,246)	(473,246)	(473,246)	(513,288)	(473,246)	(473,246)	(473,246)	(473,246)	(473,246)	(473,246)	(665,558)	(473,246)
Expressed in escalated dollars with sens	sitivity adjustme	ents																												
Capital Outlays																														
Total	0	0) 0	C	0 0	0	0 15,265,319	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total capital outlays	0	0	0	0) 0	0	0 15,265,319	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Benefits:																														
0	0	0	0 0	0	0 0	0	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other Other	0	0		0			0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total benefits	0	0 0) 0	(0 0	0	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0 0
Annual Running Costs:	~		,		· · ·		· · ·	v	v	v	v	~	v	•	v	J	v	v	v	~	~	v	•	•	•	v	~	J	•	v
Energy Cost (\$/year)	0	0) 0	C	0 0	C	0 0	25,514	26,279	27,068	27,880	28,716	29,578	30,465	31,379	32,320	33,290	34,289	35,317	36,377	37,468	38,592	39,750	40,943	42,171	43,436	44,739	46,081	47,464	48,888
Total Polymer Cost (\$/year)	0	0	0	C	0 0	0	0 0	294,661	303,500	312,605	321,984	331,643	341,592	351,840	362,395	373,267	384,465	395,999	407,879	420,116	432,719	445,701	459,072	472,844	487,029	501,640	516,689	532,190	548,155	564,600
Annual Water Cost (\$/year)	0	0) 0	C	0 0	C	0 0	56,899	58,606	79,228	81,605	84,053	86,574	89,172	91,847	94,602	97,440	100,363	103,374	106,476	109,670	112,960	116,349	119,839	123,434	127,137	130,952	134,880	138,927	143,094
Maintenance Labor Cost (\$/year)	0	0) 0	0	0 0	0		48,515	49,970	51,470	53,014	54,604	56,242	57,929	59,667	61,457	63,301	65,200	67,156	69,171	71,246	73,383	75,585	77,852	80,188	82,594	85,071	87,623	90,252	92,960
Operational Labor Cost (\$/year) Odor Control	0	0		0	0 1	0		97,030 28,902	99,941	102,939 30,662	106,027	109,208	112,484	115,859 34,511	119,335	122,915	126,602	130,400	134,312	138,342	142,492	146,767 43,717	151,170	155,705	160,376 47,771	165,187	170,143 50,680	175,247	180,504	185,920
Other	0	0) 0) 0			20,902	29,769 0	30,002 0	31,582 0	32,529	33,505	34,311	35,546 0	36,612 0	37,711	38,842	40,007	41,207 0	42,444	43,111	45,028	46,379	41,111	49,204	JU,000 0	52,200 0	53,766 0	55,379
Other	0	0						0	0	0	0	0	0	<u> </u>	0	0	0	<u> </u>	Ŭ	0	Ŭ	0	0	Ŭ	0	Ŭ	0	0	0	0
Total running costs	0	0) 0	0) 0	0	0 0	551,521	568,066	603,972	622,091	640,754	659,976	679,776	700,169	721,174	742,809	765,094	788,046	811,688	836,038	861,120	886,953	913,562	940,969	969,198	998,274	1,028,222	1,059,069	1,090,841
R&R Costs:																														
Total Annual Repair and Replacement C	0	0	0	C	0 0	C	0 0	12,731	13,113	13,506	13,911	14,329	14,759	15,201	15,657	16,127	16,611	17,109	17,623	18,151	18,696	93,747	19,834	20,429	21,042	21,674	22,324	22,994	463,679	24,394
Other	0	0	0 0	C	0 0	C	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other	0	0	0 0	0	0 0	0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other Other	U	0			0 0			0	0	0	0	0	U	0	U	0	0	U	0	U	0	0	0	U	U	U	0	0	U	0
Total refurbishments	0	0	0	0	0 0	0	0 0	12,731	13,113	13.506	13.911	14,329	14,759	15,201	15,657	16,127	16,611	17,109	17,623	18,151	18.696	93,747	19,834	20,429	21.042	21.674	22,324	22,994	463,679	24,394
Net escalated benefit/(cost)	0	0	-	-	0 0	-	0 (15,265,319)	,	(581,179)	,	,	(655,083)	(674,735)	(694,977)	(715,827)	(737,301)	,	,	(805,669)	(829,839)	(854,734)	,	,	,	(962,011)	,	,	,	(1,522,748)	1
l ife evelo cont analyzia																														
Life cycle cost analysis								(101-1-1	//00 /	/=	(501	(500	/500	(107.0	(F 10	<i>(</i> 		(550	(50.000)	(500.5	(1996-0	(200	(500	(500.500)	(500.1	(000	(222	(0.15	(07.1	1000
PVs in 2016	0	0) 0	0	0 0	C	0 (13,555,166)	(491,215)	(496,031)	(516,678)	(521,744)	(526,859)	(532,024)	(537,240)	(542,507)	(547,826)	(553,197)	(558,620)	(564,097)	(569,627)	(575,212)	(629,998)	(586,546)	(592,296)	(598,103)	(603,967)	(609,888)	(615,867)	(874,627)	(628,002)
10010	(00 007 000)																													
NPV as of 2016	(26,827,336)																													

From Summary Sheet:		Risk adjustm	ents (+/- per	rcent):											npire Utilities															
Year of analysis	2016		Benefits	0%										RP-5 (20	16-22, 22-30	30-45)														
Escalation rate	3.00%	C	apital costs	0%									Lif	e Cycle Alte	ernative Cost	Analysis (\$)														
Discount rate	2.00%	Ru	nning costs	0%											-															
ravity Belt Thickener Separate				1												ear														
unun and in 0040 dallana una and ta d	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
xpressed in 2016 dollars, unescalated																														
apital Outlays Total Capital							14,523,769																							
Total capital outlays	0	0	0	0	0	0	, ,	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
lenefits:	•		•			v	14,020,100	•			•	•		•	•	•	v	•	•	•	•	•	v	•	v	•	•	•		•
Other																														
Other																														
Other																														
Total benefits	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Annual Running Costs:																													+	
Energy Cost (\$/year)								\$19,525	\$19,525		\$19,525	\$19,525	\$19,525	\$19,525	\$19,525	\$19,525	\$19,525	\$19,525	\$19,525	\$19,525	\$19,525	\$19,525	\$19,525	\$19,525	\$29,287	\$29,287	\$29,287	\$29,287		\$29,287
Total Polymer Cost (\$/year) Annual Water Cost (\$/year)								\$239,586 \$98,311	\$239,586 \$98,311		\$239,586 \$98,311	\$239,586 \$138,792	\$239,586 \$138,792	\$239,586 \$138,792	\$239,586 \$138,792		\$239,586 \$138,792													
Maintenance Labor Cost (\$/year)								52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596	78,894	78,894	78,894	78,894	78,894	78,894
Operational Labor Cost (\$/year)								105,192	105,192	105,192	105,192	105,192	105,192	105,192	105,192	105,192	105,192	105,192	105,192	105,192	105,192	105,192	105,192	105,192	157,789	157,789	157,789	157,789	157,789	157,789
Odor Control								23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500
Total supping costs			0	0	0	0	0	538,711	538,711	538,711	538,711	538,711	538,711	538,711	538,711	538,711	538,711	538,711	538,711	538,711	538,711	538,711	538,711	538,711	667.848	667.848	667.848	667.848	667,848	667,848
Total running costs			U	U	U	U	U	000,711	000,711	000,711	000,711	000,711	030,711	000,711	000,711	000,711	000,711	000,711	000,711	000,711	000,711	000,711	000,711	000,711	007,040	007,040	007,040	007,040	007,040	007,040
R&R Costs: Total Annual Repair and Replacement Cost					0	0	0	31,756	31,756	39,137	31,756	39,137	31,756	39,137	31,756	39,137	31,756	45,837	31,756	39,137	31,756	39,137	31,756	39,137	31,756	39,137	31,756	39,137	344,268	39,137
Other						U U	Ĭ	51,750	51,750	55,157	51,750	33,137	51,750	55,157	51,750	55,157	51,750	43,007	51,750	55,157	51,750	35,157	51,750	33,137	51,750	55,157	51,750	33,137	344,200	55,157
Other																														
Other																														
Other																														
Total refurbishments		0	0	0	•	0			31,756	39,137	31,756	39,137	31,756	39,137	31,756	39,137	31,756	45,837	31,756	39,137	31,756	39,137	31,756	39,137	31,756	39,137	31,756	39,137	,	39,137
Net Benefit/(cost)	0	0	0	0	0	0	(14,523,769)	(570,466)	(570,466)	(577,847)	(570,466)	(577,847)	(570,466)	(577,847)	(570,466)	(577,847)	(570,466)	(584,548)	(570,466)	(577,847)	(570,466)	(577,847)	(570,466)	(577,847)	(699,604)	(706,985)	(699,604)	(706,985)	(1,012,117)	(706,985)
Expressed in escalated dollars with sensitiv	lity adjustments																													
Capital Outlays Total Capital	0	0	0	0	0	0	17,342,140	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total capital outlays	0	0	0	0	0	0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Benefits:	•		•	-		-	,0.12,1.10	•	•		-	-	-	-	•		-	•	•	-	•		•	-	•	•	•	•	•	•
Other	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total benefits	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Annual Running Costs:										05.170		07.007	07.000	00.070						0 1 007				00.504	50 505	01.001	22.121	25.052		
Energy Cost (\$/year) Total Polymer Cost (\$/year)	0	0	0	0	0	0	0	24,013 294,661	24,734 303,500	25,476 312,605	26,240 321,984	27,027 331,643	27,838 341,592	28,673 351,840	29,533 362,395	30,419 373,267	31,332 384,465	32,272 395,999	33,240 407,879	34,237 420,116	35,264 432,719	36,322 445,701	37,412 459,072	38,534 472,844	59,535 487,029	61,321 501,640	63,161 516,689	65,056 532,190	67,008 548,155	69,018 564,600
Annual Water Cost (\$/year)	0	0	0	0	0	0	0	294,001	303,500	312,605	321,984 132,122	136,086	341,592 140,168	351,840 144,373	362,395	373,267	384,405	395,999 162,493	407,879	420,116	432,719	445,701	459,072	472,844	487,029 282,136	290,600	516,689 299,318	532,190 308,297	548,155 317,546	327,073
Maintenance Labor Cost (\$/year)	0	0	0	0	0	0	0	64,687	66,627	68,626	70,685	72,805	74,990	77,239	79,556	81,943	84,401	86,933	89,541	92,228	94,995	97,844	100,780	103,803	160,376	165,187	170,143	175,247	180,504	185,920
Operational Labor Cost (\$/year)	0	0	0	0	0	0	0	129,373	133,255	137,252	141,370	145,611	149,979	154,479	159,113	163,886	168,803	173,867	179,083	184,455	189,989	195,689	201,559	207,606	320,752	330,374	340,285	350,494	361,009	371,839
Odor Control	0	0	0	0	0	0	0	28,902	29,769	30,662	31,582	32,529	33,505	34,511	35,546	36,612	37,711	38,842	40,007	41,207	42,444	43,717	45,028	46,379	47,771	49,204	50,680	52,200	53,766	55,379
0	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	0	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	0	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	0	<u>0</u>	<u>0</u>	<u>0</u>	0	0	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	0	<u>0</u>	<u>0</u>	<u>0</u>
0 Total running costs	0	0	0	0	0	0	0	0 662,546	0 682,422	0 702,895	0 723,982	745,701	0 768.072	0 791,115	0 814.848	0 839,294	0 864.472	0 890,407	0 917,119	0 944.632	0 972,971	0 1.002,160	0	1 063 102	0 1,357,598	0 1,398,326	0 1,440,276	0	0 1,527,989	0 1,573,828
R&R Costs:	U		U	v	v	v	U	002,040	002,422	102,030	120,002	140,101	100,012	131,113	014,040	003,234	004,412	000,407	517,113	J-+,UJZ	512,311	1,002,100	1,002,220	1,000,102	1,007,000	1,000,020	1,770,210	1,400,404	1,021,303	1,010,020
Total Annual Repair and Replacement Cost	0	0	0	0	0	0	0	39,055	40,227	51,064	42,677	54,174	45,276	57,473	48,033	60,974	50,959	75,762	54,062	68,626	57,354	72,806	60,847	77,240	64,553	81,943	68,484	86,934	787,661	92,228
Other	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other Total refurbishmente		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total refurbishments	0		0	•	-	0	-	,	40,227	,	42,677	54,174	45,276	57,473	48,033	60,974	50,959	75,762	54,062	68,626	57,354	72,806	60,847	77,240	64,553	81,943	68,484	86,934	,	92,228
	0	0	0	0	0	0	(17,342,140)	(701,602)	(722,650)	(753,960)	(766,659)	(799,876)	(813,348)	(848,588)	(862,881)	(900,267)	(915,431)	(966,169)	(971,181)	(1,013,259)	(1,030,326)	(1,074,966)	(1,093,072)	(1,140,431)	(1,422,151)	(1,480,270)	(1,508,760)	(1,570,418)	(2,315,650)	(1,666,056)
Life cycle cost analysis																														
	0 (32,591,733)	, i i i i i i i i i i i i i i i i i i i	0	0	0	0	(15,399,324)	(610,786)	(616,774)	(630,880)	(628,927)	(643,310)	(641,320)	(655,986)	(653,956)	(668,912)	(666,842)	(690,002)	(679,981)	(695,532)	(693,380)	(709,237)	(707,042)	(723,211)	(884,182)	(902,270)	(901,604)	(920,048)	(1,330,050)	(938,177)

From Summary Sheet:		Risk adjustme	nts (+/- percent):												pire Utilities															
Year of analysis	2016		Benefits	0%											16-22, 22-30,															
Escalation rate	3.00%		Capital costs	0%									L	Life Cycle Alt	ernative Cost	Analysis (\$)														
Discount rate	2.00%		Running costs	0%											•															
AFT Co-thickening															Vaa	-														
JAF I CO-unickenning	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	Yea 2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
Expressed in 2016 dollars, unescalated	2010	2011	2010	2010	2020			2020		2020	2020		2020	2020	2000	2001	2002	2000	2004	2000	2000	2001	2000	2000	2040			2010		2040
Capital Outlays																														
Total Capital							19,047,354																							
Total capital outlays	0	0	0	0	(0 (0 19,047,354	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Benefits:																														
Other	-																					0								
Other																														
Total benefits	0	0	0	0	(0 (0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Annual Running Costs:																														
Energy Cost (\$/year)								\$235,623		\$471,246	\$471,246	\$471,246	\$471,246	\$471,246	\$471,246	\$471,246		\$471,246		\$471,246	\$471,246	\$471,246	\$471,246	\$471,246	\$471,246	\$471,246	\$471,246	\$471,246	\$471,246	\$471,246
Total Polymer Cost (\$/year)	-							\$291,158	\$295,313	\$299,469		\$320,427	\$330,906	\$341,385	\$351,865	\$358,188		\$370,835		\$383,483	\$390,439	\$397,395	\$404,351	\$411,307	\$418,263	\$423,502	\$428,742		\$439,221	\$444,461
Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year)								\$23,132 \$90,789	\$23,132 \$90,789	\$28,915 \$181,578		\$28,915 \$181,578		\$28,915 \$181,578		\$28,915 \$181,578														
Operational Labor Cost (\$/year)								\$30,263	\$30,263	\$60,526	\$60,526	\$60,526	\$60,526	\$60,526	\$60,526	\$60,526	\$60,526	\$60,526		\$60,526	\$60,526	\$60,526	\$60,526	\$60,526	\$60,526	\$60,526	\$60,526	\$60,526	\$60,526	\$60,526
Odor Control								\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500		\$23,500		\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500	\$23,500
Other	_																													
Other Total running costs	0	0	0	0		0 0	0 0	694,464	698.620	1.065,233	1,075,712	1,086,191	1,096,671	1,107,150	1,117,629	1,123,953	1,130,276	1,136,600	1,142,923	1,149,247	1,156,203	1,163,159	1,170,115	1,177,071	1,184,027	1,189,267	1,194,506	1,199,746	1,204,985	1,210,225
R&R Costs:	U	v	v	U		,	0 0	054,404	090,020	1,000,200	1,075,712	1,000,191	1,090,071	1,107,100	1,117,029	1,123,933	1,130,270	1,130,000	1,142,923	1,149,247	1,100,200	1,105,159	1,170,115	1,177,071	1,104,027	1,109,207	1,194,500	1,139,740	1,204,900	1,210,225
Total Annual Repair and Replacement Cost								3,853	3,853	7,706	7,706	12,706	7,706	12,706	7,706	7,706	12,706	7,706	12,706	7,706	7,706	19,206	7 706	19,206	7,706	7,706	12,706	7,706	619.642	7,706
Other								0,000	0,000	1,100	.,	12,100	1,100	12,100	1,100	.,	12,100	1,100	12,100	1,100	1,100	10,200	1,100	10,200	1,100	1,100	12,100	1,100	010,012	1,100
Other																														
Other	-																													
Other Total refurbishments		0	0	0		0 0	0 0	3,853	3,853	7,706	7,706	12.706	7,706	12,706	7,706	7.706	12.706	7.706	12.706	7.706	7,706	19,206	7,706	19,206	7,706	7,706	12.706	7,706	619.642	7,706
Net Benefit/(cost)	0		-	0			0 (19.047.354)	,	,	,	,	(1,098,898)	,	,	,	,	,		(1,155,630)	,		,	,	(1,196,277)	,	,	,	(1,207,452)	,	,
	v	v	v				0 (19,047,334)	(050,510)	(102,413)	(1,072,540)	(1,005,415)	(1,050,050)	(1,104,377)	(1,119,000)	(1,120,000)	(1,131,033)	(1,142,505)	(1,144,500)	(1,100,000)	(1,100,000)	(1,105,505)	(1,102,000)	(1,177,021)	(1,190,211)	(1,191,733)	(1,130,373)	(1,207,213)	(1,207,402)	(1,024,027)	(1,217,951)
Expressed in escalated dollars with sensitivit	tv adiustments																													
Capital Outlays																														
Total Capital	0	0	0	0	(0 (0 22,743,537	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total capital outlays	0	0	0	0		0 (0 22,743,537	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Benefits:																														
0	0	0	0	0	(0 (0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other Other	0	0	0	0				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total benefits	0	0	0	0		0 0	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Annual Running Costs:																														
Energy Cost (\$/year)	0	0	0	0	(0 (0 0	289,786	298,480	614,869	633,315	652,314	671,884	692,040	712,801	734,185	756,211	778,897	802,264	826,332	851,122	876,656	902,955	930,044	957,945	986,684	1,016,284	1,046,773	1,078,176	1,110,521
Total Polymer Cost (\$/year)	0	0	0	0	(0 (0 0	358,087	374,094	390,739	416,544	443,546	471,793	501,336	532,227	558,046	584,934	612,934	642,088	672,439	705,176	739,271	774,778	811,749	850,242	886,720	924,621	963,998	1,004,906	1,047,400
Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year)	0	0	0	0		0 (0 (28,449 111,659	29,303 115,009	37,728 236,918	38,859 244,025	40,025 251,346	41,226 258,886	42,463 266,653	43,737 274,653	45,049 282,892	46,400 291,379	47,792 300,120	49,226 309,124	50,703 318,398	52,224 327,950	53,790 337,788	55,404 347,922	57,066 358,359	58,778 369,110	60,542 380,184	62,358 391,589	64,229 403,337	66,155 415,437	68,140 427,900
Operational Labor Cost (\$/year)	0	0	0	0			0 0	37,220	38,336	78,973	81,342	83,782	208,880	200,003	91,551	282,892	291,379 97,126	100,040	103,041	106,133	109,317	112,596	347,922 115,974	119,453	123,037	126,728	130,530	403,337	415,437 138,479	427,900
Odor Control	0	0	0	0	(0 0	0 0	28,902	29,769	30,662	31,582	32,529	33,505	34,511	35,546	36,612	37,711	38,842	40,007	41,207	42,444	43,717	45,028	46,379	47,771	49,204	50,680	52,200	53,766	55,379
Other	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	(<u>0</u>	<u>0</u> <u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>
Other	0	0	0	0	(0 (0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0 750 046	0
Total running costs	0	0	0	0		0 (0 0	854,104	884,991	1,389,888	1,445,667	1,503,543	1,563,590	1,625,887	1,690,514	1,751,081	1,813,761	1,878,626	1,945,751	2,015,212	2,088,231	2,163,818	2,242,061	2,323,051	2,406,883	2,490,060	2,576,062	2,664,982	2,756,919	2,851,974
R&R Costs: Total Annual Repair and Replacement Cost	0	0	0	^		0 0	0 0	4,739	/ 001	10,055	10,357	17,589	10,987	18,660	11,657	12,006	20 200	12,738	21,632	13,513	13,919	35,730	14,766	37,905	15,666	16,135	27,403	17,118	1,417,696	18,161
Other	0	0	0	0			0 0	4,139	4,881	10,000	10,307	0	0,907	10,000	0	12,000	20,390 0	12,738	21,052	13,313	0	33,730	14,700	37,900	10,000	0,155	21,403	0	1,417,090	10,101
Other	0	0	0	0	(0 0	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other	0	0	0	0	(0 (0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Other		0	0	0	(0 (0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total refurbishments Net escalated benefit/(cost)	0		-	0		-	0 0 0 (22,743,537)	.,	4,881 (889,872)	10,055 (1,399,943)	10,357 (1,456,024)	17,589 (1,521,132)	10,987 (1,574,578)	18,660 (1,644,547)	11,657 (1,702,171)	12,006 (1,763,088)	20,390 (1,834,151)	12,738 (1,891,364)	21,632 (1,967,382)	13,513 (2,028,725)	13,919 (2,102,150)	35,730 (2,199,548)	14,766 (2,256,828)	37,905 (2,360,957)	15,666 (2,422,549)	16,135 (2,506,196)	27,403 (2,603,464)	17,118 (2,682,100)	, ,	18,161 (2,870,135)
l ife cycle cost analysis																														
Life cycle cost analysis	0	0	0	٥		n (0 (20.105.610)	(747 674)	(750 407)	(1 171 400)	(1 104 447)	(1 222 200)	(1 241 544)	(1)71)00\	(1 200 022)	(1 310 000)	(1 326 000)	(1 350 7/4)	(1 277 401)	(1 302 570)	(1 414 607)	(1 451 200)	(1 450 004)	(1 407 015)	(1 506 151)	(1 507 604)	(1 555 776)	(1 571 244)	(2) 207 702	(1.616.000)
Life cycle cost analysis PVs in 2016 NPV as of 2016	0		0	0	(0 (0 (20,195,610)	(747,674)	(759,497)	(1,171,409)	(1,194,447)	(1,223,390)	(1,241,544)	(1,271,288)	(1,290,033)	(1,310,000)	(1,336,080)	(1,350,741)	(1,377,481)	(1,392,579)	(1,414,687)	(1,451,209)	(1,459,804)	(1,497,215)	(1,506,151)	(1,527,604)	(1,555,776)	(1,571,341)	(2,397,793)	(1,616,208)

From Summary Sheet:		Risk adjustments (+	- nercentl.										Inland Em	pire Utilities	Adency														
Year of analysis	2016		nefits 0%											16-22, 22-30,															
Escalation rate	3.00%	Capital											Life Cycle Alte																
Discount rate	2.00%	Running											allo eyolo i lite	-															
Diocount rate	2.0070	i valining v	Jata 0,0											-															
Centrifuges Co-thickening						. <u> </u>		I	<u> </u>						Year			I						1	1				
wontanages ee anonen.g	2016	2017 20	18 2019	9 2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
Expressed in 2016 dollars, unescalated			-			1																							
Capital Outlays																													
Total Capital						21,469,777																							
Total capital outlays	0	0	0	0 0	0 0	21,469,777	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Benefits:							+																						
Other																													
Other																													
Other																													
Total benefits	0	0	0	0 0	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Annual Running Costs:																													
Energy Cost (\$/year)							\$252,197		\$252,197	\$252,197	\$252,197	\$252,197	\$252,197	\$252,197	\$252,197	\$252,197	\$252,197	\$252,197	\$378,296		\$378,296	\$378,296	\$378,296	\$378,296	\$378,296	\$378,296	\$378,296	\$378,296	\$378,296
Total Polymer Cost (\$/year)							238,220	241,620	245,020	253,594	262,168	270,741	279,315	287,889	293,063		303,411	308,585	313,759		325,141	330,832	336,524	342,215	346,502	350,789	355,076	359,363	363,650
Annual Water Cost (\$/year)							\$29,493				\$29,493	\$29,493	\$29,493	\$29,493			\$29,493	\$29,493	\$35,565			\$35,565	\$35,565	\$35,565	\$35,565	\$35,565	\$35,565	\$35,565	\$35,565
Maintenance Labor Cost (\$/year)							35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064		35,064	35,064	52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596	52,596
Operational Labor Cost (\$/year)							70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128		70,128	70,128	105,192		105,192	105,192	105,192	105,192	105,192	105,192	105,192	105,192	105,192
Odor Control							23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500	23,500
Total running costs		0	0	0 0	0 0	0	648,603	652,003	655,403	663,977	672,551	681,125	689,698	698,272	703,446	708,620	713,794	718,968	908,909	914,600	920,291	925,982	931,674	937,365	941,652	945,939	950,226	954,513	958,800
-		•					040,000				012,001	001,120	000,000	000,212	100,440	100,020	110,104	110,000	500,000	01-1,000	520,201	520,002	301,014	301,000	041,002	340,000	500,220	504,010	300,000
R&R Costs:					0	0	14.034	16 783	40.682	16 783	25 021	21 544	25.021	16 783	40.682	16 783	40.682	14.234	16 793	158 645	16 783	25.021	21.544	25.021	16 783	40.682	16 783	667.004	14.034
Total Annual Repair and Replacement Cost							14,234	16,783	40,682	16,783	25,921	31,544	25,921	16,783	40,682	16,783	40,682	14,234	16,783	156,645	16,783	25,921	31,544	25,921	16,783	40,682	16,783	667,994	14,234
Total refurbishments		0		0 0	0 0	0	14.234	16,783	40.682	16,783	25.921	31.544	25.921	16,783	40.682	16,783	40.682	14,234	16,783	156.645	16,783	25,921	31.544	25,921	16,783	40,682	16.783	667.994	14,234
Tutai returbishmenta		•					17,697	10,100	40,002	10,100	20,021	01,044	20,021	10,100	40,002	10,100	40,002	14,204	10,100	100,040	10,100	20,021	,	,	,	,	,	,	'
Not Donofit/(post)	0	٥	0	1 0	1 0	(04 460 777)	(660 939)	(660 786)	(806 909)	(600 750)	(600 471)	(712 660)	(715 610)	(715.055)	(744 120)	(725 /03)	(754 476)	(733 202)	(025 601)	(4 074 245)	(037 074)	(051 003)	(062 212)	(063 286)	(050 435)	(006 621)	(067 008)	(4 600 507)	1072 03/1
Net Benefit/(cost)	0	0	0	0 0	0 0	(21,469,777)	(662,838)	(668,786)	(696,086)	(680,759)	(698,471)	(712,669)	(715,619)	(715,055)	(744,129)	(725,403)	(754,476)	(733,202)	(925,691)	(1,071,245)	(937,074)	(951,903)	(963,218)	(963,286)	(958,435)	(986,621)	(967,008)	(1,622,507)	(973,034)
		0	0	0	0 0	(21,469,777)	(662,838)	(668,786)	(696,086)	(680,759)	(698,471)	(712,669)	(715,619)	(715,055)	(744,129)	(725,403)	(754,476)	(733,202)	(925,691)	(1,071,245)	(937,074)	(951,903)	(963,218)	(963,286)	(958,435)	(986,621)	(967,008)	(1,622,507)	(973,034)
Expressed in escalated dollars with sensitivity a		0	0		0 0	(21,469,777)	(662,838)	(668,786)	(696,086)	(680,759)	(698,471)	(712,669)	(715,619)	(715,055)	(744,129)	(725,403)	(754,476)	(733,202)	(925,691)	(1,071,245)	(937,074)	(951,903)	(963,218)	(963,286)	(958,435)	(986,621)	(967,008)	(1,622,507)	(973,034)
Expressed in escalated dollars with sensitivity a Capital Outlays	adjustments		0				, , , , , , , , , , , , , , , , , , ,															(951,903)							(973,034)
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital	adjustments	0	0	0 0	0 0	25,636,037	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	(951,903)	0	0	0	0	0	0	0
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays	adjustments	0	0		0 0		, , , , , , , , , , , , , , , , , , ,	0								0				0		(951,903) 0 0							(973,034)
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits:	adjustments	0	0 0 0	0 0	0 0	25,636,037	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	(951,903) 0 0	0	0	0	0	0	0	0
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other	adjustments	0	0 0 0 0	0 0	0 0	25,636,037	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	(951,903) 0 0 0	0	0	0	0	0	0	0
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other	adjustments	0	0 0 0 0 0	0 0	0 0	25,636,037	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	(951,903) 0 0 0 0	0	0	0	0	0	0	0
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0 0 0 0	0 0	0 0	25,636,037	0	0	0	0	0 0 0 0 0	0	0 0 0 0 0 0	0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0	0	0 0 0 0 0 0 0	0	0 0 0 0 0	(951,903) 0 0 0 0 0 0	0	0 0 0 0 0	0	0	0 0 0 0 0 0	0 0 0 0 0 0	0 0 0 0 0 0 0
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other	adjustments	0	0 0 0 0 0 0 0 0 0	0 0	0 0	25,636,037	0	0	0	0	0	0	0	0	0	0 0 0 0 0	0	0	0	0	0	(951,903) 0 0 0 0 0 0 0 0 0 0	0	0	0	0	0	0	0
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs:	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0 0 0 0	0 0	0 0	25,636,037	0	0	0	0	0 0 0 0 0	0	0 0 0 0 0 0	0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0	0	0 0 0 0 0 0 0	0	0 0 0 0 0	(951,903) 0 0 0 0 0 0 0 0 0	0	0 0 0 0 0	0	0	0 0 0 0 0 0	0 0 0 0 0 0	0 0 0 0 0 0 0
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year)	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0 0 0 0 0	0 0	0 0	25,636,037	0 0 0 0 0 0 0 310,171	0 0 0 0 0 0 0 319,476	0 0 0 0 0 0 0 0 329,060	0 0 0 0 0 0 0 338,932	0 0 0 0 0 0 349,100	0 0 0 0 0 0 359,573	0 0 0 0 0 0 0 370,360	0 0 0 0 0 0 0 381,471	0 0 0 0 0 0 392,915	0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0 0 429,349	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 703,742	0 0 0 0 0 0 0 724,854	0 0 0 0 0 0 746,600	0 0 0 0 0	0 0 0 0 0 0 792,068	0 0 0 0 0 0 815,830	0 0 0 0 0 0 840,305	0 0 0 0 0 0	0 0 0 0 0 0 891,480
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year)	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0	0 0	25,636,037	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 319,476 306,077	0 0 0 0 0 0 0 0 0 329,060 319,695	0 0 0 0 0 0 0 0 338,932 340,809	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 359,573 386,013	0 0 0 0 0 0 0 0	0 0 0 0 0 0 381,471 435,458	0 0 0 0 0 0 0 392,915 456,583	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 429,349 525,345	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 724,854 633,909	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 815,830 756,508	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 891,480 856,964
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year)	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0	0 0	25,636,037	0 0 0 0 0 0 0 0 310,171 292,981 36,273	0 0 0 0 0 0 0 0 319,476 306,077 37,361	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 349,100 362,901 40,826	0 0 0 0 0 0 0 0 359,573 386,013 42,050	0 0 0 0 0 0 0 0 0 370,360 410,184 43,312	0 0 0 0 0 0 0 381,471 435,458 44,611	0 0 0 0 0 0 0 392,915 456,583 45,950	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 416,844 501,492 48,748	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 703,742 604,858 66,162	0 0 0 0 0 0 0 724,854 633,909 68,147	0 0 0 0 0 0 0 746,600 664,158 70,192	0 0 0 0 0 0 0 0 768,998 695,652 72,297	0 0 0 0 0 0 0 0 0 792,068 725,498 74,466	0 0 0 0 0 0 0 0 815,830 756,508 76,700	0 0 0 0 0 0 0 840,305 788,726 79,001	0 0 0 0 0 0 0 0 865,514 822,196 81,371	0 0 0 0 0 0 0 891,480 856,964 83,812
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year)	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0	0 0	25,636,037	0 0 0 0 0 0 0 310,171 292,981 36,273 43,124	0 0 0 0 0 0 0 0 319,476 306,077 37,361 44,418	0 0 0 0 0 0 0 0 329,060 319,695 38,482 45,751	0 0 0 0 0 0 338,932 340,809 39,637 47,123	0 0 0 0 0 0 349,100 362,901 40,826 48,537	0 0 0 0 0 0 359,573 386,013 42,050 49,993	0 0 0 0 0 0 0 370,360 410,184 43,312 51,493	0 0 0 0 0 0 381,471 435,458 44,611 53,038	0 0 0 0 0 0 392,915 456,583 45,950 54,629	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 416,844 501,492 48,748 57,956	0 0 0 0 0 0 429,349 525,345 50,210 59,694	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 703,742 604,858 66,162 97,844	0 0 0 0 0 0 724,854 633,909 68,147 100,780	0 0 0 0 0 0 0 746,600 664,158 70,192 103,803	0 0 0 0 0 0 0 768,998 695,652 72,297 106,917	0 0 0 0 0 0 792,068 725,498 74,466 110,125	0 0 0 0 0 815,830 756,508 76,700 113,428	0 0 0 0 0 0 840,305 788,726 79,001 116,831	0 0 0 0 0 0 865,514 822,196 81,371 120,336	0 0 0 0 0 0 891,480 856,964 83,812 123,946
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year)	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0	0 0	25,636,037	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 329,060 319,695 38,482 45,751 91,501	0 0 0 0 0 0 0 338,932 340,809 39,637 47,123 94,246	0 0 0 0 0 0 0 349,100 362,901 40,826 48,537 97,074	0 0 0 0 0 0 0 359,573 386,013 42,050 49,993 99,986	0 0 0 0 0 0 0 0 370,360 410,184 43,312 51,493 102,986	0 0 0 0 0 0 0 0 381,471 435,458 44,611 53,038 106,075	0 0 0 0 0 392,915 456,583 45,950 54,629 109,258	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 416,844 501,492 48,748 57,956 115,911	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 703,742 604,858 66,162 97,844 195,689	0 0 0 0 0 0 724,854 633,909 68,147 100,780 201,559	0 0 0 0 0 0 0 0 746,600 664,158 70,192 103,803 207,606	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 792,068 725,498 74,466 110,125 220,249	0 0 0 0 0 815,830 756,508 76,700 113,428 226,857	0 0 0 0 0 0 840,305 788,726 79,001 116,831 233,663	0 0 0 0 0 0 0 0 865,514 822,196 81,371 120,336 240,673	0 0 0 0 0 0 0 0 891,480 856,964 83,812 123,946 247,893
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year)	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0	0 0	25,636,037	0 0 0 0 0 0 0 310,171 292,981 36,273 43,124	0 0 0 0 0 0 0 0 319,476 306,077 37,361 44,418	0 0 0 0 0 0 0 0 329,060 319,695 38,482 45,751	0 0 0 0 0 0 338,932 340,809 39,637 47,123	0 0 0 0 0 0 349,100 362,901 40,826 48,537	0 0 0 0 0 0 359,573 386,013 42,050 49,993	0 0 0 0 0 0 0 370,360 410,184 43,312 51,493	0 0 0 0 0 0 381,471 435,458 44,611 53,038	0 0 0 0 0 0 392,915 456,583 45,950 54,629	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 416,844 501,492 48,748 57,956	0 0 0 0 0 0 429,349 525,345 50,210 59,694	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 703,742 604,858 66,162 97,844	0 0 0 0 0 0 724,854 633,909 68,147 100,780	0 0 0 0 0 0 0 746,600 664,158 70,192 103,803	0 0 0 0 0 0 0 768,998 695,652 72,297 106,917	0 0 0 0 0 0 792,068 725,498 74,466 110,125	0 0 0 0 0 815,830 756,508 76,700 113,428	0 0 0 0 0 0 840,305 788,726 79,001 116,831	0 0 0 0 0 0 865,514 822,196 81,371 120,336	0 0 0 0 0 0 891,480 856,964 83,812 123,946
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year)	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0	0 0	25,636,037	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 329,060 319,695 38,482 45,751 91,501	0 0 0 0 0 0 0 338,932 340,809 39,637 47,123 94,246	0 0 0 0 0 0 0 349,100 362,901 40,826 48,537 97,074	0 0 0 0 0 0 0 359,573 386,013 42,050 49,993 99,986	0 0 0 0 0 0 0 0 370,360 410,184 43,312 51,493 102,986	0 0 0 0 0 0 0 0 381,471 435,458 44,611 53,038 106,075	0 0 0 0 0 392,915 456,583 45,950 54,629 109,258	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 416,844 501,492 48,748 57,956 115,911	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 703,742 604,858 66,162 97,844 195,689	0 0 0 0 0 0 724,854 633,909 68,147 100,780 201,559	0 0 0 0 0 0 0 0 746,600 664,158 70,192 103,803 207,606	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 792,068 725,498 74,466 110,125 220,249	0 0 0 0 0 815,830 756,508 76,700 113,428 226,857	0 0 0 0 0 0 840,305 788,726 79,001 116,831 233,663	0 0 0 0 0 0 0 0 865,514 822,196 81,371 120,336 240,673	0 0 0 0 0 0 0 0 891,480 856,964 83,812 123,946 247,893
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Odor Control 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 329,060 319,695 38,482 45,751 91,501 30,662 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 349,100 362,901 40,826 48,537 97,074 32,529 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 392,915 456,583 45,950 54,629 109,258 36,612 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Odor Control 0 Total running costs	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 329,060 319,695 38,482 45,751 91,501	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 349,100 362,901 40,826 48,537 97,074	0 0 0 0 0 0 0 359,573 386,013 42,050 49,993 99,986	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 381,471 435,458 44,611 53,038 106,075	0 0 0 0 0 392,915 456,583 45,950 54,629 109,258	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 416,844 501,492 48,748 57,956 115,911	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 724,854 633,909 68,147 100,780 201,559	0 0 0 0 0 0 0 0 746,600 664,158 70,192 103,803 207,606	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 792,068 725,498 74,466 110,125 220,249	0 0 0 0 0 815,830 756,508 76,700 113,428 226,857	0 0 0 0 0 0 840,305 788,726 79,001 116,831 233,663	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 891,480 856,964 83,812 123,946 247,893
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control 0 Total running costs R&R Costs:	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 329,060 319,695 38,482 45,751 91,501 30,662 0 0 855,152	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 349,100 362,901 40,826 48,537 97,074 32,529 0 0 930,967	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 392,915 456,583 45,950 54,629 109,258 36,612 0 0 1,095,946	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 724,854 633,909 68,147 100,780 201,559 45,028 0 0 1,774,278	0 0 0 0 0 0 0 0 0 0 0 0 0 746,600 664,158 70,192 103,803 207,606 46,379 0 0 1,838,739	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 792,068 725,498 74,466 110,125 220,249 49,204 9_0 0 1,971,610	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 113,428 226,857 50,680 0 0 0 2,040,003	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 891,480 856,964 83,812 123,946 247,893 55,379 0 0 2,259,474
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Odor Control 0 Total running costs	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 329,060 319,695 38,482 45,751 91,501 30,662 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 349,100 362,901 40,826 48,537 97,074 32,529 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 392,915 456,583 45,950 54,629 109,258 36,612 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control 0 Total running costs R&R Costs:	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 329,060 319,695 38,482 45,751 91,501 30,662 0 0 855,152	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 349,100 362,901 40,826 48,537 97,074 32,529 0 0 930,967	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 392,915 456,583 45,950 54,629 109,258 36,612 0 0 1,095,946	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 724,854 633,909 68,147 100,780 201,559 45,028 0 0 1,774,278	0 0 0 0 0 0 0 0 0 0 0 0 0 746,600 664,158 70,192 103,803 207,606 46,379 0 0 1,838,739	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 792,068 725,498 74,466 110,125 220,249 49,204 9_0 0 1,971,610	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 113,428 226,857 50,680 0 0 0 2,040,003	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 891,480 856,964 83,812 123,946 247,893 55,379 0 0 2,259,474
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control 0 Total running costs R&R Costs:	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 329,060 319,695 38,482 45,751 91,501 30,662 0 0 855,152	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 349,100 362,901 40,826 48,537 97,074 32,529 0 0 930,967	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 392,915 456,583 45,950 54,629 109,258 36,612 0 0 1,095,946	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 724,854 633,909 68,147 100,780 201,559 45,028 0 0 1,774,278	0 0 0 0 0 0 0 0 0 0 0 0 0 746,600 664,158 70,192 103,803 207,606 46,379 0 0 1,838,739	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 792,068 725,498 74,466 110,125 220,249 49,204 9_0 0 1,971,610	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 113,428 226,857 50,680 0 0 0 2,040,003	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 891,480 856,964 83,812 123,946 247,893 55,379 0 0 2,259,474
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control 0 Total running costs R&R Costs:	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 329,060 319,695 38,482 45,751 91,501 30,662 0 0 855,152	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 349,100 362,901 40,826 48,537 97,074 32,529 0 0 930,967	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 392,915 456,583 45,950 54,629 109,258 36,612 0 0 1,095,946	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 724,854 633,909 68,147 100,780 201,559 45,028 0 0 1,774,278	0 0 0 0 0 0 0 0 0 0 0 0 0 746,600 664,158 70,192 103,803 207,606 46,379 0 0 1,838,739	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 792,068 725,498 74,466 110,125 220,249 49,204 9_0 0 1,971,610	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 113,428 226,857 50,680 0 0 0 2,040,003	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 891,480 856,964 83,812 123,946 247,893 55,379 0 0 2,259,474
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Operational Labor Cost (\$/year) Odor Control O Total running costs R&R Costs: Total Annual Repair and Replacement Cost O O O O O O O O O O O O O O O O O O O	adjustments	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 329,060 319,695 38,482 45,751 91,501 30,662 <u>0</u> 0 855,152 53,081 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 99,986 33,505 0 0 971,121 44,975 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,012,845 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,056,199 25,385 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,137,127 26,931 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,179,793 67,242 0 0 0 0,242 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,223,995 24,233 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,838,739 0 0 1,838,739 0 0 1,838,739 0 0 0 1,838,739	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,971,610 0 0 0,0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 113,428 226,857 50,680 0 0 2,040,003 87,736 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 2,183,856 1,528,323 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 2,259,474 33,544 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control 0 Total running costs R&R Costs:	adjustments	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 971,121 0 0 971,121 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,012,845 0 0 0 1,012,845 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,137,127 0 0 1,137,127 26,931	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,179,793 0 1,179,793 0 0 1,179,793 0 0 0,0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,223,995 24,233 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,651,869 282,918 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,712,013 0 1,712,013 0 0 0 0 1,712,013	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,838,739 0 0 1,838,739 0 0 1,838,739 0 0 0 1,838,739 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,905,470 0 1,905,470 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,971,610 0 1,971,610 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 113,428 226,857 50,680 0 0 2,040,003 87,736 0 0 0 0 0 87,736	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 2,183,856 1,528,323 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 2,259,474 0 0 0 2,259,474 0 0 0 0 33,544
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Annual Water Cost (\$/year) Maintenance Labor Cost (\$/year) Odor Control 0 Total running costs R&R Costs: Total Annual Repair and Replacement Cost 0 0 0	adjustments	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 971,121 0 0 971,121 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,012,845 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,056,199 25,385 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,137,127 26,931 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,179,793 0 1,179,793 0 0 1,179,793 0 0 0,0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,223,995 24,233 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,651,869 282,918 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,712,013 0 1,712,013 0 0 0 1,712,013	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,838,739 0 0 1,838,739 0 0 1,838,739 0 0 0 1,838,739 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,905,470 0 1,905,470 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,971,610 0 0 0,0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 113,428 226,857 50,680 0 0 2,040,003 87,736 0 0 0 0 0 87,736	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 2,183,856 1,528,323 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 2,259,474 0 0 0 2,259,474 0 0 0 0 33,544
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control O Total running costs R&R Costs: Total Annual Repair and Replacement Cost O Total refurbishments	adjustments	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 971,121 0 0 971,121 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,012,845 0 0 0 1,012,845 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,137,127 0 0 1,137,127 26,931	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,179,793 0 1,179,793 0 0 1,179,793 0 0 0,0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,223,995 24,233 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,651,869 282,918 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,712,013 0 1,712,013 0 0 0 0 1,712,013	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,838,739 0 0 1,838,739 0 0 1,838,739 0 0 0 1,838,739 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,905,470 0 1,905,470 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,971,610 0 1,971,610 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 113,428 226,857 50,680 0 0 2,040,003 87,736 0 0 0 0 0 87,736	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 2,183,856 1,528,323 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 2,259,474 0 0 0 2,259,474 0 0 0 0 33,544
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control O Total running costs R&R Costs: Total Annual Repair and Replacement Cost O Total refurbishments	adjustments	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 971,121 0 0 971,121 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,012,845 0 0 0 1,012,845 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,137,127 0 0 1,137,127 26,931	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,179,793 0 1,179,793 0 0 1,179,793 0 0 0,0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,223,995 24,233 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,651,869 282,918 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,712,013 0 1,712,013 0 0 0 0 1,712,013	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,838,739 0 0 1,838,739 0 0 1,838,739 0 0 0 1,838,739 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,905,470 0 1,905,470 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,971,610 0 1,971,610 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 113,428 226,857 50,680 0 0 2,040,003 87,736 0 0 0 0 2,043,000 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 2,183,856 1,528,323 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 2,259,474 33,544 0 0 0 0 33,544
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Maintenance Labor Cost (\$/year) Operational Labor Cost (\$/year) Odor Control 0 Total running costs R&R Costs: Total Annual Repair and Replacement Cost 0 <	adjustments	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 349,100 362,901 40,826 48,537 97,074 32,529 0 0 930,967 35,880 0 0 0 0 0 0 35,880 0 0 0 930,967 9 0 930,967 9 935,880 0 0 935,880 0 9 0 935,880	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 971,121 0 0 971,121 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,012,845 0 0 0 1,012,845 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,137,127 26,931 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,137,127	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,179,793 0 1,179,793 0 0 1,179,793 0 0 0,0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,223,995 24,233 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,712,013 0 1,712,013 0 0 0 0 1,712,013	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,724,854 633,909 68,147 100,780 201,559 45,028 0 0 1,774,278 49,667 0 0 0 0 1,774,278 49,667 0 0 0 1,823,945)	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,838,739 0 0 1,838,739 0 0 1,838,739 0 0 1,838,739 0 0 1,838,739 0 0 0 1,838,739 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,905,470 0 1,905,470 0 0 1,905,470 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,971,610 0 1,971,610 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 113,428 226,857 50,680 0 0 2,040,003 2,040,003 2,040,003 0 0 0 0 0 0 0 0 0 2,040,003 2,040,003 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 2,259,474 0 0 0 0 2,259,474 0 0 0 0 0 0 33,544 (2,293,019)
Expressed in escalated dollars with sensitivity a Capital Outlays Total Capital Total capital outlays Benefits: Other Other Other Other Total benefits Annual Running Costs: Energy Cost (\$/year) Total Polymer Cost (\$/year) Maintenance Labor Cost (\$/year) Odor Control O Total running costs R&R Costs: Total Annual Repair and Replacement Cost O Total refurbishments Net escalated benefit/(cost)	adjustments 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0	0 0 0 0 0 0 0	25,636,037 25,636,037 25,636,037 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 349,100 362,901 40,826 48,537 97,074 32,529 0 0 930,967 35,880 0 0 0 0 0 0 35,880 0 0 0 930,967 9 0 930,967 9 935,880 0 0 935,880 0 9 0 935,880	0 0 0 0 0 0 0 0 0 0 0 0 0 0 971,121 0 99,986 33,505 0 0 971,121 0 971,121 0 0 0 0 0 0 0 0 0 0 0 1 0 1 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,012,845 0 0 0 1,012,845 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,056,199 25,385 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,137,127 26,931 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,137,127	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,416,844 501,492 48,748 57,956 115,911 38,842 0 0 1,179,793 - - - - - - - - - - - - - - - - - - -	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,223,995 24,233 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,724,854 633,909 68,147 100,780 201,559 45,028 0 0 1,774,278 49,667 0 0 0 0 1,774,278 49,667 0 0 0 1,823,945)	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,838,739 0 0 1,838,739 0 0 1,838,739 0 0 1,838,739 0 0 1,838,739 0 0 0 1,838,739 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,905,470 0 1,905,470 0 0 1,905,470 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 1,97,498 74,466 110,125 220,249 49,204 9,204 9,204 0 0 1,97,1610 0 0 0 0 0 35,139 0 0 0 0 1,97,108 1,97,	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 113,428 226,857 50,680 0 0 2,040,003 2,040,003 2,040,003 0 0 0 0 0 0 0 0 0 2,040,003 2,040,003 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 2,259,474 33,544 0 0 0 0 33,544 (2,293,019)

From Summary Sheet:		Risk adir	stments (+/- pero	arcent):										Inland "	Empire Utilities Age	ency														
Year of analysis	2016		Benefits	· · · ·	1										2016-22, 22-30, 30-															
Escalation rate	3.00%	+	Capital costs												Alternative Cost Ana															
Discount rate	2.00%		Running costs										·	alle eyele ta	-	x19515 (#)														
Discount rate	2.0070		uthing coole .	010																										
Rotary Drum Thickener Co-thickening	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	Year 2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
expressed in 2016 dollars, unescalated																														
Capital Outlays																										1		1	í	
Total Capital							11,212,164																							
Total capital outlays	0	0 0	0 0	<u> </u>	0 0	<u> </u>	0 11,212,164	0) 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Benefits:																														
Other																														
Other Other																														
Total benefits	0	۰	0 0	0 0	0 0	0 0	0 0	0) 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Annual Running Costs:	[+		+			+																	, 						
Energy Cost (\$/year)								\$13,830						\$13,830	\$13,830	\$13,830	\$13,830	\$13,830	\$13,830	\$20,745	\$20,745	\$20,745			\$20,745		\$20,745	\$20,745		\$20,745
Total Polymer Cost (\$/year)								238,220	241,620	245,020	253,594	262,168	270,741	279,315	287,889	293,063	298,237	303,411	308,585	313,759	319,450	325,141	330,832	336,524	342,215	346,502	350,789	355,076	359,363	363,650
Annual Water Cost (\$/year)								\$52,047		\$52,047	7 \$52,047	7 \$52,047		\$52,047	\$52,047	\$52,047	\$52,047	\$52,047	\$52,047	\$69,396	\$69,396	\$69,396	\$69,396	\$69,396	\$69,396	6 \$69,396	\$69,396			\$69,396
Maintenance Labor Cost (\$/year)								26,298				26,298	26,298	26,298	26,298	26,298	26,298	26,298	26,298	39,447	39,447 78,904	39,447			39,447		39,447			39,447
Operational Labor Cost (\$/year)								52,596 23,500	,	52,596				52,596 23,500	52,596 23,500	52,596 23,500	52,596 23,500	52,596 23,500	52,596 23,500	78,894 23,500	78,894	78,894 23,500			78,894		78,894 23,500			78,894 23,500
Odor Control								25,500	23,500	23,500	23,500	23,300	23,500	23,000	23,000	23,500	23,500	23,500	25,500	23,000	23,500	23,300	23,300	23,000	23,500	23,300	23,500	23,000	23,300	23,300
Total running costs		f	0 0	0 0	0 0	0 0	0 0	406,491	409,891	413,291	421,865	430,439	439,013	447,587	456,161	461,335	466,508	471,682	476,856	545,741	551,433	557,124	562,815	568,506	574,198	578,485	582,771	587,058	591,345	595,632
R&R Costs:					-			+		+	+														, +				1	
Total Annual Repair and Replacement Cost								6,862	6,862	6,862	6,862	6,862	6,862	6,862	6,862	6,862	6,862	6,862	6,862	10,293	10,293	39,564	10,293	10,293	10,293	10,293	10,293	10,293	202,605	10,293
Other																														
Other																														
Other Other																														
Other Total refurbishments			0 0	0 0	0 0	0 0	0 0	6.862	2 6.862	6,862	6.862	6.862	6,862	6.862	6,862	6,862	6.862	6,862	6,862	10,293	10.293	39,564	10.293	10,293	10,293	10,293	10,293	10,293	202,605	10,293
Net Benefit/(cost)	0		0 0				0 (11,212,164)	,	,	-1	,			-1	,	(468,197)	(473,371)	(478,545)	,	,	,	(596,688)		,	,	,			,	(605,926)
Net beneniv(cosi)	-	+	· · · · · ·				(11,212,107)	(410,00-)	(410,104)	(420,10-1)	(420,120)	(401,00.)	(440,010)	(404,440)	(400,020)	(400,107)	(410,011)	(4/0,040)	(400,110)	(000,000)	(001,120)	(050,000)	(010,100)	(010,000)	(004,401)	(000,110)	(030,000)	(001,002)	(190,001)	(000,020,
Expressed in escalated dollars with sensitivity ac	diustments	+	+		+	+																			+					
Capital Outlays	juannensa																													
Total Capital	e	0	0 0	0 0	0 r	n r	0 13,387,910	0) 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	· · · · · · · · · · · · · · · · · · ·
Total capital outlays	0	st	0 0			_	0 13,387,910	0	-	-	-		0	0	-	0	0	0	-	0	0	0	-	-		+	0	0		0
Benefits:		+	+		+																								1	
Other	0	J	0 0	J0	0 0	0 0	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	ſ
Other	0	J′	0 0	J 0'	J 0	J 0	J 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	ſ
Other	0	<u>/</u> /	0 0	× 0 '	<u> </u>	<u> </u>	<u>J</u> 0	0	0	0	+ <u>0</u>	0	0	0	0	0	0	0	0	0	0	0	0	0	0	+ 0	0	0	+ 0	0
Total benefits	U	"	0 0	0 0	0 0	0 0	0 0	0) 0	0	0	0	0	0	0	0	0	0	0		0	0	0	0	0	0	0	0	0	0
Annual Running Costs:				,	-	-		47.000	47 500	10 04F	40 507	10 144	10 710	20.210		04 547	00 402	00.050	00 545	06.077	07 460	20 500	20.750	40.042	40.171	42.426	44 720	40.001	47.464	20.01
Energy Cost (\$/year) Total Polymer Cost (\$/year)	+ <u> </u>	'	U V		<u> </u>	v U,		17,009 292,981		18,045 319,695				20,310 410,184	20,919 435,458	21,547 456,583	22,193 478,583	22,859 501,492	23,545 525,345	36,377 550,178	37,468 576,962	38,592 604,858	39,750 633,909		42,171 695,652		44,739 756,508			48,888 856,964
Annual Water Cost (\$/year)	t <u>c</u>	n	<u> </u>	n r	n r			292,981 64,011						410,184 76,433	435,458 78,726	456,583	478,583 83,520	501,492 86,026	525,345 88,607	550,178 121,686	576,962	604,858 129,097					149,659			856,964
Maintenance Labor Cost (\$/year)	0	0	0 0	a <u>e</u>	0 <u>r</u>	0 r	0 0	32,343						38,620	39,778	40,972	42,201	43,467	44,771	69,171	71,246	73,383			80,188		85,071	87,623		92,960
Operational Labor Cost (\$/year)	0	J	0 0	J0'	00	0 0	0 0	64,687		68,626				77,239	79,556	81,943	84,401	86,933	89,541	138,342	142,492	146,767			160,376		170,143			185,920
Odor Control	0	J	0 0	J 0 '	JO	J 0	J 0	28,902	,	· · · ·				34,511	35,546	36,612	37,711	38,842	40,007	41,207	42,444	43,717			47,771		50,680			55,379
0 '	<u>0</u>	2′	<u>0</u> 0	∠ 0'	<u>ı</u> 0	<u>J</u> Ō	<u>1</u>	<u>0</u>	<u>0</u>	<u>0</u>)	<u>0</u>			<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	0	0	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>]	1 <u>0</u>	0	<u>0</u>	<u>0</u>	
0 '	0	· · · · ·	<u> </u>	<u> </u>	<u> </u>	<u> </u>				<u> </u>	+ <u>0</u>	- 0 	0	0	0		0	0	0	0	0	0	0 070 442		0	+ 0	1 256 200	0	0	1 403 6/
Total running costs	0		0 0		0 0	0 0	0 0	499,933	519,238	539,252	566,952	595,828	625,928	657,296	689,984	718,744	748,609	779,619	811,816	956,961	995,949	1,036,414	1,078,412	1,121,996	1,167,226	1,211,218	1,256,800	1,304,026	1,352,955	1,403,646
R&R Costs: Total Annual Repair and Replacement Cost	(-		<u> </u>			9 140	9 603	9.05/	0.222	0 400	0.784	10.078	10.380	10 601	44.012	44 242	11 693	19.050	10 501	73 601	10 723	20.315	20.025	01.552	22 100	22.865	462.546	24.9F
Total Annual Repair and Replacement Cost Other	+ <u> </u>	^ ``	<u> </u>		v,	v v ,	v v	8,440) <u>8,693</u>	8,954	9,222	9,499	9,784	10,078	10,380	10,691	11,012	11,342	11,683	18,050	18,591	73,601	19,723	20,315	20,925	21,552	22,199	22,865	463,546	24,25
Other	t e	n		n ř	n r	n r			, <u> </u>	· 0+	. 0+	· · · · · · · · · · · · · · · · · · ·			0	0	0	0	0		0		,		,				0	
Other	0	٥	00	a0'	0 <u></u> P	0P	0 0	0	, <u> </u>	0	0	1	10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	ı <u>0</u>	0	
	·		0 0	J0'	J0	<u>υ</u> 0	J 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Other	0	·′	0 0	/ 0'	0 0	0 0	0 0	8,440	8,693	8,954	9,222	9,499	9,784	10,078	10,380	10,691	11,012	11,342	11,683	18,050	18,591	73,601	19,723	20,315	20,925	21,552	22,199	22,865	463,546	24,25
Other Total refurbishments	-	_		0 0	0 0	0 0	0 (13,387,910)	(508,373)	(527,931)	(548,205)) (576,174)) (605,327)) (635,712)	(667,374)	(700,364)	(729,435)	(759,621)	(790,961)	(823,498)	(975,010)	(1,014,540)	(1,110,015)	(1,098,135)	(1,142,312)	(1,188,150)	(1,232,770)	(1,278,999)	(1,326,891)) (1,816,502)	(1,427,90
	0	0 0	v	• <u> </u>	- <u> </u>		- <u></u>	(000,010	<u> </u>	<u> </u>																				
Total refurbishments Net escalated benefit/(cost)	C	0				+																								
Total refurbishments	0		0 0		0 0		0 (11.888.081)) (472,663)	(486,843)	(501,254)	(515,902)	(530,788)	(541,981)	(553,343)	(564,875)	(576,580)	(669,277)	(682,756)	(732,361)	(710.317)	(724,404)	(738.698)) (751,412)	(764,303)	(777 375)) (1,043,352)	(804.07

From Summary Sheet:	,	Risk adjustr	ments (+/- percen	Jent):									Inland Er	mpire Utilities A	Agency														
Year of analysis	2016		Benefits											016-22, 22-30, 3															
Escalation rate	3.00%	r	Capital costs		1									ternative Cost A		+													
Discount rate	2.00%				1							1		-															
					1																								
Gravity Belt Thickener Co-thickening														Yea	⊿ar														
	2016	2017	2018	2019	2020 2021	021 2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
Expressed in 2016 dollars, unescalated	·				+				+									+		l									4
Capital Outlays																													
Total Capital						11,850,933			<u> </u>	<u> </u>	<u> </u>	<u> </u>				<u> </u>				<u> </u>									
Total capital outlays	0) 0	0	0	0	0 11,850,933	33 0	0	0	0 0	0) 0) 0	0	0	0	0 0	0	0	0	0	0	0	0	0	0	0	0	0 0
Benefits:		+						<u></u>									+												
Other Other																													
Other																													
Total benefits	0) 0	0	0	0	0 0	0 0	0	0	0 0	0) 0) 0	0	0	0	0 0	0	0	0	0	0	0	0	0	0	0	0	0 0
Annual Running Costs:																		1						. — — — — — — — — — — — — — — — — — — —					
Energy Cost (\$/year)							\$19,525	5 \$19,525	5 \$19,525	25 \$19,525	5 \$19,525	5 \$19,525	5 \$19,525	\$19,525	\$19,525	\$19,525	25 \$19,525	5 \$19,525	\$19,525	\$19,525	5 \$19,525	\$19,525	\$19,525		\$19,525	\$19,525	\$19,525	5 \$19,525	\$19,525
Total Polymer Cost (\$/year)							\$238,220	0 \$241,620	\$245,020	20 \$253,594	4 \$262,168	8 \$270,741	1 \$279,315	\$287,889	\$293,063	\$298,237	37 \$303,411	\$308,585	\$313,759	\$319,450	0 \$325,141	\$330,832	\$336,524	\$342,215	\$346,502	\$350,789	\$355,076	6 \$359,363	3 \$363,650
Annual Water Cost (\$/year)							\$98,311							\$28,915	\$28,915										\$28,915				
Maintenance Labor Cost (\$/year)							52,596	52,596 105,102		· · · · · ·				52,596	52,596	52,596	<i>'</i>		52,596 105,102				52,596	52,596	52,596	52,596 105 102	52,596 105 102		
Operational Labor Cost (\$/year) Odor Control							105,192 23,500	· · · · ·	· · · · · · · · · · · · · · · · · · ·	· · · · ·	· · · · · · · · · · · · · · · · · · ·			105,192 23,500	105,192 23,500	105,192 23,500	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	105,192 23,500		· · · · · · · · · · · · · · · · · · ·	105,192 23,500	105,192 23,500	105,192 23,500	105,192 23,500	105,192 23,500	105,192 23,500	· · · · · · · · · · · · · · · · · · ·	
							23,000	23,300	20,000	23,000	23,300	23,300	23,300	23,300	23,300	23,000	23,300	23,300	23,300	23,300	23,300	23,000	23,300	23,300	23,300	23,300	23,300	20,000	20,000
Total running costs	·,		0	0	0	0 0	0 537,345	471,348	474,748	8 483,322	491,896	5 500,470) 509,044	517,618	522,792	527,965	5 533,139	538,313	543,487	549,178	554,870	560,561	566,252	571,943	576,230	580,517	584,804	589,091	1 593,378
R&R Costs:	·	+							, + +		+	+				+		1		, +									
Total Annual Repair and Replacement Cost					0	0 0	0 23,112	11,556	25,572	2 23,112	28,032	2 23,112	28,032	23,112	28,032	23,112	2 30,266	23,112	30,266	23,112	28,032	23,112	28,032	23,112	28,032	23,112	28,032	331,157	7 28,032
Other																													
Other																													
Other																													
Other			0			0 0		44 556	25.572	- 03.112	20 032		20 032	03 442	00.032	22.112		03.412	20.266	22 112	20 032	02.412	00 032	02 112		02.442		224 157	
Total refurbishments		0		•	-		0 23,112	,	,	· · ·		,		23,112	· ·	23,112	,	<i>,</i>	,	,	,	<i>,</i>	'	23,112	,	23,112	,	,	
Net Benefit/(cost)	0) 0	0	0	0	0 (11,850,933)	33) (560,456)) (482,904)) (500,321)	1) (506,434)	(519,929)	9) (523,582)	2) (537,076)	(540,729)	(550,824)	(551,077)	7) (563,405)) (561,425)	(573,753)	(572,290)) (582,902)	(583,673)	(594,284)	(595,055)	(604,263)	(603,629)	(612,837)	(920,248)	B) (621,410)
the second		+					+			+								·											
Expressed in escalated dollars with sensitivity adjus	stments																												
Capital Outlays								+	+								+				+							+	
Total Capital	0			0	-	0 14,150,633 0 14,150,633					-		.+	0		0	-		0		0	0	0		0	0	U 0	0	0 0 0 0
Total capital outlays			v	V		0 14,100,000			<u> </u>		<u> </u>	v	–		U		v				– – –							<u> </u>	
Benefits: Other	<u> </u>	.+	1 0	0				t	<u> </u>			.+	.++	0			^ + 0+	0	0	0	0	0	0		0	0	0	1 0	.+
Other Other	ر ب	.+ 0	0						0		. 0	.	. 0	0	0	0		1 0		· · · · · · · · · · · · · · · · · · ·		·	0		·	0	·0		,†
Other	. <u> </u>	, t <u> </u>					n+ 0+		· 0+	at 0+	. 0+	, I 0 ⁺	, I 0 +	ı 0	0			1 0		, — <u> </u>		. 0	0	. — <u> </u>	, — <u> </u>	0	, — <u> </u>	. 1 0+	, terre i
Total benefits	0) 0	0	0	0	0 0	0 0	0	0	0 0	0) 0) 0	0	0	0	0 0	0	0	0	0	0	0	0	0	0	0	0) (
Annual Running Costs:																		1						. — — — —		(
Energy Cost (\$/year)	0	· <u> </u>	0	0	0	0 0	0 24,013	24,734	25,476	6 26,240	27,027	7 27,838	3 28,673	29,533	30,419	31,332	2 32,272	33,240	34,237	35,264	36,322	37,412	38,534	39,690	40,881	42,107	43,371	44,672	2 46,012
Total Polymer Cost (\$/year)	0 '	. []	0	0	0	0 0	0 292,981	306,077	319,695	5 340,809	362,901	1 386,013		435,458	456,583	478,583			550,178	576,962	604,858	633,909	664,158	695,652	725,498	756,508	788,726	822,196	6 856,964
Annual Water Cost (\$/year)	0'	0	0	0	0	0 0	0 120,910							43,737	45,049	46,400	,		50,703	52,224		55,404	57,066	58,778	60,542	62,358	64,229		
Maintenance Labor Cost (\$/year)	0		0	0	0	0 0	0 64,687	66,627						79,556	81,943	84,401			92,228	94,995		100,780	103,803	106,917	110,125	113,428	116,831	120,336	
Operational Labor Cost (\$/year)	U 1	U		U 0	0		0 129,373							159,113	163,886	168,803			184,455			201,559	207,606	213,834	220,249	226,857	233,663		
Odor Control	ر ب	·+					0 28,902	29,769	30,662	2 31,582	2 32,529	33,505	5 34,511 0 0	35,546	36,612	37,711	1 <u>38,842</u>	40,007	41,207	42,444	43,717	45,028	46,379	47,771	49,204	50,680	52,200	53,766	3 55,379
0	. <u> </u>	, t <u> </u>	0	0						at <u>0</u> +	. 0	, i <u> </u>	, <u> </u>		0	<u> </u>		ı <u>0</u>	0			0	0		·	0	- <mark>0</mark>	. 1 0 +	,t – *
Total running costs	0	0 0	0			0 0	0 660,866	597,090	619,439	9 649,545	680,899	713,551	747,548	782,943	814,492	847,230	0 881,198	916,442	953,008	991,877	1,032,221	1,074,093	1,117,548	1,162,643	1,206,498	1,251,938	1,299,019	1,347,798	1,398,33
R&R Costs:									+																	····			
Total Annual Repair and Replacement Cost		, O ⁺	0	0	0	0 0	0 28,425	14,639	33,366	6 31,060	38,803	3 32,952	2 41,166	34,959	43,674	37,088	8 50,025	39,346	53,072	41,742	52,148	44,284	55,324	46,981	58,694	49,843	62,268	757,664	4 66,060
Other	. 0	· [0]	0	0	0	00	J 0	0	0	J 0	0	0	0	. 0	0	0	0	. 0	0	0	1 0	. 0	0	0	0	0	0	1 0	/
	0 '	0	0	0	0	0 0	J 0	0	0	/ 0	0	0	0	0	0	0	0	. 0	0	0	0	0	0	0	0	. 0	0	0	
Other	0 '		0	0	0	0 0 '	· 0	0	0	0	0	- 0	0	0	0	0		+ 0	0	0	+ 0	0	0	0	0	0	0	- 0]	
Other		I 0 I	+ 0	0	0	0 0'	0		0		+ 0	- 0	+ 0	0	0	0	+ 0 +	0	0	0	0	0	0	0	0	0	0		
Other Other			· · · · ·	0	0	0 0	0 28,425	· · · · ·		· · ·	,	í.	· · ·		43,674	,	,		,	, í	,		55,324		58,694	,	,	, í	· · · ·
Other Other Total refurbishments	0														(050 (00))	(004 047)	(004.000)	(055 700)	(1 006 070)	(1 033 620)	(1 004 260)	. /4 440 277\	(4 470 070)	(4 000 005)	(4.005.400)	4 004 7041	(4 264 207)	1 (0 405 400)	a (1 464 3′
Other Other	0		-		0	0 (14,150,633)	(689,291)	(611,729)) (652,805)	5) (680,605)	i) (719,703)	(746,502)	2) (788,715)	(817,902)	(858,166)	(884,317,	7) (931,223)	(955,766)	(1,000,079)	(1,033,020,	(1,064,309)	(1,110,377)	(1,1/2,8/2)	(1,209,625)	(1,200,192)	(1,301,781)	(1,301,207)	(2,105,462)	(1,404,0
Other Other Total refurbishments Net escalated benefit/(cost)			-		0	0 (14,150,63、	3) (689,291,	(611,729)	(652,805	5) (680,605 <u>,</u>	(719,703,	(746,502	(788,715,	(817,902)	(858,166)	(884,31)	(931,223)	(955,786)	(1,000,079)	(1,033,020	(1,084,309)	(1,118,377)	(1,172,872)	(1,209,625)	(1,205,192)	(1,301,781)	(1,301,207)	(2,105,462,	-/ (1,404,0
Other Other Total refurbishments			-		0																								
Other Other Total refurbishments Net escalated benefit/(cost)			0														7) (931,223) 7) (665,045)) (715,441)							i) (1,209,324)	



Inland Empire Utilities Agency 149055 - IEUA - RP5 - Digestion Alternatives Net Present Value Analysis

Agency:	Inland Empire Utilities Agency		Sensitivi	ty Adjustm	ents (%)		Results (\$000s)	
Project/Problem:	149055 - IEUA - RP5 - Digestion	Risk Premium	Benefits	Capital Costs	Running Costs	Capital Cost	20-year NPV	Difference from Highest NPV
Alternative 1	THP					\$116,538,345	(\$274,254,479)	(\$139,240,036)
Alternative 2	MAD					\$70,332,830	(\$152,476,515)	(\$17,462,071)
Alternative 3	2 Phase					\$61,077,295	(\$135,014,444)	
Alternative 4								
Alternative 5								
Alternative 6								
Alternative 7								
Alternative 8								
Alternative 9								
Alternative 10								
Alternative 11								
Alternative 12								
Alternative 13								
Alternative 14								
Alternative 15								
Alternative 16								

Year of analysis: 2016 Escalation rate: 3.00% Discount rate: 2.00%

From Summary Sheet:		Risk a	djustments	(+/- percent):											Inland Em	pire Utilities	Agency														
	of analysis 2016			Benefits											149055 - IE	EUA - RP5 - D	igestion														
	lation rate 3.00%			apital costs										Life			nalysis (\$000s	;)													
Disc	count rate 2.00%	/o	Ru	nning costs											Alte	rnative 1 - Th	12														
			047	0040	040	2020	0004	2022	0002	2024	2025	2026	0007	2020	2020	Yea		0020	0022	2024	0025	0026	2037	0020	2020	2040	2044	20.42	0042	2044	20.45
Expressed in 2016 dollars, unescalated	2016		017	2018 2	019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
Capital Outlays																															
THP Other									116,538,345																						
Other																															
Other Other																															
Other																															
Total capital outlays									116,538,345																						
Benefits:																															
THP Dewatering Benefit									\$437,653	\$444,006	\$450,358	\$466,066	\$481,774		\$513,190	\$528,898	\$538,517	\$548,136		\$567,375	\$576,995	\$587,409	\$597,824	\$608,238	\$618,653	\$629,068		\$644,776	\$652,630	\$660,483	
Gas Benefit Total benefits									188,341 625,994	<u>191,195</u> 635,201	<u>193,498</u> 643,856		199,185 680,959	202,039 699,521	204,892 718,082	227,232 756,130	230,005 768,522	232,858 780,995	235,712 793,468	238,565 805,941	247,889 824,883	251,122 838,531	253,975 851,799	256,829 865,067	259,683 878,336	270,254 899,321	273,380 910,302	276,234 921,009	279,087 931,717	281,941 942,424	
Annual Running Costs:										, ,		,					, ,					, ,						, ,		, ,	
Electrical	-								\$1,924,500	\$1,924,500	\$1,924,500	\$1,924,500	\$1,924,500	\$1,924,500	\$1,924,500	\$2,055,900	\$2,055,900	\$2,055,900	\$2,055,900	\$2,055,900	\$2,055,900	\$2.055.900	\$2,055,900	\$2,055,900	\$2,055,900	\$2,055,900	\$2,055,900	\$2,055,900	\$2,055,900	\$2.055.900	\$2,055,9
Polymer									\$1,057,000	\$1,072,400			\$1,924,500		\$1,239,500	\$1,277,400		\$1,323,800		\$2,033,900	\$2,033,900	\$2,033,900	\$1,443,800	\$1,468,900	\$1,494,100	\$2,033,900		\$1,557,200	\$1,576,100	\$1,595,100	
Labor									\$1,202,200	\$1,202,200	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,600	\$1,402,6
Maintenance									\$360,660	\$360,660	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,780	\$420,7
Other																															
Other Total running costs									4,544,360	4,559,760	4,835,580	4,873,480	4,911,480	4,949,380	4,987,380	5,156,680	5,179,880	5,203,080	5,226,380	5,249,580	5,272,780	5,297,880	5,323,080	5,348,180	5,373,380	5,398,480	5,417,480	5,436,480	5,455,380	5,474,380	5,493,28
R&R Costs:																															
Other Other									1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,21
Other																															
Other Other																															
Total refurbishments									1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,212	1,058,21
Net Benefit/(cost)									(121,514,923)	(4,982,771)	(5,249,935)	(5,269,294)	(5,288,733)	(5,308,071)	(5,327,510)	(5,458,762)	(5,469,570)	(5,480,297)	(5,491,124)	(5,501,851)	(5,506,108)	(5,517,561)	(5,529,493)	(5,541,324)	(5,553,256)	(5,557,370)	(5,565,390)	(5,573,682)	(5,581,875)	(5,590,167)	(5,596,03
Expressed in escalated dollars with sensitivit Capital Outlays	ity adjustments																														
THP									143,327,465																						
Other Other																															
Other																															
Other Other																															
Total capital outlays									143,327,465																						
Benefits:								1																							1
THP Dewatering Benefit									538,258	562,453	587,615	626,354	666,888	709,290	753,636	800,005	838,992	879,598	921,885	965,918	1,011,764	1,060,926	1,112,128	1,165,448	1,220,965	1,278,765	1,333,572	1,390,517	1.449.679	1.511.138	1,574,98
Gas Benefit									231,636	242,200	252,471	263,853	275,719	288,059	300,891	343,709	358,340	373,669	389,596	406,142	434,674	453,553	472,469	492,111	512,506	549,370	572,397	595,723	619,934	645,061	676,61
Total benefits									769,894	804,653	840,087	890,207	942,607	997,349	1,054,528	1,143,714	1,197,332	1,253,267	1,311,481	1,372,060	1,446,438	1,514,480	1,584,597	1,657,558	1,733,471	1,828,135	1,905,970	1,986,241	2,069,612	2,156,199	2,251,60
Annual Running Costs:					1	Ι										1													1		
Electrical									2,366,892	2,437,899		2,586,367	2,663,958	2,743,877	2,826,193	3,109,733	3,203,025	3,299,116	3,398,089	3,500,032	3,605,033	3,713,184	3,824,580	3,939,317	4,057,497	4,179,221	4,304,598	4,433,736	4,566,748	4,703,751	
Polymer Labor									1,299,977 1,478,554	1,358,484 1,522,911		1,512,712 1,884,977	1,610,695 1,941,526	1,713,052 1,999,772	1,820,248 2,059,765	1,932,182 2,121,558	2,026,292 2,185,205	2,124,310 2,250,761		2,332,844 2,387,833	2,443,511 2,459,468	2,562,149 2,533,252	2,685,893 2,609,249	2,814,564 2,687,527	2,948,736 2,768,152	3,088,221 2,851,197	3,220,649 2,936,733	3,358,244 3,024,835	3,500,974 3,115,580	3,649,473 3,209,047	
Maintenance Other									443,566	456,873	549,022	565,493	582,458	599,932	617,930	636,468	655,562	675,228	695,485	716,350	737,840	759,975	782,775	806,258	830,446	855,359	881,020	907,450	934,674	962,714	991,59
Other																															
Total running costs								1	5,588,990	5,776,168	6,309,335	6,549,550	6,798,637	7,056,632	7,324,136	7,799,941	8,070,084	8,349,416	8,638,410	8,937,059	9,245,852	9,568,561	9,902,497	10,247,666	10,604,830	10,973,998	11,343,000	11,724,265	12,117,976	12,524,986	12,945,27
R&R Costs: Other									1,301,467	1,340,511	1,380,726	1,422,148	1,464,813	1,508,757	1,554,020	1,600,640	1,648,659	1,698,119	1,749,063	1,801,535	1,855,581	1,911,248	1,968,586	2,027,643	2,088,472	2,151,127	2,215,660	2,282,130	2,350,594	2,421,112	2,493,74
Other																															
Other																															1
Other Other Other																															
Other Other Other Total refurbishments									1,301,467			1,422,148																			
Other Other Other Total refurbishments												1,422,148 (7,081,491)																			
Other Other Other																															
Other Other Total refurbishments Net escalated benefit/(cost)										(6,312,026)	(6,849,975)	(7,081,491)	(7,320,843)	(7,568,040)	(7,823,627)	(8,256,867)	(8,521,412)	(8,794,268)	(9,075,991)	(9,366,533)	(9,654,994)	(9,965,329)	(10,286,485)	(10,617,751)	(10,959,831)	(11,296,990)	(11,652,691)	(12,020,155)	(12,398,957)	(12,789,898)	(13,187,42

Year of analysis		lisk adjustments												oire Utilities Ag															
- · · · · · · · · · · · · · · · · · · ·	2016		Benefits											JA - RP5 - Dig															
Escalation rate	3.00%	•	tal costs									Life C		tive Cost Anal native 2 - MAD															
Discount rate	2.00%	Runnin	ng costs										Altern	ative 2 - MAD															
F														Year															
16 dollars, unescalated		2017 2	2018 201	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	
10 doile 2,	u 																												
							70,332,830																						
al outlays							70,332,830															t	·	f	<u></u>	<u></u>	<u></u>	<u> </u>	
-																													
its																													
ig Costs:																							1						
							769,700	769,700	769,700	769,700	769,700	769,700	769,700	1,156,200	1,156,200	1,156,200	1,156,200	1,156,200 1,	,156,200 1	1,156,200	1,156,200	1,156,200	1,156,200	1,276,600	0 1,276,600	0 1,276,600	0 1,276,600	0 1,276,600	600
							801,500	801,500	801,500	801,500	801,500	801,500	801,500	1,001,900	1,001,900	1,001,900	1,001,900	1,001,900 1,	,001,900 1	1,001,900	1,001,900	1,001,900	1,001,900	1,202,200	0 1,202,200	0 1,202,200	0 1,202,200	0 1,202,200	,200
e							240,450	240,450	240,450	240,450	240,450	240,450	240,450	300,570	300,570	300,570	300,570	300,570	300,570	300,570	300,570	300,570	300,570	360,660	0 360,660	0 360,660	360,660	0 360,660	<mark>,60</mark>
ing costs					4		1 911 650	1 911 650	1 911 650	1 911 650	1 911 650	1,811,650 1	4 941 650	2,458,670	2 458 670	2 458 670	2 458 670	2 459 670 2	459 670	2 458 670	2 458 670	2 458 670	2 458 670	2 839.461	2 839.460	2 839.461	0 2,839,460	2 839.46	460
Ig cosis	I					·	1,011,000	1,011,000	1,011,000	1,011,000	1,811,000	1,811,000 .	,811,000	2,400,010	2,400,010	2,400,010	2,406,010	2,456,010,	408,070	2,456,070	2,400,010	2,400,010	2,400,010	2,000,700	2,000,700	2,000,400	/ 2,000,400	2,000,-00	10
							424,453	424,453	424,453	424,453	424,453	424,453	424,453	424,453	424,453	424,453	424,453	424,453	424,453	424,453	424,453	424,453	424,453	424,453	3 424,453	3 424,453	53 424,453	3 424,453	, <mark>453</mark>
																													<u> </u>
rbishments					<u> </u>	<u> </u>	424,453					424,453		424,453	424,453	424,453	· · · ·	424,453			424,453			424,453		3 424,453		,	·
cost)						<u> </u>	(72,568,933)	(2,236,103)	(2,236,103)	(2,236,103)	(2,236,103) (7	(2,236,103) (2	2,236,103)	(2,883,123)	(2,883,123)	(2,883,123)	(2,883,123) (2,883,123) (2,	,883,123) (2	2,883,123)	2,883,123)	(2,883,123)	(2,883,123)	(3,263,913)) (3,263,913)) (3,263,913)	(3,263,913)) (3,263,913	<u>,13)</u>
n escalated dollars with se	eneitivity adjustr	mente																											_
ys	montry	Sine																											
5						1	86,500,510																1						_
						1																. I	Í Í						
						1																. 1	1						
						1																. I	í '						
	1	1	1	1		1								1			1	1			1		1						
-l outlave							26 500 510				1	1											·	+	+	+		+	
tal outlays							86,500,510															·		<u> </u>	<u>+</u>	<u> </u>		<u> </u>	_
tal outlays		<u> </u>					86,500,510								t								<u> </u>	<u>+</u>	<u>+</u>		 		_
tal outlays						<u> </u>	86,500,510																 			± 			_
tal outlays																				 			<u> </u>						_
																													_
efits																													
efits							946,634		1,004,284			1,097,408 1 1,142,747 1		1,748,856				1,968,353 2, 1,705,668 1,									2,835,698 2,670,434		
efits							946,634		1,045,776	1,077,149	1,109,463	1,142,747 1	1,177,030	1,748,856 1,515,464 454,639		1,607,755	1,655,988		,756,838 1			1,919,744		3 2,443,825	5 2,517,140	0 2,592,654	2,835,698 2,670,434 801,130	4 2,750,547	,547
efits							946,634 985,744	1,015,316	1,045,776	1,077,149	1,109,463	1,142,747 1	1,177,030	1,515,464	1,560,928	1,607,755	1,655,988	1,705,668 1,	,756,838 1	1,809,543	1,863,829	1,919,744	1,977,336	3 2,443,825	5 2,517,140	0 2,592,654	2,670,434	4 2,750,547	,547
efits							946,634 985,744	1,015,316	1,045,776	1,077,149	1,109,463	1,142,747 1	1,177,030	1,515,464	1,560,928	1,607,755	1,655,988	1,705,668 1,	,756,838 1	1,809,543	1,863,829	1,919,744	1,977,336	3 2,443,825	5 2,517,140	0 2,592,654	2,670,434	4 2,750,547	,547
efits ing Costs:							946,634 985,744 295,723	1,015,316 304,595	1,045,776 313,733	1,077,149 323,145	1,109,463 332,839	1,142,747 1 342,824	1,177,030 353,109	1,515,464 454,639	1,560,928 468,278	1,607,755 482,327	1,655,988 496,796	1,705,668 1, 511,700	,756,838 1 527,051	1,809,543 542,863	1,863,829 559,149	1,919,744 575,923	1,977,336 593,201	2,443,825 733,148	5 2,517,140 8 755,142	0 2,592,654 2 777,796	54 2,670,434 96 801,130	4 2,750,547 0 825,164	,547 ,164
efits							946,634 985,744 295,723	1,015,316 304,595	1,045,776 313,733	1,077,149 323,145	1,109,463 332,839	1,142,747 1	1,177,030 353,109	1,515,464	1,560,928 468,278	1,607,755 482,327	1,655,988 496,796	1,705,668 1, 511,700	,756,838 1 527,051	1,809,543 542,863	1,863,829 559,149	1,919,744 575,923	1,977,336 593,201	2,443,825 733,148	5 2,517,140 8 755,142	0 2,592,654 2 777,796	2,670,434	4 2,750,547 0 825,164	,547 ,164
efits ing Costs:							946,634 985,744 295,723 2,228,101	1,015,316 304,595 2,294,944	1,045,776 313,733 2,363,792	1,077,149 323,145 2,434,706	1,109,463 332,839 2,507,747	1,142,747 1 342,824 2,582,980 2	1,177,030 353,109 2,660,469	1,515,464 454,639 3,718,959	1,560,928 468,278 3,830,528	1,607,755 482,327 3,945,444	1,655,988 496,796 4,063,807	1,705,668 1, 511,700 4,185,721 4,	,756,838 1 527,051 ,311,293 4	1,809,543 542,863 4,440,632	1,863,829 559,149 4,573,850	1,919,744 575,923 4,711,066	1,977,336 593,201 4,852,398	 2,443,825 733,148 5,772,038 	5 2,517,140 8 755,142 8 5,945,199	0 2,592,654 2 777,796 9 6,123,555	54 2,670,434 801,130 55 6,307,261	4 2,750,547 D 825,164 1 6,496,479	,547 ,164 ,47 9
efits ing Costs:							946,634 985,744 295,723	1,015,316 304,595 2,294,944	1,045,776 313,733 2,363,792	1,077,149 323,145	1,109,463 332,839 2,507,747	1,142,747 1 342,824 2,582,980 2	1,177,030 353,109	1,515,464 454,639	1,560,928 468,278 3,830,528	1,607,755 482,327 3,945,444	1,655,988 496,796 4,063,807	1,705,668 1, 511,700	,756,838 1 527,051 ,311,293 4	1,809,543 542,863 4,440,632	1,863,829 559,149	1,919,744 575,923 4,711,066	1,977,336 593,201 4,852,398	 2,443,825 733,148 5,772,038 	5 2,517,140 8 755,142 8 5,945,199	0 2,592,654 2 777,796 9 6,123,555	54 2,670,434 96 801,130	4 2,750,547 0 825,164 1 6,496,479	,547 ,164 ,47 9
efits ing Costs:							946,634 985,744 295,723 2,228,101	1,015,316 304,595 2,294,944	1,045,776 313,733 2,363,792	1,077,149 323,145 2,434,706	1,109,463 332,839 2,507,747	1,142,747 1 342,824 2,582,980 2	1,177,030 353,109 2,660,469	1,515,464 454,639 3,718,959	1,560,928 468,278 3,830,528	1,607,755 482,327 3,945,444	1,655,988 496,796 4,063,807	1,705,668 1, 511,700 4,185,721 4,	,756,838 1 527,051 ,311,293 4	1,809,543 542,863 4,440,632	1,863,829 559,149 4,573,850	1,919,744 575,923 4,711,066	1,977,336 593,201 4,852,398	 2,443,825 733,148 5,772,038 	5 2,517,140 8 755,142 8 5,945,199	0 2,592,654 2 777,796 9 6,123,555	54 2,670,434 801,130 55 6,307,261	4 2,750,547 0 825,164 1 6,496,479	,547 ,164
efits ing Costs:							946,634 985,744 295,723 2,228,101	1,015,316 304,595 2,294,944	1,045,776 313,733 2,363,792	1,077,149 323,145 2,434,706	1,109,463 332,839 2,507,747	1,142,747 1 342,824 2,582,980 2	1,177,030 353,109 2,660,469	1,515,464 454,639 3,718,959	1,560,928 468,278 3,830,528	1,607,755 482,327 3,945,444	1,655,988 496,796 4,063,807	1,705,668 1, 511,700 4,185,721 4,	,756,838 1 527,051 ,311,293 4	1,809,543 542,863 4,440,632	1,863,829 559,149 4,573,850	1,919,744 575,923 4,711,066	1,977,336 593,201 4,852,398	 2,443,825 733,148 5,772,038 	5 2,517,140 8 755,142 8 5,945,199	0 2,592,654 2 777,796 9 6,123,555	54 2,670,434 801,130 55 6,307,261	4 2,750,54 0 825,16 1 6,496,47	,54 ,16 ,47
efits ing Costs:							946,634 985,744 295,723 2,228,101 522,023	1,015,316 304,595 2,294,944 537,684	1,045,776 313,733 2,363,792 553,815	1,077,149 323,145 2,434,706 570,429	1,109,463 332,839 2,507,747 2 587,542	1,142,747 1 342,824 2,582,980 2	1,177,030 353,109 2,660,469 623,323	1,515,464 454,639 3,718,959	1,560,928 468,278 3,830,528 661,283	1,607,755 482,327 3,945,444 681,122	1,655,988 496,796 4,063,807 701,556	1,705,668 1, 511,700 4,185,721 4, 722,602	,756,838 1 527,051 , ,311,293 4 744,280	1,809,543 542,863 4,440,632 766,609	1,863,829 559,149 4,573,850 789,607	1,919,744 575,923 4,711,066 813,295	1,977,336 593,201 4,852,398 837,694	à 2,443,825 733,148 b 5,772,038 b 862,825	5 2,517,140 755,142 8 5,945,199 5 888,710	0 2,592,654 777,796 9 6,123,555 0 915,371	54 2,670,434 801,130 55 6,307,261	4 2,750,547 0 825,164 1 6,496,479 2 971,117	,547 ,164 , 47 ,117
efits ing Costs: re ing costs							946,634 985,744 295,723 2,228,101 522,023	1,015,316 304,595 2,294,944 537,684 537,684	1,045,776 313,733 2,363,792 553,815 553,815	1,077,149 323,145 2,434,706 570,429 570,429	1,109,463 332,839 2,507,747 2 587,542 587,542	1,142,747 1 342,824 1 2,582,980 2 605,168 605,168	1,177,030 353,109 2,660,469 623,323 623,323	1,515,464 454,639 3,718,959 642,023	1,560,928 468,278 3,830,528 661,283 661,283	1,607,755 482,327 3,945,444 681,122 681,122	1,655,988 496,796 4,063,807 701,556 701,556	1,705,668 1, 511,700 4, 1,185,721 4, 722,602 722,602 722,602	756,838 1 527,051 1 ,311,293 4 744,280 7 44,280 7	1,809,543 542,863 4,440,632 766,609 766,609	1,863,829 559,149 4,573,850 789,607 789,607	1,919,744 575,923 4,711,066 813,295 813,295	1,977,336 593,201 4,852,398 837,694 837,694	3 2,443,825 733,148 8 5,772,038 4 862,825 4 862,825	5 2,517,140 755,142 8 5,945,199 5 888,710 5 888,710	0 2,592,654 777,796 9 6,123,655 0 915,371 0 915,371	2,670,434 801,130 55 6,307,261 71 942,832	4 2,750,54 0 825,16 1 6,496,47 2 971,11 2 971,11	,54 ,16 , 47 ,11
fits ng Costs: e ng costs bishments							946,634 985,744 295,723 2,228,101 522,023 522,023	1,015,316 304,595 2,294,944 537,684 537,684	1,045,776 313,733 2,363,792 553,815 553,815	1,077,149 323,145 2,434,706 570,429 570,429	1,109,463 332,839 2,507,747 2 587,542 587,542	1,142,747 1 342,824 1 2,582,980 2 605,168 605,168	1,177,030 353,109 2,660,469 623,323 623,323	1,515,464 454,639 3,718,959 642,023 642,023	1,560,928 468,278 3,830,528 661,283 661,283	1,607,755 482,327 3,945,444 681,122 681,122	1,655,988 496,796 4,063,807 701,556 701,556	1,705,668 1, 511,700 4, 1,185,721 4, 722,602 722,602 722,602	756,838 1 527,051 1 ,311,293 4 744,280 7 44,280 7	1,809,543 542,863 4,440,632 766,609 766,609	1,863,829 559,149 4,573,850 789,607 789,607	1,919,744 575,923 4,711,066 813,295 813,295	1,977,336 593,201 4,852,398 837,694 837,694	3 2,443,825 733,148 8 5,772,038 4 862,825 4 862,825	5 2,517,140 755,142 8 5,945,199 5 888,710 5 888,710	0 2,592,654 777,796 9 6,123,655 0 915,371 0 915,371	2,670,434 801,130 55 6,307,261 71 942,832 71 942,832	4 2,750,5 9 825,1 1 6,496,4 2 971,1 2 971,1	,54 ,16 , 47 ,11

From Summary Sheet:		Risk adjustments (+/- percent):									npire Utilities															
Year of analysis Escalation rate	2016 3.00%	Benefits Capital costs									EUA - RP5 - D native Cost A	Digestion Analysis (\$000	/00s)													
Discount rate	2.00%	Running costs									native 3 - 2 Pl															
ļ	2016	2017 2018 2019	2020 2021 2022	22 2023	2024	2025	2026	2027	2028	2029	Year 2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
pressed in 2016 dollars, unescalate			·	<u>_</u>																						
apital Outlays 2 Phase				61,077,295																						
Other Other																										
Other Other																										
Other	,	//		A1 077 005			<u> </u>												<u> </u>							
Total capital outlays	L			61,077,295		L	L		L		L		L				L	L		L	L			L	L	
Dewatering Benefit				69,627 188 341	'	<i>'</i>	· · · · ·	· · · · · · · · · · · · · · · · · · ·	79,145	81,644	· · · · ·	85,673	87,204		<i>'</i>	91,795	93,451	95,108 253 075		<i>'</i>	<i>'</i>	101,328	· · · · ·	103,827	· · · · · ·	
Gas benefit Other				188,341	,	, i	,	,		204,892		,	232,858	,		247,889	251,122		, í		,			279,087		, , , , , , , , , , , , , , , , , , ,
Total benefits Annual Running Costs:				257,968	261,832	265,146	270,478	275,831	281,184	286,536	311,375	315,678	320,062	324,446	328,830	339,683	344,573	349,084	353,594	358,105	370,333	374,708	378,812	382,915	387,018	393,447
				250.000																						
Electrical Labor				652,800 901,700	652,800 901,700	<i>'</i>	652,800 901,700	652,800 901,700	· · · · ·	· · · · · · · · · · · · · · · · · · ·	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	· · · ·	· · · · ·	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	· · ·	1,152,300 1,102,100	· · ·		1,152,300 1,102,100				, ,	· · ·	, ,	· · ·
maintenance				270,510	1 1 1	1 / I	1 / 1		1 / / I	270,510	1 7 7 1	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	330,630		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	330,630	and the second		the second s	and the second	and the second		A CONTRACT OF		A CONTRACT OF	
Total running costs R&R Costs:				1,825,010	1,825,010	1,825,010	1,825,010	1,825,010	1,825,010	1,825,010	2,585,030	2,585,030 2	2,585,030	2,585,030	2,585,030	2,585,030	2,585,030	2,585,030	2,585,030	2,585,030	3,024,850	3,024,850	3,024,850	3,024,850	3,024,850	3,024,850
Other				368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490	368,490
Other Other																										
Other Other																										
Total refurbishments				368,490	,	,	,	,	,	368,490			,		,	368,490	,	,	,	· · · ·	,	,		,	,	
Net Benefit/(cost)				(63,012,828)	(1,931,668)	(1,928,354)	(1,923,022)) (1,917,669)	(1,912,317)	(1,906,964)	(2,642,145)	(2,637,843) (2	2,633,459)	(2,629,075)	(2,624,691)	(2,613,837)	(2,608,947)	(2,604,437)	(2,599,926)	(2,595,416)	(3,023,008)	(3,018,632)	(3,014,529)	(3,010,425)	(3,006,322)	(2,999,893)
Expressed in escalated dollars with s	sensitivity adju	ustments				. <u> </u>																				
Capital Outlays 2 Phase	[75,117,369	,	,T				,						, <u> </u>	. <u> </u>	,T		, , , , , , , , , , , , , , , , , , ,		,		, 	, , , , , , , , , , , , , , , , , , ,	
Other				10,111,000	1	.	r I	1	1	ļ	1			1			, J.	.	, I	1	, I	, J.	. -	, I	1	1
Other Other					1	.	r I	1	1	ļ	1			1			, J.	.	, I	1	, I	, J.	. -	, I	1	1
Other Other					1	.	, I	1	1	ļ	1			1		, I	, I		(I I	, I	, J.		, I	1	
Total capital outlays				75,117,369																						
Benefits: Dewatering Benefit				85,632	89,481	93,484	99,647	106,096	112,842	119,897	127,274	133,476	139,936	146,664	153,669	160,962	168,784	176,930	185,412				221,219	230,631	240,408	3 250,565
Gas benefit Other				231,636		252,471	263,853	275,719		300,891	343,709		373,669		406,142	434,674	453,553		492,111							
Total benefits		⁺		317,268	331,681	345,955	363,500	381,814	400,901	420,788	470,983	491,816	513,605	536,259	559,811	595,637	622,337	649,398	677,523	706,750	752,810	784,556	816,942	850,564	885,469	927,184
Annual Running Costs:				T		,T	,		1	T	IT			1		, 	,	,	,,	· · · · ·	,T	,	ı — — — — — — — — — — — — — — — — — — —	,	· · · · ·	
Electrical Labor				802,862 1,108,977	· · · ·		· · ·									2,020,565 1,932,539	2,081,182 1,990,515		2,207,926 2,111,738	2,274,164 2,175,090						
maintenance				332,693						397,253			530,564		562,875	579,762						830,706				
ļ					1		, J.	1	1	ļ	1			1		, I.	, J	,	ļ.	1	, I	, J.		, I	1	1
ļ					1		r J	1	1	ļ	1			r I		, I	, J	,	і. Г		, I	, J		, I	1	1
Total running costs				2,244,532	2,311,868	2,381,224	2,452,661	2,526,241	2,602,028	2,680,089	3,910,090	4,027,393 4	4,148,214	4,272,661	4,400,841	4,532,866	4,668,852	4,808,917	4,953,185	5,101,780	6,148,897	6,333,364	6,523,365	6,719,066	6,920,638	7,128,257
R&R Costs: Other				453,197	466,792	480,796	495,220	510,077	525,379	541,140	557,375	574,096	591,319	609,058	627,330	646,150	665,534	685,500	706,065	727,247	749,065	771,537	794,683	818,523	843,079	868,371
Other Other							·)		1	·]	1			í .		· .	, i J	· .	i I			, j	1	·	1	
Other					1	,	, I.	1	1	ļ	1			(, I	, J	,	i. I	1	, I	, J.		, I	1	1
Other Total refurbishments				453,197	466,792	480,796	495,220	510,077	525,379	541,140	557,375	574,096	591,319	609,058	627,330	646,150	665,534	685,500	706,065	727,247	749,065	771,537	794,683	818,523	843,079	868,371
Net escalated benefit/(cost)				(77,497,830)	(2,446,979)	(2,516,065)	(2,584,381)) (2,654,503)	(2,726,506)	(2,800,441)	(3,996,482)	(4,109,673) (4	(4,225,928)	(4,345,460)	(4,468,360)	(4,583,379)	(4,712,049)	(4,845,019)	(4,981,727)	(5,122,277)	(6,145,152)	(6,320,345)	(6,501,106)	(6,687,025)	(6,878,248)	(7,069,445)
Life cycle cost analysis																										
PVs in 2016	(135,014,444)			(67,466,525)	(2,088,473)	(2,105,330)	(2,120,092)	(2,134,919)	(2,149,832)	(2,164,832)	(3,028,834)	(3,053,547)	3,078,359)	(3,103,365)	(3,128,564)	(3,146,172)	(3,171,074)	(3,196,627)	(3,222,376)	(3,248,322)	(3,820,573)	(3,852,445)	(3,884,926)	(3,917,674)	(3,950,691)	(3,980,891)

RP-5 Dewatering

Inland Empire Utilities Agency

Alternatives Net Present Value Analysis

Agency:	Inland Empire Utilities Agency		Sensitivi	ty Adjustm	ents (%)	Re	sults
Project/Problem:		Risk Premium	Benefits	Capital Costs	Running Costs	Capital Cost	NPV
Alternative 1 Alternative 2 Alternative 3	Centrifuge Belt Filter Press Screw Press					\$64,333,526 \$71,962,967 \$57,498,791	(\$174,857,985) (\$192,882,039) (\$177,641,253)
Year of analysis:	2016						
Escalation rate: Discount rate:	3.00% 2.00%						

Make entries in yellow cells only.

Inland Empire

From Summary Sheet:		Risk adjustments (+/- percent):								Inland En	npire Utilitie	s Agency														
Year of analysis Escalation rate	2016 3.00%	Benefits Capital costs							l ife C	vcle Alterr	native Cost	Analysis (\$	000e)													
Discount rate	2.00%	Running costs							Life G		ative 1 - Ce		00037													
												•														
-	2016	2017 2018 2019 2020	2021 2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	ear 2038	2039	2040	2041	2042	2043	2044	2045
pressed in 2016 dollars, unescalated															L. L											
apital Outlays Total Capital			48.250.145	16,083,382																						
Other			40,200,140	10,000,002																						
Other Other																										
Other																										
Other			40.050.445	46 002 202																						
Total capital outlays			48,250,145	10,083,382																						
Other																										
Other Other																										
Total benefits																										
nnual Running Costs:																										
Dewatering Electrical				27,007 797,294	27,399 808,868	27,791 820,442	28,760 849,056	29,729 877,669	30,699 906,283	31,668 934,896	32,637 963,510	33,230 981,028	33,824 998,546	34,417 1,016,065	35,011 1.033.583	35,604 1,051,101	36,247 1,070,072	36,889 1,089,043	37,532 1,108,014	38,174 1,126,985	38,817 1,145,956	39,302 1,160,263	39,786 1,174,569	40,271 1,188,876	40,755 1,203,183	41,2 1,217,4
Polymer Usage Labor				797,294 50,092	808,868 50,092	820,442 50,092	849,056 50,092	877,669 50,092	906,283 50,092	934,896 50,092	L /	981,028 50,092	998,546 50,092	1,016,065	1,033,583	1,051,101 50,092	1,070,072 50,092	1,089,043	1,108,014 50,092	1,126,985	1,145,956	1,160,263	1,174,569	1,188,876	1,203,183	L
Hauling & Disposal				2,032,352	2,061,855	2,091,359	2,164,296	2,237,234	2,310,171	2,383,108	2,456,046	2,500,701	2,545,357	2,590,012	2,634,667	2,679,323	2,727,681	2,776,039	2,824,397	2,872,755	2,921,113	2,957,581	2,994,050	3,030,519	3,066,987	3,103,4
Odor Control Operating Costs Other				56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,115	56,1
Other																										
Other Total running costs				2 962 859	3,004,329	3 045 798	3 1/8 318	3 250 838	3 353 350	3 455 879	3 558 399	3 621 166	3 683 933	3 746 700	3 809 467	3 872 234	3 940 206	4 008 177	4 076 149	4 144 120	4 212 092	4 263 352	4 314 612	4 365 872	4 417 132	4 468 3
R&R Costs:				2,302,003	0,004,023	0,040,750	0,140,010	0,200,000	0,000,000	0,400,075	0,000,000	0,021,100	0,000,000	0,140,100	0,003,407	0,012,204	0,040,200	4,000,111	4,070,145	4,144,120	4,212,032	4,200,002	4,014,012	4,000,072	4,417,102	4,400,0
Other				75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,0
Other Other																										
Other																										
Other				75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.000	75.0
Total refurbishments			(48,250,145)	75,000	75,000	75,000	,	,	75,000	75,000		75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	75,000	,	75,000	
			(40,200,140)	(13,121,241)	(0,013,023)	(0,120,130)	(0,220,010)	(0,020,000)	(0,420,003)	(0,000,073)	(0,000,000)	(0,030,100)	(0,700,500)	(0,021,700)	(0,004,407)	(0,347,204)	(4,010,200)	(4,000,111)	(4,101,143)	(4,213,120)	(4,207,032)	(4,000,002)	(4,003,012)	(4,440,072)	(4,432,102)	(4,040,0
Expressed in escalated dollars with sensi	itivity adjustment	s																								
Capital Outlays			57.040.400	40 700 504							1													1	1	1
Total Capital Other			57,613,196	19,780,531																						
Other																										
Other Other																										
Other																										
Total capital outlays			57,613,196	19,780,531																						
Benefits: Other																										
Other																										
Other																										
Annual Running Costs:																										
Dewatering Electrical				33,215	34,708	36,261		41,152	43,769	46,505	49,366	51,772		56,886	59,603	62,432	65,465	68,625	71,915		78,907	82,289	85,803	· · ·	· · ·	
Polymer Usage Labor				980,571 61,606	1,024,650 63,455	1,070,491 65,358			1,292,143 71,419	1,372,927 73,561	1,457,395 75,768	1,528,410 78,041	1,602,374 80,382	1,679,400 82,794	1,759,606 85,278	1,843,113 87,836	1,932,670 90,471	2,025,941 93,185	2,123,070 95,981	2,224,202 98,860	2,329,492 101,826	2,429,332 104,881	2,533,066 108,027		2,752,795 114,606	2,869,0 118,0
Hauling & Disposal				2,499,537	2,611,897	2,728,749			3,293,751	3,499,675			4,084,550	4,280,895	4,485,345	4,698,209	4,926,495	5,164,250			5,938,020	6,192,518	6,456,942			
Odor Control Operating Costs				69,014		73,217			80,006	82,406		87,425	90,048	92,749	95,531	98,397	101,349	104,390		110,747	114,070					
Other Other																										
Other																										
Total running costs				3,643,943	3,805,794	3,974,076	4,231,077	4,499,921	4,781,087	5,075,074	5,382,397	5,641,659	5,911,631	6,192,725	6,485,363	6,789,987	7,116,450	7,456,390	7,810,322	8,178,780	8,562,315	8,926,512	9,304,854	9,697,863	10,106,078	10,530,0
&R Costs: Other				92,241	95,008	97,858	100,794	103,818	106,932	110,140	113,444	116,848	120,353	123,964	127,682	131,513	135,458	139,522	143,708	148,019	152,460	157,033	161,744	166,597	171,595	176,7
Other				, 1	22,000	1,000	,	,,0.0	,	,		,0.10	,000	,,	,		,	,	,,	,,0.0		,000			,000	
Other Other																										
Other																										
Other				92,241	95,008	97,858	100,794	103,818	106,932	110,140	113,444	116,848	120,353	123,964	127,682	131,513	135,458	139,522	143,708	148,019	152,460	157,033	161,744	166,597	171,595	176,7
Total refurbishments																										
			(57,613,196)	(23,516,715)	(3,900,802)	(4,071,934)	(4,331,870)	(4,603,738)	(4,888,020)	(5,185,214)	(5,495,842)	(5,758,506)	(6,031,984)	(6,316,688)	(6,613,046)	(6,921,500)	(7,251,908)	(7,595,913)	(7,954,030)	(8,326,799)	(8,714,774)	(9,083,545)	(9,466,598)	(9,864,460)	(10,277,673)	(10,706,8
Total refurbishments			(57,613,196)	(23,516,715)	(3,900,802)	(4,071,934)	(4,331,870)	(4,603,738)	(4,888,020)	(5,185,214)	(5,495,842)	(5,758,506)	(6,031,984)	(6,316,688)	(6,613,046)	(6,921,500)	(7,251,908)	(7,595,913)	(7,954,030)	(8,326,799)	(8,714,774)	<mark>(</mark> 9,083,545)	(9,466,598)	(9,864,460)	(10,277,673)	(10,706,8
Total refurbishments			(57,613,196)			-																				

NPV as of 2016

(174,857,985)

		Risk adjustment	· · ·										Inland Em	pire Utilitie	s Agency													
Year of analysis	2016		Benefits																									
Escalation rate	3.00%	-	tal costs									Life Cy	ycle Altern	ative Cost /	Analysis (\$0)00s)												
Discount rate	2.00%] Runni	ng costs										Alternative	e 2 - Belt Fi	ter Press													
F	0040	0047	2040	0 0	000	0000	0002	0004	0005	0000	0007	2022	2000	0000	0024	0000	0020	0024	0005	0020	Ye		0000	00.40	0044	0040	20.42	0044
2016 dollars, unescalated	2016	2017	2018 201	9 203	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044
6																												
ıl						53,972,225	17,990,742																					
al outlays						53,972,225	17,990,742																					
fits																												
ng Costs: Electrical							15,511	15,511	15,511	15,511	19,388	19,388	19,388	19,388	19,388	19,388	19,388	19,388	19,388	19,388	19,388	23,266	23,266	23,266	23,266	23,266	23,266	23,266
age							341,697	346,658	351,618	363,881	376,144	388,407	400,670	412,933	420,441	427,948	435,456	442,964	450,472	458,602	466,733	474,863	482,994	491,124	497,255	503,387	509,518	23,266 515,650
							100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183	100,183
Disposal ol Operating Costs							2,709,803 92,667	2,749,141 92.667	2,788,478 92.667	2,885,728 92,667	2,982,978 92,667	3,080,228 92,667	3,177,478 92.667	3,274,728 92.667	3,334,268 92,667	3,393,809 92,667	3,453,349 92,667	3,512,890 92,667	3,572,430 92,667	3,636,908 92,667	3,701,385 92,667	3,765,862 92,667	3,830,339 92,667	3,894,817 92,667	3,943,442 92,667	3,992,067 92,667	4,040,692 92,667	4,089,317 92,667
							52,007	92,007	52,007	52,007	52,007	52,007	92,007	52,007	52,007	52,007	92,007	52,007	92,007	52,007	52,007	52,007	52,007	32,007	52,007	52,007	52,007	92,007
ing costs							3,259,861	3 304 159	3,348 457	3,457,970	3,571 360	3,680,873	3,790,386	3,899,800	3,966,947	4.033.995	4,101 044	4,168,092	4,235 141	4.307 749	4,380,356	4,456,841	4.529 449	4,602.056	4,656,813	4,711,569	4,766 326	4,821 082
ing costs		II	I				0,200,001	5,004,105	0,040,407	0,401,010	0,011,000	3,000,010	3,103,000	0,000,000	3,000,041	4,000,000	-,.01,044	4,100,002	4,200,141	4,001,140	4,000,000	4,400,041	7,020,440	4,002,000	4,000,010	4,111,000	-,,,00,020	-,021,002
							77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028	77,028
rbishments							77,028	77,028	, í		77,028	77,028				77,028				77,028				77,028	77,028		77,028	77,028
(cost)						(53,972,225)	(21,327,631)	(3,381,187)	(3,425,485)	(3,534,998)	(3,648,389)	(3,757,901)	(3,867,414)	(3,976,927)	(4,043,975)	(4,111,024)	(4,178,072)	(4,245,121)	(4,312,169)	(4,384,777)	(4,457,384)	(4,533,869)	(4,606,477)	(4,679,085)	(4,733,841)	(4,788,598)	(4,843,354)	(4,898,110)
in escalated dollars with sens	sitivity adjustmen	nts																										
ys																												
						64,445,659	22,126,343																					
						64,445,659	22,126,343																					
						64,445,659	22,126,343																					
						64,445,659	22,126,343																					
						64,445,659	22,126,343																					
al							22,126,343 22,126,343																					
ays tal vital outlays																												
ial																												
al																												
al ital outlays																												
al ital outlays efits ing Costs:							22,126,343																					
ital outlays							22,126,343 19,076	19,648 439 136		20,845 489.026	26,838 520 671	27,643 553,775	28,472 588,397	29,326	30,206	31,112 686 732		33,007	33,997	35,017	36,068	44,580	45,917 953 230	47,295	48,714	· · · · · ·	51,680	
al ital outlays efits ing Costs:							22,126,343	19,648 439,136 126,909		20,845 489,026 134,638	26,838 520,671 138,677	27,643 553,775 142,837	28,472 588,397 147,122	29,326 624,598 151,536	30,206 655,033 156,082	31,112 686,732 160,765	719,743	33,007 754,117 170,555	33,997 789,905 175,672	35,017 828,287 180,942	36,068 868,260 186,370	44,580 909,887 191,961	45,917 953,230 197,720	47,295 998,354 203,652	48,714 1,041,142 209,761	· · · · · ·	51,680 1,131,787 222,536	1,179,769
ial outlays							22,126,343 19,076 420,245 123,213 3,332,716	439,136 126,909 3,482,529	458,782 130,716 3,638,332	489,026 134,638 3,878,177	520,671 138,677 4,129,139	553,775 142,837 4,391,669	588,397 147,122 4,666,234	624,598 151,536 4,953,320	655,033 156,082 5,194,682	686,732 160,765 5,446,067	719,743 165,588 5,707,860	754,117 170,555 5,980,460	789,905 175,672 6,264,278	828,287 180,942 6,568,660	868,260 186,370 6,885,666	909,887 191,961 7,215,781	953,230 197,720 7,559,506	998,354 203,652 7,917,360	1,041,142 209,761 8,256,691	1,085,600 216,054 8,609,256	1,131,787 222,536 8,975,544	1,179,769 229,212 9,356,060
al tal outlays							22,126,343 19,076 420,245 123,213	439,136 126,909	458,782 130,716	489,026 134,638	520,671 138,677	553,775 142,837	588,397 147,122	624,598 151,536	655,033 156,082	686,732 160,765	719,743 165,588 5,707,860	754,117 170,555	789,905 175,672	828,287 180,942	868,260 186,370	909,887 191,961	953,230 197,720 7,559,506	998,354 203,652	1,041,142 209,761	1,085,600 216,054	1,131,787 222,536	1,179,769 229,212 9,356,060
al tal outlays							22,126,343 19,076 420,245 123,213 3,332,716	439,136 126,909 3,482,529	458,782 130,716 3,638,332	489,026 134,638 3,878,177	520,671 138,677 4,129,139	553,775 142,837 4,391,669	588,397 147,122 4,666,234	624,598 151,536 4,953,320	655,033 156,082 5,194,682	686,732 160,765 5,446,067	719,743 165,588 5,707,860	754,117 170,555 5,980,460	789,905 175,672 6,264,278	828,287 180,942 6,568,660	868,260 186,370 6,885,666	909,887 191,961 7,215,781	953,230 197,720 7,559,506	998,354 203,652 7,917,360	1,041,142 209,761 8,256,691	1,085,600 216,054 8,609,256	1,131,787 222,536 8,975,544	1,179,769 229,212 9,356,060
i al outlays							22,126,343 19,076 420,245 123,213 3,332,716 113,968	439,136 126,909 3,482,529 117,387	458,782 130,716 3,638,332 120,909	489,026 134,638 3,878,177 124,536	520,671 138,677 4,129,139 128,272	553,775 142,837 4,391,669 132,121	588,397 147,122 4,666,234 136,084	624,598 151,536 4,953,320 140,167	655,033 156,082 5,194,682 144,372	686,732 160,765 5,446,067 148,703	719,743 165,588 5,707,860 153,164	754,117 170,555 5,980,460 157,759	789,905 175,672 6,264,278 162,492	828,287 180,942 6,568,660 167,366	868,260 186,370 6,885,666 172,387	909,887 191,961 7,215,781 177,559	953,230 197,720 7,559,506 182,886	998,354 203,652 7,917,360 188,372	1,041,142 209,761 8,256,691 194,023	1,085,600 216,054 8,609,256 199,844	1,131,787 222,536 8,975,544 205,839	1,179,769 229,212 9,356,060 212,015
al outlays							22,126,343 19,076 420,245 123,213 3,332,716	439,136 126,909 3,482,529 117,387	458,782 130,716 3,638,332 120,909	489,026 134,638 3,878,177 124,536	520,671 138,677 4,129,139 128,272	553,775 142,837 4,391,669 132,121	588,397 147,122 4,666,234 136,084	624,598 151,536 4,953,320 140,167	655,033 156,082 5,194,682 144,372	686,732 160,765 5,446,067 148,703	719,743 165,588 5,707,860 153,164	754,117 170,555 5,980,460 157,759	789,905 175,672 6,264,278 162,492	828,287 180,942 6,568,660 167,366	868,260 186,370 6,885,666 172,387	909,887 191,961 7,215,781 177,559	953,230 197,720 7,559,506 182,886	998,354 203,652 7,917,360 188,372	1,041,142 209,761 8,256,691 194,023	1,085,600 216,054 8,609,256	1,131,787 222,536 8,975,544 205,839	1,179,769 229,212 9,356,060 212,015
al tal outlays							22,126,343 19,076 420,245 123,213 3,332,716 113,968 4,009,218	439,136 126,909 3,482,529 117,387	458,782 130,716 3,638,332 120,909 4,368,977	489,026 134,638 3,878,177 124,536	520,671 138,677 4,129,139 128,272	553,775 142,837 4,391,669 132,121	588,397 147,122 4,666,234 136,084 5,566,309	624,598 151,536 4,953,320 140,167 5,898,947	655,033 156,082 5,194,682 144,372 6,180,374	686,732 160,765 5,446,067 148,703	719,743 165,588 5,707,860 153,164 6,778,401	754,117 170,555 5,980,460 157,759 7,095,898	789,905 175,672 6,264,278 162,492 7,426,345	828,287 180,942 6,568,660 167,366	868,260 186,370 6,885,666 172,387 8,148,752	909,887 191,961 7,215,781 177,559 8,539,768	953,230 197,720 7,559,506 182,886	998,354 203,652 7,917,360 188,372	1,041,142 209,761 8,256,691 194,023	1,085,600 216,054 8,609,256 199,844 10,160,929	1,131,787 222,536 8,975,544 205,839	229,212 9,356,060 212,015
al tal outlays							22,126,343 19,076 420,245 123,213 3,332,716 113,968	439,136 126,909 3,482,529 117,387 4,185,610	458,782 130,716 3,638,332 120,909 4,368,977	489,026 134,638 3,878,177 124,536 4,647,222	520,671 138,677 4,129,139 128,272 4,943,598	553,775 142,837 4,391,669 132,121 5,248,045	588,397 147,122 4,666,234 136,084 5,566,309	624,598 151,536 4,953,320 140,167 5,898,947	655,033 156,082 5,194,682 144,372 6,180,374	686,732 160,765 5,446,067 148,703 6,473,378	719,743 165,588 5,707,860 153,164 6,778,401	754,117 170,555 5,980,460 157,759 7,095,898	789,905 175,672 6,264,278 162,492 7,426,345	828,287 180,942 6,568,660 167,366 7,780,272	868,260 186,370 6,885,666 172,387 8,148,752	909,887 191,961 7,215,781 177,559 8,539,768	953,230 197,720 7,559,506 182,886 8,939,259	998,354 203,652 7,917,360 188,372 9,355,033	1,041,142 209,761 8,256,691 194,023 9,750,332	1,085,600 216,054 8,609,256 199,844 10,160,929	1,131,787 222,536 8,975,544 205,839 10,587,387	1,179,769 229,212 9,356,060 212,015 11,030,287
I al outlays							22,126,343 19,076 420,245 123,213 3,332,716 113,968 4,009,218	439,136 126,909 3,482,529 117,387 4,185,610	458,782 130,716 3,638,332 120,909 4,368,977	489,026 134,638 3,878,177 124,536 4,647,222	520,671 138,677 4,129,139 128,272 4,943,598	553,775 142,837 4,391,669 132,121 5,248,045	588,397 147,122 4,666,234 136,084 5,566,309	624,598 151,536 4,953,320 140,167 5,898,947	655,033 156,082 5,194,682 144,372 6,180,374	686,732 160,765 5,446,067 148,703 6,473,378	719,743 165,588 5,707,860 153,164 6,778,401	754,117 170,555 5,980,460 157,759 7,095,898	789,905 175,672 6,264,278 162,492 7,426,345	828,287 180,942 6,568,660 167,366 7,780,272	868,260 186,370 6,885,666 172,387 8,148,752	909,887 191,961 7,215,781 177,559 8,539,768	953,230 197,720 7,559,506 182,886 8,939,259	998,354 203,652 7,917,360 188,372 9,355,033	1,041,142 209,761 8,256,691 194,023 9,750,332	1,085,600 216,054 8,609,256 199,844 10,160,929	1,131,787 222,536 8,975,544 205,839 10,587,387	1,179,769 229,212 9,356,060 212,015 11,030,287
I al outlays							22,126,343 19,076 420,245 123,213 3,332,716 113,968 4,009,218	439,136 126,909 3,482,529 117,387 4,185,610	458,782 130,716 3,638,332 120,909 4,368,977	489,026 134,638 3,878,177 124,536 4,647,222	520,671 138,677 4,129,139 128,272 4,943,598	553,775 142,837 4,391,669 132,121 5,248,045	588,397 147,122 4,666,234 136,084 5,566,309	624,598 151,536 4,953,320 140,167 5,898,947	655,033 156,082 5,194,682 144,372 6,180,374	686,732 160,765 5,446,067 148,703 6,473,378	719,743 165,588 5,707,860 153,164 6,778,401	754,117 170,555 5,980,460 157,759 7,095,898	789,905 175,672 6,264,278 162,492 7,426,345	828,287 180,942 6,568,660 167,366 7,780,272	868,260 186,370 6,885,666 172,387 8,148,752	909,887 191,961 7,215,781 177,559 8,539,768	953,230 197,720 7,559,506 182,886 8,939,259	998,354 203,652 7,917,360 188,372 9,355,033	1,041,142 209,761 8,256,691 194,023 9,750,332	1,085,600 216,054 8,609,256 199,844 10,160,929	1,131,787 222,536 8,975,544 205,839 10,587,387	1,179,769 229,212 9,356,060 212,015 11,030,287
al outlays							22,126,343 19,076 420,245 123,213 3,332,716 113,968 4,009,218	439,136 126,909 3,482,529 117,387 4,185,610 97,577	458,782 130,716 3,638,332 120,909 4,368,977 100,505	489,026 134,638 3,878,177 124,536 4,647,222	520,671 138,677 4,129,139 128,272 4,943,598 106,625	553,775 142,837 4,391,669 132,121 5,248,045	588,397 147,122 4,666,234 136,084 5,566,309 113,119	624,598 151,536 4,953,320 140,167 5,898,947 116,512	655,033 156,082 5,194,682 144,372 6,180,374 120,008	686,732 160,765 5,446,067 148,703 6,473,378 123,608	719,743 165,588 5,707,860 153,164 6,778,401 127,316	754,117 170,555 5,980,460 157,759 7,095,898	789,905 175,672 6,264,278 162,492 7,426,345 135,070	828,287 180,942 6,568,660 167,366 7,780,272 139,122	868,260 186,370 6,885,666 172,387 8,148,752 143,296	909,887 191,961 7,215,781 177,559 8,539,768 147,594	953,230 197,720 7,559,506 182,886 8,939,259 152,022	998,354 203,652 7,917,360 188,372 9,355,033 156,583	1,041,142 209,761 8,256,691 194,023 9,750,332 161,280	1,085,600 216,054 8,609,256 199,844 10,160,929	1,131,787 222,536 8,975,544 205,839 10,587,387 171,102	1,179,769 229,212 9,356,060 212,015 11,030,287 176,235
al a						64,445,659	22,126,343 19,076 420,245 123,213 3,332,716 113,968 4,009,218 94,735	439,136 126,909 3,482,529 117,387 4,185,610 97,577 97,577	458,782 130,716 3,638,332 120,909 4,368,977 100,505 100,505	489,026 134,638 3,878,177 124,536 4,647,222 103,520 103,520	520,671 138,677 4,129,139 128,272 4,943,598 106,625 106,625	553,775 142,837 4,391,669 132,121 5,248,045 109,824 109,824	588,397 147,122 4,666,234 136,084 5,566,309 113,119 113,119	624,598 151,536 4,953,320 140,167 5,898,947 116,512 116,512	655,033 156,082 5,194,682 144,372 6,180,374 120,008 120,008	686,732 160,765 5,446,067 148,703 6,473,378 123,608 123,608	719,743 165,588 5,707,860 153,164 6,778,401 127,316 127,316	754,117 170,555 5,980,460 157,759 7,095,898 131,136 131,136	789,905 175,672 6,264,278 162,492 7,426,345 135,070 135,070	828,287 180,942 6,568,660 167,366 7,780,272 139,122 139,122	868,260 186,370 6,885,666 172,387 8,148,752 143,296 143,296	909,887 191,961 7,215,781 177,559 8,539,768 147,594 147,594	953,230 197,720 7,559,506 182,886 8,939,259 152,022 152,022	998,354 203,652 7,917,360 188,372 9,355,033 156,583 156,583	1,041,142 209,761 8,256,691 194,023 9,750,332 161,280 161,280	1,085,600 216,054 8,609,256 199,844 10,160,929 166,119	1,131,787 222,536 8,975,544 205,839 10,587,387 171,102 171,102	1,179,769 229,212 9,356,060 212,015 11,030,287 176,235 176,235
al tal outlays						64,445,659	22,126,343 19,076 420,245 123,213 3,332,716 113,968 4,009,218 94,735 94,735	439,136 126,909 3,482,529 117,387 4,185,610 97,577 97,577	458,782 130,716 3,638,332 120,909 4,368,977 100,505 100,505	489,026 134,638 3,878,177 124,536 4,647,222 103,520 103,520	520,671 138,677 4,129,139 128,272 4,943,598 106,625 106,625	553,775 142,837 4,391,669 132,121 5,248,045 109,824 109,824	588,397 147,122 4,666,234 136,084 5,566,309 113,119 113,119	624,598 151,536 4,953,320 140,167 5,898,947 116,512 116,512	655,033 156,082 5,194,682 144,372 6,180,374 120,008 120,008	686,732 160,765 5,446,067 148,703 6,473,378 123,608 123,608	719,743 165,588 5,707,860 153,164 6,778,401 127,316 127,316	754,117 170,555 5,980,460 157,759 7,095,898 131,136 131,136	789,905 175,672 6,264,278 162,492 7,426,345 135,070 135,070	828,287 180,942 6,568,660 167,366 7,780,272 139,122 139,122	868,260 186,370 6,885,666 172,387 8,148,752 143,296 143,296	909,887 191,961 7,215,781 177,559 8,539,768 147,594 147,594	953,230 197,720 7,559,506 182,886 8,939,259 152,022 152,022	998,354 203,652 7,917,360 188,372 9,355,033 156,583 156,583	1,041,142 209,761 8,256,691 194,023 9,750,332 161,280 161,280	1,085,600 216,054 8,609,256 199,844 10,160,929 166,119 166,119	1,131,787 222,536 8,975,544 205,839 10,587,387 171,102 171,102	1,179,769 229,212 9,356,060 212,015 11,030,287 176,235 176,235

(192,882,039)

From Summary Sheet:		Risk adjustn	ents (+/- percent):									Inland Err	pire Utilities	s Agency													
Year of analysis	2016		Benefits																								
Escalation rate Discount rate	3.00% 2.00%		Capital costs Inning costs								Life Cy		ative Cost A		000s)												
	2.00 %											Alternat	ive J - Ociev	w TTC35													
_	2016	2017	2018 2019	2020	2021 2	022 2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	ear 2038	2039	2040	2041	2042	2043	2044
ssed in 2016 dollars, unescalated		2011	2010 2010	LULU			2024	2020	2020	2027	2020	2020	2000	2001	2002	2000	2004	2000	2000	2001	2000	2000	2040	2041	2042	2040	2011
Outlays																											
Capital r					43,1	24,093 14,374,698																					
er																											
ier ier																											
ier																											
tal capital outlays					43,1	24,093 14,374,698																					
its:																											
er er																											
er																											
tal benefits																											
al Running Costs: vatering Electrical						17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449	17,449
ymer Usage						569,496	577,763	586,030	606,468	626,907	647,345	667,783	688,221	700,734	713,247	725,761	738,274	750,787	764,337	777,888	791,439	804,989	818,540	828,759	838,978	849,197	859,416
						150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275	150,275
uling & Disposal or Control Operating Costs						2,438,823 56,115	2,474,227 56,115	2,509,630 56,115	2,597,155 56,115	2,684,680 56,115	2,772,205 56,115	2,859,730 56,115	2,947,255 56,115	3,000,842 56,115	3,054,428 56,115	3,108,014 56,115	3,161,601 56,115	3,215,187 56,115	3,273,217 56,115	3,331,246 56,115	3,389,276 56,115	3,447,305 56,115	3,505,335 56,115	3,549,097 56,115	3,592,860 56,115	3,636,622 56,115	3,680,385 56,115
ner																											
ier ier																											
tal running costs						3,232,157	3,275,828	3,319,500	3,427,463	3,535,426	3,643,389	3,751,352	3,859,315	3,925,415	3,991,514	4,057,614	4,123,713	4,189,813	4,261,393	4,332,973	4,404,553	4,476,134	4,547,714	4,601,695	4,655,677	4,709,658	4,763,640
Costs:																											
er er						126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950
er																											
er																											
ner						126.950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126,950	126.950	126,950	126,950	126,950
enefit/(cost)					(43.1	24,093) (17,733,805)	,	,		,		,		,	,	,	,	,	,	, ,	,	,	,	,	,	,	,
					((-,,,	(-)	(-,,	(-))/	(-,,	(-,,,	(-,,	(-,,)	(-)	(-)/	(-)/	(-,,,	(-,,,-	(-,,,	(-)/	(-)))	(-)	(.,	(-,,,	(-,,,	(-,,,
essed in escalated dollars with ser	nsitivity adjustme	nts																									
al Outlays																											
			1						1 1																		
					51,4	17,679,065																					
er					51,4	17,679,065																					
er er er					51,4	192,422 17,679,065																					
er er er					51,4	192,422 17,679,065																					
er e						192,422 17,679,065 192,422 17,679,065																					
er e																											
er er fits:																											
al Capital er er er otal capital outlays fits: er																											
er																											
er er er er er fits: fits: er er er etal benefits al Running Costs:						192,422 17,679,065																					
er						192,422 17,679,065	22,104	22,767		24,154 867 785	24,879	25,625 980 662	26,394	27,186	28,001	28,841	29,706	30,598	31,516	32,461	33,435	34,438	35,471	36,535	37,631	38,760	39,923
ner						192,422 17,679,065	22,104 731,893 199,364	764,637 196,075	815,043 201,957	867,785 208,015	922,959 214,256	25,625 980,662 220,684	1,040,996 227,304	1,091,721 234,123	28,001 1,144,553 241,147	1,199,572 248,381	1,256,861 255,833	1,316,509 263,508	1,380,478 271,413	1,447,101 279,555	33,435 1,516,478 287,942	34,438 1,588,716 296,580	1,663,923 305,478	1,735,237 314,642	37,631 1,809,333 324,081	38,760 1,886,312 333,804	39,923 1,966,282 343,818
er e						192,422 17,679,065 21,461 700,408 184,819 2,999,444	731,893 190,364 3,134,276	764,637 196,075 3,274,498	815,043 201,957 3,490,360	867,785 208,015 3,716,225	922,959 214,256 3,952,502	980,662 220,684 4,199,610	1,040,996 227,304 4,457,988	1,091,721 234,123 4,675,213	1,144,553 241,147 4,901,460	1,199,572 248,381 5,137,074	1,256,861 255,833 5,382,414	1,316,509 263,508 5,637,851	1,380,478 271,413 5,911,794	1,447,101 279,555 6,197,100	1,516,478 287,942 6,494,203	1,588,716 296,580 6,803,556	1,663,923 305,478 7,125,624	1,735,237 314,642 7,431,022	1,809,333 324,081 7,748,330	1,886,312 333,804 8,077,989	1,966,282 343,818 8,420,454
er or capital outlays capital outlays capital benefits capital benefits capital benefits capital benefits capital control operating Costs capital costs capita						192,422 17,679,065 21,461 700,408 184,819	731,893 190,364	764,637 196,075	815,043 201,957 3,490,360	867,785 208,015 3,716,225	922,959 214,256	980,662 220,684	1,040,996 227,304	1,091,721 234,123	1,144,553 241,147	1,199,572 248,381	1,256,861 255,833 5,382,414	1,316,509 263,508	1,380,478 271,413	1,447,101 279,555	1,516,478 287,942	1,588,716 296,580	1,663,923 305,478 7,125,624	1,735,237 314,642 7,431,022	1,809,333 324,081	1,886,312 333,804 8,077,989	1,966,282 343,818
ar a						192,422 17,679,065 21,461 700,408 184,819 2,999,444	731,893 190,364 3,134,276	764,637 196,075 3,274,498	815,043 201,957 3,490,360	867,785 208,015 3,716,225	922,959 214,256 3,952,502	980,662 220,684 4,199,610	1,040,996 227,304 4,457,988	1,091,721 234,123 4,675,213	1,144,553 241,147 4,901,460	1,199,572 248,381 5,137,074	1,256,861 255,833 5,382,414	1,316,509 263,508 5,637,851	1,380,478 271,413 5,911,794	1,447,101 279,555 6,197,100	1,516,478 287,942 6,494,203	1,588,716 296,580 6,803,556	1,663,923 305,478 7,125,624	1,735,237 314,642 7,431,022	1,809,333 324,081 7,748,330	1,886,312 333,804 8,077,989	1,966,282 343,818 8,420,454
er or control Operating Costs or control Operati						192,422 17,679,065 21,461 700,408 184,819 2,999,444 69,014	731,893 190,364 3,134,276 71,084	764,637 196,075 3,274,498 73,217	815,043 201,957 3,490,360 75,413	867,785 208,015 3,716,225 77,676	922,959 214,256 3,952,502 80,006	980,662 220,684 4,199,610 82,406	1,040,996 227,304 4,457,988 84,878	1,091,721 234,123 4,675,213 87,425	1,144,553 241,147 4,901,460 90,048	1,199,572 248,381 5,137,074 92,749	1,256,861 255,833 5,382,414 95,531	1,316,509 263,508 5,637,851 98,397	1,380,478 271,413 5,911,794 101,349	1,447,101 279,555 6,197,100 104,390	1,516,478 287,942 6,494,203 107,522	1,588,716 296,580 6,803,556 110,747	1,663,923 305,478 7,125,624 114,070	1,735,237 314,642 7,431,022 117,492	1,809,333 324,081 7,748,330 121,016	1,886,312 333,804 8,077,989 124,647	1,966,282 343,818 8,420,454 128,386
er ar						192,422 17,679,065 21,461 700,408 184,819 2,999,444 69,014	731,893 190,364 3,134,276 71,084	764,637 196,075 3,274,498 73,217	815,043 201,957 3,490,360 75,413	867,785 208,015 3,716,225 77,676	922,959 214,256 3,952,502 80,006	980,662 220,684 4,199,610 82,406	1,040,996 227,304 4,457,988 84,878	1,091,721 234,123 4,675,213 87,425	1,144,553 241,147 4,901,460 90,048	1,199,572 248,381 5,137,074 92,749	1,256,861 255,833 5,382,414 95,531	1,316,509 263,508 5,637,851 98,397	1,380,478 271,413 5,911,794 101,349	1,447,101 279,555 6,197,100 104,390	1,516,478 287,942 6,494,203 107,522	1,588,716 296,580 6,803,556 110,747	1,663,923 305,478 7,125,624 114,070	1,735,237 314,642 7,431,022 117,492	1,809,333 324,081 7,748,330 121,016	1,886,312 333,804 8,077,989	1,966,282 343,818 8,420,454 128,386
r diamond and a construction of the constructi						192,422 17,679,065 21,461 700,408 184,819 2,999,444 69,014	731,893 190,364 3,134,276 71,084 4,149,721	764,637 196,075 3,274,498 73,217	815,043 201,957 3,490,360 75,413 4,606,223	867,785 208,015 3,716,225 77,676 4,893,856	922,959 214,256 3,952,502 80,006 5,194,601	980,662 220,684 4,199,610 82,406 5,508,987	1,040,996 227,304 4,457,988 84,878	1,091,721 234,123 4,675,213 87,425	1,144,553 241,147 4,901,460 90,048 6,405,209	1,199,572 248,381 5,137,074 92,749 6,706,617	1,256,861 255,833 5,382,414 95,531 7,020,346	1,316,509 263,508 5,637,851 98,397	1,380,478 271,413 5,911,794 101,349	1,447,101 279,555 6,197,100 104,390	1,516,478 287,942 6,494,203 107,522	1,588,716 296,580 6,803,556 110,747	1,663,923 305,478 7,125,624 114,070 9,244,566	1,735,237 314,642 7,431,022 117,492 9,634,928	1,809,333 324,081 7,748,330 121,016	1,886,312 333,804 8,077,989 124,647 10,461,512	1,966,282 343,818 8,420,454 128,386
er e						192,422 17,679,065 21,461 700,408 184,819 2,999,444 69,014 3,975,146	731,893 190,364 3,134,276 71,084 4,149,721	764,637 196,075 3,274,498 73,217 4,331,194	815,043 201,957 3,490,360 75,413 4,606,223	867,785 208,015 3,716,225 77,676 4,893,856	922,959 214,256 3,952,502 80,006 5,194,601	980,662 220,684 4,199,610 82,406 5,508,987	1,040,996 227,304 4,457,988 84,878 5,837,560	1,091,721 234,123 4,675,213 87,425 6,115,668	1,144,553 241,147 4,901,460 90,048 6,405,209	1,199,572 248,381 5,137,074 92,749 6,706,617	1,256,861 255,833 5,382,414 95,531 7,020,346	1,316,509 263,508 5,637,851 98,397 7,346,862	1,380,478 271,413 5,911,794 101,349 7,696,550	1,447,101 279,555 6,197,100 104,390 8,060,607	1,516,478 287,942 6,494,203 107,522 8,439,580	1,588,716 296,580 6,803,556 110,747 8,834,037	1,663,923 305,478 7,125,624 114,070 9,244,566	1,735,237 314,642 7,431,022 117,492 9,634,928	1,809,333 324,081 7,748,330 121,016 10,040,392	1,886,312 333,804 8,077,989 124,647 10,461,512	1,966,282 343,818 8,420,454 128,386 10,898,864
er e						192,422 17,679,065 21,461 700,408 184,819 2,999,444 69,014 3,975,146	731,893 190,364 3,134,276 71,084 4,149,721	764,637 196,075 3,274,498 73,217 4,331,194	815,043 201,957 3,490,360 75,413 4,606,223	867,785 208,015 3,716,225 77,676 4,893,856	922,959 214,256 3,952,502 80,006 5,194,601	980,662 220,684 4,199,610 82,406 5,508,987	1,040,996 227,304 4,457,988 84,878 5,837,560	1,091,721 234,123 4,675,213 87,425 6,115,668	1,144,553 241,147 4,901,460 90,048 6,405,209	1,199,572 248,381 5,137,074 92,749 6,706,617	1,256,861 255,833 5,382,414 95,531 7,020,346	1,316,509 263,508 5,637,851 98,397 7,346,862	1,380,478 271,413 5,911,794 101,349 7,696,550	1,447,101 279,555 6,197,100 104,390 8,060,607	1,516,478 287,942 6,494,203 107,522 8,439,580	1,588,716 296,580 6,803,556 110,747 8,834,037	1,663,923 305,478 7,125,624 114,070 9,244,566	1,735,237 314,642 7,431,022 117,492 9,634,928	1,809,333 324,081 7,748,330 121,016 10,040,392	1,886,312 333,804 8,077,989 124,647 10,461,512	1,966,282 343,818 8,420,454 128,386 10,898,864
er e						192,422 17,679,065 21,461 700,408 184,819 2,999,444 69,014 3,975,146 156,132	731,893 190,364 3,134,276 71,084 4,149,721 160,816	764,637 196,075 3,274,498 73,217 4,331,194 165,641	815,043 201,957 3,490,360 75,413 4,606,223 170,610	867,785 208,015 3,716,225 77,676 4,893,856 175,728	922,959 214,256 3,952,502 80,006 5,194,601 181,000	980,662 220,684 4,199,610 82,406 5,508,987 186,430	1,040,996 227,304 4,457,988 84,878 5,837,560 192,023	1,091,721 234,123 4,675,213 87,425 6,115,668 197,784	1,144,553 241,147 4,901,460 90,048 6,405,209 203,717	1,199,572 248,381 5,137,074 92,749 6,706,617 209,829	1,256,861 255,833 5,382,414 95,531 7,020,346 216,124	1,316,509 263,508 5,637,851 98,397 7,346,862 222,608	1,380,478 271,413 5,911,794 101,349 7,696,550 229,286	1,447,101 279,555 6,197,100 104,390 8,060,607 236,164	1,516,478 287,942 6,494,203 107,522 8,439,580 243,249	1,588,716 296,580 6,803,556 110,747 8,834,037 250,547	1,663,923 305,478 7,125,624 114,070 9,244,566 258,063	1,735,237 314,642 7,431,022 117,492 9,634,928 265,805	1,809,333 324,081 7,748,330 121,016 10,040,392 273,779	1,886,312 333,804 8,077,989 124,647 10,461,512 281,993	1,966,282 343,818 8,420,454 128,386 10,898,864 290,452
er e					51,4	192,422 17,679,065 21,461 700,408 184,819 2,999,444 69,014 3,975,146 156,132 156,132	731,893 190,364 3,134,276 71,084 4,149,721 160,816 160,816	764,637 196,075 3,274,498 73,217 4,331,194 165,641 165,641	815,043 201,957 3,490,360 75,413 4,606,223 170,610 170,610	867,785 208,015 3,716,225 77,676 4,893,856 175,728 175,728	922,959 214,256 3,952,502 80,006 5,194,601 181,000 181,000	980,662 220,684 4,199,610 82,406 5,508,987 186,430 186,430	1,040,996 227,304 4,457,988 84,878 5,837,560 192,023 192,023	1,091,721 234,123 4,675,213 87,425 6,115,668 197,784 197,784	1,144,553 241,147 4,901,460 90,048 6,405,209 203,717 203,717	1,199,572 248,381 5,137,074 92,749 6,706,617 209,829 209,829	1,256,861 255,833 5,382,414 95,531 7,020,346 216,124 216,124	1,316,509 263,508 5,637,851 98,397 7,346,862 222,608 222,608	1,380,478 271,413 5,911,794 101,349 7,696,550 229,286 229,286	1,447,101 279,555 6,197,100 104,390 8,060,607 236,164 236,164	1,516,478 287,942 6,494,203 107,522 8,439,580 243,249 243,249	1,588,716 296,580 6,803,556 110,747 8,834,037 250,547 250,547	1,663,923 305,478 7,125,624 114,070 9,244,566 258,063 258,063	1,735,237 314,642 7,431,022 117,492 9,634,928 265,805 265,805	1,809,333 324,081 7,748,330 121,016 10,040,392 273,779 273,779	1,886,312 333,804 8,077,989 124,647 10,461,512 281,993 281,993	1,966,282 343,818 8,420,454 128,386 10,898,864 290,452 290,452
r					51,4	192,422 17,679,065 21,461 700,408 184,819 2,999,444 69,014 3,975,146 156,132	731,893 190,364 3,134,276 71,084 4,149,721 160,816 160,816	764,637 196,075 3,274,498 73,217 4,331,194 165,641 165,641	815,043 201,957 3,490,360 75,413 4,606,223 170,610 170,610	867,785 208,015 3,716,225 77,676 4,893,856 175,728 175,728	922,959 214,256 3,952,502 80,006 5,194,601 181,000 181,000	980,662 220,684 4,199,610 82,406 5,508,987 186,430 186,430	1,040,996 227,304 4,457,988 84,878 5,837,560 192,023 192,023	1,091,721 234,123 4,675,213 87,425 6,115,668 197,784 197,784	1,144,553 241,147 4,901,460 90,048 6,405,209 203,717 203,717	1,199,572 248,381 5,137,074 92,749 6,706,617 209,829 209,829	1,256,861 255,833 5,382,414 95,531 7,020,346 216,124 216,124	1,316,509 263,508 5,637,851 98,397 7,346,862 222,608 222,608	1,380,478 271,413 5,911,794 101,349 7,696,550 229,286 229,286	1,447,101 279,555 6,197,100 104,390 8,060,607 236,164 236,164	1,516,478 287,942 6,494,203 107,522 8,439,580 243,249 243,249	1,588,716 296,580 6,803,556 110,747 8,834,037 250,547 250,547	1,663,923 305,478 7,125,624 114,070 9,244,566 258,063 258,063	1,735,237 314,642 7,431,022 117,492 9,634,928 265,805 265,805	1,809,333 324,081 7,748,330 121,016 10,040,392 273,779 273,779	1,886,312 333,804 8,077,989 124,647 10,461,512 281,993 281,993	1,966,282 343,818 8,420,454 128,386 10,898,864 290,452 290,452
capital outlays					51,4	192,422 17,679,065 21,461 700,408 184,819 2,999,444 69,014 3,975,146 156,132 156,132	731,893 190,364 3,134,276 71,084 4,149,721 160,816 160,816	764,637 196,075 3,274,498 73,217 4,331,194 165,641 165,641	815,043 201,957 3,490,360 75,413 4,606,223 170,610 170,610	867,785 208,015 3,716,225 77,676 4,893,856 175,728 175,728	922,959 214,256 3,952,502 80,006 5,194,601 181,000 181,000	980,662 220,684 4,199,610 82,406 5,508,987 186,430 186,430	1,040,996 227,304 4,457,988 84,878 5,837,560 192,023 192,023	1,091,721 234,123 4,675,213 87,425 6,115,668 197,784 197,784	1,144,553 241,147 4,901,460 90,048 6,405,209 203,717 203,717	1,199,572 248,381 5,137,074 92,749 6,706,617 209,829 209,829	1,256,861 255,833 5,382,414 95,531 7,020,346 216,124 216,124	1,316,509 263,508 5,637,851 98,397 7,346,862 222,608 222,608	1,380,478 271,413 5,911,794 101,349 7,696,550 229,286 229,286	1,447,101 279,555 6,197,100 104,390 8,060,607 236,164 236,164	1,516,478 287,942 6,494,203 107,522 8,439,580 243,249 243,249	1,588,716 296,580 6,803,556 110,747 8,834,037 250,547 250,547	1,663,923 305,478 7,125,624 114,070 9,244,566 258,063 258,063	1,735,237 314,642 7,431,022 117,492 9,634,928 265,805 265,805	1,809,333 324,081 7,748,330 121,016 10,040,392 273,779 273,779	1,886,312 333,804 8,077,989 124,647 10,461,512 281,993 281,993	1,966,282 343,818 8,420,454 128,386 10,898,864 290,452 290,452
I capital outlays						192,422 17,679,065 21,461 700,408 184,819 2,999,444 69,014 3,975,146 156,132 156,132	731,893 190,364 3,134,276 71,084 4,149,721 160,816 160,816 (4,310,538)	764,637 196,075 3,274,498 73,217 4,331,194 165,641 165,641 (4,496,835)	815,043 201,957 3,490,360 75,413 4,606,223 170,610 170,610 (4,776,833)	867,785 208,015 3,716,225 77,676 4,893,856 175,728 175,728 (5,069,585)	922,959 214,256 3,952,502 80,006 5,194,601 181,000 (5,375,602)	980,662 220,684 4,199,610 82,406 5,508,987 186,430 186,430 (5,695,417)	1,040,996 227,304 4,457,988 84,878 5,837,560 192,023 192,023 (6,029,584)	1,091,721 234,123 4,675,213 87,425 6,115,668 197,784 197,784 (6,313,452)	1,144,553 241,147 4,901,460 90,048 6,405,209 203,717 203,717 (6,608,926)	1,199,572 248,381 5,137,074 92,749 6,706,617 209,829 209,829 (6,916,446)	1,256,861 255,833 5,382,414 95,531 7,020,346 216,124 216,124 (7,236,470)	1,316,509 263,508 5,637,851 98,397 7,346,862 222,608 222,608 222,608 (7,569,470)	1,380,478 271,413 5,911,794 101,349 7,696,550 229,286 229,286 (7,925,836)	1,447,101 279,555 6,197,100 104,390 8,060,607 236,164 236,164 (8,296,771)	1,516,478 287,942 6,494,203 107,522 8,439,580 243,249 243,249 (8,682,829)	1,588,716 296,580 6,803,556 110,747 8,834,037 250,547 250,547 (9,084,584)	1,663,923 305,478 7,125,624 114,070 9,244,566 258,063 258,063 (9,502,629)	1,735,237 314,642 7,431,022 117,492 9,634,928 265,805 265,805 (9,900,733)	1,809,333 324,081 7,748,330 121,016 10,040,392 273,779 273,779 (10,314,171)	1,886,312 333,804 8,077,989 124,647 10,461,512 281,993 281,993 (10,743,505) (1,966,282 343,818 8,420,454 128,386 10,898,864 290,452 290,452 11,189,316)

RP-5 Odor Control

Inland Empire Utilities Agency



Alternatives Net Present Value Analysis

Agency:	Inland Empire Utilities Agency		Sensitivi	ty Adjustm	ents (%)		Results (\$000s)	
Project/Problem:		Risk Premium	Benefits	Capital Costs	Running Costs	Capital Cost	20-year NPV	Difference from highest NPV
Alternative 1 Alternative 2 Alternative 3	Biofilter Bioscrubber+ Activated Carbon Activated Carbon					\$4,792,919 \$6,333,500 \$2,995,574	(\$13,200,928) (\$11,956,550) (\$6,593,093)	(\$5,363,458)
Year of analysis:	2016							

Escalation rate: 3.00% Discount rate: 2.00%

From Summary Sh	eet:		Risk adjustn	nents (+/- per	rcent):										Inland Em	pire Utilitie	s Agency														
	Year of analysis	2016]	Benefits	· ·	7											,														
	Escalation rate	3.00%		Capital costs										Life C	ycle Alterna	ative Cost /	Analysis (\$	000s)													
	Discount rate	2.00%		unning costs												ative 1 - Bio		···· ,													
	Г															Year															
	-	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
xpressed in 2016 d	ollars, unescalated																														
apital Outlays		4 700 040																													
Other Other		4,792,919																													
Other																															
Other																															
Other																															
Other		4 702 040																													
Total capital outlay	5 [4,792,919																													
enefits: Other																															
Other																															
Other																															
Total benefits																															
nnual Running Costs																															
Other									177,475	185,461	193,807	202,528	211,642	221,166	231,118	241,519	252,387	263,744	275,613	288,015	300,976	314,520	328,673	343,464	358,920	375,071	391,949	409,587	428,018	447,279	467,407
Other Other																															
Other																															
Other																															
Other																															
Other																															
Other Total running costs									177,475	185,461	193,807	202 529	211,642	221,166	024 440	244 540	252 297	262 744	075 642	299.015	200.076	314,520	200 672	242 464	259.020	275 074	201.040	409,587	428,018	447,279	467 407
	L								177,475	165,401	193,807	202,528	211,042	221,100	231,118	241,019	252,387	203,744	275,013	200,015	300,970	314,520	328,073	343,404	358,920	375,071	391,949	409,567	420,010	441,219	407,407
&R Costs: Other																															
Other																															
Other																															
Other																															
Other																															
Total refurbishmen	ls [1									(000 000)				(000.070)	(0.1.1.000)		(0.10.10.1)	(0.50, 0.00)						
let Benefit/(cost)	L	(4,792,919))						(177,475)) (185,461)	(193,807)	(202,528) (211,642)	(221,166)	(231,118)	(241,519)	(252,387)	(263,744)	(275,613)	(288,015)	(300,976)	(314,520)	(328,673)	(343,464)	(358,920)	(375,071)	(391,949)	(409,587)	(428,018)	(447,279)	(467,407)
xpressed in escalat			-																												
	ed dollars with sen	isitivity adjustme	nts																												
apital Outlays Other	Г	4,792,919	1							1			1																		
Other		4,752,515																													
Other																															
Other																															
Other																															
Other Total capital outlays	-	4,792,919																													
	s ا	4,732,313								1			1																		
Benefits: Other	Г																														
Other																															
Other																															
Total benefits																															
nnual Running Costs	: 	·		1	1		1				1	1							1	,,							1				
Other									218,272	234,937	252,874	272,181	292,962	315,330	339,405	365,319	393,211	423,232	455,546	490,327	527,763	568,058	611,429	658,112	708,359	762,442	820,654	883,311	950,752	1,023,342	1,101,474
Other Other																															
Other																															
Other																															
Other																															
Other																															
Other	-								040.070	024.027	050.074	070 404	202.062	245 220	220 405	265 240	202 044	402.020	455 546	400 207	507 762	560.050	644 400	650 440	700.250	760 440	000 654	002 244	050 750	4 002 240	4 404 474
Total running costs	· L	L			1	1	1		218,272	234,937	202,8/4	272,181	292,962	315,330	ა ა 9 ,405	300,319	393,211	423,232	400,046	490,327	021,103	508,058	011,429	008,112	108,359	/ 02,442	820,054	883,311	900,752	1,023,342	1,101,4/4
&R Costs: Other	Г															I						I									
Other																															
Other																															
Other																															
Other	_	L																													
Total refurbishmen	-								1																						
let escalated benefit/	(cost)	(4,792,919)						(218,272)) (234,937)	(252,874)	(272,181) (292,962)	(315,330)	(339,405)	(365,319)	(393,211)	(423,232)	(455,546)	(490,327)	(527,763)	(568,058)	(611,429)	(658,112)	(708,359)	(762,442)	(820,654)	(883,311)	(950,752)	(1,023,342)	(1,101,474)
ife cycle cost analy	sis																														
Vs in 2016	[(4,792,919))						(190,018)) (200,516)	(211,594)	(223,283)) (235,618)	(248,635)	(262,371)	(276,866)	(292,161)	(308,302)	(325,334)	(343,307)	(362,273)	(382,287)	(403,406)	(425,693)	(449,210)	(474,027)	(500,214)	(527,849)	(557,010)	(587,782)	(620,254)
IPV as of 2016	Γ	(13,200,928))																												

2037	2038	2039	2040	2041	2042	2043	2044	2045
328,673	343,464	358,920	375,071	391,949	409,587	428,018	447,279	467,407
328,673	343,464	358,920	375,071	391,949	409,587	428,018	447,279	467,407
(328,673)	(343,464)	(358,920)	(375,071)	(391,949)	(409,587)	(428,018)	(447,279)	(467,407)

611,429	658,112	708,359	762,442	820,654	883,311	950,752	1,023,342	1,101,474
		,						
611,429	658,112	708,359	762,442	820,654	883,311	950,752	4 002 240	4 404 474
011,429	008,112	708,359	102,442	820,004	883,311	900,702	1,023,342	1,101,474
	1							

From Summary Sheet:		Risk adjustme	ents (+/- per	cent):	_									Inland Err	npire Utilitie	es Agency						
Year of analysis	2016		Benefits																			
Escalation rate	3.00%	1	apital costs													Analysis (\$						
Discount rate	2.00%	Rur	nning costs										Alterna	ative 2 - Bio	scrubber+	Activated	Carbon					
				1	1	1	1					I	1	1	Year		1			1		
xpressed in 2016 dollars, unescalated	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2
Capital Outlays																						
Other	6,333,500																					
Other																						
Other Other																						
Other																						
Other																						
Other Total capital outlays	6,333,500																					
Senefits:	0,000,000	1 1																				
Other																						
Other																						
Other Total benefits																						
Annual Running Costs:		I																				
Other								118,690	124,031	129,613	135,445	141,540	147,910	154,566	161,521	168,790	176,385	184,322	192,617	201,285	210,343	2
Other																						
Other																						
Other Other																						
Other																						
Other																						
Other Total running costs								118,690	124,031	129,613	135,445	141,540	147,910	154,566	161,521	168,790	176,385	184,322	192,617	201,285	210,343	2
&R Costs:								,			,	,	,	,	,			,	,		2.0,010	
Other																						
Other																						
Other Other																						
Other																						
Total refurbishments																						
let Benefit/(cost)	(6,333,500)							(118,690)	(124,031)	(129,613)	(135,445)	(141,540)	(147,910)	(154,566)	(161,521)	(168,790)	(176,385)	(184,322)	(192,617)	(201,285)	(210,343)	(2
xpressed in escalated dollars with se	noitivity odivotmor																					
Capital Outlays		115																				
Other	6,333,500																					
Other																						
Other																						
Other Other																						
Other																						
Other	0.000.500																					
Total capital outlays	6,333,500																					
Benefits: Other																						
Other																						
Other																						
Total benefits																						
nnual Running Costs: Other								145,974	157,119	169,115	182,027	195,925	210,884	226,985	244,315	262,969	283,046	304,657	327,917	352,954	379,902	4
Other								,	,	,	,	,	,	,	,	, í	,	,	·	,	,	
Other																						
Other Other																						
Other																						
Other																						
Other Total running costs								145,974	157,119	169,115	182,027	195,925	210,884	226,985	244,315	262,969	283,046	304,657	327,917	352,954	379,902	4
&R Costs:		1						140,014	107,110	105,110	102,021	100,020	210,004	220,000	244,010	202,505	200,040	004,001	021,011	002,004	010,002	
Other																						
Other																						
Other Other																						
Other																						
Total refurbishments																						
let escalated benefit/(cost)	(6,333,500)							(145,974)	(157,119)	(169,115)	(182,027)	(195,925)	(210,884)	(226,985)	(244,315)	(262,969)	(283,046)	(304,657)	(327,917)	(352,954)	(379,902)	(4
ife cycle cost analysis	(2.005	,						(107.5	(40) (· · · · '	(1.10		(100	(175 · · · ·	(105.15)	//05	(000.171)	(0.17.5	(000 55 5	(0/0 /	(055)	
PVs in 2016	(6,333,500)						1	(127,079)	(134,100)	(141,508)	(149,326)	(157,575)	(166,281)	(175,467)	(185,160)	(195,390)	(206,184)	(217,575)	(229,594)	(242,278)	(255,663)	(2
IPV as of 2016	(11,956,550)]																				

2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
			-	-					
210,343	219,808	229,699	240,036	250,837	262,125	273,921	286,247	299,128	312,589
210,040	210,000	223,000	240,000	200,001	202,120	210,321	200,247	233,120	012,000
210,343	219,808	229,699	240,036	250,837	262,125	273,921	286,247	299,128	312,589
_ 10,040						213,321		200,120	
210,343)	(219,808)	(229,699)	(240,036)	(250,837)	(262,125)	(273,921)	(286,247)	<mark>(299,128)</mark>	(312,589)
379,902	408,908	440 400	473,731	509,901	548,832	590,735	635,838	604 204	736,636
379,902	400,900	440,128	4/3,/31	509,901	040,03Z	590,755	035,656	684,384	730,030
370 002	409 009	440 120	472 724	500 001	549 932	500 735	635 030	684 304	736 636
379,902	408,908	440,128	473,731	509,901	548,832	590,735	635,838	684,384	736,636
379,902)	(408,908)	(440,128)	(473,731)	(509,901)	(548,832)	(590,735)	(635,838)	(684,384)	(736,636)
255,663)	(269,787)	(284,692)	(300,420)	(317,016)	(334,530)	(353,011)	(372,513)	(393,093)	(414,809)

From Summary Sheet: Year of analysis		Risk adjustme	nts (+/- pero Benefits	cent):	7										pire Utilities															
Escalation rate Discount rate			pital costs ning costs												ative Cost A 3 - Activate	ed Carbon														
	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	Yea 2030	ar 2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
expressed in 2016 dollars, unescal		2017	2010	2013	2020	2021	2022	2020	2024	2020	2020	2021	2020	2023	2000	2001	2002	2000	2004	2000	2000	2007	2000	2003	2040	2041	2042	2040	2044	2040
Capital Outlays	0.005.574																													
Other Other	2,995,574																													
Other																														
Other Other																														
Other																														
Total capital outlays	2,995,574																													
Benefits: Other																														
Other																														
Other Total benefits																														
Annual Running Costs:																														
Other								75,936	79,353	82,924	86,655	90,555	94,630	98,888	103,338	107,988	112,848	117,926	123,233	128,778	134,573	140,629	146,957	153,570	160,481	167,703	175,249	183,135	191,376	199,988
Other Other Other																														
Other																														
Other Other																														
Other Other																														
Other																														
Total running costs								75,936	79,353	82,924	86,655	90,555	94,630	98,888	103,338	107,988	112,848	117,926	123,233	128,778	134,573	140,629	146,957	153,570	160,481	167,703	175,249	183,135	191,376	199,988
&R Costs: Other																														
Other Other																														
Other Other																														
Other																														
Total refurbishments																														
let Benefit/(cost)	(2,995,574)							(75,936)	(79,353)	(82,924)	(86,655)	(90,555)	(94,630)	(98,888)	(103,338)	(107,988)	(112,848)	(117,926)	(123,233)	(128,778)	(134,573)	(140,629)	(146,957)	(153,570)	(160,481)	(167,703)	(175,249)	(183,135)	(191,376)	(199,988)
xpressed in escalated dollars with	n sensitivity ad	liustments																												
Capital Outlays																														
Other	2,995,574																													
Other Other																														
Other																														
Other Other																														
Total capital outlays	2,995,574																													
Benefits:																														
Other Other																														
Other																														
Total benefits																														
Annual Running Costs: Other								93,391	100,522	108,197	116,457	125,349	134,919	145,221	156,308	168,242	181,088	194,914	209,795	225,813	243,054	261,611	281,585	303,084	326,225	351,132	377,941	406,797	137 855	471,286
Other								55,551	100,322	100,157	110,457	125,545	154,515	143,221	150,500	100,242	101,000	134,314	203,135	223,013	243,034	201,011	201,505	505,004	520,225	331,132	511,541	400,757	457,055	471,200
Other																														
Other Other																														
Other																														
Other Other																														
Total running costs								93,391	100,522	108,197	116,457	125,349	134,919	145,221	156,308	168,242	181,088	194,914	209,795	225,813	243,054	261,611	281,585	303,084	326,225	351,132	377,941	406,797	437,855	471,286
&R Costs:																														
Other Other																														
Other																														
Other																														
Other Total refurbishments							-																							
let escalated benefit/(cost)	(2,995,574)					1	<u> </u>	(93,391)	(100,522)	(108,197)	(116,457)	(125,349)	(134,919)	(145,221)	(156,308)	(168,242)	(181,088)	(194,914)	(209,795)	(225,813)	(243,054)	(261,611)	(281,585)	(303,084)	(326,225)	(351,132)	(377,941)	(406,797)	(437,855)	(471,286)
· ·		- I	· · · · · ·	-																										
ife cycle cost analysis																														
Vs in 2016	(2,995,574)	-						(81,303)	(85,794)	(90,534)	(95,536)	(100,814)	(106,383)	(112,260)	(118,462)	(125,006)	(131,912)	(139,200)	(146,890)	(155,005)	(163,568)	(172,605)	(182,140)	(192,203)	(202,821)	(214,026)	(225,850)	(238,327)	(251,493)	(265,387)
IPV as of 2016	(6,593,093)																													

I							ll	1
261,611	281,585	303,084	326,225	351,132	377,941	406,797	437,855	471,286
261,611	281,585	303,084	326,225	351,132	377,941	406,797	437,855	471,286
261,611	281,585	303,084	326,225	351,132	377,941	406,797	437,855	471,286
261,611	281,585	303,084	326,225	351,132	377,941	406,797	437,855	471,286
261,611	281,585	303,084	326,225	351,132	377,941	406,797	437,855	471,286
261,611	281,585	303,084	326,225	351,132	377,941	406,797	437,855	471,286
261,611	281,585	303,084	326,225	351,132	377,941	406,797	437,855	471,286
261,611		303,084 (303,084)	326,225 (326,225)		377,941 (377,941)			
				(351,132)		(406,797)	(437,855)	

	140,629	146,957	153,570	160,481	167,703	175,249	183,135	191,376	199,988
(140,629) (146,957) (153,570) (160,481) (167,703) (175,249) (183,135) (191,376) (199,988	(140,629)	(146,957)	(153,570)	(160,481)	(167,703)	(175,249)	(183,135)	(191,376)	(199,988)



Inland Empire Utilities Agency 149055 - IEUA - RP5 - Waste Gas Alternatives Net Present Value Analysis

Agency:	Inland Empire Utilities Agency		Sensitivi	ty Adjustm	ents (%)	Res	sults
Project/Problem:	149055 - IEUA - RP5 - Waste Gas	Risk Premium	Benefits	Capital Costs	Running Costs	Capital Cost	NPV
Alternative 1A	Flare Combined Streams Duplex Treatment					\$7,160,000	(\$13,436,746)
Alternative 2	Flare and Thermal Oxidizer					\$8,030,000	(\$13,626,805)
Alternative 3	Flare Separate Streams					\$6,370,000	(\$11,644,886)
Alternative 1B	Flare Combined Streams Merged Treatment					\$4,630,000	(\$6,920,842)

Year of analysis:	2016
Escalation rate:	3.00%
Discount rate:	2.00%

Make entries in yellow cells only.

F		Risk adjust	ments (+/- perc	cent):									ies Agen														
Year of analysis	2016		Benefits										- Waste														
Escalation rate	3.00%		Capital costs										t Analys														
Discount rate	2.00%	F	lunning costs						Alternat	tive 1A -	Flare Co	mbined S	Streams [ouplex T	reatment												
Г														Year													
-	2016	2017	2018	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
ed in 2016 dollars, unescalated		•							•			•			•												
Dutlays		-													-												
capital				7,160,000																							
capital outlays				7,160,000																							
			1	, ,						1			1											1			
penefits																											
unning Costs:											(== -												. ==	/			
Gas Electrical Demand eatment Media Usage					4,751 31,772	4,751 32,984	4,751 34,249	4,751 35,439	4,751 36,630	4,751 37,821	4,751 39,012	4,751 40,202	4,751 40,930	4,751 41,657	4,751 42,384	4,751 43,111	4,751 43,838	4,751 44,628	4,751 45,419	4,751 46,209	4,751 46,999	4,751 47,790	4,751 48,390	4,751 48,991	4,751 49,592	4,751 50,192	4,751 50,793
Gas Operating Labor					31,772	32,984	34,249 35,064	35,439	36,630	37,821	39,012	40,202 35,064	40,930 35,064	41,657 35,064	42,384 35,064	43,111 35,064	43,838 35,064	44,628 35,064	45,419 35,064	46,209 35,064	46,999 35,064	47,790 35,064	48,390 35,064	48,991 35,064	49,592 35,064	50,192 35,064	50,793 35,064
Gas (Digester gas)					93,000	93,000	95,000	97,000	99,000	104,000		109,000		113,000	115,000	115,000	118,000	120,000	122,000	124,000	127,000	129,000	131,000	136,000	138,000	142,000	145,000
running costs					164,587	165,799	169,064	172,254	175,445	181,636	184,827	189,018	191,745	194,472	197,199	197,926	201,653	204,443	207,234	210,024	213,815	216,605	219,206	224,806	227,407	232,008	235,608
ts:				1	12,411	12.411	40.444	40.444	40 444	40 444	40.444	40 444	40.444	40.444	40.444	40.444	40 444	40.444	40.444	40.444	40 444	40.444	40.444	40.444	40.444	10 111	40 444
						12411	12.411	12.411	12.411	12.411	12.411	12,411	12,411	12.411	12.411	12,411	12,411	12,411	12,411	12,411	12,411	12,411	12,411	12,411	12,411	12,411	12,411
				1	12,711	,	,	,	,	,,	, i	, i i	, i	,	, í												
refurbishments					12,411	12,411	12,411	,	,	,	12,411	12,411		12,411	12,411	12,411	12,411	12,411	12,411	12,411	12,411	12,411	12,411	12,411	12,411	12,411	12,411
refurbishments efit/(cost)	sitivity adjus	stments		(7,160,000)	12,411	12,411	12,411	12,411	12,411	12,411			12,411	12,411		-			-			-					
refurbishments efit/(cost) sed in escalated dollars with sens	sitivity adjus	tments		(7,160,000)	12,411	12,411	12,411	12,411	12,411	12,411			12,411	12,411		-			-			-					
l refurbishments efit/(cost) sed in escalated dollars with sen Outlays Capital	sitivity adjus	stments			12,411	12,411	12,411	12,411	12,411	12,411			12,411	12,411		-			-			-					
refurbishments efit/(cost) sed in escalated dollars with sen: Dutlays Capital	sitivity adjus	tments		8,549,414	12,411	12,411	12,411	12,411	12,411	12,411			12,411	12,411		-			-			-					
refurbishments efit/(cost) ced in escalated dollars with sen Dutlays Capital capital outlays	sitivity adjus	tments			12,411	12,411	12,411	12,411	12,411	12,411			12,411	12,411		-			-			-					
refurbishments efit/(cost) ced in escalated dollars with sen Dutlays Capital capital outlays	sitivity adjus	itments		8,549,414	12,411	12,411	12,411	12,411	12,411	12,411			12,411	12,411		-			-			-					
refurbishments efit/(cost) sed in escalated dollars with sen Outlays Capital capital outlays	sitivity adjus	stments		8,549,414	12,411	12,411	12,411	12,411	12,411	12,411			12,411	12,411		-			-			-					
I refurbishments lefit/(cost) Sed in escalated dollars with sen: Outlays Capital I capital outlays	sitivity adjus	stments		8,549,414	12,411	12,411	12,411	12,411	12,411	12,411			12,411	12,411		-			-			-					
I refurbishments Lefit/(cost) sed in escalated dollars with sense Outlays Capital I capital outlays Lisenefits Running Costs:	sitivity adjus	stments		8,549,414	12,411	12,411	12,411	12,411	12,411	12,411			12,411	12,411		-			-			-					
I refurbishments effit/(cost) sed in escalated dollars with sens Outlays Capital I capital outlays I capital outlays I benefits Running Costs: Gas Electrical Demand	sitivity adjus	stments		8,549,414	<u>12,411</u> (176,998))	<u>12,411</u> (178,210)	6,199	6,385	6,576	6,774	6,977	(201,428)	12,411 (204,156)	<u>12,411</u> (206,883)	7,853	(210,337)	8,331	8,581	(219,645) 8,838	9,103	9,376	(229,016) 9,658	9,947	(237,217)	(239,818)	(244,418)	(248,019)
I refurbishments effit/(cost) sed in escalated dollars with sens Outlays Capital I capital outlays S: I benefits Running Costs: Gas Electrical Demand Freatment Media Usage	sitivity adjus	stments		8,549,414	<u>12,411</u> (176,998)) (176,998) (176,9	12,411 (178,210)	6,199 44,687	6,385 47,627	6,576 50,705	6,774 53,924	6,977 57,290	(201,428) (201,428) 7,186 60,810	12,411 (204,156) 7,402 63,767	12,411 (206,883)	7,853 70,054	(210,337) (210,337) (20,037) ((214,064) 8,331 76,870	(216,854) (216,854) 8,581 80,604	(219,645) (219,645) 8,838 8,838 84,492	9,103 88,541	(226,225) 9,376 92,758	9,658 97,147	(231,616) 9,947 101,319	(237,217) (237,217)	(239,818) (239,818) (10,553 (10,553) (10,553) (10,158)	(244,418) (244,4	(248,019) (248,019) (11,196 (119,697)
I refurbishments effit/(cost) sed in escalated dollars with sense Outlays Capital I capital outlays S: I benefits Running Costs: Gas Electrical Demand Freatment Media Usage Gas Operating Labor	sitivity adjus	stments		8,549,414	12,411 (176,998)) (176,998	12,411 (178,210)	6,199 44,687 45,751	6,385 47,627 47,123	6,576 50,705 48,537	6,774 53,924 49,993	6,977 57,290 51,493	(201,428) (201,428) 7,186 60,810 53,038	12,411 (204,156) (204,156) 7,402 63,767 54,629	12,411 (206,883) (206,883)	7,853 70,054 57,956	(210,337) (210,337) 8,088 73,394 59,694	8,331 76,870 61,485	8,581 80,604 63,330	(219,645) (219,645) 8,838 84,492 65,230	9,103 88,541 67,186	(226,225) 9,376 92,758 69,202	9,658 97,147 71,278	(231,616) 9,947 101,319 73,416	(237,217) (237,217) 10,246 105,654 75,619	(239,818) (239,818) (10,553 (10,553) (10,553) (10,158) (77,888)	(244,418) (244,418) (0,870 (10,870 (114,837 (80,224)	(248,019) (248,019)
I refurbishments efit/(cost) (ced in escalated dollars with sen: Outlays Capital (capital outlays capital outlays c benefits Running Costs: e Gas Electrical Demand reatment Media Usage e Gas Operating Labor Gas (Digester gas)	sitivity adjus	stments		8,549,414	<u>12,411</u> (176,998)) (176,998) (176,9	<u>12,411</u> (178,210) 6,018 41,783	6,199 44,687	6,385 47,627	6,576 50,705 48,537	6,774 53,924 49,993	6,977 57,290	(201,428) (201,428) 7,186 60,810	12,411 (204,156) 7,402 63,767	12,411 (206,883)	7,853 70,054	(210,337) (210,3	(214,064) 8,331 76,870	(216,854) (216,854) 8,581 80,604	(219,645) (219,645) 8,838 8,838 84,492	9,103 88,541	(226,225) 9,376 92,758	9,658 97,147	(231,616) 9,947 101,319	(237,217) (237,217)	(239,818) (239,818) (10,553 (10,553) (10,553) (10,158)	(244,418) (244,4	(248,019) (248,019) (11,196 (119,697)
efit/(cost)	sitivity adjus	itments		8,549,414 8,549,414	12,411 (176,998)) (176,998)) (176,998) (176,99	12,411 (178,210) (178,210) 6,018 41,783 44,418 117,810	6,199 44,687 45,751 123,953	6,385 47,627 47,123 130,360	6,576 50,705 48,537 137,039	6,774 6,774 53,924 49,993 148,279	6,977 57,290 51,493 155,665	7,186 60,810 53,038 164,872	12,411 (204,156) (204,156) 7,402 63,767 54,629 172,934	12,411 (206,883)	7,853 70,054 57,956 190,077	8,088 73,394 59,694 195,780	8,331 76,870 61,485 206,914	8,581 80,604 63,330 216,733	8,838 84,492 65,230 226,956	9,103 88,541 67,186 237,597	9,376 92,758 69,202 250,645	9,658 97,147 71,278 262,230	9,947 101,319 73,416 274,285	(237,217) (237,217) 10,246 105,654 75,619 293,296	(239,818) (239,818) 10,553 110,158 77,888 306,538	(244,418) (244,418) 10,870 114,837 80,224 324,886	(248,019) (248,019) 11,196 119,697 82,631 341,702
efit/(cost)	sitivity adjus	itments		8,549,414 8,549,414	12,411 (176,998)) (176,998)) (176,998) (176,99	12,411 (178,210) (178,210) 6,018 41,783 44,418 117,810	6,199 44,687 45,751 123,953	6,385 47,627 47,123 130,360	6,576 50,705 48,537 137,039	6,774 6,774 53,924 49,993 148,279	6,977 57,290 51,493 155,665	7,186 60,810 53,038 164,872	12,411 (204,156) (204,156) 7,402 63,767 54,629	12,411 (206,883)	7,853 70,054 57,956 190,077	8,088 73,394 59,694 195,780	8,331 76,870 61,485 206,914	8,581 80,604 63,330 216,733	8,838 84,492 65,230 226,956	9,103 88,541 67,186 237,597	9,376 92,758 69,202 250,645	9,658 97,147 71,278 262,230	9,947 101,319 73,416 274,285	(237,217) (237,217) 10,246 105,654 75,619 293,296	(239,818) (239,818) 10,553 110,158 77,888 306,538	(244,418) (244,418) 10,870 114,837 80,224 324,886	(248,019) (248,019) 11,196 119,697 82,631 341,702
I refurbishments hefit/(cost) sed in escalated dollars with sense Outlays Capital I capital outlays I capital outlays I benefits Running Costs: Gas Electrical Demand Freatment Media Usage Gas Operating Labor I Gas (Digester gas) I running costs Dists:	sitivity adjus	itments		8,549,414 8,549,414	12,411 (176,998)) (176,998)) (176,998) (176,99	12,411 (178,210) (178,210) 6,018 41,783 44,418 117,810 210,029	6,199 44,687 45,751 123,953 220,590	12,411 (184,665)	6,576 50,705 48,537 137,039 242,857	6,774 6,774 53,924 49,993 148,279 258,969	6,977 57,290 51,493 155,665 271,424	(201,428) (201,428) 7,186 60,810 53,038 164,872 285,906	12,411 (204,156) (204,156) 7,402 63,767 54,629 172,934 298,732	12,411 (206,883) (206,883) 7,624 66,847 56,268 181,332 312,070	7,853 70,054 57,956 190,077 325,940	(210,337) (210,337) 8,088 73,394 59,694 195,780 336,956	8,331 76,870 61,485 206,914 353,600	(216,854) (216,854) 8,581 80,604 63,330 216,733 369,248	(219,645) (219,645) 8,838 84,492 65,230 226,956 385,516	(222,435) 9,103 88,541 67,186 237,597 402,428	(226,225) 9,376 92,758 69,202 250,645 421,981	(229,016) 9,658 97,147 71,278 262,230 440,313	(231,616) (231,616) 9,947 101,319 73,416 274,285 458,968	(237,217) (237,217) 10,246 105,654 75,619 293,296 484,815	(239,818) (239,818) 10,553 110,158 77,888 306,538 505,136	(244,418) 10,870 114,837 80,224 324,886 530,816	(248,019) (248,019) (11,196 (119,697 (82,631) (341,702) (555,226)
I refurbishments I refurbishments I refurbishments I refit/(cost) Sed in escalated dollars with sense Outlays Capital I capital outlays I running costs I capital outlays I c	sitivity adjus	itments		8,549,414 8,549,414	12,411 (176,998)) (176,998)) (176,998) (176,99	12,411 (178,210) (178,210) 6,018 41,783 44,418 117,810	6,199 44,687 45,751 123,953 220,590	12,411 (184,665)	6,576 50,705 48,537 137,039 242,857	6,774 6,774 53,924 49,993 148,279 258,969	6,977 57,290 51,493 155,665 271,424	(201,428) (201,428) 7,186 60,810 53,038 164,872 285,906	12,411 (204,156) (204,156) 7,402 63,767 54,629 172,934 298,732	12,411 (206,883)	7,853 70,054 57,956 190,077 325,940	8,088 73,394 59,694 195,780	8,331 76,870 61,485 206,914 353,600	(216,854) (216,854) 8,581 80,604 63,330 216,733 369,248	(219,645) (219,645) 8,838 84,492 65,230 226,956 385,516	9,103 88,541 67,186 237,597	(226,225) 9,376 92,758 69,202 250,645 421,981	9,658 97,147 71,278 262,230	9,947 101,319 73,416 274,285	(237,217) (237,217) 10,246 105,654 75,619 293,296	(239,818) (239,818) 10,553 110,158 77,888 306,538 505,136	(244,418) 10,870 114,837 80,224 324,886 530,816	(248,019) (248,019) 11,196 119,697 82,631 341,702
I refurbishments lefit/(cost) sed in escalated dollars with sense Outlays Capital I capital outlays : I benefits Running Costs: 2 Gas Electrical Demand Treatment Media Usage 2 Gas Operating Labor : Gas (Digester gas) I running costs Dists:	sitivity adjus	stments		8,549,414 8,549,414	12,411 (176,998)) (176,998)) (176,998) (176,99	12,411 (178,210) (178,210) 6,018 41,783 44,418 117,810 210,029 15,722	6,199 44,687 45,751 123,953 220,590 16,193	6,385 47,627 47,123 130,360 231,495	6,576 50,705 48,537 137,039 242,857	6,774 53,924 49,993 148,279 258,969 17,695	6,977 57,290 51,493 155,665 271,424 18,226	7,186 60,810 53,038 164,872 285,906	12,411 (204,156)	12,411 (206,883) (206,883) 7,624 66,847 56,268 181,332 312,070 19,916	7,853 70,054 57,956 190,077 325,940 20,513	(210,337) (210,337) 8,088 73,394 59,694 195,780 336,956 21,129	(214,064) (214,064) 8,331 76,870 61,485 206,914 353,600 21,763	(216,854) (216,854) 8,581 80,604 63,330 216,733 369,248 22,415	(219,645) (219,645) 8,838 84,492 65,230 226,956 385,516 23,088	9,103 88,541 67,186 237,597 402,428 23,781	(226,225) 9,376 92,758 69,202 250,645 421,981 24,494	(229,016) 9,658 97,147 71,278 262,230 440,313 25,229	(231,616) 9,947 101,319 73,416 274,285 458,968 25,986	(237,217) (237,217) 10,246 105,654 75,619 293,296 484,815 26,765	(239,818) (239,818) 10,553 110,158 77,888 306,538 505,136 27,568	(244,418) (244,418) 10,870 114,837 80,224 324,886 530,816 28,395	(248,019) (248,019) 11,196 119,697 82,631 341,702 555,226 29,247
refurbishments efit/(cost) (Sed in escalated dollars with sense Dutlays Capital capital outlays : benefits Running Costs: Gas Electrical Demand reatment Media Usage Gas Operating Labor Gas (Digester gas) running costs sts:	sitivity adjus	stments		8,549,414 8,549,414	12,411 (176,998)) (176,998	12,411 (178,210) (178,210) 6,018 41,783 44,418 117,810 210,029 15,722 15,722	6,199 44,687 45,751 123,953 220,590 16,193 16,193	12,411 (184,665)	12,411 12,411 (187,856) (187,856) 6,576 50,705 48,537 137,039 242,857 17,180 17,180	12,411 (194,047)	6,977 57,290 51,493 155,665 271,424 18,226 18,226	7,186 60,810 53,038 164,872 285,906 18,773 18,773	12,411 (204,156)	12,411 (206,883) (206,883) 7,624 66,847 56,268 181,332 312,070 19,916 19,916	7,853 70,054 57,956 190,077 325,940 20,513 20,513	(210,337) (210,337) 8,088 73,394 59,694 195,780 336,956 21,129 21,129 21,129	(214,064) (214,064) 8,331 76,870 61,485 206,914 353,600 21,763 21,763	(216,854) (216,854) 8,581 80,604 63,330 216,733 369,248 22,415 22,415	(219,645) (219,645) 8,838 84,492 65,230 226,956 385,516 23,088 23,088	9,103 88,541 67,186 237,597 402,428 23,781 23,781	(226,225) 9,376 92,758 69,202 250,645 421,981 24,494 24,494	(229,016) 9,658 97,147 71,278 262,230 440,313 25,229 25,229	(231,616) 9,947 101,319 73,416 274,285 458,968 25,986 25,986	(237,217) (237,217) 10,246 105,654 75,619 293,296 484,815 26,765 26,765	(239,818) (239,818) 10,553 110,158 77,888 306,538 505,136 27,568 27,568	(244,418) (244,418) 10,870 114,837 80,224 324,886 530,816 28,395 28,395	(248,019) (248,019) 11,196 119,697 82,631 341,702 555,226 29,247 29,247 29,247

PVs in 2016

(13,436,746)

NPV as of 2016

(7,591,635) (189,508) (192,676) (198,129) (203,590) (209,138) (218,148) (223,909) (230,908) (236,329) (241,834) (247,424) (250,716) (257,660) (263,578) (269,587) (275,688) (283,135) (289,437) (295,594) (305,710) (312,091) (321,197) (329,124)

From Summary Sheet:		Risk adjustments (+/- percent):	Inland Empire Utilities Agency
Year of analysis	2016	Benefits	149055 - IEUA - RP5 - Waste Gas
Escalation rate	3.00%	Capital costs	Life Cycle Alternative Cost Analysis (\$000s)
Discount rate	2.00%	Running costs	Alternative 2 - Flare and Thermal Oxidizer

		2017 2018	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
in 2016 dollars, unescalated	2016																									
ays																										
ital			8.030.000																							
			0,000,000																							
pital outlays			8,030,000																							
· · ·																										
nefits																										
ining Costs:		•																								
s Electrical Demand				12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266	12,266
tment Media Usage				31,477	32,677	33,930	35,110	36,289	37,469	38,649	39,829	40,549	41,269	41,990	42,710	43,430	44,213	44,996	45,779	46,562	47,345	47,940	48,536	49,131	49,726	50,321
is Operating Labor				70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128	70,128
s (Natural gas)				12,267	12,267	12,267	12,267	12,267	12,267	12.267	12,267	12,267	12,267	12.267	12,267	12,267	12,267	12,267	12,267	12,267	12,267	12,267	12,267	12,267	12,267	12,267
Treatment O&M				35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000	35,000
nning costs				161,138	162,339	163,591	164,771	165,951	167,131	168,310	169,490	170,210	170,931	171,651	172,372	173,092	173,875	174,658	175,441	176,224	177,007	177,602	178,197	178,792	179,387	179,982
:																										
				13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911
										10.011	40.044	10.011	10.011	10.011	40.044	13.911	13.911	13.911	13.911	13.911	13.911	13.911	13.911	13.911	13.911	13,911
furbishments				13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911	13,911										
efurbishments [sitivity adjust	tments	(8,030,000)		13,911 (176,250)	13,911 (177,502)	13,911 (178,682)	<u>13,911</u> (179,862)	13,911 (181,042)	<u>13,911</u> (182,221)	- 1-		<u>13,911</u> (184,842)	13,911 (185,562)	(186,282)	(187,003)	(187,786)	(188,569)	(189,352)	(190,135)	- / -	- 1.	(192,108)	(192,703)	(193,298)	
it/(cost) d in escalated dollars with sensi utlays	sitivity adjust	tments			- 1-	- /-	,	- 7 -	- / -	- /-	- 1-		- 1-	- / -	- 7 -		- /-	- / -	- 1 -		- 7 -	- 1.	- 7 -	(192,703)	- / -	
t/(cost) d in escalated dollars with sensi	sitivity adjust	tments	(8,030,000) 9,588,240		- 1-	- /-	,	- 7 -	- / -	- /-	- 1-		- 1-	- / -	- 7 -		- /-	- / -	- 1 -		- 7 -	- 1.	- 7 -	(192,703)	- / -	
it/(cost) d in escalated dollars with sensi utlays	sitivity adjust	tments			- 1-	- /-	,	- 7 -	- / -	- /-	- 1-		- 1-	- / -	- 7 -		- /-	- / -	- 1 -		- 7 -	- 1.	- 7 -	(192,703)	- / -	
t/(cost) d in escalated dollars with sensi tlays pital	sitivity adjust	tments	9,588,240		- 1-	- /-	,	- 7 -	- / -	- /-	- 1-		- 1-	- / -	- 7 -		- /-	- / -	- 1 -		- 7 -	- 1.	- 7 -	(192,703)	- / -	
t/(cost)	sitivity adjust	tments			- 1-	- /-	,	- 7 -	- / -	- /-	- 1-		- 1-	- / -	- 7 -		- /-	- / -	- 1 -		- 7 -	- 1.	- 7 -	(192,703)	- / -	
t/(cost) d in escalated dollars with sensi tlays	sitivity adjust	tments	9,588,240		- 1-	- /-	,	- 7 -	- / -	- /-	- 1-		- 1-	- / -	- 7 -		- /-	- / -	- 1 -		- 7 -	- 1.	- 7 -	(192,703)	- / -	
t/(cost) d in escalated dollars with sensi tlays pital	sitivity adjust	tments	9,588,240		- 1-	- /-	,	- 7 -	- / -	- /-	- 1-		- 1-	- / -	- 7 -		- /-	- / -	- 1 -		- 7 -	- 1.	- 7 -	(192,703)	- / -	
I/(cost)	sitivity adjust	tments	9,588,240		- 1-	- /-	,	- 7 -	- / -	- /-	- 1-		- 1-	- / -	- 7 -		- /-	- / -	- 1 -		- 7 -	- 1.	- 7 -	(192,703)	- / -	
/(cost)	sitivity adjust	tments	9,588,240		- 1-	- /-	,	- 7 -	- / -	- /-	- 1-		- 1-	- / -	- 7 -		- /-	- / -	- 1 -		- 7 -	- 1.	- 7 -	(192,703)	- / -	
t/(cost)	sitivity adjust	tments	9,588,240	(175,049)	(176,250)	(177,502)	(178,682)	(179,862)	(181,042)	(182,221)	(183,401)	(184,121)		(185,562)	(186,282)	(187,003)	(187,786)	(188,569)	(189,352)	(190,135)	(190,918)	(191,513)	(192,108)		(193,298)	(193,893)
t/(cost)	sitivity adjust	tments	9,588,240	(175,049)	(176,250)	(177,502)	(178,682)	(179,862)	(181,042)	182,221)	(183,401)	(184,121)	(184,842)	(185,562)	(186,282)	(187,003)	(187,786)	(188,569)	(189,352)	(190,135)	(190,918) (190,918) 24,934	(191,513)	(192,108)	27,246	(193,298)	(193,893)
t/(cost)	sitivity adjust	tments	9,588,240	(175,049) (175,049)	(176,250) (176,250) (176,250) (176,250) (176,250) (176,250) (176,250) (176,250) (176,250)	(177,502) (177,5	(178,682) (178,682)	(179,862) (179,862)	(181,042) (181,042) (181,042)	(182,221) (182,221) (182,221) (182,221) (182,221) (182,221) (182,221) (182,221) (182,221) (182,221) (182,221) (182,221) (182,221) (182,221) (182,221) (182,227) (182,27) (182,27) (182,27) (182,27) (182,27) (182,27) (182,27) (18	(183,401) (183,401)	(184,121) (184,121)	(184,842) (184,842) (19,683 (66,225)	(185,562) (185,562) 20,274 69,403	(186,282) (186,282) 20,882 72,711	(187,003) (187,0	(187,786) (187,786) 22,154 79,854	(188,569) (188,569) (188,569) (199) (199) (199) (199) (199) (199) (199) (199) (199) (198)	(189,352) (189,352) 23,503 87,718	(190,135) (190,1	(190,918) (190,9	(191,513) (191,513) 25,682 100,377	(192,108) (193,108) (193,1	27,246	(193,298) (193,298) 28,064 113,769	(193,893) (193,893) (193,893) (193,893) (193,893) (193,893) (193,893) (193,893) (193,893) (193,893) (193,893) (193,893) (193,893) (193,893)
t/(cost)	sitivity adjust	tments	9,588,240	(175,049) (175,049)	(176,250) (176,250) (15,538 (11,394) (15,538) (13,94)	(177,502) (177,502) (16,004 (44,271) (91,501)	(178,682) (178,682)	(179,862) (179,862) (16,979) 50,233 97,074	(181,042) (181,0	(182,221) (182,221) (18,013) (18,013) (18,013) (18,013) (19,014) ((183,401) (183,401) (183,554 (0,244 (0,075)	(184,121) (184,121)	(184,842) (184,842) (19,683 66,225 (112,535)	(185,562) (185,562) 20,274 69,403 115,911	(186,282) (186,282) 20,882 72,711 119,389	(187,003) (187,003) 21,509 76,155 122,970	(187,786) (187,7	(188,569) (188,579) (189,579) (189,5	(189,352) (189,352) 23,503 87,718 134,373	(190,135) (190,135) 24,208 91,895 138,404	(190,918) (190,9	(191,513) (191,513) 25,682 100,377 146,833	(192,108) (192,1	27,246 109,133 155,775	(193,298) (193,298) 28,064 113,769 160,448	(193,893) (193,8
/(cost)	sitivity adjust	tments	9,588,240	(175,049) (175,049) (15,086 (38,712) (38,712) (38,249) (15,087)	(176,250) (176,250) (15,538 (15,538) (15,538) (15,538) (15,540)	(177,502) (177,502) (16,004 (44,271 (91,501 (16,006)	(178,682) (178,682) (16,485) (16,485) (16,485) (16,485) (16,485) (16,486) (16,486)	(179,862) (179,862) (16,979) 50,233 97,074 16,981	(181,042) (181,0	(182,221) (182,221) (182,221) (182,013) (182,013) (182,013) (182,013) (182,013) (182,013) (182,013) (182,013) (182,014) (182,0	(183,401) (183,401) 18,554 18,554 106,075 18,555	(184,121) (184,121) 19,110 63,174 109,258 19,112	(184,842) (184,842) (19,683 (66,225 (112,535 (112,535) (19,685)	(185,562) (185,562) 20,274 69,403 115,911 20,276	(186,282) (186,282) 20,882 72,711 119,389 20,884	(187,003) (187,003) 21,509 76,155 122,970 21,511	(187,786) (187,786) 22,154 79,854 126,659 22,156	(188,569) (189,569) (189,5	(189,352) (189,352) (189,352) (199,100) (199,100) (199,100) (199,100) (199,100) (199,100) (199,100) (199,100) (199,152) (199,1	(190,135) (190,1	(190,918) (190,918) (190,918) (24,918) (24,934)	(191,513) (191,513) (191,513) (25,682 (100,377 (146,833 (25,685)	(192,108) (192,108) 26,453 104,671 151,238 26,455	27,246 109,133 155,775 27,249	(193,298) (193,298) 28,064 113,769 160,448 28,066	(193,893) (193,893) (193,893) (28,906) (118,584) (165,262) (28,908)
I in escalated dollars with sensi tlays pital upital outlays enefits as Electrical Demand atment Media Usage as Operating Labor as (Natural gas)	sitivity adjust	tments	9,588,240	(175,049) (175,049)	(176,250) (176,250) (15,538 (11,394) (15,538) (13,94)	(177,502) (177,502) (16,004 (44,271 (91,501)	(178,682) (178,682) (16,485) (16,485) (16,485) (17,185) ((179,862) (179,862) (16,979) 50,233 97,074	(181,042) (181,0	(182,221) (182,221) (18,013) (18,013) (18,013) (18,013) (19,014) ((183,401) (183,401) (183,54 (18,554 (60,244 (106,075)	(184,121) (184,121)	(184,842) (184,842) (19,683 66,225 (112,535)	(185,562) (185,562) 20,274 69,403 115,911	(186,282) (186,282) 20,882 72,711 119,389	(187,003) (187,003) 21,509 76,155 122,970	(187,786) (187,786) 22,154 79,854 126,659	(188,569) (188,579) (189,579) (189,5	(189,352) (189,352) 23,503 87,718 134,373	(190,135) (190,135) 24,208 91,895 138,404	(190,918) (190,9	(191,513) (191,513) 25,682 100,377 146,833	(192,108) (192,1	27,246 109,133 155,775	(193,298) (193,298) 28,064 113,769 160,448	(193,893) (193,8
/(cost)	sitivity adjust	tments	9,588,240	(175,049) (175,049) (15,086 (38,712) (38,712) (38,249) (15,087)	(176,250) (176,250) (15,538 (15,538) (15,538) (15,538) (15,540)	(177,502) (177,502) (16,004 (44,271 (91,501 (16,006)	(178,682) (178,682) (16,485) (16,485) (16,485) (16,485) (16,485) (16,486) (16,486)	(179,862) (179,862) (16,979) 50,233 97,074 16,981	(181,042) (181,0	(182,221) (182,221) (182,221) (182,013) (182,013) (182,013) (182,013) (182,013) (182,013) (182,013) (182,013) (182,014) (182,0	(183,401) (183,401) 18,554 18,554 106,075 18,555	(184,121) (184,121) 19,110 63,174 109,258 19,112	(184,842) (184,842) (19,683 (66,225 (112,535 (112,535) (19,685)	(185,562) (185,562) 20,274 69,403 115,911 20,276	(186,282) (186,282) 20,882 72,711 119,389 20,884	(187,003) (187,003) 21,509 76,155 122,970 21,511	(187,786) (187,786) 22,154 79,854 126,659 22,156	(188,569) (189,569) (189,5	(189,352) (189,352) (189,352) (199,100) (199,100) (199,100) (199,100) (199,100) (199,100) (199,100) (199,100) (199,152) (199,1	(190,135) (190,1	(190,918) (190,918) (190,918) (24,918) (24,934)	(191,513) (191,513) (191,513) (25,682 (100,377 (146,833 (25,685)	(192,108) (192,108) 26,453 104,671 151,238 26,455	27,246 109,133 155,775 27,249	(193,298) (193,298) 28,064 113,769 160,448 28,066	(193,893) (193,893) (193,893) (28,906) (118,584) (165,262) (28,908)
/(cost)	sitivity adjust	tments	9,588,240	(175,049) (175,049) (15,086 (38,712) (15,087) (15,087) (15,087) (15,087) (15,086) (1	(176,250) (176,2	(177,502) (177,502) (16,004 (44,271) (16,006) (45,667)	(178,682) (178,682) (16,485) (16,485) (16,485) (16,485) (16,486) (16,486) (178,682)	(179,862) (179,862) (16,979 50,233 97,074 16,981 48,448	(181,042) (181,0	(182,221) (182,221) 18,013 56,757 102,986 18,015 51,399	(183,401) (183,401) 18,554 60,244 106,075 18,555 52,941	(184,121) (184,121) 19,110 63,174 109,258 19,112 54,529	(184,842) (184,842) (19,683 66,225 (112,535 (112,535) (19,685) (56,165)	(185,562) (185,562) 20,274 69,403 115,911 20,276 57,850	(186,282) (186,282) 20,882 72,711 119,389 20,884 59,585	(187,003) (187,003) 21,509 76,155 122,970 21,511 61,373	(187,786) (187,7	(188,569) (188,569) (188,569) (199,569) (199,569) (199,569) (199,569) (199,569) (199,569) (199,569) (199,569) (199,569) (198,5	(189,352) (189,352) 23,503 87,718 134,373 23,505 67,064	(190,135) (190,1	(190,918) (190,918) 24,934 96,243 142,556 24,937 71,148	(191,513) 25,682 100,377 146,833 25,685 73,282	(192,108) (192,108) 26,453 104,671 151,238 26,455 75,481	27,246 109,133 155,775 27,249 77,745	(193,298) (193,298) 28,064 113,769 160,448 28,066 80,077	(193,893) 28,906 118,584 165,262 28,908 82,480
I/(cost)	sitivity adjust	tments	9,588,240	(175,049) (175,049) (15,086 (38,712) (38,712) (38,249) (15,087)	(176,250) (176,250) (15,538 (15,538) (15,538) (15,538) (15,540)	(177,502) (177,502) (16,004 (44,271 (91,501 (16,006)	(178,682) (178,682) (16,485) (16,485) (16,485) (16,485) (16,485) (16,486) (16,486)	(179,862) (179,862) (16,979) 50,233 97,074 16,981	(181,042) (181,0	(182,221) (182,221) (182,221) (182,013) (182,013) (182,013) (182,013) (182,013) (182,013) (182,013) (182,013) (182,014) (182,0	(183,401) (183,401) 18,554 18,554 106,075 18,555	(184,121) (184,121) 19,110 63,174 109,258 19,112 54,529	(184,842) (184,842) (19,683 (66,225 (112,535 (112,535) (19,685)	(185,562) (185,562) 20,274 69,403 115,911 20,276	(186,282) (186,282) 20,882 72,711 119,389 20,884	(187,003) (187,003) 21,509 76,155 122,970 21,511	(187,786) (187,786) 22,154 79,854 126,659 22,156	(188,569) (189,569) (189,5	(189,352) (189,352) (189,352) (199,100) (199,100) (199,100) (199,100) (199,100) (199,100) (199,100) (199,100) (199,152) (199,1	(190,135) (190,1	(190,918) (190,918) 24,934 96,243 142,556 24,937 71,148	(191,513) 25,682 100,377 146,833 25,685 73,282	(192,108) (192,108) 26,453 104,671 151,238 26,455	27,246 109,133 155,775 27,249 77,745	(193,298) (193,298) 28,064 113,769 160,448 28,066	(193,893) (193,893) (193,893) (28,906) (118,584) (165,262) (28,908)
/(cost)	sitivity adjust	tments	9,588,240	(175,049) (175,049) (15,086 (38,712) (3	(176,250) (176,2	(177,502) (177,502) (16,004 (44,271 (91,501 (16,006 (45,667) (213,450)	(178,682) (178,682) (16,485 47,185 94,246 16,486 47,037 (221,439)	(179,862) (179,862) 16,979 50,233 97,074 16,981 48,448 229,715	(181,042) (181,042) (181,042) (17,488 (53,422) (99,986) (17,490) (49,902) (49,902) (238,288)	(182,221) (182,221) 18,013 56,757 102,986 18,015 51,399 247,169	(183,401) (183,401) 18,554 60,244 106,075 18,555 52,941 256,369	(184,121) (184,121) 19,110 63,174 109,258 19,112 54,529 265,182	(184,842) (184,842) (184,842) (19,683 (66,225 (112,535) ((185,562) (185,562) 20,274 69,403 115,911 20,276 57,850 283,713	(186,282) (186,282) 20,882 72,711 119,389 20,884 59,585 293,451	(187,003) (187,003) 21,509 76,155 122,970 21,511 61,373 303,518	(187,786) (187,7	(188,569) (188,569) (188,569) (188,569) (199,569) (199,569) (199,569) (199,569) (199,569) (199,569) (199,569) (198,5	(189,352) (189,352) 23,503 87,718 134,373 23,505 67,064 336,163	(190,135) (190,135) (190,135) (24,208 91,895 138,404 24,210 69,076 (347,793)	(190,918) (190,918) (190,918) (24,934) (190,243) (190,243) (190,243) (190,918) (190,91	(191,513) 25,682 100,377 146,833 25,685 73,282 371,859	(192,108) (192,108) 26,453 104,671 151,238 26,455 75,481 384,298	27,246 109,133 155,775 27,249 77,745 397,149	(193,298) (193,298) 28,064 113,769 160,448 28,066 80,077 410,425	(193,893) 28,906 118,584 165,262 28,908 82,480 424,140
t/(cost)	sitivity adjust	tments	9,588,240	(175,049) (175,049) (15,086 (38,712) (15,087) (15,087) (15,087) (15,087) (15,086) (1	(176,250) (176,2	(177,502) (177,502) (16,004 (44,271) (16,006) (45,667)	(178,682) (178,682) (16,485) (16,485) (16,485) (16,485) (16,486) (16,486) (178,682)	(179,862) (179,862) (16,979 50,233 97,074 16,981 48,448	(181,042) (181,0	(182,221) (182,221) 18,013 56,757 102,986 18,015 51,399	(183,401) (183,401) 18,554 60,244 106,075 18,555 52,941	(184,121) (184,121) 19,110 63,174 109,258 19,112 54,529	(184,842) (184,842) (19,683 66,225 (112,535 (112,535) (19,685) (56,165)	(185,562) (185,562) 20,274 69,403 115,911 20,276 57,850	(186,282) (186,282) 20,882 72,711 119,389 20,884 59,585	(187,003) (187,003) 21,509 76,155 122,970 21,511 61,373	(187,786) (187,7	(188,569) (188,569) (188,569) (199,569) (199,569) (199,569) (199,569) (199,569) (199,569) (199,569) (199,569) (199,569) (198,5	(189,352) (189,352) 23,503 87,718 134,373 23,505 67,064	(190,135) (190,1	(190,918) (190,918) 24,934 96,243 142,556 24,937 71,148	(191,513) 25,682 100,377 146,833 25,685 73,282	(192,108) (192,108) 26,453 104,671 151,238 26,455 75,481	27,246 109,133 155,775 27,249 77,745	(193,298) (193,298) 28,064 113,769 160,448 28,066 80,077	(193,893) 28,906 118,584 165,262 28,908 82,480
/(cost) I in escalated dollars with sensi lays pital pital outlays inefits as Electrical Demand timent Media Usage as Operating Labor as (Natural gas) Treatment O&M nning costs :	sitivity adjust	tments	9,588,240	(175,049) (175,049) (15,086 (38,712) (15,087) (15,087) (15,087) (15,087) (15,087) (15,087) (15,087) (15,086) (17,09) (17,09) (17,049) (17,	(176,250) 15,538 41,394 88,836 15,540 44,337 205,646 17,622	(177,502) (177,502) (16,004 (44,271 (91,501 (16,006 (45,667) (213,450) (18,151)	(178,682) (178,682) (16,485 47,185 94,246 16,486 47,037 (221,439) 18,695	(179,862) 16,979 50,233 97,074 16,981 48,448 229,715 19,256	(181,042) (181,0	(182,221) (182,221) 18,013 56,757 102,986 18,015 51,399 247,169 20,429	(183,401) (183,401) 18,554 60,244 106,075 18,555 52,941 256,369 21,041	(184,121) (184,121) (19,110 (63,174 109,258 19,112 54,529 265,182 21,673	(184,842) (184,842) (19,683 66,225 112,535 19,685 56,165 274,294 22,323	(185,562) (185,562) 20,274 69,403 115,911 20,276 57,850 283,713 22,993	(186,282) (186,282) 20,882 72,711 119,389 20,884 59,585 293,451 23,682	(187,003) (187,003) 21,509 76,155 122,970 21,511 61,373 303,518 24,393	(187,786) (187,786) 22,154 79,854 126,659 22,156 63,214 314,037 25,125	(188,569) (188,569) 22,819 83,707 130,459 22,821 65,110 324,915 25,878	(189,352) (189,352) 23,503 87,718 134,373 23,505 67,064 336,163 26,655	(190,135) (190,135) 24,208 91,895 138,404 24,210 69,076 347,793 27,454	(190,918) (190,918) 24,934 96,243 142,556 24,937 71,148 359,819 28,278	(191,513) 25,682 100,377 146,833 25,685 73,282 371,859 29,126	(192,108) (192,108) 26,453 104,671 151,238 26,455 75,481 384,298 30,000	27,246 109,133 155,775 27,249 77,745 397,149 30,900	(193,298) (193,298) 28,064 113,769 160,448 28,066 80,077 410,425 31,827	(193,893) 28,906 118,584 165,262 28,908 82,480 424,140 32,782
/(cost)	sitivity adjust	tments	9,588,240	(175,049) (175,049) (15,086 (38,712) (3	(176,250) (176,2	(177,502) (177,502) (16,004 (44,271 (91,501 (16,006 (45,667) (213,450)	(178,682) (178,682) (16,485 47,185 94,246 16,486 47,037 (221,439)	(179,862) (179,862) 16,979 50,233 97,074 16,981 48,448 229,715	(181,042) (181,0	(182,221) (182,221) 18,013 56,757 102,986 18,015 51,399 247,169	(183,401) (183,401) 18,554 60,244 106,075 18,555 52,941 256,369	(184,121) (184,121) 19,110 63,174 109,258 19,112 54,529 265,182	(184,842) (184,842) (184,842) (19,683 (66,225 (112,535) ((185,562) (185,562) 20,274 69,403 115,911 20,276 57,850 283,713	(186,282) (186,282) 20,882 72,711 119,389 20,884 59,585 293,451	(187,003) (187,003) 21,509 76,155 122,970 21,511 61,373 303,518	(187,786) (187,786) 22,154 79,854 126,659 22,156 63,214 314,037	(188,569) (188,569) (188,569) (188,569) (199,569) (199,569) (199,569) (199,569) (199,569) (199,569) (199,569) (198,5	(189,352) (189,352) 23,503 87,718 134,373 23,505 67,064 336,163	(190,135) (190,135) (190,135) (24,208 91,895 138,404 24,210 69,076 (347,793)	(190,918) (190,918) (190,918) (24,934) (190,243) (190,243) (190,243) (190,918) (190,91	(191,513) 25,682 100,377 146,833 25,685 73,282 371,859	(192,108) (192,108) 26,453 104,671 151,238 26,455 75,481 384,298	27,246 109,133 155,775 27,249 77,745 397,149	(193,298) (193,298) 28,064 113,769 160,448 28,066 80,077 410,425	(193,893) 28,906 118,584 165,262 28,908 82,480 424,140

Siloxane Treatment O&M Other Other			43,046	44,337	45,667	47,037	48,448	49,902	51,399	52,941	54,529	56,165	57,850	59,585	61,373	63,214	65,110	67,064	69
Total running costs			198,180	205,646	213,450	221,439	229,715	238,288	247,169	256,369	265,182	274,294	283,713	293,451	303,518	314,037	324,915	336,163	347
R&R Costs:																			
Other			17,109	17,622	18,151	18,695	19,256	19,834	20,429	21,041	21,673	22,323	22,993	23,682	24,393	25,125	25,878	26,655	27
Other																			
Total refurbishments			17,109	17,622	18,151	18,695	19,256	19,834	20,429	21,041	21,673	22,323	22,993	23,682	24,393	25,125	25,878	26,655	27
Net escalated benefit/(cost)		(9,588,240)	(215,288)	(223,268)	(231,600)	(240,134)	(248,971)	(258,122)	(267,598)	(277,410)	(286,855)	(296,617)	(306,706)	(317,133)	(327,910)	(339,162)	(350,793)	(362,818)	(375

Life cycle cos PVs in 2016

(8,514,083) (187,421) (190,557) (193,793) (196,993) (200,238) (203,527) (206,862) (210,242) (213,138) (216,069) (219,038) (222,044) (225,088) (228,246) (231,445) (234,685) (237,965) (241,288) (244,413) (247,576) (250,778) (250,778) (254,018) (257,298) (13,626,805) NPV as of 2016

From Summary Sheet:			k adjustn	nents (+/- p	ercent):							•	oire Utiliti	•															
Year of an	-			Benefits									JA - RP5 -																
Escalatio	n rate 3.00%	6	Сар	ital costs							Life Cyc	le Alterna	ative Cost	Analysis	(\$000s)														
Discour	t rate 2.00%	6	Runn	ing costs							Alterr	native 3 -	Flare Sep	arate Stre	eams														
															Yea														
	2016		2017	2018	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045	2046
Expressed in 2016 dollars, un	escalated																												
Capital Outlays																							1						
Total Capital					6,370,000																								
Other																													
Other Total capital outlays					6,370,000																								
					6,370,000																								
Benefits:																													
Other Other																													
Total benefits																													
Annual Running Costs: Waste Gas Electrical Demano						4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	
H2S Treatment Media Usage						31,477	32,677	33,930	35,110	36,289	37,469	38,649	39,829	40,549	4,751	4,751	4,751	43,430	4,751	4,751	4,751	46,562	4,751	47,940	48,536	49,131	49,726	50,321	
Waste Gas Operating Labor						35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	35,064	
Assist Gas (Natural gas)						64.712	68,307	68,307	71,902	71,902	75,497	75,497	79,092	79,092	82,687	82,687	82,687	86,282	86,282	86,282	89,878	89,878	93.473	93,473	97,068	100.663	100,663	104,258	
Other						0.,7.12	00,001	00,001	,001	,	,	,	. 0,002	. 0,001	02,001	02,001	02,001	00,202	00,202	00,202	00,010	00,010	00,110	00,110	01,000	,	,	101,200	
Other																													
Total running costs						136,004	140,799	142,052	146,827	148,007	152,781	153,961	158,736	159,456	163,772	164,492	165,212	169,528	170,311	171,094	175,472	176,255	180,633	181,228	185,418	189,609	190,204	194,394	
R&R Costs:	-																												
Other						11,041	11.041	11,041	11,041	11.041	11,041	11,041	11,041	11,041	11,041	11.041	11,041	11.041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	
Other				· · · ·						, -				, - , -									,						
Total refurbishments						11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	11,041	
Net Benefit/(cost)					(6,370,000)	(147.045)	(151,841)	(153,093)	(157.868)	(159,048)	(163,823)	(165.002)	(169.777)	(170.498)	(174.813)	(175.533)	(176.254)	(180,569)	(181.352)	(182,135)	(186.513)	(187,296)	(191.674)	(192,270)	(196.460)	(200,650)	(201.245)	(205.435)	í –
					(-,,,,	(111,010)	(101,011)	(100,000)	(101,000)	(,	(***,*=*)	(,,	(,,	(,,	(,)	(,	((,)	(101,002)	(10-,100)	(100,000)	(,=,	((102,210)	(,,	(/	((,)	
Expressed in escalated dollar	s with sensitivity	/ adjustr	ments																										
Capital Outlays																													
Total Capital					7,606,113																								1
Other																													
Other																													1
Total capital outlays					7,606,113																								
											-																		
Benefits:																													
Other																													
Other																													───
Total benefits																													<u> </u>

Annual Running Costs:																			
Waste Gas Electrical Demand			5,843	6,018	6,199	6,385	6,576	6,774	6,977	7,186	7,402	7,624	7,853	8,088	8,331	8,581	8,838	9,103	9,37
H2S Treatment Media Usage			38,712	41,394	44,271	47,185	50,233	53,422	56,757	60,244	63,174	66,225	69,403	72,711	76,155	79,854	83,707	87,718	91,89
Waste Gas Operating Labor			43,124	44,418	45,751	47,123	48,537	49,993	51,493	53,038	54,629	56,268	57,956	59,694	61,485	63,330	65,230	67,186	69,20
Assist Gas (Natural gas)			79,587	86,529	89,125	96,630	99,529	107,641	110,870	119,634	123,223	132,689	136,670	140,770	151,297	155,836	160,511	172,215	177,38
Other					-														
Other																			
Total running costs			167,267	178,360	185,346	197,323	204,876	217,830	226,097	240,102	248,428	262,806	271,880	281,263	297,268	307,601	318,285	336,223	347,85
R&R Costs:																			
Other			13,579	13,987	14,406	14,839	15,284	15,742	16,215	16,701	17,202	17,718	18,250	18,797	19,361	19,942	20,540	21,156	21,79
Other																			
Total refurbishments			13,579	13,987	14,406	14,839	15,284	15,742	16,215	16,701	17,202	17,718	18,250	18,797	19,361	19,942	20,540	21,156	21,79
Net escalated benefit/(cost)		(7,606,113)	(180,847)	(192,347)	(199,752)	(212,162)	(220,159)	(233,572)	(242,312)	(256,803)	(265,630)	(280,524)	(290,130)	(300,060)	(316,629)	(327,542)	(338,825)	(357,379)	(369,64

Life cycle cost analysis

PVs in 2016

(6,754,011) (157,438) (164,166) (167,144) (174,046) (177,066) (184,170) (187,315) (194,625) (197,367) (204,346) (207,200) (210,090) (217,344) (220,427) (223,549) (231,167) (234,413) (242,244) (245,379) (253,184) (261,120) (264,462) (272,615)

NPV as of 2016

(11,644,886)

,376	9,658	9,947	10,246	10,553	10,870	11,196	
895	96,243	100,377	104,671	109,133	113,769	118,584	
,202	71,278	73,416	75,619	77,888	80,224	82,631	
,381	190,011	195,711	209,336	223,601	230,309	245,691	
,	,	,	,		,	,	
,855	367,190	379,452	399,872	421,175	435,172	458,102	
,	,	0.0,.02		,			
,791	22,445	23,118	23,812	24,526	25,262	26,020	
,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	22,440	20,110	20,012	27,020	20,202	20,020	
,791	22,445	23,118	23,812	24,526	25,262	26,020	
,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	22,443	20,110	20,012	27,320	23,202	20,020	
,646)	(389,635)	(402,570)	(423,683)	(445,701)	(460,434)	(484,121)]
,040)	(303,035)	(402,570)	(423,003)	(443,701)	(400,434)	(404,121)	

rom Summary Sheet:		Risk adjust	ments (+/- per	,								pire Utilitie															
Year of analysis	2016		Benefits									JA - RP5 - V															
Escalation rate	3.00%		Capital costs							-		ative Cost A	•	,													
Discount rate	2.00%	R	lunning costs						Alt	ernative 1B	- Flare Cor	nbined Stre	eams Merg	ged Treatme	ent												
														Yea													
ssed in 2016 dollars, unescalated	2016 d	2017	2018	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
Outlays																											
Capital				4,630,000																							
r r																											
I capital outlays				4,630,000																			!		i di la constante di la consta		
r r																											
al benefits																											
Running Costs:																											
e Gas Electrical Demand					4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,751	4,
Treatment Media Usage te Gas Operating Labor					31,772 17,532	32,984 17,532	34,249 17,532	35,439 17,532	36,630 17,532	37,821 17,532	39,012 17,532	40,202 17,532	40,930 17,532	41,657 17,532	42,384 17,532	43,111 17,532	43,838 17,532	44,628 17,532	45,419 17,532	46,209 17,532	46,999 17,532	47,790 17,532	48,390 17,532	48,991 17,532	49,592 17,532	50,192 17,532	50, 17,
er					17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,552	17,5
er tal running costs					54.055	55,267	56,531	57,722	58,913	60,104	61,295	62,485	63,213	63,940	64,667	65,394	66,121	66,911	67,702	68,492	69,282	70,073	70,673	71,274	71,875	72,475	73,0
-					54,055	55,207	50,551	51,122	50,915	00,104	01,295	02,405	05,215	03,340	04,007	05,594	00,121	00,911	07,702	00,492	09,202	10,013	10,013	/1,2/4	/1,0/3	12,413	/ / 3,0
osts: r					8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,0
er																											
al refurbishments					8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,015	8,0
enefit/(cost)				(4,630,000)	(62,070)	(63,282)	(64,547)	(65,737)	(66,928)	(68,119)	(69,310)	(70,501)	(71,228)	(71,955)	(72,682)	(73,409)	(74,136)	(74,927)	(75,717)	(76,507)	(77,298)	(78,088)	(78,689)	(79,289)	(79,890)	(80,491)	(81,0
al Outlays al Capital er er				5,528,462																							
tal capital outlays				5,528,462																					í de la compañía de		
īits:																											
er																							í		í T	— i	
er tal benefits		+	-																				لــــــا		/ł		
	·		1		I																				ł	1	
al Running Costs: ste Gas Electrical Demand					5,843	6,018	6,199	6,385	6,576	6,774	6,977	7,186	7,402	7,624	7,853	8,088	8,331	8,581	8,838	9,103	9,376	9,658	9,947	10,246	10,553	10,870	11,1
S Treatment Media Usage					39,076	41,783	44,687	47,627	50,705	53,924	57,290	60,810	63,767	66,847	70,054	73,394	76,870	80,604	84,492	88,541	92,758	97,147	101,319	105,654	110,158	114,837	119,6
ste Gas Operating Labor ler					21,562	22,209	22,875	23,562	24,268	24,997	25,746	26,519	27,314	28,134	28,978	29,847	30,743	31,665	32,615	33,593	34,601	35,639	36,708	37,809	38,944	40,112	41,3
er																							۱		ı	ļ	1
al running costs					66,481	70,010	73,761	77,574	81,549	85,694	90,013	94,515	98,483	102,604	106,884	111,329	115,944	120,849	125,945	131,238	136,735	142,444	147,975	153,709	159,655	165,819	172,
osts:																											
r -					9,858	10,153	10,458	10,772	11,095	11,428	11,771	12,124	12,487	12,862	13,248	13,645	14,055	14,476	14,911	15,358	15,819	16,293	16,782	17,286	17,804	18,338	18,
r al refurbishments					9,858	10,153	10,458	10,772	11,095	11,428	11,771	12,124	12,487	12,862	13,248	13,645	14,055	14,476	14,911	15,358	15,819	16,293	16,782	17,286	17,804	18,338	18,
calated benefit/(cost)				(5,528,462)	(76,339)	(80,164)	(84,219)	(88,346)	(92,644)	(97,122)	(101,784)	(106,639)	(110,971)	(115,467)	(120,132)	(124,974)	(129,998)	(135,326)	(140,856)	(146,596)	(152,554)	(158,737)	(164,757)	(170,995)	(177,459)	(184,157)	(191,
	L	I		(3,328,462)	(10,339)	(00,104)	(04,219)	(00,340)	(92,044)	(97,122)	(101,784)	(100,039)	(110,971)	(115,467)	(120,132)	(124,974)	(129,998)	(135,326)	(140,000)	(140,090)	(152,554)	(156,737)	(104,/5/)	(170,995)	(177,459)	(104,157)	(191,0
cle cost analysis																											
2016		Т		(4.909.116)	(66.457)	(68,419)	(70.471)	(72,474)	(74.510)	(76.580)	(78.682)	(80.819)	(82,453)	(84,111)	(85,794)	(87,502)	(89,235)	(91.070)	(92,933)	(94.824)	(96,743)	(98.690)	(100.424)	(102,183)	(103.966)	(105,775)	(107,6

(6,920,842)

2039	2040	2041	2042	2043	2044	2045	2046
2039	2040	2041	2042	2043	2044	2045	2046
1	1					1	
4,751 46,999	4,751 47,790	4,751 48,390	4,751 48,991	4,751 49,592	4,751 50,192	4,751 50,793	
17,532	17,532	17,532	17,532	17,532	17,532	17,532	
69,282	70,073	70,673	71,274	71,875	72,475	73,076	
8,015	8,015	8,015	8,015	8,015	8,015	8,015	
8,015	8,015	8,015	8,015	8,015	8,015	8,015	
(77,298)	(78,088)	(78,689)	(79,289)	(79,890)	(80,491)	(81,091)	
9,376	9,658	9,947	10,246	10,553	10,870	11,196	
92,758 34,601	97,147 35,639	101,319 36,708	105,654 37,809	110,158 38,944	114,837 40,112	119,697 41,315	
136,735	142,444	147,975	153,709	159,655	165,819	172,209	
15,819	16,293	16,782	17,286	17,804	18,338	18,888	
15,819	16,293	16,782	17,286	17,804	18,338	18,888	
(152,554)	(158,737)	(164,757)	(170,995)	(177,459)	(184,157)	(191,097)	

RP-5 Food Waste



Agency:	Inland Empire Utilities Agency	R	Results (\$000s)	
Project/Problem:		Capital Cost	30-year NPV	Benefit over 'Do Nothing'
Alternative 1	FW Alt 1	\$134,500,000	(\$283,824,619)	
Alternative 2	FW Alt 2	\$153,700,000	(\$303,508,513)	(\$19,683,894)
Alternative 3	FW Alt 3	\$146,400,000	(\$331,463,251)	(\$47,638,632)
Alternative 4				
Alternative 5				
Alternative 6				
Alternative 7				
Alternative 8				
Alternative 9				
Alternative 10				
Alternative 11				
Alternative 12				

Year of analysis: 2016 Escalation rate: 3.00 Discount rate: 2.00

016	
.00%	
.00%	

	Year of analysis	2016																													
	Escalation rate	3.00%												Life				\$000s)													
	Discount rate								т			т								т		n				-					-
	ad in 2016 dollare unascalata		2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	1
	utlays																														
	4			13,450,000	13,450,000	13,450,000	26,900,000	26,900,000	40,350,000																						
	anital outlave			13 450 000	13,450,000	13,450,000	26 900 000	26 900 000	40 350 000																						
	ibital outravs		1 1	13.430.000	13.430.000	13.430.000	20.500.000	20.900.000	40.330.000			1	11							1						1					-
										1,304,282	1,322,940	1,369,075	1,415,211	1,461,346		1,553,617	1,581,865	1,610,113	1,638,361	1,666,609	1,694,857	1,725,442	1,756,027	1,786,612			1,870,849	1,893,917			
									129,830	133,284	136,737	140,191	143,644	147,098	150,552	154,005	157,459	160,913	164,366	167,820	171,273	174,078	176,883	179,688	182,493	185,298	188,103	190,908	193,713	196,518	
	mefits								1.415.453	1.437.565	1.459.677	1 509 266	1.558.855	1.608.444	1.658.033	1,707,622	1,739,324	1,771,025	1 802 727	1.834.428	1,866,130	1,899,520	1,932,910	1.966.300	1,999,690	2.033.080	2 058 952	2.084.825	2,110,698	2 136 570	
									4,999,291	5,036,509	5,073,727	5,165,763	5,257,799	5,349,835	5,441,871	5,967,707	6,297,083	6,353,446	6,409,809	6,466,172	6,522,535	6,583,553	6,644,571	6,705,589	6,766,607	6,937,125	7,269,657	7,315,668	7,361,679	7,407,690	
																															Τ.
Negation	nning costs								4,999,291	5,036,509	5,073,727	5,165,763	5,257,799	5,349,835	5,441,871	5,967,707	6,297,083	6,353,446	6,409,809	6,466,172	6,522,535	6,583,553	6,644,571	6,705,589	6,766,607	6,937,125	7,269,657	7,315,668	7,361,679	7,407,690	
while and bin																															_
	Repair and Replacement								663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	
sexade other were were were were were were were w	- Frank Tallana and in												000.000		000.000			000.000	000.000	000.000	000.000	000.000		000.000		000.000	000.000	000.000		000.000	
Image: construction Image: construction<	efurbishments it/(cost) d in escalated dollars with se utlays	nsitivity adjust	ments	(13,450,000)	(13,450,000)	(13,450,000)	(26,900,000)	(26,900,000)																							
Image: construction Image: construction<	/(cost) I in escalated dollars with set tlays	nsitivity adjust	ments						(44,596,838)																						
Image: construction Image: construction<	t/(cost) d in escalated dollars with settlays	nsitivity adjust	ments						(44,596,838)																						
Image: construction Image: construction<	t/(cost) d in escalated dollars with settlays	nsitivity adjust	ments						(44,596,838)																						
Image: biol	/(cost) I in escalated dollars with set tlays	nsitivity adjust	ments						(44,596,838)																						
Image: biol	/(cost) I in escalated dollars with se lays	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,838) 49,625,410	(4,261,944)																					
Image: biole biol	V(cost) d in escalated dollars with se tlays	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,838) 49,625,410 49,625,410	(4,261,944)	(4,277,050)	(4,319,497)) (4,361,944)	(4,404,391)	(4,446,838)	(4,923,085)	(5,220,759)	(5,245,421)	(5,270,082)	(5,294,743)	(5,319,405)	(5,347,033)	(5,374,661)	(5,402,289)	(5,429,917) (5,567,045)	(5,873,704	(5,893,843)	(5,913,981)	(5,934,120)	
Ninit Colls: Ninit Coll NinitColl Ninit Coll Ninit Coll	/(cost) I in escalated dollars with se lays	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,838) 49,625,410 49,625,410 1,581,154	(4,261,944)	(4,277,050)	(4,319,497)	1,958,983	(4,404,391) 2,083,530	(4,446,838) 2,213,787	(4,923,085)	(5,220,759) 2,464,494	2,583,758	(5,270,082) 2,707,961	2,837,290	2,971,941	(5,347,033)	(5,374,661) 3,266,727	(5,402,289)	(5,429,917	3,756,159	(5,873,704	(5,893,843)	(5,913,981) 4.258,176	(5,934,120)	
Image: space spac	(rcost) in escalated dollars with se lays pital outays	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,838) 49,625,410 49,625,410 1,581,154 159,675	(4,261,944) (4,261,944) (4,261,944) (4,261,944)	(4,277,050) (4,277,050) 1,726,137 178,411	(4,319,497) (4,319,497) (4,319,497) (4,319,497) (4,319,497) (4,319,497)	1,958,983 196,838	(4,404,391) 2,083,530 209,727	(4,446,838) 2,213,787 221,090	(4,923,085) (4,923,085) 2,349,985 232,947	(5,220,759) 2,464,494 245,316	2,583,758 258,217	(5,270,082) 2,707,981 271,672	2,837,290 285,702	(5,319,405) (5,319,405) (5,319,405) (5,319,405) (5,319,405) (5,319,405) (5,319,405) (5,319,405)	(5,347,033) 3,116,339 314,405	(5,374,661) 3,266,727 329,055	(5,402,289) (5,402,289) (5,402,289) (5,402,289) (5,402,289) (5,402,289) (5,402,289) (5,402,289)	(5,429,917 (5,429,917 (5,429,917) (5,429,9	3,756,159 376,673	(5,873,704 3,917,143 393,847	(5.893,843) (5.893,843) (5.893,843) (5.893,843) (5.893,843)	(5,913,981) 4,258,176 430,293	(5,934,120) (5,934,120) 4,438,699 449,620	
Implication	/(cost) I in escalated dollars with so lays pital outlays mefits	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,838) 49,625,410 49,625,410 1,581,154 159,675	(4,261,944) (4,261,944) (4,261,944) (4,261,944)	(4,277,050) (4,277,050) 1,726,137 178,411	(4,319,497) (4,319,497) (4,319,497) (4,319,497) (4,319,497) (4,319,497)	1,958,983 196,838	(4,404,391) 2,083,530 209,727	(4,446,838) 2,213,787 221,090	(4,923,085) (4,923,085) 2,349,985 232,947	(5,220,759) 2,464,494 245,316	2,583,758 258,217	(5,270,082) 2,707,981 271,672	2,837,290 285,702	(5,319,405) (5,319,405) (5,319,405) (5,319,405) (5,319,405) (5,319,405) (5,319,405) (5,319,405)	(5,347,033) 3,116,339 314,405	(5,374,661) 3,266,727 329,055	(5,402,289) (5,402,289) (5,402,289) (5,402,289) (5,402,289) (5,402,289) (5,402,289) (5,402,289)	(5,429,917 (5,429,917 (5,429,917) (5,429,9	3,756,159 376,673	(5,873,704 3,917,143 393,847	(5.893,843) (5.893,843) (5.893,843) (5.893,843) (5.893,843)	(5,913,981) 4,258,176 430,293	(5,934,120) (5,934,120) 4,438,699 449,620	
Centre Control Control <th< td=""><td>/(cost) I in escalated dollars with so lays pital outlays mefits</td><td>nsitivity adjust</td><td>ments</td><td>14,269,105</td><td>14,697,178</td><td>15,138,093</td><td>31,184,473</td><td>32,120,007</td><td>(44,596,838) 49,625,410 49,625,410 1,581,154 159,675 1,740,829</td><td>(4,261,944) (4,261,944) 1,652,225 168,840 1.821.065</td><td>1,726,137 178,411 1.904,548</td><td>1,839,923 188,405 2,028,328</td><td>1.958,983 198,838 2.157,820</td><td>(4,404,391) 2,083,530 209,727 2.293.257</td><td>(4,446,838) 2,213,787 221,090 2,434.877</td><td>(4,923,085) 2,349,985 232,947 2,582,931</td><td>(5,220,759) 2,464,494 245,316 2,709,809</td><td>2,583,758 288,217 2.841,976</td><td>(5,270,082) 2,707,961 271,672 2,979,633</td><td>2,837,290 285,702 3.122,992</td><td>(5,319,405) 2,971,941 300,329 3.272,270</td><td>(5,347,033) 3,116,339 314,405 3.430,744</td><td>(5,374,661) 3,266,727 329,055 3,595,782</td><td>(5,402,289) 3,423,332 344,301 3,767,634</td><td>(5,429,917 3,586,394 360,166 3,946,561</td><td>3,756,159 376,673 4,132,833</td><td>(5,873,704 3,917,143 393,847 4,310,989</td><td>(5.893,843) 4.084,404 411,711 4.496,116</td><td>(5,913,981) 4,258,176 430,293 4,688,470</td><td>(5,934,120) 4,438,699 449,620 4,888,319</td><td></td></th<>	/(cost) I in escalated dollars with so lays pital outlays mefits	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,838) 49,625,410 49,625,410 1,581,154 159,675 1,740,829	(4,261,944) (4,261,944) 1,652,225 168,840 1.821.065	1,726,137 178,411 1.904,548	1,839,923 188,405 2,028,328	1.958,983 198,838 2.157,820	(4,404,391) 2,083,530 209,727 2.293.257	(4,446,838) 2,213,787 221,090 2,434.877	(4,923,085) 2,349,985 232,947 2,582,931	(5,220,759) 2,464,494 245,316 2,709,809	2,583,758 288,217 2.841,976	(5,270,082) 2,707,961 271,672 2,979,633	2,837,290 285,702 3.122,992	(5,319,405) 2,971,941 300,329 3.272,270	(5,347,033) 3,116,339 314,405 3.430,744	(5,374,661) 3,266,727 329,055 3,595,782	(5,402,289) 3,423,332 344,301 3,767,634	(5,429,917 3,586,394 360,166 3,946,561	3,756,159 376,673 4,132,833	(5,873,704 3,917,143 393,847 4,310,989	(5.893,843) 4.084,404 411,711 4.496,116	(5,913,981) 4,258,176 430,293 4,688,470	(5,934,120) 4,438,699 449,620 4,888,319	
Kessair and Resolacement Image: Control of the state sta	V(cost) 5 In escalated dollars with so flays pital outlays	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,838) 49,625,410 49,625,410 1,581,154 159,675 1,740,829	(4,261,944) (4,261,944) 1,652,225 168,840 1.821.065	1,726,137 178,411 1.904,548	1,839,923 188,405 2,028,328	1.958,983 198,838 2.157,820	(4,404,391) 2,083,530 209,727 2.293.257	(4,446,838) 2,213,787 221,090 2,434.877	(4,923,085) 2,349,985 232,947 2,582,931	(5,220,759) 2,464,494 245,316 2,709,809	2,583,758 288,217 2.841,976	(5,270,082) 2,707,961 271,672 2,979,633	2,837,290 285,702 3.122,992	(5,319,405) 2,971,941 300,329 3.272.270	(5,347,033) 3,116,339 314,405 3.430,744	(5,374,661) 3,266,727 329,055 3,595,782	(5,402,289) 3,423,332 344,301 3,767,634	(5,429,917 3,586,394 360,166 3,946,561	3,756,159 376,673 4,132,833	(5,873,704 3,917,143 393,847 4,310,989	(5.893,843) 4.084,404 411,711 4.496,116	(5,913,981) 4,258,176 430,293 4,688,470	(5,934,120) 4,438,699 449,620 4,888,319	
Centre Control Control <th< td=""><td>/(cost) I in escalated dollars with so lays pital outlays mefits</td><td>Institivity adjust</td><td>ments</td><td>14,269,105</td><td>14,697,178</td><td>15,138,093</td><td>31,184,473</td><td>32,120,007</td><td>(44,596,838) 49,625,410 49,625,410 1,581,154 159,675 1,740,829</td><td>(4,261,944) (4,261,944) 1,652,225 168,840 1.821.065</td><td>1,726,137 178,411 1.904,548</td><td>1,839,923 188,405 2,028,328</td><td>1.958,983 198,838 2.157,820</td><td>(4,404,391) 2,083,530 209,727 2.293.257</td><td>(4,446,838) 2,213,787 221,090 2,434.877</td><td>(4,923,085) 2,349,985 232,947 2,582,931</td><td>(5,220,759) 2,464,494 245,316 2,709,809</td><td>2,583,758 288,217 2.841,976</td><td>(5,270,082) 2,707,961 271,672 2,979,633</td><td>2,837,290 285,702 3.122,992</td><td>(5,319,405) 2,971,941 300,329 3.272.270</td><td>(5,347,033) 3,116,339 314,405 3.430,744</td><td>(5,374,661) 3,266,727 329,055 3,595,782</td><td>(5,402,289) 3,423,332 344,301 3,767,634</td><td>(5,429,917 3,586,394 360,166 3,946,561</td><td>3,756,159 376,673 4,132,833</td><td>(5,873,704 3,917,143 393,847 4,310,989</td><td>(5.893,843) 4.084,404 411,711 4.496,116</td><td>(5,913,981) 4,258,176 430,293 4,688,470</td><td>(5,934,120) 4,438,699 449,620 4,888,319</td><td></td></th<>	/(cost) I in escalated dollars with so lays pital outlays mefits	Institivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,838) 49,625,410 49,625,410 1,581,154 159,675 1,740,829	(4,261,944) (4,261,944) 1,652,225 168,840 1.821.065	1,726,137 178,411 1.904,548	1,839,923 188,405 2,028,328	1.958,983 198,838 2.157,820	(4,404,391) 2,083,530 209,727 2.293.257	(4,446,838) 2,213,787 221,090 2,434.877	(4,923,085) 2,349,985 232,947 2,582,931	(5,220,759) 2,464,494 245,316 2,709,809	2,583,758 288,217 2.841,976	(5,270,082) 2,707,961 271,672 2,979,633	2,837,290 285,702 3.122,992	(5,319,405) 2,971,941 300,329 3.272.270	(5,347,033) 3,116,339 314,405 3.430,744	(5,374,661) 3,266,727 329,055 3,595,782	(5,402,289) 3,423,332 344,301 3,767,634	(5,429,917 3,586,394 360,166 3,946,561	3,756,159 376,673 4,132,833	(5,873,704 3,917,143 393,847 4,310,989	(5.893,843) 4.084,404 411,711 4.496,116	(5,913,981) 4,258,176 430,293 4,688,470	(5,934,120) 4,438,699 449,620 4,888,319	
x x	U(cost) d in escalated dollars with se they apital outlays anefits	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,838) 49,625,410 49,625,410 1,581,154 159,675 1,740,829	(4,261,944) (4,261,944) 1,652,225 168,840 1.821.065	1,726,137 178,411 1.904,548	1,839,923 188,405 2,028,328	1.958,983 198,838 2.157,820	(4,404,391) 2,083,530 209,727 2.293.257	(4,446,838) 2,213,787 221,090 2,434.877	(4,923,085) 2,349,985 232,947 2,582,931	(5,220,759) 2,464,494 245,316 2,709,809	2,583,758 288,217 2.841,976	(5,270,082) 2,707,961 271,672 2,979,633	2,837,290 285,702 3.122,992	(5,319,405) 2,971,941 300,329 3.272.270	(5,347,033) 3,116,339 314,405 3.430,744	(5,374,661) 3,266,727 329,055 3,595,782	(5,402,289) 3,423,332 344,301 3,767,634	(5,429,917 3,586,394 360,166 3,946,561	3,756,159 376,673 4,132,833	(5,873,704 3,917,143 393,847 4,310,989	(5.893,843) 4.084,404 411,711 4.496,116	(5,913,981) 4,258,176 430,293 4,688,470	(5,934,120) 4,438,699 449,620 4,888,319	
Centre Control Control <th< td=""><td>/(cost) I in escalated dollars with so lays pital outlays mefits</td><td>nsitivity adjust</td><td>ments</td><td>14,269,105</td><td>14,697,178</td><td>15,138,093</td><td>31,184,473</td><td>32,120,007</td><td>(44,596,838) 49,625,410 49,625,410 1,581,154 159,675 1,740,829</td><td>(4,261,944) (4,261,944) 1,652,225 168,840 1.821.065</td><td>1,726,137 178,411 1.904,548</td><td>1,839,923 188,405 2,028,328</td><td>1.958,983 198,838 2.157,820</td><td>(4,404,391) 2,083,530 209,727 2.293.257</td><td>(4,446,838) 2,213,787 221,090 2,434.877</td><td>(4,923,085) 2,349,985 232,947 2,582,931</td><td>(5,220,759) 2,464,494 245,316 2,709,809</td><td>2,583,758 288,217 2.841,976</td><td>(5,270,082) 2,707,961 271,672 2,979,633</td><td>2,837,290 285,702 3.122,992</td><td>(5,319,405) 2,971,941 300,329 3.272.270</td><td>(5,347,033) 3,116,339 314,405 3.430,744</td><td>(5,374,661) 3,266,727 329,055 3,595,782</td><td>(5,402,289) 3,423,332 344,301 3,767,634</td><td>(5,429,917 3,586,394 360,166 3,946,561</td><td>3,756,159 376,673 4,132,833</td><td>(5,873,704 3,917,143 393,847 4,310,989</td><td>(5.893,843) 4.084,404 411,711 4.496,116</td><td>(5,913,981) 4,258,176 430,293 4,688,470</td><td>(5,934,120) 4,438,699 449,620 4,888,319</td><td></td></th<>	/(cost) I in escalated dollars with so lays pital outlays mefits	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,838) 49,625,410 49,625,410 1,581,154 159,675 1,740,829	(4,261,944) (4,261,944) 1,652,225 168,840 1.821.065	1,726,137 178,411 1.904,548	1,839,923 188,405 2,028,328	1.958,983 198,838 2.157,820	(4,404,391) 2,083,530 209,727 2.293.257	(4,446,838) 2,213,787 221,090 2,434.877	(4,923,085) 2,349,985 232,947 2,582,931	(5,220,759) 2,464,494 245,316 2,709,809	2,583,758 288,217 2.841,976	(5,270,082) 2,707,961 271,672 2,979,633	2,837,290 285,702 3.122,992	(5,319,405) 2,971,941 300,329 3.272.270	(5,347,033) 3,116,339 314,405 3.430,744	(5,374,661) 3,266,727 329,055 3,595,782	(5,402,289) 3,423,332 344,301 3,767,634	(5,429,917 3,586,394 360,166 3,946,561	3,756,159 376,673 4,132,833	(5,873,704 3,917,143 393,847 4,310,989	(5.893,843) 4.084,404 411,711 4.496,116	(5,913,981) 4,258,176 430,293 4,688,470	(5,934,120) 4,438,699 449,620 4,888,319	
Centre Control Control <th< td=""><td>/(cost) I in escalated dollars with so lays pital outlays melits</td><td></td><td>ments</td><td>14,269,105</td><td>14,697,178</td><td>15,138,093</td><td>31,184,473</td><td>32,120,007</td><td>(44,596,838) 49,625,410 49,625,410 1,581,154 159,675 1,740,829</td><td>(4,261,944) (4,261,944) 1,652,225 168,840 1.821.065</td><td>1,726,137 178,411 1.904,548</td><td>1,839,923 188,405 2,028,328</td><td>1.958,983 198,838 2.157,820</td><td>(4,404,391) 2,083,530 209,727 2.293.257</td><td>(4,446,838) 2,213,787 221,090 2,434.877</td><td>(4,923,085) 2,349,985 232,947 2,582,931</td><td>(5,220,759) 2,464,494 245,316 2,709,809</td><td>2,583,758 288,217 2.841,976</td><td>(5,270,082) 2,707,961 271,672 2,979,633</td><td>2,837,290 285,702 3.122,992</td><td>(5,319,405) 2,971,941 300,329 3.272.270</td><td>(5,347,033) 3,116,339 314,405 3.430,744</td><td>(5,374,661) 3,266,727 329,055 3,595,782</td><td>(5,402,289) 3,423,332 344,301 3,767,634</td><td>(5,429,917 3,586,394 360,166 3,946,561</td><td>3,756,159 376,673 4,132,833</td><td>(5,873,704 3,917,143 393,847 4,310,989</td><td>(5.893,843) 4.084,404 411,711 4.496,116</td><td>(5,913,981) 4,258,176 430,293 4,688,470</td><td>(5,934,120) 4,438,699 449,620 4,888,319</td><td></td></th<>	/(cost) I in escalated dollars with so lays pital outlays melits		ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,838) 49,625,410 49,625,410 1,581,154 159,675 1,740,829	(4,261,944) (4,261,944) 1,652,225 168,840 1.821.065	1,726,137 178,411 1.904,548	1,839,923 188,405 2,028,328	1.958,983 198,838 2.157,820	(4,404,391) 2,083,530 209,727 2.293.257	(4,446,838) 2,213,787 221,090 2,434.877	(4,923,085) 2,349,985 232,947 2,582,931	(5,220,759) 2,464,494 245,316 2,709,809	2,583,758 288,217 2.841,976	(5,270,082) 2,707,961 271,672 2,979,633	2,837,290 285,702 3.122,992	(5,319,405) 2,971,941 300,329 3.272.270	(5,347,033) 3,116,339 314,405 3.430,744	(5,374,661) 3,266,727 329,055 3,595,782	(5,402,289) 3,423,332 344,301 3,767,634	(5,429,917 3,586,394 360,166 3,946,561	3,756,159 376,673 4,132,833	(5,873,704 3,917,143 393,847 4,310,989	(5.893,843) 4.084,404 411,711 4.496,116	(5,913,981) 4,258,176 430,293 4,688,470	(5,934,120) 4,438,699 449,620 4,888,319	
Lessing and Residence effect Lessing and Residence effect Lessing and Residence effect Ling and Residence effect <	(cost) In escalated dollars with se pitel outlays netts costs:	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,838) 49,625,410 49,625,410 1,581,154 159,675 1,740,829 6,148,497	(4,261,944) (4,261,944) 1,652,225 168,840 1,821,065 6,380,099	1.726.137 178.411 1.904.548 6.620.063	(4,319,497) (4,319,497) 1,839,923 188,405 2,028,328 6,942,354	(4,361,944) (4,361,944) 1.958,963 198,838 2.157,820 7,278,024	(4,404,391) 2,083,530 209,727 2,293,257 7,627,585	(4,446,838) 2,213,787 221,090 2,434,877 7,991,571	(4,923,085) 2,349,985 232,947 2,562,931 9,026,692	(5,220,759) 2,464,494 245,316 2,709,809 9,810,650	2,583,758 2,583,758 258,217 2,841,976 10,195,415	(5,270,082) 2,707,981 271,672 2,979,633 10,594,437	(5,294,743) 2,837,290 285,702 3,122,992 11,008,225	(5,319,405) 2,971,941 300,329 3,272,270 11,437,304	(5,347,033) 3,116,339 314,405 3,430,744 11,890,629	(5,374,661) 3,266,727 329,055 3,595,782 12,360,859	(5,402,289) 3,423,332 344,301 3,767,634 12,848,602	(5,429,917 3,586,394 360,166 3,946,561 13,354,484	3.756.159 376.673 4.132.833 14.101.747	(5,873,704 3,917,143 393,847 4,310,989 15,221,046	(5,883,843) (5,883,843) 4,084,404 411,711 4,496,116 15,776,905	(5,913,981) 4,258,176 430,293 4,688,470 16,352,417	(5,934,120) 4,438,699 449,620 4,888,319 16,948,260	
ed bendlij(cost) (14,289,105) (14,687,178) (15,138,093) (0,194,473) (0,2120,007) (54,848,485) (5,385,503) (5,385,503) (5,005,643) (6,077,569) (6,279,609) (6,530,331) (7,446,607) (0,133,773) (8,417,360) (0,710,431) (0,035,346) (0,035,3	(cost) In escalated dollars with se inve pital outlays nefts ming Costs:	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,838) 49,625,410 49,625,410 1,581,154 159,675 1,740,829 6,148,497	(4,261,944) (4,261,944) 1,652,225 168,840 1,821,065 6,380,099	1.726.137 178.411 1.904.548 6.620.063	(4,319,497) (4,319,497) 1,839,923 188,405 2,028,328 6,942,354	(4,361,944) (4,361,944) 1.958,963 198,838 2.157,820 7,278,024	(4,404,391) 2,083,530 209,727 2,293,257 7,627,585	(4,446,838) 2,213,787 221,090 2,434,877 7,991,571	(4,923,085) 2,349,985 232,947 2,562,931 9,026,692	(5,220,759) 2,464,494 245,316 2,709,809 9,810,650	2,583,758 2,583,758 258,217 2,841,976 10,195,415	(5,270,082) 2,707,981 271,672 2,979,633 10,594,437	(5,294,743) 2,837,290 285,702 3,122,992 11,008,225	(5,319,405) 2,971,941 300,329 3,272,270 11,437,304	(5,347,033) 3,116,339 314,405 3,430,744 11,890,629	(5,374,661) 3,266,727 329,055 3,595,782 12,360,859	(5,402,289) 3,423,332 344,301 3,767,634 12,848,602	(5,429,917 3,586,394 360,166 3,946,561 13,354,484	3.756.159 376.673 4.132.833 14.101.747	(5,873,704 3,917,143 393,847 4,310,989 15,221,046	(5,883,843) (5,883,843) 4,084,404 411,711 4,496,116 15,776,905	(5,913,981) 4,258,176 430,293 4,688,470 16,352,417	(5,934,120) 4,438,699 449,620 4,888,319 16,948,260	
(14,289,105) (14,687,178) (15,138,093) (11,344,473) (6,279,609) (6,279,609) (6,279,609) (6,337,773) (8,417,260) (0,273,640) (0,351,245) (10,351,245) (10,351,245) (11,346,657) (12,289,232) (12,710,610) (13,156,652) (13,576,839) (6,377,850) (7,378,850) (7,378,850)	ricost In escalated dollars with se pital cutays mattis costs	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,839) 49,625,410 49,625,410 1,581,154 1,581,154 1,581,154 1,58,675 1,740,829 6,148,497 6,148,497	(4,261,944) (4,261,944)(4,261,944) (4,261,944)(4,261,944) (4,261,944)(4,261	1.726.137 1.726.137 178.411 1.904.548 6.620.063	(4,319,497) (4,319,497) 1,839,923 188,405 2,028,328 6,942,354 6,942,354	(4,361,944) (4,361,944) 1,958,983 198,934 198,983 198,998 199,998 199,998 199,998 199,998 199,999 199,998 199,998 199,999 199,999 199,999 199,	(4,404,391) 2,083,530 209,727 2,293,257 7,627,585 7,627,585	(4,446,838) 2,213,787 221,090 2,434,877 7,991,571 7,991,571	(4,923,085) (4,923,085) 2,349,985 232,947 2,582,931 9,026,692 9,026,692	(5,220,759) 2,464,494 245,316 2,709,809 9,810,650 9,810,650	2,583,758 258,217 2,841,976 10,195,415	(5.270,082) 2,707,981 271,872 2.979,633 10,594,437	(5,294,743) 2,837,290 285,702 3,122,992 11,008,225 11,008,225	(5,319,405) 2,971,941 300,329 3,272,270 11,437,304	(5,347,033) 3,116,339 314,405 3,430,744 11,890,629	(5,374,661) 3,266,727 329,055 3,595,782 12,360,859 12,360,859	(5,402,289) 3,423,332 344,301 3,767,634 12,848,602	(5.429,917 3.586,394 360,166 3.946.561 13.354,484 13.354,484	3.756.159 376.673 4.132.833 14.101.747	(5,873,704 3,917,143 393,847 4,310,989 15,221,046 15,221,046	(5,893,843) (5,893,843) 4,084,404 411,711 4,496,116 15,776,905	(5,913,981) 4,258,176 430,293 4,688,470 16,352,417 16,352,417	(5,934,120) 4,438,699 449,620 4,888,319 16,948,260 16,948,260	
(14,289,105) (14,687,178) (15,138,093) (11,344,473) (6,279,609) (6,279,609) (6,279,609) (6,337,773) (8,417,260) (0,273,640) (0,351,245) (10,351,245) (10,351,245) (11,346,657) (12,289,232) (12,710,610) (13,156,652) (13,576,839) (6,377,850) (7,378,850) (7,378,850)	ricost In escalated dollars with se pital cutays mattis costs	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,839) 49,625,410 49,625,410 1,581,154 1,581,154 1,581,154 1,58,675 1,740,829 6,148,497 6,148,497	(4,261,944) (4,261,944) 1,652,225 168,840 1,821,065 6,380,099 6,380,099	1.726.137 1.726.137 178.411 1.904.548 6.620.063	(4,319,497) (4,319,497) 1,839,923 188,405 2,028,328 6,942,354 6,942,354	(4,361,944) (4,361,944) 1,958,983 198,934 198,983 198,998 199,998 199,998 199,998 199,998 199,999 199,998 199,998 199,999 199,999 199,999 199,	(4,404,391) 2,083,530 209,727 2,293,257 7,627,585 7,627,585	(4,446,838) 2,213,787 221,090 2,434,877 7,991,571 7,991,571	(4,923,085) (4,923,085) 2,349,985 232,947 2,582,931 9,026,692 9,026,692	(5,220,759) 2,464,494 245,316 2,709,809 9,810,650 9,810,650	2,583,758 258,217 2,841,976 10,195,415	(5.270,082) 2,707,981 271,872 2.979,633 10,594,437	(5,294,743) 2,837,290 285,702 3,122,992 11,008,225 11,008,225	(5,319,405) 2,971,941 300,329 3,272,270 11,437,304	(5,347,033) 3,116,339 314,405 3,430,744 11,890,629	(5,374,661) 3,266,727 329,055 3,595,782 12,360,859 12,360,859	(5,402,289) 3,423,332 344,301 3,767,634 12,848,602	(5.429,917 3.586,394 360,166 3.946.561 13.354,484 13.354,484	3.756.159 376.673 4.132.833 14.101.747	(5,873,704 3,917,143 393,847 4,310,989 15,221,046 15,221,046	(5,893,843) (5,893,843) 4,084,404 411,711 4,496,116 15,776,905	(5,913,981) 4,258,176 430,293 4,688,470 16,352,417 16,352,417	(5,934,120) 4,438,699 449,620 4,888,319 16,948,260 16,948,260	
(r4.289.105) (r4.289.105) (r4.289.105) (r4.289.105) (r5.138.093) (r5.138.093) (r5.288.293) (r5.288.293)<	vircost) in escalated dollars with se initian poter outpy another costs another anothe	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	(44,596,839) 49,625,410 49,625,410 1,581,154 1,581,154 1,581,154 1,58,675 1,740,829 6,148,497 6,148,497	(4,261,944) (4,261,944) 1,652,225 168,840 1,821,065 6,380,099 6,380,099	1.726.137 1.726.137 178.411 1.904.548 6.620.063	(4,319,497) (4,319,497) 1,839,923 188,405 2,028,328 6,942,354 6,942,354	(4,361,944) (4,361,944) 1,958,983 198,934 198,983 198,998 199,998 199,998 199,998 199,998 199,998 199,998 199,998 199,	(4,404,391) 2,083,530 209,727 2,293,257 7,627,585 7,627,585	(4,446,838) 2,213,787 221,090 2,434,877 7,991,571 7,991,571	(4,923,085) (4,923,085) 2,349,985 232,947 2,582,931 9,026,692 9,026,692	(5,220,759) 2,464,494 245,316 2,709,809 9,810,650 9,810,650	2,583,758 258,217 2,841,976 10,195,415	(5.270,082) 2,707,981 271,872 2.979,633 10,594,437	(5,294,743) 2,837,290 285,702 3,122,992 11,008,225 11,008,225	(5,319,405) 2,971,941 300,329 3,272,270 11,437,304	(5,347,033) 3,116,339 314,405 3,430,744 11,890,629	(5,374,661) 3,266,727 329,055 3,595,782 12,360,859 12,360,859	(5,402,289) 3,423,332 344,301 3,767,634 12,848,602	(5.429,917 3.586,394 360,166 3.946.561 13.354,484 13.354,484	3.756.159 376.673 4.132.833 14.101.747	(5,873,704 3,917,143 393,847 4,310,989 15,221,046 15,221,046	(5,893,843) (5,893,843) 4,084,404 411,711 4,496,116 15,776,905	(5,913,981) 4,258,176 430,293 4,688,470 16,352,417 16,352,417	(5,934,120) 4,438,699 449,620 4,888,319 16,948,260 16,948,260	
cost analysis	Vicces) In escalated dollars with se initiana polal cullars molific costs: vicinic Costs: k Receir and Replacement		ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	44,596,839) 49,625,410 49,625,410 1,581,154 15,81,154 19,675 1,740,829 6,148,497 815,406	(4,261,944) (4,261,944) 1,662,225 166,840 1,821,065 6,380,099 6,380,099 839,869	1,726,137 1777,1377 1777,1377 1777,1377 1777,1377 1777,1377 1777,1377 1777,1377 1777,1377 1777,1377 1777,1377 1777,1377 1777,1377 1777,1377,13	1,839,923 188,405 2,028,328 6,942,354 6,942,354 891,017	1.956,983 1.956,983 1.956,983 198,638 2.157,820 7.278,024 7.278,024 917.747	(4,404,391) 2,083,530 209,727 2,293,257 7,827,585 7,627,585 945,279	(4,446,838) 2,213,787 221,090 2,434,877 7,991,571 7,991,571 973,638	(4,923,085) 2,343,985 232,947 2,582,931 9,026,692 1.002,847	(5,220,759) 2,464,494 245,316 2,709,809 9,810,650 9,810,650 1.032,932	2,583,758 258,217 2,841,976 10,195,415 10,195,415 1.063,920	(5.270,082) 2.707.961 271.672 2.979.633 10.594.437 1.095.838	(5,294,743) 2,837,290 285,702 3,122,992 11,008,225 11,008,225 11,008,225	(5,319,405) 2,971,941 300,329 3,272,270 11,437,304 11,437,304 1.162,575	(5,347,033) 3,116,339 314,405 3,430,744 11,890,629 1,197,452	(5.374,661) 3.266,727 329,055 3.595,782 12,360,859 12,360,859 1.233,375	(5.402,289) 3.423,332 3.443,301 3.767,634 12,848,602 1.2,848,602 1.2,70,377	(5,429,917 3,586,394 360,166 3,946,561 13,354,484 13,354,484 1,306,488	3.756,159 3.756,159 376,873 4.132,833 14,101,747 14,101,747 1.347,742	(5,873,794 3,917,143 393,847 4,310,389 15,221,046 15,221,046 15,221,046	(5,993,843) (5,993,843) (5,993,843) (5,993,843) (4,084,404 (411,711) (4,496,116) (15,776,905) (15,776,905) (1,429,820) (1,429,820)	(5,913,981) 4,258,176 430,293 4,688,470 16,352,417 16,352,417 1,472,715	(5,934,120) 4,438,699 449,620 4,888,319 16,948,260 1,516,896	
	ricesal in escalated dollars with se bial outlays metts ricesal ricesa	nsitivity adjust	ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	44,596,839) 49,625,410 49,625,410 49,625,410 1,581,154 159,675 1,740,829 6,148,497 815,406 815,406	1,652,225 168,840 1.821,065 6,380,099 6,380,099 839,869 839,869	(4,277,050) 1,726,137 17,78,1411 1,904,546 6,620,063 865,065 865,065	(4,319,497) 1,839,923 188,405 2,028,328 6,942,354 891.017 891.017	1.956.963 198,838 2.157.820 7.278.024 917.747 917.747	(4.404.391) 2.083.530 209.727 2.293.257 7.627.585 7.627.585 945.279 945.279	(4,446,838) 2.213,767 221,090 2.434,877 7,991,571 973,638 973,638	(4,923,085) 2,349,985 232,947 2,582,931 9,026,692 1,002,847 1,002,847	(5.220,759) 2.464,494 245,316 2.709,809 9,810,650 9,810,650 1.032,932 1,032,932	2,583,758 25,83,758 258,217 2,841,976 10,195,415 10,195,415 1,063,920 1,063,920	(5.270,082) 2,707,961 271,672 2,979,633 10,594,437 10,594,437 1,095,838	(5,294,743) 2,837,290 285,702 3,122,992 11,008,225 1,128,713 1,128,713	(5,319,405) 2,971,941 300,329 3,272,270 11,437,304 11,437,304 1,162,575 1,162,575	(5.347,033) (5.347,033) (5.347,033) (5.3430,744 (11,890,629) (11,890,629) (11,890,629) (11,890,629) (1,197,452) (1,197,452)	(5.374,661) 3.266,727 329,055 3.595,782 12,360,859 1.233,375	(5.402,289) 3.423,332 3.44,301 3.767.634 12.848,602 1.270,377 1.270,377	(5,429,917 (5,429,917 3,596,394 360,166 3,946,561 13,354,484 1,3354,484 1,3354,484	3.756.159 376.873 4.132.833 14.101,747 14.101,747 1.347,742	(5,873,704 3,917,143 393,847 4,310,989 15,221,046 1,388,175	(5,893,843) (5,893,843) (5,893,843) (4,084,404 411,711 (4,496,116 (15,776,905 (1,429,820 (1,429,820) (1,429,820)	(5,913,981) 4,258,176 430,283 4,688,470 16,352,417 1,472,715 1,472,715	(5,934,120) 4,438,639 449,620 16,948,260 16,948,260 1,516,896	
	vircest) in escalated dollars with se polari outlays polari outlays aneffs international costs: it Resair and Reolacement Authalments		ments	14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	44,596,839) 49,625,410 49,625,410 49,625,410 1,581,154 159,675 1,740,829 6,148,497 815,406 815,406	1,652,225 168,840 1.821,065 6,380,099 6,380,099 839,869 839,869	(4,277,050) 1,726,137 17,78,1411 1,904,546 6,620,063 865,065 865,065	(4,319,497) 1,839,923 188,405 2,028,328 6,942,354 891.017 891.017	1.956.963 198,838 2.157.820 7.278.024 917.747 917.747	(4.404.391) 2.083.530 209.727 2.293.257 7.627.585 7.627.585 945.279 945.279	(4,446,838) 2.213,767 221,090 2.434,877 7,991,571 973,638 973,638	(4,923,085) 2,349,985 232,947 2,582,931 9,026,692 1,002,847 1,002,847	(5.220,759) 2.464,494 245,316 2.709,809 9,810,650 9,810,650 1.032,932 1,032,932	2,583,758 25,83,758 258,217 2,841,976 10,195,415 10,195,415 1,063,920 1,063,920	(5.270,082) 2,707,961 271,672 2,979,633 10,594,437 10,594,437 1,095,838	(5,294,743) 2,837,290 285,702 3,122,992 11,008,225 1,128,713 1,128,713	(5,319,405) 2,971,941 300,329 3,272,270 11,437,304 11,437,304 1,162,575 1,162,575	(5.347,033) (5.347,033) (5.347,033) (5.3430,744 (11,890,629) (11,890,629) (11,890,629) (11,890,629) (1,197,452) (1,197,452)	(5.374,661) 3.266,727 329,055 3.595,782 12,360,859 1.233,375	(5.402,289) 3.423,332 3.44,301 3.767.634 12.848,602 1.270,377 1.270,377	(5,429,917 (5,429,917 3,596,394 360,166 3,946,561 13,354,484 1,3354,484 1,3354,484	3.756.159 376.873 4.132.833 14.101,747 14.101,747 1.347,742	(5,873,704 3,917,143 393,847 4,310,989 15,221,046 1,388,175	(5,893,843) (5,893,843) (5,893,843) (4,084,404 411,711 (4,496,116 (15,776,905 (1,429,820 (1,429,820) (1,429,820)	(5,913,981) 4,258,176 430,283 4,688,470 16,352,417 1,472,715 1,472,715	(5,934,120) 4,438,639 449,620 16,948,260 16,948,260 1,516,896	
	In escalated dollars with si in an			14,269,105	14,697,178	15,138,093	31,184,473	32,120,007	44,596,839) 49,625,410 49,625,410 49,625,410 1,581,154 159,675 1,740,829 6,148,497 815,406 815,406	1,652,225 168,840 1.821,065 6,380,099 6,380,099 839,869 839,869	(4,277,050) 1,726,137 17,78,1411 1,904,546 6,620,063 865,065 865,065	(4,319,497) 1,839,923 188,405 2,028,328 6,942,354 891.017 891.017	1.956.963 198,838 2.157.820 7.278.024 917.747 917.747	(4.404.391) 2.083.530 209.727 2.293.257 7.627.585 7.627.585 945.279 945.279	(4,446,838) 2.213,767 221,090 2.434,877 7,991,571 973,638 973,638	(4,923,085) 2,349,985 232,947 2,582,931 9,026,692 1,002,847 1,002,847	(5.220,759) 2.464,494 245,316 2.709,809 9,810,650 9,810,650 1.032,932 1,032,932	2,583,758 25,83,758 258,217 2,841,976 10,195,415 10,195,415 1,063,920 1,063,920	(5.270,082) 2,707,961 271,672 2,979,633 10,594,437 10,594,437 1.095,838	(5,294,743) 2,837,290 285,702 3,122,992 11,008,225 1,128,713 1,128,713	(5,319,405) 2,971,941 300,329 3,272,270 11,437,304 11,437,304 1,162,575 1,162,575	(5.347,033) (5.347,033) (5.347,033) (5.3430,744 (11,890,629) (11,890,629) (11,890,629) (11,890,629) (1,197,452) (1,197,452)	(5.374,661) 3.266,727 329,055 3.595,782 12,360,859 1.233,375	(5.402,289) 3.423,332 3.44,301 3.767.634 12.848,602 1.270,377 1.270,377	(5,429,917 (5,429,917 3,596,394 360,166 3,946,561 13,354,484 1,3354,484 1,3354,484	3.756.159 376.873 4.132.833 14.101,747 14.101,747 1.347,742	(5,873,704 3,917,143 393,847 4,310,989 15,221,046 1,388,175	(5,893,843) (5,893,843) (5,893,843) (4,084,404 411,711 (4,496,116 (15,776,905 (1,429,820 (1,429,820) (1,429,820)	(5,913,981) 4,258,176 430,283 4,688,470 16,352,417 1,472,715 1,472,715	(5,934,120) 4,438,639 449,620 16,948,260 16,948,260 1,516,896	

Total risk-adjusted capital outlays: \$134,500,000 Alternative: 1 Row: 8 Alternative Alt. number Alt. name Risk premium Benefit sens. Capital sens Running sens. Summarv!A8 Summarv!B8 Summarv!C8 Summarv!E8 Summarv!B8 Summarv!B8

	2016		Benefits												mpire Utilities														
Escalation rate Discount rate	3.00%		Capital costs unning costs										L	ife Cycle Alte. Alte	native Cost A native 2 - FW		is)												
			9 L		-										Year														
016 dollars, unescalated	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044
oro donara, unescalated																													
			15,370,000	15,370,000	15,370,000	30,740,000	30,740,000	46,110,000																					
outays			15,370,000	15,370,000	15,370,000	30,740,000	30,740,000	46,110,000																					
								2,271,686	2,304,103	2,336,521	2,413,962	2,491,404	2,568,845	2,646,287	2,723,728	2,771,745	2,819,762	2,867,779	2,915,796	2,956,500	2,956,500	2,956,500	2,956,500	2,956,500	2,956,500	2,956,500	2,956,500	2,956,500	2,956,500
res									133,284											171,273									
ts Costs:								2,401,516	2,437,387	2,473,258	2,554,153	2,635,048	2,715,943	2,796,838	2,877,733	2,929,204	2,980,675	3,032,145	3,083,616	3,127,773	3,130,578	3,133,383	3,136,188	3,138,993	3,141,798	3,144,603	3,147,408	3,150,213	3,153,018
COMA.								6,464,968	6,571,829	6,678,690	6,797,258	6,915,825	6,996,224	7,076,623	7,829,343	7,902,092	7,974,841	8,052,586	8,130,332	8,206,176	8,271,438	8,336,699	8,385,915	8,435,131	8,902,268	8,951,484	9,000,700	4,762,350	4,762,350
q costs								6,464,968	6 674 820	6 678 600	6 707 359	6.045.005	6 006 004	7.076.623	7 820 242	7 000 000	7 074 044	0.050.505	8 4 3 9 3 3 3	0.000 470	0.074.400	0.000	0.305.045	0.435.434	8 000 000	0.054.404	0 000 700	1752 350	4760.050
g costs		I																											
air and Replacement								713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000	713,000
									1	1		l.	I.	1		1		l l	1	1	1		1		l i	l i		1	l
																												1	
st)			(15 270 000)	(15 370 000)	(15 370 000)	(30,740,000)	(20 740 000)	713,000 (50,886,452)						(4,992,785)		713,000						713,000						713,000	
			16,306,033	16,795,214	17,299,070	35,636,085	36,705,168	56,709,484					1																
			16,306,033	16,795,214	17,299,070	35,636,085	36,705,168	56,709,484																					
oufays						35,636,085 35,636,085																							
ouflays								56,709,484 2,793,887	2,918,769	3,048,630	3,244,163	3,448,685	3,662,559		4,119,883	4,318,289	4,524,890	4,740,002	4,963,948	5,184,241	5,339,768	5,499,961	5,664,960	5,834,909	6,009,956	6,190,254	6,375,962	6,567,241	6.764.258
85								56,709,484 2,793,887 159,675	168,840	178,411	188,405	198,838	209,727	221,090	232,947	245,316	258,217	271,672	285,702	300,329	314,405	329,055	344,301	360,166	376,673	393,847	411,711	430,293	449,620
us 5								56,709,484 2,793,887 159,675 2,953,562	168,840 3.087.609	178,411 3.227.041	188,405 3.432.568	198,838 3.647.523	209,727 3.872.286	221,090 4.107.251	232,947 4.352.830	245,316 4,563,604	258,217 4.783.108	271,672 5.011.674	285,702 5.249.650	300,329 5.484.570	314,405 5.654.173	329,055 5.829.016	344,301 6.009.261	360,166 6.195.075	376,673 6.386.629	393,847 6.584.101	411,711 6.787.673	430,293 6.997.534	449,620 7.213.878
us 5								56,709,484 2,793,887 159,675	168,840	178,411	188,405	198,838	209,727	221,090 4.107.251	232,947	245,316	258,217	271,672	285,702	300,329	314,405	329,055	344,301	360,166	376,673	393,847	411,711	430,293	449,620
ioutays res Is (Costs:								56,709,484 2,793,887 159,675 2,953,562	168,840 3.087.609	178,411 3.227.041	188,405 3.432.568	198,838 3.647.523	209,727 3.872.286	221,090 4.107.251	232,947 4.352.830	245,316 4,563,604	258,217 4.783.108	271,672 5.011.674	285,702 5.249.650	300,329 5.484.570	314,405 5.654.173	329,055 5.829.016	344,301 6.009.261	360,166 6.195.075	376,673 6.386.629	393,847 6.584.101	411,711 6.787.673	430,293 6.997.534	449,620 7.213.878
res Is								56,709,484 2,793,887 159,675 2,953,562	168,840 3.087.609	178,411 3.227.041	188,405 3.432.568	198,838 3.647.523	209,727 3.872.286	221,090 4.107.251	232,947 4.352.830	245,316 4,563,604	258,217 4.783.108	271,672 5.011.674	285,702 5.249.650	300,329 5.484.570	314,405 5.654.173	329,055 5.829.016	344,301 6.009.261	360,166 6.195.075	376,673 6.386.629	393,847 6.584.101	411,711 6.787.673	430,293 6.997.534	449,620 7.213.878
res Is								56,709,484 2,793,887 159,675 2,953,562	168,840 3.087.609	178,411 3.227.041	188,405 3.432.568	198,838 3.647.523	209,727 3.872.286	221,090 4.107.251	232,947 4.352.830	245,316 4,563,604	258,217 4.783.108	271,672 5.011.674	285,702 5.249.650	300,329 5.484.570	314,405 5.654.173	329,055 5.829.016	344,301 6.009.261	360,166 6.195.075	376,673 6.386.629	393,847 6.584.101	411,711 6.787.673	430,293 6.997.534	449,620 7.213.878
es s Costs:								56,709,484 2,793,887 159,675 2,953,562 7,951,096	168,840 3.087.609 8,324,997	178,411 3.227.041 8,714,176	188,405 3,432,568 9,134,946	198,838 3.647.523 9,573,119	209,727 3.872.286 9,974,943	221,090 4.107.251	232,947 4.352,830 11,842,583	245,316 4,563,604 12,311,201	258,217 4.783.108 12,797,278	271,672 5.011.674 13,309,698	285,702 5.249.650 13,841,346	300,329 5.484.570 14,389,580	314,405 5.654.173 14,939,136	329,055 5.829.016 15,508,716	344,301 6.009.261 16,068,281	360,166 6.195.075 16,647,462	376,673 6.386.629 18,096,477	393,847 6.584.101 18,742,419	411,711 6.787.673 19,410,831	430,293 6.997,534 10,578,556	449,620 7.213.878 10,895,912
es s Conts:								56,709,484 2,793,887 159,675 2,953,562 7,951,096 7,951,096	168,840 3.087.609 8.324.997 8.324.997	178,411 3.227.041 8,714,176 8,714,176	188,405 3,432,568 9,134,946 9,134,946	198,838 3.647.523 9,573,119 9,573,119	209,727 3.872.286 9,974,943 9.974,943	221,090 4,107,251 10,392,260 10,392,260	232,947 4.352,830 11,842,583 11,842,583	245,316 4,563,604 12,311,201 12,311,201	258,217 4.783.108 12,797,278 12.797,278	271,672 5,011,674 13,309,698 13,309,698	285,702 5 249,650 13,841,346 13,841,346	300,329 5.484.570 14,389,580 14.389,580	314,405 5,654,173 14,939,136 14,939,136	329,055 5.829,016 15,508,716 15,508,716	344,301 6,009.261 16,068,281 16,068,281	360,166 6.195.075 16,647,462 16,647,462	376,673 6.386.629 18,096,477 18,096,477	393,847 6,584,101 18,742,419 18,742,419	411,711 6.787.673 19,410,831 19,410,831	430,293 6.997.534 10,578,556 10,578,555	449,620 7.213,875 10,895,912 10,895,912
es s Costs: g costs								56,709,484 2,793,887 159,675 2,953,562 7,951,096	168,840 3.087.609 8,324,997	178,411 3.227.041 8,714,176	188,405 3,432,568 9,134,946	198,838 3.647.523 9,573,119 9,573,119	209,727 3.872.286 9,974,943 9.974,943	221,090 4,107,251 10,392,260 10,392,260	232,947 4.352,830 11,842,583	245,316 4,563,604 12,311,201	258,217 4.783.108 12,797,278	271,672 5.011.674 13,309,698	285,702 5.249.650 13,841,346	300,329 5.484.570 14,389,580	314,405 5.654.173 14,939,136	329,055 5.829.016 15,508,716	344,301 6.009.261 16,068,281	360,166 6.195.075 16,647,462	376,673 6.386.629 18,096,477	393,847 6,584,101 18,742,419 18,742,419	411,711 6.787.673 19,410,831	430,293 6.997.534 10,578,556 10,578,555	449,620 7.213,875 10,895,912 10,895,912
res Is								56,709,484 2,793,887 159,675 2,953,562 7,951,096 7,951,096	168,840 3.087.609 8.324.997 8.324.997	178,411 3.227.041 8.714,176 8.714,176	188,405 3,432,568 9,134,946 9,134,946	198,838 3.647.523 9,573,119 9,573,119	209,727 3.872.286 9,974,943 9.974,943	221,090 4,107,251 10,392,260 10,392,260	232,947 4.352,830 11,842,583 11,842,583	245,316 4,563,604 12,311,201 12,311,201	258,217 4.783.108 12,797,278 12.797,278	271,672 5,011,674 13,309,698 13,309,698	285,702 5 249,650 13,841,346 13,841,346	300,329 5.484.570 14,389,580 14.389,580	314,405 5,654,173 14,939,136 14,939,136	329,055 5.829,016 15,508,716 15,508,716	344,301 6,009.261 16,068,281 16,068,281	360,166 6.195.075 16,647,462 16,647,462	376,673 6.386.629 18,096,477 18,096,477	393,847 6,584,101 18,742,419 18,742,419	411,711 6.787.673 19,410,831 19,410,831	430,293 6.997.534 10,578,556 10,578,555	449,620 7.213,875 10,895,912 10,895,912
es s Conts:								56,709,484 2,790,887 159,675 2,953,562 7,951,096 7,951,096 876,900	168,840 3.087,609 8,324,997 8,324,997 903,207	178,411 3.227,041 8,714,176 8,714,176 930,303	188,405 3,432,568 9,134,946 9,134,946 9,134,946 958,212	198,838 3,647,523 9,573,119 9,573,119 9,573,119 986,959	209,727 3.872.286 9,974,943 9,974,943 9,974,943 1,016,568	221,090 4,107,251 10,392,260 10,392,260	232,947 4.352,830 11,842,583 11,842,583 11,842,583 1,078,476	245,316 4,553,604 12,311,201 12,311,201 12,311,201 1,110,831	258,217 4.783.108 12,797,278 12,797,278 12,797,278 1,144,156	271,672 5.011.674 13,309,698 13,309,698 13,309,698	285,702 5 249,650 13,841,346 13,841,346 13,841,346 1,213,835	300,329 5.484.570 14,389,580 14,389,580 14,389,580 1,250,250	314,405 5,654,173 14,939,136 14,939,136 14,939,135 1,287,757	329,055 5.829,016 15,508,716 15,508,716 1,326,390	344,301 6,009,261 16,068,281 16,068,281 16,068,281 1,366,182	360,166 6.195.075 16,647,462 16,647,462 1,407,167	376,673 6.386,629 18,096,477 18,096,477 1,449,382	393,847 6.584.101 18,742,419 18,742,419 1,492,864	411,711 6.787.673 19,410,831 19,410,831 19,410,831 1,537,650	430,293 6.997.534 10,578,556 10,578,555	449,620 7.213.875 10,895,912 10,895,912 1,631,292
es s Conts:			16,306,033	16,795,214	17,299,070		36,705,168	56,709,454 2,793,887 159,875 2,953,552 7,951,096 7,951,096 876,900	168.840 3.087.609 8.324.997 8.324.997 903.207 903.207	178,411 3,227,041 8,714,176 8,714,176 930,303 930,303	188,405 3,432,568 9,134,946 9,134,946 958,212 958,212	198,838 3,647,523 9,573,119 9,573,119 986,959 986,959	209,727 3.872.286 9,974,943 9,974,943 1,016,568 1,016,568	221,090 4.107.251 10,392,260 10,392,260 1,047,065 1,047,065	232,947 4.352,830 11,842,583 11,842,583 1,078,476 1,078,476	245,316 4,553,604 12,311,201 12,311,201 1,110,831 1,110,831	258,217 4.783.108 12,797,278 12,797,278 1,144,156 1,144,156	271,672 5.011.674 13,309,698 13,309,698 1,178,480	285,702 5 249,650 13,841,346 13,841,346 1,213,836 1,213,835	300,329 5.484.570 14,389,580 14,389,580 14,389,580 1,250,250 1,250,250	314,405 5.654,173 14,939,136 14,939,136 1,287,757 1,287,757	329,055 5.829.016 15,508,716 15,508,716 1,326,390 1,326,390	344,301 6,009,261 16,068,281 16,068,281 1,366,182 1,366,182	360,166 6.195.075 16,647,462 16,647,462 1,407,167 1,407,167	376,673 6.386,629 18,096,477 18,096,477 1,449,382 1,449,382	393,847 6,584,101 18,742,419 18,742,419 1,492,864 1,492,864	411,711 6,787,673 19,410,831 19,410,831 1,537,650 1,537,650	430,293 6.997.534 10,578,556 10,578,556 1,583,779 1,583,779	449,620 7,213,879 10,895,912 1,631,292 1,631,292
s Costs: ir and Replacement anelfe(cost)			16,306,033	16,795,214	17,299,070	35,636,085	36,705,168	56,709,454 2,793,887 159,875 2,953,552 7,951,096 7,951,096 876,900	168.840 3.087.609 8.324.997 8.324.997 903.207 903.207	178,411 3,227,041 8,714,176 8,714,176 930,303 930,303	188,405 3,432,568 9,134,946 9,134,946 958,212 958,212	198,838 3,647,523 9,573,119 9,573,119 986,959 986,959	209,727 3.872.286 9,974,943 9,974,943 1,016,568 1,016,568	221,090 4.107.251 10,392,260 10,392,260 1,047,065 1,047,065	232,947 4.352,830 11,842,583 11,842,583 1,078,476 1,078,476	245,316 4,553,604 12,311,201 12,311,201 1,110,831 1,110,831	258,217 4.783.108 12,797,278 12,797,278 1,144,156 1,144,156	271,672 5.011.674 13,309,698 13,309,698 1,178,480	285,702 5 249,650 13,841,346 13,841,346 1,213,836 1,213,835	300,329 5.484.570 14,389,580 14,389,580 14,389,580 1,250,250 1,250,250	314,405 5.654,173 14,939,136 14,939,136 1,287,757 1,287,757	329,055 5.829.016 15,508,716 15,508,716 1,326,390 1,326,390	344,301 6,009,261 16,068,281 16,068,281 1,366,182 1,366,182	360,166 6.195.075 16,647,462 16,647,462 1,407,167 1,407,167	376,673 6.386,629 18,096,477 18,096,477 1,449,382 1,449,382	393,847 6,584,101 18,742,419 18,742,419 1,492,864 1,492,864	411,711 6,787,673 19,410,831 19,410,831 1,537,650 1,537,650	430,293 6.997.534 10,578,556 10,578,556 1,583,779 1,583,779	449,620 7,213,879 10,895,912 1,631,292 1,631,292
ss Costs: costs			16,306,033	16,795,214 (16,795,214)	17,299,070	35,636,085	36,705,168	56.709.484 2.793.887 159.675 2.953.562 7.951.096 7.951.096 876.900 876.900 876.900	168,840 3.087.609 8.324.997 8.324.997 903,207 903,207 (6.140,595)	178,411 3.227,041 8,714,176 8,714,176 930,303 930,303 (6,417,439)	188,405 3.432.568 9,134.946 9,134.946 958,212 958,212 (6,660.590)	198,838 3.647.523 9.573.119 9.573.119 965,959 966,959 (6.512.555)	209,727 3.872 286 9.974.943 9.974.943 1.016.568 1.016.568 (7.119.225	221,090 i 4.107.251 10,392,260 i 10,392,260 i 10,392,260 i 10,392,260 i 10,392,260 i 10,392,260 i 1,047,065 i 1,047,065 i 1,047,065	232,947 4.352,830 11,842,583 11,842,583 1,078,476 (8.568,230)	245,316 4,553,604 12,311,201 12,311,201 1,2311,201 1,110,831 (8,858,428)	258,217 4.783,108 12,797,278 12,797,278 1,144,156 (9,158,326)	271,672 5.011.674 13.309,698 13.309,698 1.178,480 1.178,480 (9.476,505)	285,702 5 249,650 13,841,346 13,841,346 1,213,835 1,213,835 (9,805,531)	300,329 5,484,570 14,389,580 14,389,580 14,389,580 1,250,250 1,250,250 (10,155,260)	314,405 5,654,171 14,939,136 14,939,136 1,287,757 (10,572,721)	329,055 5,829,016 15,508,716 15,508,716 1,508,716 1,326,390 (11,006,090)	344,301 6,009,261 16,068,281 16,068,281 1,366,182 1,366,182 (11,425,201)	360,166 6.195,075 16,647,462 16,647,462 1,407,167 1,407,167 (11,859,554)	376,673 6.386.629 18.096.477 18.096.477 1.449,382 1,449,382 (13.159.230)	393,847 6.584.101 18,742,419 18,742,419 1,492,864 1,492,864 (13,651,182)	411,711 6.787.673 19,410,831 19,410,831 19,410,831 1,537,650 (14,160,807)	430,293 6.997.534 10,578,556 10,578,556 10,578,556 1,583,779 1,583,779 1,583,779 1,583,779	449,620 7.213,879 10,895,912 1,631,292 1,631,292 (5,313,327

Totat nisk-adjustid capital outsiny: \$153,700,000 Atematik: 2 Ros: 9 Summay/84 Summay/89 At. name Summay/69 At. name Summay/69 Risk preminue Summay/19 Risk preminue Summay/19 Risk preminue Summay/19 Risk preminue

Discount rate	3.00% 2.00%		Capital costs Running costs										L		mative Cost Ar)												
	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	Year 2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044
unescalated																													
			14,640,000	14,640,000	14,640,000	29,280,000	29,280,000	43,920,000																					
			14.640.000	14.640.000	14,640,000	29,280.000	29.280.000	43.920.000																					
								2,956,500	2,956,500	2.956.500	2,956,500	2.956.500	2.956.500	2,956,500	2.956.500	2,956,500	2,956,500	2,955,500	2.956.500	2,956,500	2,956,500	2.956.500	2.956.500	2.956.500	2,956,500	2,956,500	2.956.500	2,956,500	2,95
								129,830	133,284	136,737	140,191	143,644	147,098	150,552	154,005	157,459	160,913	164,366	167,820	171,273	174,078	176,883	179,688	182,493	185,298	188,103	190,908	193,713	19
								3,086,330	3,089,784	3,093,237	3,096,691	3,100,144	3,103,598	3,107,052	3,110,505	3,113,959	3,117,413	3,120,866	3,124,320	3,127,773	3,130,578	3,133,383	3,136,188	3,138,993	3,141,798	3,144,603	3,147,408	3,150,213	3,15
								7,408,847	7,453,225	7,497,603	7,585,646	7,673,690	7,761,733	7,849,776	8,371,620	8,689,161	8,746,182	8,803,203	8,860,225	8,917,246	8,978,315	9,039,383	9,100,452	9,161,521	9,332,090	9,666,639	9,714,669	9,762,699	9,81
L						L		7,408,847	7,453,225	7,497,603	7,585,646	7,673,690	7,761,733	7,849,776	8,3/1,620	8,689,161	8,746,182	8,803,203	8,860,225	8,917,246	8,9/8,315	9,039,383	9,100,452	9,161,521	9,332,090	9,666,639	9,714,669	9,762,699	9,8
								833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	833,000	8
								833,000	833,000			833,000				833,000	833,000	833,000		833,000	833,000	833,000		833,000	833,000	833,000	833,000	833,000	
			(14.640.000)	(14.640.000)	(14.640.000)	(29.280.000)	(29,280,000)	833,000 (49,075,517)							833,000 (6,094,114)		833,000 (6.461.770)		833,000 (6,568,905)	833,000 (6.622.473)					833,000 (7.023.291)	833,000 (7.355.036)			
	- Contemporte		(14.640.000)	(14,640,000)	(14.640.000)	(29.280.000)	(29,280,000)																						
llars with sensitivity a	adiustments		(14.640.000)	(14.640.000)	(14.640.000)	(29.280.000)	(29,280.000)																						
llars with sensitivity a	adiustments		(14.640.000) 15,531,576	(14.640.000) 15,997,523	(14.640.000)		(29.280.000) 34,961,851																						
llars with sensitivity a	adiustments							(49.075.517)																					
llars with sensitivity a	adiustments							(49.075.517)																					
llars with sensitivity a	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	(49.075.517) 54,016,060																					
llars with sensitivity a	adiustments		15,531,576		16,477,449	33,943,545	34,961,851	(49.075.517)																					
Ilars with sensitivity a	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	(49.075.517) 54,016,060 54,016,060 3,636,122	(5.196.441)	(5.237.365) 3,857,562	(5.321.955)	(5.406.545)	(5.491.135) 4,215.262	(5.575.725) 4,341,720	(6.094.114) (6.094.114)	(6.408.2021 4.606,131	(6.461.770) 4.744.315	(6.515.337) 4,885,644	16.568.9051	(6.622.473) 5.184.241	(6.680.736)	(6.739.000) 5,499,961	(6.797.264) 5,864.960	(6.855.528) 5.834,309	6,009,956	(7.255.038) 6,190,254	(7.490.261) 6,375,962	6,567,241	6,7
llars with sonsitivity a	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	(49.075.517) 54,016,060 54.016,060 3,636,122 159,675	(5.196.441) 3.745,206 168,840	(5.237.365) 3,857,562 178,411	(5.321.955) (5.321.955) (5.321.955) (5.321.955) (5.321.955)	(5.406.545) 4.092,487 198,838	(5.491.135) 4,215,262 209,727	(5.575.725) (5.575.725) (5.575.725) (5.575.725) (5.575.725) (5.575.725) (5.575.725) (5.575.725)	4,471,972 232,947	46.408.2021 4,606,131 245,316	45.461.7701 4,744,315 258,217	(6.515.337) (6.515.337) 4,886,644 271,672	(6.568.905) (6.568	6.622.473) 5,184,241 300,329	(6.580,736) 5.339,768 314,405	(6.739.000) (6.739.000) (6.739.000) (6.739.000) (6.739.000) (6.739.000) (6.739.000)	(6.797.264) 5,664.960 344,301	6.855.528) (6.855.528) 5.834,309 360,166	(7.023.291) 6,009,956 376,673	(7.355.036) 6,190,254 393,847	(7.400.261) 6,375,962 411,711	6,567,241 430,293	6,7
flars with sensitivity a	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	(49.075.517) 54,016,060 54,016,060 3,636,122	(5.196.441) 3.745,206 168,840	(5.237.365) 3,857,562 178,411	(5.321.955) (5.321.955) (5.321.955) (5.321.955) (5.321.955)	(5.406.545) 4.092,487 198,838	(5.491.135) 4,215,262 209,727	(5.575.725) (5.575.725) (5.575.725) (5.575.725) (5.575.725) (5.575.725) (5.575.725) (5.575.725)	(6.094.114) (6.094.114)	46.408.2021 4,606,131 245,316	(6.461.770) 4.744.315	(6.515.337) (6.515.337) 4,886,644 271,672	16.568.9051	(6.622.473) 5.184.241	(6.580,736) 5.339,768 314,405	(6.739.000) 5,499,961	(6.797.264) 5,664.960 344,301	(6.855.528) 5.834,309	(7.023.291) 6,009,956 376,673	(7.255.038) 6,190,254	(7.400.261) 6,375,962 411,711	6,567,241 430,293	(7.45 6,76 44
	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	(49.075.517) 54,016,060 54.016,060 3,636,122 159,675	(5.196.441) 3.745,206 168,840	(5.237.365) 3,857,562 178,411	(5.321.955) (5.321.955) (5.321.955) (5.321.955) (5.321.955)	(5.406.545) 4.092,487 198,838	(5.491.135) 4,215,262 209,727	(5.575.725) (5.575.725) (5.575.725) (5.575.725) (5.575.725) (5.575.725) (5.575.725) (5.575.725)	4,471,972 232,947	46.408.2021 4,606,131 245,316	45.461.7701 4,744,315 258,217	(6.515.337) (6.515.337) 4,886,644 271,672	(6.568.905) (6.568	6.622.473) 5,184,241 300,329	(6.580,736) 5.339,768 314,405	(6.739.000) (6.739.000) (6.739.000) (6.739.000) (6.739.000) (6.739.000) (6.739.000)	(6.797.264) 5,664.960 344,301	6.855.528) (6.855.528) 5.834,309 360,166	(7.023.291) 6,009,956 376,673	(7.355.036) 6,190,254 393,847	(7.400.261) 6,375,962 411,711	6,567,241 430,293	6,76 44 7.21
flars with sensitivity a	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	(49.075.517) 54.016.060 54.016.060 3.636,122 159.675 3.795.797	(5.196.441) 3,745,206 168,840 3,914.045	(5.237.365) 3,857,562 178,411 4,035.973	(5.321,955) (5.321	(5.406.545) 4,092,487 198,838 4,291,325	(5.491.135) (5.491.135) 4.215.262 209,727 4.424.989	(5.575.725) (5.575	(5.094.114) (5.094.114) 4,471.972 232.947 4.704.918	46.408.2021 4,606,131 245,316 4,851,447	(5.461.770) 4,744.315 258.217 5.002.532	(6.515.337) (6.515.337) 4.886,644 271,672 5.158.316	6.5683051 6.5033,243 285,702 5.318,945	(6.622.473) 5,184,241 300,329 5,484.570	(6.580,736) 5,339,768 314,405 5,654,173	(6.739.000) (6.730	(6.797.264) (6.797.264) 5,664.960 344.301 6.009.261	6,855,528 6,855,528 5,834,309 360,166 6,195,075	(7,023,291) (7,023,291) (6,009,956 (3,76,673) (6,386,629)	(7.355.035) 6.190,254 393,847 6.584.101	(7.400.261) 6,375,962 411,711 6,787,673	(7.445.485) (7.445.485) (6.567.241 (4.30.293) (6.997.534)	(7.4) 6,7) 4 7.2
	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	(49.075.517) 54.016.060 54.016.060 3.636,122 159.675 3.795.797	(5.196.441) 3,745,206 168,840 3,914.045	(5.237.365) 3,857,562 178,411 4,035.973	(5.321,955) (5.321	(5.406.545) 4,092,487 198,838 4,291,325	(5.491.135) (5.491.135) 4.215.262 209,727 4.424.989	(5.575.725) (5.575	(5.094.114) (5.094.114) 4,471.972 232.947 4.704.918	46.408.2021 4,606,131 245,316 4,851,447	(5.461.770) 4,744.315 258.217 5.002.532	(6.515.337) (6.515.337) 4.886,644 271,672 5.158.316	6.5683051 6.5033,243 285,702 5.318,945	(6.622.473) 5,184,241 300,329 5,484.570	(6.580,736) 5,339,768 314,405 5,654,173	(6.739.000) (6.730	(6.797.264) (6.797.264) 5,664.960 344.301 6.009.261	6,855,528 6,855,528 5,834,309 360,166 6,195,075	(7,023,291) (7,023,291) (6,009,956 (3,76,673) (6,386,629)	(7.355.035) 6.190,254 393,847 6.584.101	(7.400.261) 6,375,962 411,711 6,787,673	(7.445.485) (7.445.485) (6.567.241 (4.30.293) (6.997.534)	(7.4) 6,7) 4 7.2
Aars with sensitivity a	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	(49.075.517) 54.016.060 54.016.060 3.636,122 159.675 3.795.797	(5.196.441) 3,745,206 168,840 3,914.045	(5.237.365) 3,857,562 178,411 4,035.973	(5.321,955) (5.321	(5.406.545) 4,092,487 198,838 4,291,325	(5.491.135) (5.491.135) 4.215.262 209,727 4.424.989	(5.575.725) (5.575	(5.094.114) (5.094.114) 4,471.972 232.947 4.704.918	46.408.2021 4,606,131 245,316 4,851,447	(5.461.770) 4,744.315 258.217 5.002.532	(6.515.337) (6.515.337) 4.886,644 271,672 5.158.316	6.5683051 6.5033,243 285,702 5.318,945	(6.622.473) 5,184,241 300,329 5,484.570	(6.580,736) 5,339,768 314,405 5,654,173	(6.739.000) (6.730	(6.797.264) (6.797.264) 5,664.960 344.301 6.009.261	6,855,528 6,855,528 5,834,309 360,166 6,195,075	(7,023,291) (7,023,291) (6,009,956 (3,76,673) (6,386,629)	(7.355.035) 6.190,254 393,847 6.584.101	(7.400.261) 6,375,962 411,711 6,787,673	(7.445.485) (7.445.485) (6.567.241 (4.30.293) (6.997.534)	6,76 44 7.21
	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	(49.075.517) 54.016.060 54.016.060 3.636,122 159.675 3.795.797	(5.196.441) 3,745,206 168,840 3,914.045	(5.237.365) 3,857,562 178,411 4,035.973	(5.321,955) (5.321	(5.406.545) 4,092,487 198,838 4,291,325	(5.491.135) (5.491.135) 4.215.262 209,727 4.424.989	(5.575.725) (5.575	(5.094.114) (5.094.114) 4,471.972 232.947 4.704.918	46.408.2021 4,606,131 245,316 4,851,447	(5.461.770) 4,744.315 258.217 5.002.532	(6.515.337) (6.515.337) 4.886,644 271,672 5.158.316	6.5683051 6.5033,243 285,702 5.318,945	(6.622.473) 5,184,241 300,329 5,484.570	(6.580,736) 5,339,768 314,405 5,654,173	(6.739.000) (6.730	(6.797.264) (6.797.264) 5,664.960 344.301 6.009.261	6,855,528 6,855,528 5,834,309 360,166 6,195,075	(7,023,291) (7,023,291) (6,009,956 (3,76,673) (6,386,629)	(7.355.035) 6.190,254 393,847 6.584.101	(7.400.261) 6,375,962 411,711 6,787,673	(7.445.485) (7.445.485) (6.567.241 (4.30.293) (6.997.534)	6,76 44 7.21
Bars with sensitivity a	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	(49.075.517) 54.016.060 54.016.060 3.636,122 159.675 3.795.797	(5.195.441) 3.745.206 168,840 3.914.045 9,441,523	65.227.365) 3.857.562 178,411 4.035.973 9.782,671	(5.321.955) 3.9773.280 188,405 4.161.694 10,194,474	(5.405.545) 4.092,487 198,838 4.291.325 10,622,181	4.215,282 208,727 4.424.389 11,066,375	4.541,720 4.341,720 221,090 4.552,810 11,527,661	(5.094.114) (5.094.114) 4,471.972 232.947 4.704.918	(6.498.202) 4.606.131 245,316 4.851.447 13.537,430	(5.461.770) 4,744.315 258.217 5.002.532	(6.515.337) 4.586.544 271,672 5.158.316 14.550,354	6.5683051 6.5033,243 285,702 5.318,945	(6.522.473) 5.184.241 300,329 5.684.570 15,636,445	(6.680.736) 5.339.766 314,405 5.654.173 16,215,835	(6.739.000) 5,499.961 329,055 5,829.016 16,815,916	(6.797.264) 5.664.960 344.301 6.009.261 17,437,407	6,855,528 6,855,528 5,834,309 360,166 6,195,075	(7.023.291) 6.009.356 376.673 6.386.629 18.970.217	(7.355.035) 6.190,254 393,847 6.584.101	(7.420.261) 6.375,962 411,711 6.787.673 20,950,570	(7.465.485) 6.567.241 430.293 6.997.534 21,665.775	6.74 6.77 44 7.21
	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	49.075.577) 54.016.060 3.088.122 155.675 3.795.797 9.111.948	(5.196,441) 3,745,206 166,840 3,914,045 9,441,523 9,441,523	6.227.365) 3.857.562 178.411 9.782.671 9.782.671	(6.321.955) 3.973.289 188.405 4.161.694 10,194.474	(5.405.545) 4.092,487 198,838 4.291,325 10,622,181	4.215.262 209.727 4.424.389 11.066.375	4.341,720 221,030 4.562.810 11.527,661	(6.0%,114) (6.0%,114)	6.498.2021 4.606,131 245,316 4.851,447 13.537,430	(6,461,770) 4,744,315 258,217 5,002,532 14,035,055	(6.515.337) 4,886,644 271,672 5.158,316 14,550,354	6.588.803	(6.622.473) 5.184,241 300,329 5.484,570 15,636,445	(6.680.736) (6.680.736) 5.339.768 314.405 5.654.173 16.215.836 16.215.836	(6.739.000) 5,499.961 329.055 5,829.016 16,815.916	6,797,264 5,664,960 344,301 17,437,407 17,437,407	6.855 528 5.854,000 360,166 6.195,075 18.081,054	77.023.2911	(7.355.036) 6,190,254 393,847 6,584.101 20,239,796 20,239,796	(7.460.261) 6.375.962 411.711 6.787.673 20.950.570 20.950.570	(7.445.485) (7.455.485) (7.455.485) (7.455.485) (7.455.485) (7.455.485) (7.455	6,7 4 7.2 22,4
	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	(49.075.517) 54.016.060 54.016.060 3.636.127 150.627 3.795.797 9.111.948	(5.196.441) 3.745.206 168,840 3.914.045 9.441,523	65.227.365) 3.857.562 178,411 4.035.973 9.782,671	(5.321.955) 3.9773.280 188,405 4.161.694 10,194,474	(5.405.545) 4.092,487 198,838 4.291.325 10,622,181	4.215,282 208,727 4.424.389 11,066,375	4.541,720 4.341,720 221,090 4.552,810 11,527,661	4,471,372 232,947 4,704,918 12,662,826	(6.498.202) 4.606.131 245,316 4.851.447 13.537,430	(6.461,770) 4,744,315 258,217 5,002,532 14,035,055	(6.515.337) 4.586.544 271,672 5.158.316 14.550,354	(6.568.905) 5.033,243 285,702 5.318,945 15,083,939	(6.522.473) 5.184.241 300,329 5.684.570 15,636,445	(6.680.736) 5.339.766 314,405 5.654.173 16,215,835	(6.739.000) 5,499.961 329,055 5,829.016 16,815,916	(6.797.264) 5.664.960 344.301 6.009.261 17,437,407	66.855.5281 5.834.009 360,166 6.195.075 18.081,054	(7.023.291) 6.009.356 376.673 6.386.629 18.970.217	(7.355.036) 6.190.254 393,847 6.584.101 20,239,796	(7.480.261) 6.375,962 4.11,711 6.787,673 20,950,570	(7.465.485) 6.567.241 430.293 6.997.534 21,665.775	6.76 44 7.21 22,44
	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	49.075.577) 54.016.060 3.088.122 155.675 3.795.797 9.111.948	(5.196,441) 3,745,206 166,840 3,914,045 9,441,523 9,441,523	6.227.365) 3.857.562 178.411 9.782.671 9.782.671	(6.321.955) 3.973.289 188.405 4.161.694 10,194.474	(5.405.545) 4.092,487 198,838 4.291,325 10,622,181	4.215.262 209.727 4.424.389 11.066.375	4.341,720 221,030 4.562.810 11.527,661	(6.0%,114) (6.0%,114)	6.498.2021 4.606,131 245,316 4.851,447 13.537,430	(6,461,770) 4,744,315 258,217 5,002,532 14,035,055	(6.515.337) 4,886,644 271,672 5,158,316 14,550,354	6.588.803	(6.622.473) 5.184,241 300,329 5.484,570 15,636,445	(6.680.736) (6.680.736) 5.339.768 314.405 5.654.173 16.215.836 16.215.836	(6.739.000) 5,499.961 329.055 5,829.016 16,815.916	6,797,264 5,664,960 344,301 17,437,407 17,437,407	6.855 528 5.854,000 360,166 6.195,075 18.081,054	77.023.2911	(7.355.036) 6,190,254 393,847 6,584.101 20,239,796 20,239,796	(7.460.261) 6.375.962 411.711 6.787.673 20.950.570 20.950.570	(7.445.485) (7.455.485) (7.455	6.76 44 7.21 22,44
	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851	44.075.577 54.016.080 34.016.080 3.058.122 1558.75 3.795.797 9.111.948 9.111.948 1.024.485	(5.196,441) 3,745,206 168,840 3,914,045 9,441,523 9,441,523 1,055,219	6.237.365) 3.857.562 178.411 4.035.973 9.782.671 9.782.671 1.086.876	10,194,474 1,119,482	(5.466.545) 4,092,487 198,838 4,291,325 10,622,181 10,622,181 1,153,067	4.215.262 2097.727 4.424.369 11,066.375 1,187,669	4,541,720 221,030 4,562,810 11,527,661 11,527,661 1,223,289	4,471,972 232,947 4,764,918 12,662,826 12,662,826 1,259,987	6.498 2021 4.606,131 245,316 4.851,447 13.537,430 13.537,430 1.297,787	6.461.770 4.744.315 258.217 5.002.532 14.035.055 14.035.055 1.336.720	4,886,644 271,672 5,158,316 14,550,354 14,550,354 1,376,822	6.568.303	6. 622 4731 5.184,241 300,329 5.484,570 15,636,445 15,636,445 1,660,671	(6.680.736) (6.680	6,739,000 5,499,961 329,055 5,829,016 16,815,916 16,815,916 1,549,625	6,797,244 5,664,960 344,301 6,009,261 17,437,407 1,696,114	68.855.528 5.854.000 360.166 6.195.075 18.081.054 18.081.054 1.643.996	(7,023,291) 6,009,396 376,673 6,386,629 18,970,217 18,970,217 1,699,317	77.355.0350 6.190.254 393.847 6.584.101 20.239.796 20.239.796 1.744.117	6,375,982 411,711 6,787,982 411,711 20,960,570 20,960,570 1,796,441	(7.445.485) (7.445.485) (6.567.241 (4.30.293 (4.997.534) (21.685.775) (21.685.775) (3.850.334)	(7.44 6.77 4/ 7.2: 22.4/ 1.90
	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851 34,961,851	44.075.517) 54.016.060 54.016.060 3.084.122 159.075 3.757.77 9.111.946 9.111.946 1.024.485	(5.196,441) 3.745,206 168,840 3.914,045 9,441,523 1,055,219	65.237.365) 1.857.692 178,411 4.035.973 9,782.671 9,782.671 1.086.876 1.086.876	10,194,474 10,194,474 10,194,474	4,052,487 4,052,487 198,838 4,291,325 10,622,181 10,622,181 1,153,067	6.491.135) 4.215.282 200,727 4.424.989 11,066.375 1,187,659	4.541,720 4.341,720 221,090 4.562,810 11,527,661 11,527,661 1,223,289	(6.094.114) (6.094.114) (6.094.114) (4.011.977 (222.97 (222.97 (222.97) (222.97) (220.97) (12.662.826) (12.66	6.498.2021 4.606.131 246,316 4.851.447 13,537,430 12,537,430 1,297,787	6.451.770 4.744.315 258.217 5.00.235.055 14.035.055 1.336.720 1.336.720	(6.515.337) 4,888,644 271,872 5.158,376 14,550,354 14,550,354 1,376,822	15.083.939 15.083.939 15.083.939 15.083.939 14.18,127 14.18,127	6. 672 473) 6. 672 473) 6. 194 241 300,329 5. 694 570 15. 636,445 1. 660,671 1. 660,671	(6.680.736) 5.330,760 314,405 5.654,173 16.215,835 15.215,835 1.504,491 1.504,491	6, 739,000 6, 499,561 5, 499,561 5, 515,916 16, 515,916 1, 549,625 1, 549,625	6,797,264 6,797,264 5,664,360 344,301 6,609,261 17,437,407 1,596,114 1,596,114	6,855 528 5,834 509 5,834 509 360,166 18,081,054 18,081,054 18,081,054 18,081,054 1,643,988 1,643,988	6,000 866 376,673 6,870,217 18,970,217 18,970,217 1,690,317	77.355.036) 6.190.254 393,847 6.584.101 20.239,796 20.239,796 1.744,117 1.744,117	7.460.2611 6.375.962 411.711 2.0.950.570 20.950.570 1.756.441	07.445.4851 0.557.241 4.30.203 6.997.334 21.685.775 1.850.334 1.850.334	(7.45 6.7% 4 22,44 22,44 1.90 1.90
	adiustments		15,531,576	15,997,523	16,477,449	33,943,545	34,961,851 34,961,851	44.075.517) 54.016.060 54.016.060 3.084.122 159.075 3.757.77 9.111.946 9.111.946 1.024.485	(5.196,441) 3.745,206 168,840 3.914,045 9,441,523 1,055,219	65.237.365) 1.857.692 178,411 4.035.973 9,782.671 9,782.671 1.086.876 1.086.876	10,194,474 10,194,474 10,194,474	4,052,487 4,052,487 198,838 4,291,325 10,622,181 10,622,181 1,153,067	6.491.135) 4.215.282 200,727 4.424.989 11,066.375 1,187,659	4.541,720 4.341,720 221,090 4.562,810 11,527,661 11,527,661 1,223,289	(6.094.114) (6.094.114) (6.094.114) (4.011.977 (222.97 (222.97 (222.97) (222.97) (220.97) (12.662.826) (12.66	6.498.2021 4.606.131 246,316 4.851.447 13,537,430 12,537,430 1,297,787	6.451.770 4.744.315 258.217 5.00.235.055 14.035.055 1.336.720 1.336.720	(6.515.337) 4,888,644 271,872 5.158,376 14,550,354 14,550,354 1,376,822	15.083.939 15.083.939 15.083.939 15.083.939 14.18,127 14.18,127	6. 672 473) 6. 672 473) 6. 194 241 300,329 5. 694 570 15. 636,445 1. 660,671 1. 660,671	(6.680.736) 5.330,760 314,405 5.654,173 16.215,835 15.215,835 1.504,491 1.504,491	6, 739,000 6, 493,05 5, 493,05 5, 523,016 16, 815,916 16, 815,916 1, 549,625 1, 549,625	6,797,264 6,797,264 5,664,360 344,301 6,609,261 17,437,407 1,596,114 1,596,114	6,855 528 5,834 509 5,834 509 360,166 18,081,054 18,081,054 18,081,054 18,081,054 1,643,988 1,643,988	6,000 866 376,673 6,870,217 18,970,217 18,970,217 1,690,317	77.355.036) 6.190.254 393,847 6.584.101 20.239,796 20.239,796 1.744,117 1.744,117	7.460.2611 6.375.962 411.711 2.0.950.570 20.950.570 1.756.441	07.445.4851 0.557.241 4.30.203 6.997.334 21.685.775 1.850.334 1.850.334	6,76 44 22,44 1,90

RP-5 Digester Gas Utilization

Inland Empire Utilities Agency



Alternatives Net Present Value Analysis

Agency:	Inland Empire Utilities Agency	┇[R	esults (\$000s)	
Project/Problem:			Capital Cost	30-year NPV	Benefit over 'Do Nothing'
Alternative 1	DG Alt 1 - Existing IC Engines		\$7,932,000	\$17,994,618	
Alternative 2	DG Alt 2 - Microturbines		\$29,844,000	\$40,984,453	\$22,989,836
Alternative 3	DG Alt 3 - Centralized Cogen w/ Gas Turbines		\$67,500,000	\$49,994,494	\$31,999,876
Alternative 4	DG Alt 4 - RNG for Pipeline Injection		\$20,847,600	\$2,418,047	(\$15,576,571)
Alternative 5	DG Alt 5 - CNG for Vehicle Fuel	ΠΓ	\$19,620,000	\$57,917,283	\$39,922,665
., , , , .					

Year of analysis: Escalation rate: Discount rate:

s:	2016
e:	3.00%
e:	2.00%

Discount rate	3.00% 2.00%		ning costs													Analysis (\$ isting IC En													
d in 2016 dollars, unescalated	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	ar 2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044
in 2016 dollars, unescalated avs																													
			793,200	793,200	793,200	1,586,400	1,586,400	2,379,600																					
tal outlays			793,200	793,200	793,200	1,586,400	1,586,400	2,379,600																					
luction from RP-5 biogas luction from RP-5 SHF gas								1,285,623 1,670,877	1,304,282 1,652,218	1,322,940 1,633,560	1,369,075	1,415,211 1,541,289	1,461,346	1,507,481 1,449,019	1,553,617 1,402,883	1,581,865	1,610,113 1,346,387	1,638,361	1,666,609 1,289,891	1,694,857	1,725,442	1,756,027 1,200,473	1,786,612 1,169,888	1,817,196 1,139,304	1,847,781 1,108,719	1,870,849 1,085,651	1,893,917	1,916,984 1,039,516	1,940,052
very (total)								129,830	133,284	136,737	1,567,425	143,644	1495,154	150,552	1,402,883	1,374,035	160,913	164,366	167,820	1,201,043	174,078	176,883	179,688	182,493	185,298	188,103	190,908	193,713	196,518
efits								0.000.000	0.000 704	0.000.007	0.000.004	3,100,144	0.400.500	0.407.050	0.440.505	0.440.050	0.447.440	0.400.000	0.404.000	0.407.770	0.400.570	0.400.000	0.400.400	0.400.000	0.4.44 700	0.444.000	0.4.17.400	0.450.040	0.450.040
ing Costs:	L I							3,086,330	3,069,784	3,093,237	3,096,691	3,100,144	3,103,596	3,107,052	3,110,505	3,113,959	3,117,413	3,120,866	3,124,320	3,127,773	3,130,578	3,133,383	3,130,100	3,138,993	3,141,798	3,144,603	3,147,408	3,150,213	3,153,018
ad - RP-5 biogas								142,847	144,920	146,993	152,119	157,246	162,372	167,498	172,624	175,763	178,901	182,040	185,179	188,317	191,716	195,114	198,512	201,911	205,309	207,872	210,435	212,998	215,561
ad - RP-5 SHF gas e								185,653 473,040	183,580 473,040	181,507	176,381 473.040	171,254 473,040	166,128 473,040	161,002 473,040	155,876 473,040	152,737 473,040	149,599 473,040	146,460 473,040	143,321 473,040	140,183 473,040	136,784 473,040	133,386 473.040	129,988 473,040	126,589 473,040	123,191 473,040	120,628 473,040	118,065 473,040	115,502 473,040	112,939 473,040
								4/0,040	410,040	410,040	470,040	4/0,040	410,040	410,040	470,040	470,040	4/0,040	470,040	4/0,040	470,040	410,040	4/0,040	470,040	4/0,040	4/0,040	410,040	4/0,040	470,040	4/0,040
ing costs								801.540	801.540	801.540	801.540	801,540	801.540	801 540	801.540	801 540	801.540	801 540	801.540	801.540	801.540	801.540	801.540	801.540	801.540	801.540	801.540	801.540	801 540
ting REEP engines - RP-5 SHF Gas								70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000	70.000
and KEEP engines - KP-5 SHP Gas								70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000
rbishments								70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000	70,000
urbishments ((cost)	v adjustments		(793,200)	(793,200)	(793,200)	(1,586,400)	(1,586,400)	70,000 (164,810)							70,000 2,238,965							70,000 2,261,843							
	y adjustments		(793,200) 841,506	(793,200) 866,751		(1,586,400) 1,839,072																							
cost) n escalated dollars with sensitivit	y adjustments							(164,810)																					
cost) n escalated dollars with sensitivit	y adjustments							(164,810)																					
cost) n escalated dollars with sensitivit ys	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608																					
cost) n escalated dollars with sensitivit	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810)																					
cost) n escalated dollars with sensitivit ns tal outfavs	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608 2,926,608	2,218,244	2,221,697	2,225,151	2,228,604	2,232,058	2,235,512	2,238,965	2,242,419	2,245,873	2,249,326	2,252,780	2,256,233	2,259,038	2,261,843	2,264,648	2,267,453	2,270,258	2,273,063	2,275,868	2,278,673	2,281,478
oost) n escalated dollars with sensitivit ys tal outlaws luction from RP-5 biogas	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608 2.926,608 1,581,154	2,218,244 1,652,225	2,221,697	1,839,923	1,958,963	2,232,058	2,235,512	2,238,965	2,242,419	2,245,873	2,249,326	2,252,780	2,256,233	3,116,339	3,266,727	3,423,332	2,267,453 3,586,394	2,270,258	2,273,063 3,917,143	2,275,868 4,084,404	4,258,176	2,281,478 4,438,699
cost) n escalated dollars with sensitivity ys tal outfavs duction from RP-5 biogas duction from RP-5 biogas	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608 2,926,608 2,926,608 1,581,154 159,675	2,218,244	2,221,697	1,839,923 188.405	1,958,963	2,232,058 2,083,530 209.727	2,235,512 2,213,787 221.090	2,238,965	2,242,419 2,464,494 245,316	2,245,873 2,583,758 258,217	2,249,326 2,707,961 271.672	2,252,780 2,837,290 285.702	2,256,233 2,971,941 300.329	2,259,038 3,116,339 314,405	2,261,843 3,266,727 329.055	2,264,648 3,423,332 344.301	2,267,453 3,586,394 360.166	2,270,258	2,273,063	2,275,868 4,084,404 411.711	4,258,176 430,293	2,281,478
cost) n escalated dollars with sensitivity ys tal outfavs duction from RP-5 biogas erv (total) effs effs	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608 2,926,608 1,581,154 159,675 1,740,829	2,218,244 1,652,225 168,840 1,821,065	2,221,697 2,221,697 1,726,137 178,411 1,904,548	2,225,151 1,839,923 188,405 2,028,328	2,228,604 1,958,983 198,838 2,157,820	2,232,058 2,083,530 209,727 2,293,257	2,235,512 2,213,787 221.090 2,434,877	2,238,965 2,349,965 232,947 2,582,931	2,242,419 2,464,494 245,316 2,709,809	2,245,873 2,583,758 258,217 2,841,976	2,249,326 2,707,961 271,672 2,979,633	2,252,780 2,837,290 285,702 3,122,992	2,256,233 2,971,941 300,329 3,272,270	2,259,038 3,116,339 314,405 3,430,744	2,261,843 3,266,727 329,055 3,595,782	2,264,648 3,423,332 344.301 3,767,634	2,267,453 3,586,394 360,166 3,946,561	2,270,258 3,756,159 376,673 4,132,833	2,273,063 3.917,143 393,847 4,310,989	2,275,868 4,084,404 411.711 4,496,116	4,258,176 4,688,470	2,281,478 4,438,699 449,620 4,888,319
cool) e ecalated dollars with sensitivit so cal outlaws function from RP-5 bicass erv / https:// thttps:	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608 2,926,608 2,926,608 1,581,154 159,675	2,218,244	2,221,697	1,839,923 188.405	2,228,604 1,958,983 198,838 2,157,820	2,232,058 2,083,530 209.727	2,235,512 2,213,787 221.090	2,238,965	2,242,419 2,464,494 245,316	2,245,873 2,583,758 258,217	2,249,326 2,707,961 271.672	2,252,780 2,837,290 285.702	2,256,233 2,971,941 300.329	2,259,038 3,116,339 314,405	2,261,843 3,266,727 329.055	2,264,648 3,423,332 344.301	2,267,453 3,586,394 360.166	2,270,258	2,273,063 3,917,143 393,847 4,310,989 435,238	2,275,868 4,084,404 411.711	4,258,176 430,293	2,281,478
cost) n escalated dollars with sensitivit ys	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608 2.926,608 1,581,154 159,675 1,740,829 175,684	2,218,244	2,221,697 1,726,137 178,411 1,904,548 191,793	2,225,151 1,839,923 188,405 2,028,328 204,436	2,228,604 1,958,963 198,838 2,157,820 217,665 237,056	2,232,058 2,083,530 209.727 2,293,257 231,503	2,235,512 2,213,787 221.090 2,434,877 245,976	2,238,965 2,349,965 232,947 2,582,931 261,109	2,242,419 2,464,494 245,316 2,709,809 273,833	2,245,873 2,583,758 258,217 2,841,976 287,084	2,249,326 2,707,961 271,672 2,979,633 300,885	2,252,780 2,837,290 285,702 3,122,992 315,254	2,256,233 2,971,941 300.329 3,272,270 330,216	2,259,038 3,116,339 314,405 3,430,744 346,260	2,261,843 3,266,727 329.055 3,595,782 362,970	2,264,648 3,423,332 344.301 3,767,634 380,370	2,267,453 3,586,394 360,166 3,946,561 398,488	2,270,258 3,756,159 376.673 4,132,833 417,351	2,273,063 3.917,143 393,847 4,310,989	2,275,868 4,084,404 411.711 4,496,116 453,823	4.258,176 4.30.293 4,688,470 473,131 266,563	2,281,478 4,438,699 449,620 4,888,319 493,189
cott) ecclated dollars with sensitivity s al outlans luction from RP-5 bicass ever (total) not able sol able	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608 2,926,608 1,581,154 159,675 1,740,829 175,684 228,330	2,218,244	2,221,697 1,726,137 178,411 1,904,548 191,793 236,825	2,225,151 1,839,923 188,405 2,028,326 2,028,326 2,028,326	2,228,604 1,958,963 198,838 2,157,820 217,665 237,056	2,232,058 2,083,530 209,727 2,293,257 231,503 236,859	2,235,512 2,213,787 221,090 2,434,877 245,976 236,437	2,238,965 2,349,985 232,947 2,582,931 261,109 235,776	2,242,419 2,464,494 245,316 2,709,809 273,833 237,960	2,245,873 2,583,758 258,217 2,841,976 287,084 240,062	2,249,326 2,707,961 271,672 2,979,633 300,885 242,076	2,252,780 2,837,290 285.702 3,122,992 315,254 243,995	2,256,233 2,971,941 300,329 3,272,270 330,216 245,811	2,259,038 3,116,339 314,405 3,430,4405 3,46,260 247,048	2,261,843 3,266,727 329,055 3,595,782 362,970 248,137	2,264,648 3,423,332 3,44.301 3,767,634 380,370 249,070	2,267,453 3,586,394 360.166 3,946,561 398,488 249,835	2,270,258 3,756,159 376,673 4,132,833 417,351 250,422	2,273,063 3.917,143 393,847 4,310,989 435,238 252,568	2,275,868 4,084,404 411,711 4,496,116 453,823 254,618	4.258,176 4.30.293 4,688,470 473,131 266,563	2,281,478 4,438,699 449,620 4,888,319 493,189 258,395
cott) ecclated dollars with sensitivity s al outlans luction from RP-5 bicass ever (total) not able sol able	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608 2,926,608 1,581,154 159,675 1,740,829 175,684 228,330	2,218,244	2,221,697 1,726,137 178,411 1,904,548 191,793 236,825	2,225,151 1,839,923 188,405 2,028,326 2,028,326 2,028,326	2,228,604 1,958,963 198,838 2,157,820 217,665 237,056	2,232,058 2,083,530 209,727 2,293,257 231,503 236,859	2,235,512 2,213,787 221,090 2,434,877 245,976 236,437	2,238,965 2,349,985 232,947 2,582,931 261,109 235,776	2,242,419 2,464,494 245,316 2,709,809 273,833 237,960	2,245,873 2,583,758 258,217 2,841,976 287,084 240,062	2,249,326 2,707,961 271,672 2,979,633 300,885 242,076	2,252,780 2,837,290 285.702 3,122,992 315,254 243,995	2,256,233 2,971,941 300,329 3,272,270 330,216 245,811	2,259,038 3,116,339 314,405 3,430,4405 3,46,260 247,048	2,261,843 3,266,727 329,055 3,595,782 362,970 248,137	2,264,648 3,423,332 3,44.301 3,767,634 380,370 249,070	2,267,453 3,586,394 360.166 3,946,561 398,488 249,835	2,270,258 3,756,159 376,673 4,132,833 417,351 250,422	2,273,063 3.917,143 393,847 4,310,989 435,238 252,568	2,275,868 4,084,404 411,711 4,496,116 453,823 254,618	4.258,176 4.30.293 4,688,470 473,131 266,563	2,281,478 4,438,699 449,620 4,888,319 493,189 258,395
cott) ecclated dollars with sensitivity s al outlans luction from RP-5 bicass ever (total) not able sol able	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608 2,926,608 1,581,154 159,675 1,740,829 175,684 228,330	2,218,244	2,221,697 1,726,137 178,411 1,904,548 191,793 236,825	2,225,151 1,839,923 188,405 2,028,326 2,028,326 2,028,326	2,228,604 1,958,963 198,838 2,157,820 217,665 237,056	2,232,058 2,083,530 209,727 2,293,257 231,503 236,859	2,235,512 2,213,787 221,090 2,434,877 245,976 236,437	2,238,965 2,349,985 232,947 2,582,931 261,109 235,776	2,242,419 2,464,494 245,316 2,709,809 273,833 237,960	2,245,873 2,583,758 258,217 2,841,976 287,084 240,062	2,249,326 2,707,961 271,672 2,979,633 300,885 242,076	2,252,780 2,837,290 285.702 3,122,992 315,254 243,995	2,256,233 2,971,941 300,329 3,272,270 330,216 245,811	2,259,038 3,116,339 314,405 3,430,4405 3,46,260 247,048	2,261,843 3,266,727 329,055 3,595,782 362,970 248,137	2,264,648 3,423,332 344.301 3,767,634 380,370 249,070	2,267,453 3,586,394 360.166 3,946,561 398,488 249,835	2,270,258 3,756,159 376,673 4,132,833 417,351 250,422	2,273,063 3,917,143 393,847 4,310,989 435,238 252,568	2,275,868 4,084,404 411,711 4,496,116 453,823 254,618	4.258,176 4.30.293 4,688,470 473,131 266,563	2,281,478 4,438,699 449,620 4,888,319 493,189 258,395
e exclated dollars with sensitivit e active all outlans luction from RP-5 biogas e the sense the the the the the the the the the th	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608 2,926,608 1,581,154 159,875 1,740,829 175,684 228,330 581,780	2,218,244	2,221,697	2,225,151	2,228,604 1,958,963 198,838 2,157,820 217,665 237,056	2,232,058 2,083,530 2087,27 2,293,257 231,503 236,859 674,442	2,235,512 2,213,787 221,090 2,434,877 245,976 236,437 694,675	2,238,965 2,349,985 232,947 2,582,931 261,109 235,776 715,515	2,242,419 2,464,494 245,316 2,709,809 273,633 237,960 736,981	2,245,873 2,583,758 258,217 2,841,976 287,084 240,062 759,090	2,249,326 2,707,961 271,672 2,979,633 300,885 242,076 781,863	2,252,780 2,837,290 285,702 3,122,992 315,254 243,995 805,319	2,971,941 300,329 3,272,270 330,216 245,811 829,479	2,259,038 3,116,339 314,405 3,430,744 346,260 854,363	2,261,843 3,266,727 329,055 3,595,782 362,970 879,994	2,264,648 3,423,332 3,767,634 380,370 906,394	2,267,453 3,586,394 360,166 3,946,561 398,488 249,835 933,585	2,270,258 3,756,159 376,673 4,132,833 41,751 250,422 961,593	2,273,063 3,917,143 393,847 4,310,989 435,236 990,441	4,084,404 411,711 4,496,116 453,823 254,618 1,020,154	4,258,176 430,293 4,688,470 430,293 1,050,759	2,281,478 4,438,699 449,620 4,888,319 493,189 258,395 1,082,281
cost) excatated dollars with sensitivit ys tel outlaws duction from RP-5 bicease effects effec	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608 2,926,608 1,581,154 159,875 1,740,829 175,684 228,330 581,780	2,218,244	2,221,697	2,225,151	2,228,604	2,232,058 2,083,530 2087,27 2,293,257 231,503 236,859 674,442	2,235,512 2,213,787 221,090 2,434,877 245,976 236,437 694,675	2,238,965 2,349,985 232,947 2,582,931 261,109 235,776 715,515	2,242,419 2,464,494 245,316 2,709,809 273,633 237,960 736,981	2,245,873 2,583,758 258,217 2,841,976 287,084 240,062 759,090	2,249,326 2,707,961 271,672 2,979,633 300,885 242,076 781,863	2,252,780 2,837,290 285,702 3,122,992 315,254 243,995 805,319	2,971,941 300,329 3,272,270 330,216 245,811 829,479	2,259,038 3,116,339 314,405 3,430,744 346,260 854,363	2,261,843 3,266,727 329,055 3,595,782 362,970 879,994	2,264,648 3,423,332 3,767,634 380,370 906,394	2,267,453 3,586,394 360,166 3,946,561 398,488 249,835 933,585	2,270,258 3,756,159 376,673 4,132,833 41,751 250,422 961,593	2,273,063 3,917,143 393,847 4,310,989 435,236 990,441	4,084,404 411,711 4,496,116 453,823 254,618 1,020,154	4,258,176 430,293 4,688,470 430,293 1,050,759	2,281,478 4,438,699 449,620 4,888,319 493,189 258,395 1,082,281
cost) excluted dollars with sensitivity ys tal outlaws Sustion from RP-5 bicass ever forab and and RP-5 bicass and RP-5 bicass and RP-5 bicass	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608 2,926,608 1,581,154 159,875 1,740,829 175,684 228,330 581,780	2,218,244	2,221,697	2,225,151	2,228,804	2,232,058 2,083,530 2087,27 2,293,257 231,503 236,859 674,442	2,235,512 2,213,787 221,090 2,434,877 245,976 236,437 694,675	2,238,965 2,349,985 232,947 2,582,931 261,109 235,776 715,515	2,242,419 2,464,494 245,316 2,709,809 273,633 237,960 736,981	2,245,873 2,583,758 258,217 2,841,976 287,084 240,062 759,090	2,249,326 2,707,961 271,672 2,979,633 300,885 242,076 781,863	2,252,780 2,837,290 285,702 3,122,992 315,254 243,995 805,319	2,971,941 300,329 3,272,270 330,216 245,811 829,479	2,259,038 3,116,339 314,405 3,430,744 346,260 854,363	2,261,843 3,266,727 329,055 3,595,782 362,970 879,994	2,264,648 3,423,332 3,767,634 380,370 906,394	2,267,453 3,586,394 360,166 3,946,561 398,488 249,835 933,585	2,270,258 3,756,159 376,673 4,132,833 41,751 250,422 961,593	2,273,063 3,917,143 393,847 4,310,989 435,236 990,441	4,084,404 411,711 4,496,116 453,823 254,618 1,020,154	4,258,176 430,293 4,688,470 430,293 1,050,759	2,281,478 4,438,699 449,620 4,888,319 493,189 258,395 1,082,281
cost) e escalard dollars with sensitivit ye lei outres fuelon non RP-5 biogas ducion non RP-5 biogas difís d	y adjustments		841,506	866,751	892,754	1,839,072	1,894,245	(164,810) 2,926,608 2,926,608 1,581,154 158,875 1,740,829 175,684 228,330 581,780	2,218,244 1,852,225 168,840 1,821,065 183,581 232,553 599,233 1,015,367	2,221,697 1,726,137 178,411 1,904,548 191,793 236,825 617,210 1,045,828	2,225,151 1,839,923 1,88,405 2,028,328 204,436 237,041 635,726 1,077,203	2,228,804	2,232,058 2,083,530 208,530 209,727 2,293,257 231,503 238,859 674,442 1,142,804	2,235,512 2,213,787 221,090 2,434,877 245,976 2,36,437 694,675 1,177,089	2,238,965 2,349,965 232,947 2,582,931 281,109 235,776 715,515 1,212,401	2,242,419 2,464,494 2,45,316 2,708,809 273,833 237,960 736,981 1,248,773	2,245,873 2,583,758 258,217 2,841,976 287,084 240,062 759,090 1,286,236	2,249,326 2,707,961 271,672 2,979,833 300,885 2,42,076 761,863 1,324,823	2,252,780 2,837,290 285,702 3,122,992 315,254 243,995 805,319 1,364,568	2,256,233 2,271,941 300,329 3,272,270 330,216 245,811 829,479 1,405,505	2,259,038 3,116,339 314,405 3,430,744 346,260 247,048 854,363 1,447,670	2,261,843 3,266,727 322,055 3,993,782 362,970 248,137 879,994 1,491,101	2,264,648 3,423,332 3,443,301 3,767,634 380,370 249,070 906,394 1,535,834	2,267,453 3,586,394 360,166 3,946,561 398,488 249,85 933,585 933,585	2,270,258 3,756,159 376,673 4,132,833 417,351 250,422 961,593 1,629,366	2,273,063 3,917,143 393,847 4,310,889 435,238 252,568 990,441 1,678,247	4,084,404 411,711 4,496,116 453,823 254,618 1,020,154 1,728,594	2,278,673 4,258,176 430,293 4,688,470 473,131 266,563 1,050,759 1,780,452	2,281,478 4,438,699 449,620 4,886,319 433,189 258,395 1,082,281 1,833,866
cost) exclated dollars with sensitivit vs tal outlaws duction from RP-5 biogas ver, fortal taid outlaws taid outlaws tai			841,506	866,751	892,754	1,839,072	1,894,245	(164,819) 2,926,606 2,926,606 1,581,154 159,675 1,740,829 175,684 128,330 581,780 985,793 86,091	2,218,244 1,852,225 168,840 1,821,859 183,659 1,015,367 88,674	2,221,697 1,726,137 178,411 1,904,548 191,723 236,825 617,210 1,045,828 91,334	2,225,151 1,839,923 188,405 2,028,328 204,436 237,041 635,726 1,077,203 94,074	2,228,604	2,232,058 2,083,530 209,727 2,283,257 231,503 674,442 1,142,804 99,803	2,235,512 2,213,787 221,090 2,434,877 245,976 236,437 694,675 1,177,089 102,797	2,238,965 2,238,965 2,249 2,249 2,252,947 2,252,947 2,252,947 715,515 1,212,401 105,881	2,242,419 2,464,494 245,316 2,709,809 736,981 1,248,773 109,058	2,245,873 2,2583,758 258,217 2,241,976 227,084 240,082 759,090 1,286,236 112,329	2,249,326 2,707,961 271,672 2,979,653 300,885 242,076 761,863 1,324,823 1,324,823	2,252,780 2,837,290 285,702 3,122,954 243,995 805,319 1,384,568 11,944,568	2,256,233 2,271,941 300,329 3,272,270 330,274 330,274 345,811 829,479 1,405,805 122,745	2,259,038 3,116,339 314,405 3,39,744 346,269 247,048 854,363 1,447,670 126,428	3.266,727 320,055 3.366,727 320,055 3.365,728 3.65,728 3.65,728 3.65,728 3.65,728 3.65,728 3.65,728 3.65,728 3.65,728 3.66,729 3.65,728 3.66,729 3.66,727 3.20,643 3.66,727 3.20,643 3.66,727 3.20,65,728 3.66,729 3.76,729 3.66,729 3.79,729 3.66,729 3.79,729 3.66,729 3.79,729 3.66,729 3.79,729 3.70,720	3,423,332 344,301 3,767,6340 906,394 1,535,834 134,127	2,267,453 3,586,394 360,166 3,946,561 398,488 249,835 933,585 1,581,909 138,151	2,270,258 3,756,159 376,673 4,152,833 417,351 250,422 961,593 1,629,366 142,296	2,273,063 3,917,143 393,847 4,310,829 455,258 990,441 1,678,247 146,564	2,275,868 4,084,404 411,711 4,496,116 453,823 2,54,618 1,020,154 1,728,594 150,961	2,278,673 4,258,176 430,293 4,689,470 473,131 256,563 1,050,759 1,780,452 155,490	2,281,478 4,438,699 449,620 4,888,319 493,189 256,385 1,082,281 1,833,866 1,833,866
cool) e ecatade dollars with sensitivit ye cal outlans fuction from RP-5 blogas fuction from RP-5 blogas fuction from RP-5 blogas fuction from RP-5 blogas fuction from RP-5 blogas as ing costs biblinments			841,506	866.751	892,754	1.839.072	1.894.245	(164,810) 2,926,608 2,926,608 2,926,608 1,581,154 159,675 1,740,829 1,740,829 1,740,829 1,740,829 86,091 86,091 86,091	2,218,244 1,652,225 168,840 1,821,065 183,581 232,553 599,233 1,015,367 88,674 88,674	2,221,697 1,726,137 178,411 1,904,548 191,793 236,825 617,210 1,045,828 91,334 91,334	2,225,151 1,839,923 188,405 2024,336 2074,336 2074,336 237,041 635,726 1,077,203 94,074 94,074	2,228,604 1,958,963 198,838 2,157,820 2,17,865 237,056 654,798 96,896 96,896	2,232,058 2,083,530 2083,530 209,277 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,297,297 2,297,297,297 2,299,297,297,297,297,297,297,297,297,29	2,235,512 2,213,787 221,090 2,434,877 245,976 236,437 694,675 1,177,089 102,797	2,238,965 2,249,985 222,947 2,582,931 2,582,931 1,212,401 105,881	2,242,419 2,464,494 246,316 2,709,809 2,709,809 2,709,809 1,246,773 109,058	2,245,873 2,583,758 258,217 2,841,976 287,084 240,062 759,090 1,286,236 112,329 112,329	2,249,326 2,707,961 271672 2,979633 300,885 242,076 761,863 11324,823 115,699	2,252,780 2,837,290 285,702 315,254 243,995 805,319 1,384,568 119,170	2,971,941 300,329 3,327,270 3,327,270 3,327,270 1,405,505 122,745	2,259,038 3,116,339 314,05 3,430,74 3,430,74 3,430,74 1,447,670 126,428	2,261,843 3,266,727 320,055 3,595,782 3,695,782 3,695,782 3,695,782 1,491,191 1,491,191 130,221	2,264,649 3,423,332 344,301 3,767,634 3,767,634 1,535,634 1,535,634 134,127	2,267,453 3,586,394 360,166 3,346,561 398,488 249,835 933,585 1,581,909 138,151 138,151	2,270,258 3,756,159 376,673 4,132,833 417,351 250,422 961,593 1,629,366 142,296	2,273,063 3,917,143 333,847 4,310,989 435,238 252,568 990,441 1,678,247 146,564 146,564	4.084.404 411.711 4.496.116 453.823 254.618 1.020.154 1.728.594 150.961	2,278,673 4,258,176 430,283 1,050,759 1,780,452 155,490	2,281,478 4,438,699 449,620 4,888,319 433,189 258,395 1,082,281 1,833,866 160,155 160,155
exatification of the sensitivit examples of the sensitivit all outlands tuctors from RP-5 blogges tuctors from RP-5 blogges this files of come: a - RP-5 blogges of come: a -			841,506	866.751	892,754	1.839.072	1.894.245	(164,819) 2,926,606 2,926,606 1,581,154 159,675 1,740,829 175,684 128,330 581,780 985,793 86,091	2,218,244 1,652,225 168,840 1,821,065 183,581 232,553 599,233 1,015,367 88,674 88,674	2,221,697 1,726,137 178,411 1,904,548 191,793 236,825 617,210 1,045,828 91,334 91,334	2,225,151 1,839,923 188,405 2024,336 2074,336 2074,336 237,041 635,726 1,077,203 94,074 94,074	2,228,604 1,958,963 198,838 2,157,820 2,17,865 237,056 654,798 96,896 96,896	2,232,058 2,083,530 2083,530 209,277 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,297,297 2,297,297,297 2,299,297,297,297,297,297,297,297,297,29	2,235,512 2,213,787 221,090 2,434,877 245,976 236,437 694,675 1,177,089 102,797	2,238,965 2,249,985 222,947 2,582,931 2,582,931 1,212,401 105,881	2,242,419 2,464,494 246,316 2,709,809 2,709,809 2,709,809 1,246,773 109,058	2,245,873 2,583,758 258,217 2,841,976 287,084 240,062 759,090 1,286,236 112,329 112,329	2,249,326 2,707,961 271672 2,979633 300,885 242,076 761,863 11324,823 115,699	2,252,780 2,837,290 285,702 315,254 243,995 805,319 1,384,568 119,170	2,971,941 300,329 3,327,270 3,327,270 3,327,270 1,405,505 122,745	2,259,038 3,116,339 314,05 3,430,74 3,430,74 3,430,74 1,447,670 126,428	2,261,843 3,266,727 320,055 3,595,782 3,695,782 3,695,782 3,695,782 1,491,191 1,491,191 130,221	2,264,649 3,423,332 344,301 3,767,634 3,767,634 1,535,634 1,535,634 134,127	2,267,453 3,586,394 360,166 3,346,561 398,488 249,835 933,585 1,581,909 138,151 138,151	2,270,258 3,756,159 376,673 4,132,833 417,351 250,422 961,593 1,629,366 142,296	2,273,063 3,917,143 333,847 4,310,989 435,238 252,568 990,441 1,678,247 146,564 146,564	4.084.404 411.711 4.496.116 453.823 254.618 1.020.154 1.728.594 150.961	2,278,673 4,258,176 430,283 1,050,759 1,780,452 155,490	2,281,478 4,438,699 449,620 4,888,319 433,189 258,395 1,082,281 1,833,866 160,155 160,155
cool) excellent dollars with sensitivit vs tal outlans tucion toon PP-5 biogas tucion toon PP-5 biogas tucion toon PP-5 biogas tais tucion toon PP-5 biogas tucion tu			841,506	866.751	892,754	1.839.072	1.894.245	(164,810) 2,926,608 2,926,608 2,926,608 1,581,154 159,675 1,740,829 1,740,829 1,740,829 1,740,829 86,091 86,091 86,091	2,218,244 1,652,225 168,840 1,821,065 183,581 232,553 599,233 1,015,367 88,674 88,674	2,221,697 1,726,137 178,411 1,904,548 191,793 236,825 617,210 1,045,828 91,334 91,334	2,225,151 1,839,923 188,405 2024,336 2074,336 2074,336 237,041 635,726 1,077,203 94,074 94,074	2,228,604 1,958,963 198,838 2,157,820 2,17,865 237,056 654,798 96,896 96,896	2,232,058 2,083,530 2083,530 209,277 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,287 2,299,297,297 2,297,297,297 2,299,297,297,297,297,297,297,297,297,29	2,235,512 2,213,787 221,090 2,434,877 245,976 236,437 694,675 1,177,089 102,797	2,238,965 2,249,985 222,947 2,582,931 2,582,931 1,212,401 105,881	2,242,419 2,464,494 246,316 2,709,809 2,709,809 2,709,809 1,246,773 109,058	2,245,873 2,583,758 258,217 2,841,976 287,084 240,062 759,090 1,286,236 112,329 112,329	2,249,326 2,707,961 271672 2,979633 300,885 242,076 761,863 11324,823 115,699	2,252,780 2,837,290 285,702 315,254 243,995 805,319 1,384,568 119,170	2,971,941 300,329 3,327,270 3,327,270 3,327,270 1,405,505 122,745	2,259,038 3,116,339 314,05 3,430,74 3,430,74 3,430,74 1,447,670 126,428	2,261,843 3,266,727 32,005 3,595,782 3,695,782 3,695,782 3,695,782 1,491,191 1,491,191 130,221	2,264,649 3,423,332 344,301 3,767,634 3,767,634 1,535,634 1,535,634 134,127	2,267,453 3,586,394 360,166 3,346,561 398,488 249,835 933,585 1,581,909 138,151 138,151	2,270,258 3,756,159 376,673 4,132,833 417,351 250,422 961,593 1,629,366 142,296	2,273,063 3,917,143 333,847 4,310,989 435,238 252,568 990,441 1,678,247 146,564 146,564	4.084.404 411.711 4.496.116 453.823 254.618 1.020.154 1.728.594 150.961	2,278,673 4,258,176 430,283 1,050,759 1,780,452 155,490	2,281,478 4,438,699 449,620 4,888,319 433,189 258,395 1,082,281 1,833,866 160,155 160,155
sout) e estated dollars with sensitivit sel outlaws function from RP-5 biogas erv (foun) sid - RP-5 biogas ad - RP-5 biogas e ing costs ting REEP engines - RP-5 SHF Gas			841,506	866.751 866.751 (866.751)	892.754 892.754 (892.754)	1.839.072	1,894,245	(164,810) 2,926,608 2,926,608 2,926,608 1,581,154 159,675 1,740,829 1,740,829 1,740,829 1,740,829 1,740,829 86,091 86,091 86,091	2,218,244 1,852,225 168,840 1,821,085 1,821,085 1,015,367 88,674 88,674	2,221,697 1,726,137 178,411 1,904,548 191,793 226,825 617,210 1,045,828 91,334 91,334 767,386	2,225,151 1,839,923 188,405 2,028,328 204,436 237,041 635,726 1,077,203 94,074 84,074 857,051	2,228,604	2,232,058 2,083,530 209,727 2,293,257 231,503 231,503 674,442 1,142,804 99,803 1,050,649	2,235,512 2,213,767 221,090 2,243,877 245,976 236,437 694,675 102,797 1,177,089	2.349,965 2.349,965 2.229,947 2.582,931 261,109 255,767 715,515 1.212,401 105,881 105,881 1254,649	2,242,419 2,464,494 245,316 2,709,809 273,630 736,981 1,246,773 109,058 1,09,058	2,245,873 2,245,873 2,583,758 258,217 2,841,976 287,082 759,090 1,286,236 112,329 112,329 112,329	2,249,326 2,707,961 271,672 2,979,633 300,885 242,076 761,863 1,324,823 115,899 115,899 115,899	2,837,290 285,702 3,122,992 315,254 243,995 805,319 1,364,568 119,170 119,170 1,639,253	2,256,233 2,271,941 300,329 3,272,270 330,216 245,811 829,479 1,405,505 122,745 122,745 122,745	2,259,038 3,116,339 314,405 3,439,744 346,260 247,048 854,363 1,447,670 128,428 1,285,646	2,261,843 3,266,727 329,055 3,595,782 362,970 248,137 879,994 1,491,101 130,221 130,221 1,974,461	3.423.332 344.301 3.767.834 390.370 906.394 1.535.834 1.535.834 1.34.127 2.097.673	2,267,453 3,586,394 360,166 3,946,551 3,946,551 3,946,551 1,581,909 138,151 138,151 2,226,501	2,270,259 3,756,159 376,673 4,132,833 417,351 961,593 1,629,366 142,296 142,296 142,296	2,273,063 3,917,143 333,847 4,310,989 455,568 990,441 1,678,247 146,564 146,564 2,486,178	4,084,404 411,711 4,496,404 411,711 4453,823 254,618 1,020,154 1,728,594 150,961 150,961 150,961	2,278,673 4,258,176 430,293 4,688,470 4,688,470 1,050,759 1,780,452 155,490 2,752,528	2,281,478 4,438,699 449,520 4,888,319 258,395 1,082,281 1,833,866 160,155 2,894,298

Alternative: 1 Row: 8

SummanylA8 , Alternative SummanylB8 , IAIt, number SummanylC8 , Alt, name SummanylC8 , Risk cremium SummanylC8 , Benefit sens, SummanylB8 , Capital sens SummanylB , Running sens.

calation rate	3.00%		Capital costs												rnative Cost Ar - DG Alt 2 - M		s)												
iscount rate	2.00%	_	Running costs											Alternative 2	2 - DG Alt 2 - M	croturbines													
s. unescalate		2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	20
a. unesculated																													
			2,984,400	2,984,400	2,984,400	5,968,800	5,968,800	8,953,200																					
			2,984,400	2,984,400	2,984,400	5,968,800	5,968,800	8,953,200		1	1								II	I								1	
turbines								1,042,397	1,057,526	1,072,654	1,110,061	1,147,468	1,184,875	1,222,282	1,259,689	1,282,593	1,305,497	1,328,401	1,351,304	1,374,208	1,399,007	1,423,805	1,448,604	1,473,403	1,498,201	1,516,905	1,535,608	1,554,312	1,57
Engines								2,158,253	2,171,414	2,184,574	2,197,230	2,209,886	2,222,542	2,235,198	2,247,853	2,259,973	2,272,093	2,284,212	2,296,332	2,308,451	2,321,140	2,333,830	2,346,519	2,359,208	2,371,897	2,385,189	2,398,481	2,411,772	2,42
								3,330,480	3.352.223	3.393.966	3.447.482	3.500.999	3.554.515	3.608.031	3.661.548	3.700.025	3.738.502	3.776.979	3.815.456	3,853,933	3.894.226	3.934.518	3,974,811	4.015.104	4.055.396	4.090.197	4.124.997	4,159,798	4.19
bines								115,822	117 503	119,184	123.340	127 496	131 653	135,809	139.965	142 510	145.055	147 600	150 145	152,690	155.445	158,201	160.956	163,711	166.467	168 545	170 623	172,701	17
igines								239,806	241,268	242,730	244,137	245,543	246,949	248,355	249,761	251,108	252,455	253,801	255,148	256,495	257,904	259,314	260,724	262,134	263,544	265,021	266,498 690,879	267,975	26
								553,800	558,931	564,063	573,569	583,075	592,582	602,088	611,594	618,114	624,634	631,154	637,674	644,194	651,184	658,174	665,164	6/2,154	679,144	685,011	690,879	696,746	7
								909,428	917,702	925,977	941,046	956,115	971,184	986,252	1,001,321	1,011,733	1,022,144	1,032,555	1,042,967	1,053,378	1,064,533	1,075,689	1,086,844	1,097,999	1,109,155	1,118,577	1,128,000	1,137,422	1,14
acement								140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	140,000	14
										1	r i	1	1 1		і I	1			і I	1	1	1				i i	i i	1	i i
																			: · ·								; ;	2	
										1																			1
								140.000	140.000						140.000	140.000			140.000	140.000	140.000	140.000	140.000						
			(2,984,400)	(2,984,400)	(2,984,400)	(5,968,800)	(5,968,800)	140.000 (6,672,147)					140.000 2,443,331						140.000 2,632,489									140.000 2,882,376	
Iollars with se	ensitivity adjustm	nents	(2,984,400)	(2,984,400)	(2,984,400)	(5,968,800)	(5,968,800)																						
Iollars with se	ensitivity adjustm	nents	(2,984,400) 3,166,150	(2,984,400)	(2,984,400)	(5,968,800) 6,919,475	(5,968,800) 7,127,059																						
Iollars with se	ansitivity adjustm	nents						(6,672,147)																					
Iollars with se	ansitivity adjustm	nents						(6,672,147)																					
iollars with se	ensitivity adjustm	nents						(6,672,147)																					
Iollars with se	ansitivity adjustm	nents	3,166,150		3,358,968	6,919,475	7,127,059	(6,672,147)																					
follars with se outlines	ansitivity adjustm	nents	3,166,150	3,261,134	3,358,968	6,919,475	7,127,059	(6,672,147) 11,011,307 11,011,307 12,82,017	2,304,521	2,327,989	2,366,436	2,404,884	2,443,331	2,481,779	2,520,227	2,548,292	2,576,358	2,604,423	2,632,489	2,660,555	2,589,592	2,718,829	2,747,967	2,777,104	2,806,242	2,831,620	2,856,998	2,882,376	2,9
turbines	ansitivity adjustm	nents	3,166,150	3,261,134	3,358,968	6,919,475	7,127,059	(6,672,147) 11,011,307 11,011,307	2,304,521	2,327,989	2,366,436	2,404,884	2,443,331	2,481,779	2,520,227	2,548,292	2,576,358	2,604,423	2,632,489	2,660,555 2,409,682 300,329	2,689,692	2,718,829	2,747,967	2,777,104	2,806,242	2,831,520	2,856,998	2,882,376	2,9 3,5 4
	ansitivity adjustm	nents	3,166,150	3,261,134	3,358,968	6,919,475	7,127,059	(6,672,147) 11,011,307 11,011,307 1,282,017 159,675	1,339,642 163,840 2,750,682	2,327,989 1,399,570 178,411 2,850,374	2,366,436 1,491,829 188,405 2,952,893	2,404,884 1,588,364 199,838	2,443,331 2,443,331 1,689,349 209,727 3,166,813	2,481,779 1,794,963 221,090 3,282,463	2,520,227	2,548,292 1,998,238 245,316	2,576,358 2,094,933 258,217 3,646.042	2,604,423 2,195,644 271,672 3,775,455	2,632,489 2,300,505 285,702 3,909,351	2,660,555	2,689,692 2,526,762 314,405	2,718,829 2,548,697 329,055	2,747,967 2,775,675 344,301 4,496,172	2,777,104 2,777,104 2,907,887 360,166	2,806,242 3,045,535 376,673 4,821,578	2,831,620 3,176,082 393,847 4,994,056	2,856,998 3,311,679 411,711 5,172,542	2,882,376 2,882,376 3,452,575 430,293 5,557,244	2,94
turbines C Engines bines		nents	3,166,150	3,261,134	3,358,968	6,919,475	7,127,059	(6,672,147) 11,011,307 11,011,307 1,282,017 1,282,017 1,282,017 1,59,675 2,654,379 4,096,071 1,42,446	1,339,642 1,339,642 168,840 2,750,640 2,259,163 148,849	2,327,989 2,327,989 1,399,570 178,411 2,850,411 4,428,355 155,508	2,366,436 1,491,829 188,405 2,952,893 4,633,128	2,404,884 1,588,364 198,838 3,058,999 4,846,201 176,485	2,443,331 1,689,349 209,727 3,168,813 5,067,88 187,705	2,481,779 1,794,963 221,090 3,282,463 5,298,516 199,440	2,520,227 1,905,303 232,947 3,400,080 5,538,420 211,710	2,548,292 1,998,238 245,316 3,520,964 5,764,518 222,026	2,576,358 2,094,939 258,217 3,564,042 5,999,198 232,771	2,604,423 2,195,644 271,672 3,775,55 6,242,771 243,960	2,632,489 2,300,505 285,702 3,009,351 6,495,558 255,612	2,660,555 2,660,555 2,409,682 300,329 4.047,883 6.757,894 267,742	2,689,692 2,526,762 314,405 4.192,238 7.033,404 280,751	2,718,829 2,548,697 329,055 4,241,610 7,319,363 294,300	2,747,967 2,775,675 344,301 4,496,172 7,616,149 308,408	2,777,104 2,777,104 2,907,887 360,166 4,655,101 7,924,155 323,099	2,806,242 3,045,535 376,673 8,243,786 338,393	2,831,620 3,176,062 393,847 4.994,056 8,563,964 352,896	2,856,998 2,856,998 3,311,579 411,711 5,172,54 8,895,933 367,964	2,882,376 2,882,376 3,452,575 430,293 5,357,244 9,240,113 383,619	2,9 3,5 4 5,5 9,5 3
turbines È Engines		nents	3,166,150	3,261,134	3,358,968	6,919,475	7,127,059	(6,672,147) 11,011,307 11,011,307 1,282,017 159,675 2,654,379 4,096,071	1,339,642 168,840 2,750,692 4,259,163	2,327,989 1,399,570 178,411 2,850,374 4,428,355	2,366,436 1,491,829 188,405 2,952,893 4,633,128	2,404,884 2,404,884 1,588,364 199,838 3,058,999 4,846,201	2,443,331 2,443,331 1,689,349 209,727 3,168,813 5,067,888	2,481,779 1,794,963 221,090 3,282,463 5,298,516	2,520,227 1,905,393 232,947 3,400,080 5,538,420	2,548,292 1,998,238 245,316 3,520,964 5,764,518	2,576,358 2,094,939 258,217 3,646,042 5,999,198	2,604,423 2,195,644 271,672 3,775,455 6,242,771	2,632,489 2,300,505 285,702 3,909,351 6,495,558	2,660,555 2,409,682 300,329 4.047,883 6.757,894	2,689,692 2,526,762 314,405 4,192,238 7,033,404	2,718,829 2,548,697 329,055 4,241,610 7,319,363 294,300 482,401	2,747,967 2,775,675 344,301 4,495,172 7,616,149	2,777,104 2,907,887 360,166 4,655,101 7,924,155	2,806,242 3,045,535 376,673 4,821,578 8,243,786	2,831,620 3,176,062 393,847 4,994,056 8,563,964	2,856,998 3,311,679 411,711 5,172,542 8,895,933	2,882,376 3,452,575 430,293 5,357,244 9,240,113	2,9 3,5 4 5,5 9,5 3
turbines C Engines bines		nents	3,166,150	3,261,134	3,358,968	6,919,475	7,127,059	(6,672,147) 11,011,307 11,011,307 1,282,017 1,282,017 159,675 2,654,379 4,096,071 142,446 294,931	2,304,521 1,339,642 168,840 2,750,682 4,259,163 148,849 305,631	2,327,989 1,399,570 178,411 2,850,374 4,428,355 155,508 316,708	2,366,436 1,491,829 188,405 2,952,893 4,633,128 165,759 328,099	2,404,884 1,588,364 198,838 3,058,999 4,846,201 176,485 333,889	2,443,331 1,689,349 209,727 3,168,813 5,067,888 187,705 352,090	2,481,779 1,794,963 221,090 3,282,463 5,298,516 199,440 364,718	2,520,227 1,905,393 232,947 3,400,080 5,538,420 211,710 377,787	2,548,292 1,998,238 245,316 3,520,964 5,764,518 222,026 391,218	2,576,358 2,094,939 258,217 3,545,042 5,999,198 232,771 405,116	2,604,423 2,195,644 271,672 3,775,455 6,242,771 243,960 419,495	2,632,489 2,300,505 285,702 3,909,351 6,495,558 255,612 434,372	2,660,555 2,409,682 300,329 4.047,883 6.757.894 267,742 449,765	2,689,692 2,526,762 314,405 4,192,238 7,033,404 280,751 465,804	2,718,829 2,548,697 329,055 4,241,610 7,319,363 294,300	2,747,967 2,775,675 344,301 4,496,172 7,616,149 308,408 499,575	2,777,104 2,907,887 360,166 4,655,101 7,924,155 323,099 517,345	2,806,242 3,045,535 376,673 4,821,578 8,243,786 338,393 535,731	2,831,620 3,176,062 393,847 4,994,056 8,563,964 352,896 554,895	2,856,998 3,311,679 411,711 5,172,542 8,895,933 367,964 574,727	2,882,376 3,452,575 430,293 5,357,244 9,240,113 383,619 595,249	3.5 3.5 9.5 6
turbines C Engines bines		nents	3,166,150	3,261,134	3,358,968	6,919,475	7,127,059	(6,672,147) 11,011,307 11,011,307 1,282,017 1,282,017 159,675 2,654,379 4,096,071 142,446 294,931	2,304,521 1,339,642 168,840 2,750,682 4,259,163 148,849 305,631	2,327,989 1,399,570 178,411 2,850,374 4,428,355 155,508 316,708	2,366,436 1,491,829 188,405 2,952,893 4,633,128 165,759 328,099	2,404,884 1,588,364 198,838 3,058,999 4,846,201 176,485 333,889	2,443,331 1,689,349 209,727 3,168,813 5,067,888 187,705 352,090	2,481,779 1,794,963 221,090 3,282,463 5,298,516 199,440 364,718	2,520,227 1,905,393 232,947 3,400,080 5,538,420 211,710 377,787	2,548,292 1,998,238 245,316 3,520,964 5,764,518 222,026 391,218	2,576,358 2,094,939 258,217 3,545,042 5,999,198 232,771 405,116	2,604,423 2,195,644 271,672 3,775,455 6,242,771 243,960 419,495	2,632,489 2,300,505 285,702 3,909,351 6,495,558 255,612 434,372	2,660,555 2,409,682 300,329 4.047,883 6.757.894 267,742 449,765	2,689,692 2,526,762 314,405 4,192,238 7,033,404 280,751 465,804	2,718,829 2,548,697 329,055 4,241,610 7,319,363 294,300 482,401	2,747,967 2,775,675 344,301 4,496,172 7,616,149 308,408 499,575	2,777,104 2,907,887 360,166 4,655,101 7,924,155 323,099 517,345	2,806,242 3,045,535 376,673 4,821,578 8,243,786 338,393 535,731	2,831,620 3,176,062 393,847 4,994,056 8,563,964 352,896 554,895	2,856,998 3,311,679 411,711 5,172,542 8,895,933 367,964 574,727	2,882,376 3,452,575 430,293 5,357,244 9,240,113 383,619 595,249	3.5 3.5 9.5 6
turbines C Engines bines		nents	3,166,150	3,261,134	3,358,968	6,919,475	7,127,059	(6,672,147) 11,011,307 11,011,307 11,011,307 12,022,017 159,675 2,654,379 4,086,071 142,446 294,333 661,104	2,304,521 1,339,642 168,840 2,750,682 4,259,163 148,849 305,631 708,037	2,327,989 2,327,989 1,399,570 1778,411 2,800,374 4,422,335 316,708 316,708 775,974	2,366,436	2,404,884 1,588,364 198,638 3,058,999 4,846,201 176,485 399,899 807,113	2,443,331 1,689,349 209,727 3,160,813 5,067,88 187,705 352,090 844,880	2,461,779 1,794,963 221,090 3,222,090 3,222,451 5,298,516 199,440 364,718 884,187	2,520,227	2,548,292 1,998,238 245,316 3,520,964 5,764,518 222,026 391,218 963,002	2,076,358 2,094,939 288,217 3,646,02 5,999,198 232,771 405,116 1,002,354	2,504,423 2,195,644 271,672 3,775,455 6,342,771 243,960 419,495 1,043,201	2,632,489	2,660,555	2,589,692 2,526,762 314,405 4,192,238 7,033,404 1,176,110	2,548,597 329,055 4,241,510 7,319,363 294,300 4,224,397	2,747,967 2,775,675 344,301 4,496,172 7,616,149 308,408 499,575 1,274,523	2,777,104 2,907,887 380,166 4,656,101 7,924,155 323,099 517,245 1,326,554	2,806,242 3,045,535 375,673 4,821,578 8,243,786 338,393 535,731 1,380,559	2,831,620 3,176,062 393,847 4,994,056 8,863,964 352,896 554,895 1,434,261	2,856,996 3,311,679 411,711 5,172,542 8,895,933 367,964 57,727 1,489,943	2,882,576 3,462,576 430,293 5,577,244 9,246,113 383,619 555,249 1,547,674	3.5 4 5.5 9.5 1.6
turbines C Engines bines			3,166,150	3,261,134	3,358,968	6,919,475	7,127,059	(6,672,147) 11,011,307 11,011,307 11,011,307 12,022,017 159,675 2,654,379 4,086,071 142,446 294,333 661,104	2,304,521 1,339,642 168,840 2,750,682 4,259,163 148,849 305,631 708,037	2,327,989 1,399,570 178,411 2,850,374 4,428,355 155,508 316,708	2,366,436	2,404,884 1,588,364 198,638 3,058,999 4,846,201 176,485 399,899 807,113	2,443,331 1,689,349 209,727 3,168,813 5,067,888 187,705 352,090	2,461,779 1,794,963 221,090 3,222,090 3,222,451 5,298,516 199,440 364,718 884,187	2,520,227	2,548,292 1,998,238 245,316 3,520,964 5,764,518 222,026 391,218 963,002	2,076,358 2,094,939 288,217 3,646,02 5,999,198 232,771 405,116 1,002,354	2,504,423 2,195,644 271,672 3,775,455 6,342,771 243,960 419,495 1,043,201	2,632,489 2,300,505 285,702 3,909,351 6,495,558 255,612 434,372	2,660,555	2,689,692 2,526,762 314,405 4,192,238 7,033,404 280,751 465,804	2,548,597 329,055 4,241,510 7,319,363 294,300 4,224,397	2,747,967 2,775,675 344,301 4,496,172 7,616,149 308,408 499,575 1,274,523	2,777,104 2,907,887 360,166 4,655,101 7,924,155 323,099 517,345	2,806,242 3,045,535 375,673 4,821,578 8,243,786 338,393 535,731 1,380,559	2,831,620 3,176,062 393,847 4,994,056 8,863,964 352,896 554,895 1,434,261	2,856,996 3,311,679 411,711 5,172,542 8,895,933 367,964 57,727 1,489,943	2,882,376 3,452,575 430,293 5,357,244 9,240,113 383,619 595,249	3.5 4 5.5 9.5 1.6
turbines C Engines bines			3,166,150	3,261,134	3,358,968	6,919,475	7,127,059	(6,672,147) 11,011,307 11,011,307 11,011,307 12,022,017 159,675 2,654,379 4,086,071 142,446 294,333 661,104	2,304,521 1,339,642 168,840 2,750,682 4,259,163 148,849 305,631 708,037	2,327,989 2,327,989 1,399,570 1778,411 2,800,374 4,422,335 316,708 316,708 775,974	2,366,436	2,404,884 1,588,364 198,638 3,058,999 4,846,201 176,485 399,899 807,113	2,443,331 1,689,349 209,727 3,160,813 5,067,88 187,705 352,090 844,880	2,461,779 1,794,963 221,090 3,222,090 3,222,451 5,298,516 199,440 364,718 884,187	2,520,227	2,548,292 1,998,238 245,316 3,520,964 5,764,518 222,026 391,218 963,002	2,076,358 2,094,939 288,217 3,646,02 5,999,198 232,771 405,116 1,002,354	2,504,423 2,195,644 271,672 3,775,455 6,342,771 243,960 419,495 1,043,201	2,632,489	2,660,555	2,589,692 2,526,762 314,405 4,192,238 7,033,404 1,176,110	2,548,597 329,055 4,241,510 7,319,363 294,300 4,224,397	2,747,967 2,775,675 344,301 4,496,172 7,616,149 308,408 499,575 1,274,523	2,777,104 2,907,887 380,166 4,656,101 7,924,155 323,099 517,245 1,326,554	2,806,242 3,045,535 375,673 4,821,578 8,243,786 338,393 535,731 1,380,559	2,831,620 3,176,062 393,847 4,994,056 8,863,964 352,896 554,895 1,434,261	2,856,996 3,311,679 411,711 5,172,542 8,895,933 367,964 57,727 1,489,943	2,882,576 3,462,576 400,203 5,307,244 9,240,113 305,610 305,249 1,547,574 2,526,543	3.5 4 5.5 9.5 1.6
turbines 2 Engines 20nes 1gines			3,166,150	3,261,134	3,358,968	6,919,475	7,127,059	(6,572,147) 11,011,307 11,011,307 11,011,307 12,82,017 12,82,017 12,82,017 12,82,017 14,405,671 142,446 143,446 143,44	2,304,521 1,330,642 168,840 2,750,682 4,259,163 148,849 305,631 708,037 1,162,518	2,327,989 2,327,989 1,399,570 1785,411 285,414 4,428,355 165,508 316,708 316,708 316,708	2,366,436 2,366,436 1,491,829 188,405 2,822,833 4,633,128 166,759 328,099 3770,829 1,264,687	2,404,884 1,588,364 198,838 1058,999 4,846,201 176,485 339,889 807,113 1,323,486	2,443,331 2,443,331 1,6860,349 200,727 1,768,81 1,5067,888 187,705 352,007,888 187,705 352,007,888 187,705 352,000 844,880 1,384,676	2,4481,779 2,4481,779 1,794,963 221,090 3,282,463 5,298,516 199,440 3,64,718 8,84,187 1,448,345	2,520,227	2,548,292 1,998,233 245,316 3,520,945 5,764,518 963,002 1,576,247	2,094,939 268,217 3.646,042 5.999,198 222,771 405,116 1,002,354	2,604,423 2,195,644 271,672 3,775,455 6,242,771 2,43,980 4,19,495 1,043,201 1,043,201	2,632,489 2,300,505 285,702 390,9351 4,495,559 1,065,597 1,775,581	2,660,555 2,660,555 2,409,652 300,329 4,047,83 6,757,894 2,677,42 449,765 1,129,598 1,847,105	2,689,692 2,508,762 314,405 4,192,738 7,333,404 1,176,110 1,922,666	2,548,607 3280,555 4,341,510 7,319,363 244,300 1,224,397 1,224,397 2,2001,098	2,747,967 2,775,675 344,301 4,496,172 7,515,149 308,408 499,575 1,274,523 2,082,506	2,777,104 2,907,887 360,166 4,656,101 7,924,155 322,099 517,345 1,326,554 2,166,997	2,806,242 3,045,536 376,673 4,821,578 8,243,786 338,393 535,731 1,380,559 2,254,683	2,831,620 3,176,082 393,847 4994,095 8,563,964 352,896 554,895 1,434,261 2,342,052	2,856,998 3,311,577 417,741 517,742 8,895,933 367,964 574,727 1,489,943 2,432,634	2,882,576 3,462,576 400,203 5,307,244 9,240,113 305,610 305,249 1,547,574 2,526,543	3.5. 4.5. 9.5 1.6 2.6
turbines 2 Engines 20nes 1gines			3,166,150	3,261,134	3,358,968	6,919,475	7,127,059	(6,672,147) 11,011,307 11,011,307 11,011,307 11,011,307 11,011,307 12,017 12,02,017 12,02,017 14,096,071 142,446 294,331 681,104 142,446 14,118,481 172,182	2,304,521 1.339,642 168,840 2750,682 4,259,163 148,849 305,531 708,037 1.162,518 177,348	2,327,969 1,390,570 176,411 2,80,374 4,422,355 316,708 735,974 1,208,190 182,668	2,366,436	2,404,884 1,588,364 198,838 198,838 198,838 198,486 201 176,485 339,889 807,113 1,323,486 193,793	2,443,331 1,660,349 200,727 3,666,813 5,667,848 1,87,705 352,090 844,880 1,384,676 199,607	2,441,779 1,794,963 221,090 3,282,463 5,298,516 199,440 364,718 864,187 1,448,345 206,595	2,520,227 1,905,303 232,947 3400,205 5,538,429 211,77,07 925,091 1,514,588 211,763	2,548,292 1,998,238 245,316 3,520,964 5,764,518 963,002 1,576,247 218,115	2,076,358 2,094,939 258,217 3,646,042 5,999,198 232,771 405,116 1,002,354 1,640,241 224,659	2.195.644 271.672 271.672 271.575 271.5455 6.242.771 243.960 419.485 1.043.201 1.706.657 231.399	2,632,499 2,502,605 2,500,505 285,702 3,909,351 454,575 1,085,589 1,775,581 2,38,341	2,460,555 2,400,652 300,329 4,027,853 2,407,853 2,407,853 1,129,598 1,129,598 1,129,598	2,526,762 314,205 142,205 7,033,404 1,176,110 1,922,666 252,856	2,546,597 329,056 329,055 4,241,510 7,319,8457,319,345 7,319,345 7,319,3457,345 7,319,345 7,31	2,774,367 2,775,675 344,301 4,465,172 7,616,149 308,408 499,575 1,274,523 2,082,596 268,254	2,907,857 360,166 4,656,101 7,924,155 1,326,554 2,166,997 276,302	2,806,242 3,045,535 376,673 4,821,578 8,243,76 338,393 535,731 1,380,559 2,254,683 284,591	2,831,620 3,176,052 393,847 4,994,056 5,54,895 1,434,261 2,342,052 2,342,052 2,33,129	2,856,998 3,311,679 411,711 5,772,542 6,895,933 3,67,964 5,74,727 1,469,943 3,67,964 5,74,727 1,469,943 3,67,964 5,74,727 1,469,943 3,67,964 5,74,727 1,469,945 3,74,727 1,469,945 3,74,727 1,469,945 3,747,727 1,469,945 3,747,727 1,469,945 3,747,727 1,469,945 3,747,727 1,469,945 3,747,727 1,469,945 3,747,747 1,469,945 3,747,747 1,469,945 3,747,747 1,469,945 3,747,747 1,469,945 3,747,747 1,469,945 3,747,747 1,469,945 3,747,747 1,469,945 3,747,747 1,469,945 3,747,747 1,469,945 3,747,747 1,469,945 3,747,747 1,469,945 3,747,747 2,472,427 3,747,747 2,472,427 3,747,747 2,472,427 3,747,747 2,472,427 3,747,747 2,472,747 3,073,947 3,073,947 3,073,947 3,073,947 3,073,947 3,073,947 3,073,947 3,073,947 3,073,947 3,073,947 3,073,947 3,073,947 3,073,947 3,073,947 3,073,947 3,073,947 3,075,947,947 3,075,947,947,947 3,075,947,947,947,947,947,947,947,947,947,947	2,482,376 3,462,575 430,233 5,337,244 9,249,113 383,619 565,249 1,547,674 2,526,543 310,980	3.5. 4.5.5 9.5 3.6 1.6 2.6 3.3
Autines 2 Engines bines gines			3,166,150	3.261,134	3,358,968	6.919.475 6.919.475	7.127.059	(6,672,147) 11,011,307 11,01	2,304,521 1,339,642 166,840 2750,682 148,840 305,631 708,037 14,162,518 177,348	2,327,969 1,399,570 178,411 2,860,374 4,422,355 165,508 735,974 1,208,190 182,688 182,688	2,366,436	2,404,884 1,588,364 1988,384 1988,384 1988,384 3198,899 807,113 1,323,486 193,793 193,793	2,443,331 1,689,349 200,727 3,160,813 5,667,880 14,880 1,384,876 199,607 199,607	2,441,779 1,794,963 221,090 3,262,454 199,460 364,718 884,187 1,448,345 205,595	2,530,227	2,548,292 1,988,238 245,318 3,550,354 3,570,354 3,570,354 3,91,218 963,002 1,576,247 218,115 218,115	2,094,939 269,217 3,266,042 5,999,198 1,002,354 1,640,241 224,659 224,659	2,195,844 271,872 2,175,844 271,872 3,775,455 6,242,771 243,960 419,495 1,043,201 1,706,657 231,399	2,632,489 2,300,505 285,702 3,005,505 265,702 1,065,612 434,372 1,085,697 1,775,581 238,341	2,409,682 300,329 4,027,482 4,027,482 449,765 1,129,598 1,847,105 245,491	2,689,692 2,526,762 314,405 4,102,230 7,333,404 1,102,730 465,804 1,176,110 1,922,866 252,856	2,548,597 239,055 4,341,510 7,349,545 2001,098 2,001,097 2,001,000 2,001,000 2,001,000 2,000,000 2,000,000 2,000,000 2,000,000	2,774,367 2,775,875 344,301 4,486,172 7,816,143 308,408 499,575 1,274,523 2,082,596 268,254 268,254	2,777,104 2,777,104 2,907,887 360,166 4,656,101 7,924,155 1,7294,155 1,326,554 1,326,554 2,765,997 2,76,302 2,76,302	2,806,242 3,045,535 3,765,573 4,521,773 2,33,786 535,731 1,380,559 2,254,683 284,591 284,591	2,831,620 3,176,062 3,03,847 4,024,052 4,024,052 1,434,261 2,342,052 2,342,052 2,331,29 2,331,29	2,856,998 3,311,679 411,711 5,172,542 8,999,933 367,944 577,727 1,469,943 301,923 301,923	2,882,376 3,452,575 430,283 5,527,244 9,246,113 9,52,545 1,547,674 2,526,543 310,380 310,380	3.5 4 5 9.5 9.5 3 6 1.6 3 3 6 1.6 3 3 3 3 3 3
turbines 2 Engines 20nes 1gines			3,166,150	3,261,134	3,358,968	6.919.475 6.919.475	7.127.059	(6,672,147) 11,011,307 11,01	2,304,521 1,339,642 166,840 2750,682 148,840 305,631 708,037 14,162,518 177,348	2,327,969 1,399,570 178,411 2,860,374 4,422,355 165,508 735,974 1,208,190 182,688 182,688	2,366,436	2,404,884 1,588,364 1988,384 1988,384 1988,384 3198,899 807,113 1,323,486 193,793 193,793	2,443,331 1,689,349 200,727 3,160,813 5,667,880 14,880 1,384,876 199,607 199,607	2,441,779 1,794,963 221,090 3,262,454 199,460 364,718 884,187 1,448,345 205,595	2,530,227	2,548,292 1,988,238 245,318 3,550,354 3,570,354 3,570,354 3,91,218 963,002 1,576,247 218,115 218,115	2,094,939 269,217 3,266,042 5,999,198 1,002,354 1,640,241 224,659 224,659	2,195,844 271,872 2,175,844 271,872 3,775,455 6,242,771 243,960 419,495 1,043,201 1,706,657 231,399	2,632,489 2,300,505 285,702 3,005,505 265,702 1,065,612 434,372 1,085,697 1,775,581 238,341	2,409,682 300,329 4,027,482 4,027,482 449,765 1,129,598 1,847,105 245,491	2,689,692 2,526,762 314,405 4,102,230 7,333,404 1,102,730 465,804 1,176,110 1,922,866 252,856	2,548,597 239,055 4,341,510 7,349,545 2001,098 2,001,097 2,001,000 2,001,000 2,001,000 2,000,000 2,000,000 2,000,000 2,000,000	2,774,367 2,775,875 344,301 4,486,172 7,816,143 308,408 499,575 1,274,523 2,082,596 268,254 268,254	2,777,104 2,777,104 2,907,887 360,166 4,656,101 7,924,155 1,7294,155 1,326,554 1,326,554 2,765,997 2,76,302 2,76,302	2,806,242 3,045,535 3,765,573 4,521,773 2,33,786 535,731 1,380,559 2,254,683 284,591 284,591	2,831,620 3,176,062 3,03,847 4,024,052 4,024,052 1,434,261 2,342,052 2,342,052 2,331,29 2,331,29	2,856,998 3,311,679 411,711 5,172,542 8,999,933 367,944 577,727 1,469,943 301,923 301,923	2,882,376 3,452,575 430,283 5,527,244 9,246,113 9,52,545 1,547,674 2,526,543 310,380 310,380	3.5 4 5 9.5 9.5 3 6 1.6 3 3 6 1.6 3 3 3 3 3 3
Autines 2 Engines bines gines		nents	3,166,150	3.261,134	3,358,968	6.919.475 6.919.475	7,127,059	(6,872,147) (6,872,147) 11,011,307 11,011,307 12,82,017 12,82,017 12,82,017 14,096,675 264,379 4,096,671 142,446 224,405 224,305 681,104 1,118,481 172,182 172,182 172,182	2,304,521 1,339,642 168,840 2,750,682 4,259,163 148,849 305,631 706,037 1,162,518 177,348 177,348 177,348	2,327,969 2,327,969 1,389,570 176,411 2,653,74 4,422,355 16,5,08 735,574 1,208,190 182,668 182,668 182,668	2,366,436 1,491,829 188,405 2,92,289 770,929 1,264,687 188,148 188,148 188,148 188,148	2,404,864 1,588,364 109,838 1065,999 4,846,201 176,485 333,899 807,113 1,323,486 193,793 193,793 3,328,922	2,443,331 2,443,331 1,6280,349 200,727 3,162,813 3,507,288 1,327,050 844,889 1,324,876 1,324,876 1,324,876 1,99,607 1,99,607 1,99,607	2,441,779 1,794,963 227,090 3282,463 5,298,516 199,440, 364,718 854,167 1,448,345 205,595 205,595 205,595	2,530,227	2,548,292 1,968,238 245,316 3,520,865 576,247 218,115 218,115 218,115	2,576,358 2,094,309 268,217 3,646,02 20,771 405,116 1,002,354 1,640,241 224,659 224,659	2,195,644 22,195,644 271,672 3,775,455 6,242,771 24,1970 1,194,405 1,045,201 1,706,657 231,399 231,399 231,399	2,632,649 2,590,500 2,590,500 26,5702 365,702 365,702 365,702 454,572 1,085,597 1,775,581 228,341 238,341 238,341 238,341 238,341	2,466,555 2,409,652 300,329 4,037,854 1,229,5394 1,229,5394 1,229,539 1,129,538 1,129,538 1,129,538	2,689,692 2,526,762 314,405 4,192,238 7,733,404 1,176,110 1,922,666 252,856 252,856 252,856	2,718,829 2,718,829 2,848,097 330,055 4,341,810 7,319,345 2,245,307 482,407 1,224,397 2,2001,098 2,001,098 2,001,098 2,001,098 2,001,098	2,747,967 2,775,675 344,301 4,466,172 7,816,149 308,408 409,575 1,274,023 2,082,596 288,254 268,254 268,254	2,777,104 2,777,104 2,007,887 360,166 4,656,101 7,924,155 323,096 517,392 17,392 17,392 2,166,997 276,302 276,302 276,302	2,896,242 3,044,5,316 376,673 482,1578 2,343,781 1,380,559 2,254,683 284,591 284,591 5,764,512	2,831,820 3,176,082 303,847 4,994,052 4,994,052 1,434,281 2,342,052 2,331,229 2,331,299 2,	2,856,999 2,856,999 3,311,879 411,711 5,172,642 8,895,933 367,964 577,974 1,469,943 367,964 577,974 1,469,943 361,924 301,923 301,923 301,922 6,161,376	2,882,376 3,462,575 402,033 5,377,244 9,262,613 3,547,574 2,526,543 310,980 310,980 4,462,589	3.5.5 4 5.5 9.5 9.5 9.5 1.6 1.6 1.6 3 3 1.6 5 5 5 5 5 9.5 9.5 9.5 9.5 9.5 9.5 9.5 9

Total risk-adjusted capital outlays: \$29,844,000 Total rak-adjusted capital outsiys: \$29,84,000 Alexandia: \$29 SummaryIAB Alexandre SummaryIAB Alexandre SummaryIAB Alexandre SummaryIAB Rok permitin SummaryIAB Capital sens SummaryIAB Capital sens

Discount rate	3.00% 2.00%		pital costs ning costs								Alter	Life Cyc rnative 3 - D			nalysis (\$0 Cogen w/ 0		es											
	2016	2017	2018 20	19 2020	2021	2022 202	3 20	24 2	025	2026	2027	2028	2029	Yea 2030	r 2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044
n 2016 dollars, unescala	ted																											
Cogen			6,750,000 6,75	13,500,0	13,500,000	13,500,000 13,500.	000																					
																		1		1								
tal outlays			6,750,000 6,75	,000 13,500,0	13,500,000	13,500,000 13,500,	000																					
luction - Gas Turbines						3.556.	294 3.60	8.001 3.65	9.708 3.	739.635 3.0	819.561 3	3.899.487 3	979.414 4	1.059.340	4.174.378	4.289.416	4,404,453	4.519.491	4.533.300	4.533.300	4.533.300	4.533.300	4.533.300	4.533.300	4.533.300	4.533.300	4.533.300	4.533.300
ration - Total fuction - (E) IC Engines						129, 2,158,	830 13 253 2.17				143,644		150,552	154,005	157,459	160,913	164,366	167,820	171,273	174,078 2,321,140	176,883 2,333,830	179,688	182,493 2,359,208	185,298	188,103	190,908	193,713	196,518
luction - (E) IC Engines						2,158,	253 2,17	1,414 2,18	4,574 2,	197,230 2,3	209,886 2	2,222,542 2	235,198 2	2,247,853	2,259,973	2,272,093	2,284,212	2,296,332	2,308,451	2,321,140	2,333,830	2,346,519	2,359,208	2,371,897	2,385,189	2,398,481	2,411,772	2,425,064
fits						5,844,	378 5,91	2,699 5,98	1,020 6,0	077,056 6,1	173,091 6	5,269,127 6	365,163 6	6,461,199	6,591,810	6,722,421	6,853,032	6,983,643	7,013,025	7,028,519	7,044,013	7,059,507	7,075,001	7,090,495	7,106,592	7,122,689	7,138,786	7,154,883
ing Costs: ad - Gas Turbines						395.	144 40	0.889 40	6,634	415,515	424.396	433,276	442.157	451.038	463,820	476.602	489,384	502,166	503,700	503,700	503,700	503,700	503,700	503,700	503,700	503,700	503,700	503,700
ad - (E) IC Engines						239.	806 24	1,268 24	2,730	244,137	245,543	246,949	248,355	249,761	251,108	252,455	253,801	255,148	256,495	257,904	259,314	260,724	262,134	263,544	265,021	266,498	267,975	269,452
e						1.198.	.831 1.21	3.347 1.22	7.862 1.3	249.069 1.3	270.276 1	1.291.484 1	312.691 1	.333.898	1.363.446	1.392.995	1.422.543	1.452.091	1.457.344	1.459.374	1.461.405	1.463.435	1.465.465	1.467.496	1.469.622	1.471.749	1.473.876	1.476.002
ing costs		L				1,833,	781 1,85	5,504 1,87	7,227 1,9	908,721 1,9	940,215 1	1,971,709 2	003,203 2	2,034,697	2,078,374	2,122,051	2,165,728	2,209,405	2,217,539	2,220,979	2,224,419	2,227,859	2,231,299	2,234,740	2,238,343	2,241,947	2,245,550	2,249,154
						215,	.000 21	5,000 21	5,000	215,000	215,000	215,000	215,000	215,000	215,000	215,000	215,000	215,000	215,000	215,000	215,000	215,000	215,000	215,000	215,000	215,000	215,000	215,000
bishments						215	000 21	E 000 21	E 000	215.000	215.000	215.000	215.000	215 000	215 000	215 000	215.000	215 000	315 000	215.000	315 000	215.000	21E 000	215 000	215 000	21E 000	215.000	215.000
ost)			(6 750 000) (6 750	000) #######		213,																						
																					1							
vs																												
Cogen			7,161,075 7,37	i,907 15,194,3	369 15,650,200	16,119,706 16,603.	297																					
Cogen			7,161,075 7,37	i,907 15,194,3	369 15,650,200	16,119,706 16,603,	297																					
Cogen tal outlays						16,119,706 16,603, 16,119,706 16,603,																						
tal outlays Juction - Gas Turbines						16,119,706 16,603,	297								6,503,544		7,279,890	7,694,131		8,187,644		8,686,272						
al outlays luction - Gas Turbines ation - Total						16,119,706 16,603, 4,373, 159,	297 794 4,570 675 161	8,840 17	8,411	188,405	198,838	209,727	221,090	232,947	245,316	258,217	271,672	285,702	300,329	314,405	329,055	344,301	360,166	376,673	393,847	411,711	430,293	449,620
al outlays luction - Gas Turbines ation - Total luction - (E) IC Engines filis						16,119,706 16,603, 4,373, 159, 2,654,	297 794 4.570 675 160 379 2,750	8,840 17 0,682 2,85	8,411 0,374 2,1	188,405 952,893 3,0	198,838 058,999 3	209,727	221,090 282,463 3	232,947 3,400,080	245,316 3,520,964	258,217 3,646,042	271,672 3,775,455	285,702 3,909,351	300,329 4,047,883	314,405 4,192,238	329,055 4,341,610	344,301 4,496,172	360,166 4,656,101	376,673 4,821,578	393,847 4,994,056	411,711 5,172,542	430,293 5,357,244	449,620 5,548,372
tal outlays fuction - Gas Turbines ration - Total fuction - (E) IC Engines fifts ing Costs:						16,119,706 16,603, 4,373, 159, 2,654, 7,187,	297 794 4.57(675 161 379 2.75(847 7,49)	8,840 17 0,682 2,85 0,030 7,80	8,411 0,374 2,1 3,874 8,1	188,405 952,893 3,0 167,055 8,9	198,838 058,999 3 545,002 8	209,727 3,168,813 3 3,938,276 9	221,090 282,463 3 347,456 9	232,947 3,400,080 9,773,143 1	245,316 3,520,964 0,269,825	258,217 3,646,042 0,787,512	271,672 3,775,455 11,327,017	285,702 3,909,351 11,889,184	300,329 4,047,883 12,297,381	314,405 4,192,238 12,694,287	329,055 4,341,610 13,103,939	344,301 4,496,172 13,526,746	360,166 4,656,101 13,963,127	376,673 4,821,578 14,413,517	393,847 4,994,056 14,879,626	411,711 5,172,542 15,360,729	430,293 5,357,244 15,857,307	449,620 5,548,372 16,369,854
al outlays luction - Gas Turbines ation - Total luction - (E) IC Engines rifts ad - Cass Turbines ad - (E) IC Engines						16,119,706 16,603, 4,373, 159, 2,654, 7,187, 485, 284,	297 794 4,571 675 161 379 2,750 847 7,490 977 500 931 300	8,840 17 0,682 2,85 0,030 7,80 7,834 53 5,631 31	8,411 0,374 2,1 3,874 8,1 0,565 6,708	188,405 952,893 3,0 167,055 8,4 558,417 5 328,099 5	198,838 058,999 3 545,002 8 587,463 339,889	209,727 3,168,813 3 3,938,276 9 617,748 352,090	221,090 282,463 3 347,456 9 649,323 364,718	232,947 3,400,080 9,773,143 1 682,235 377,787	245,316 3,520,964 0,269,825 722,616 391,218	258,217 3,646,042 0,787,512 764,806 405,116	271,672 3,775,455 11,327,017 808,877 419,495	285,702 3,909,351 11,889,184 854,903 434,372	300,329 4,047,883 12,297,381 883,241 449,765	314,405 4,192,238 12,694,287 909,738 465,804	329,055 4,341,610 13,103,939 937,030 482,401	344,301 4,496,172 13,526,746 965,141 499,575	360,166 4,656,101 13,963,127 994,096 517,345	376,673 4,821,578 14,413,517 1,023,918 535,731	393,847 4,994,056 14,879,626 1,054,636 554,895	411,711 5,172,542 15,360,729 1,086,275 574,727	430,293 5,357,244 15,857,307 1,118,863 595,249	449,620 5,548,372 16,369,854 1,152,429 616,486
al outlays luction - Gas Turbines ation - Total luction - (E) IC Engines rifts ad - Cass Turbines ad - (E) IC Engines						16,119,706 16,603, 16,119,706 16,603, 159, 2,654, 7,187, 485,	297 794 4,571 675 161 379 2,750 847 7,490 977 500 931 300	8,840 17 0,682 2,85 0,030 7,80 7,834 53 5,631 31	8,411 0,374 2,1 3,874 8,1 0,565 6,708	188,405 952,893 3,0 167,055 8,4 558,417 5 328,099 5	198,838 058,999 3 545,002 8 587,463 339,889	209,727 3,168,813 3 3,938,276 9 617,748 352,090	221,090 282,463 3 347,456 9 649,323 364,718	232,947 3,400,080 9,773,143 1 682,235 377,787	245,316 3,520,964 0,269,825 722,616 391,218	258,217 3,646,042 0,787,512 764,806	271,672 3,775,455 11,327,017 808,877	285,702 3,909,351 11,889,184 854,903	300,329 4,047,883 12,297,381 883,241	314,405 4,192,238 12,694,287 909,738 465,804	329,055 4,341,610 13,103,939 937,030 482,401	344,301 4,496,172 13,526,746 965,141	360,166 4,656,101 13,963,127 994,096 517,345	376,673 4,821,578 14,413,517 1,023,918 535,731	393,847 4,994,056 14,879,626 1,054,636 554,895	411,711 5,172,542 15,360,729 1,086,275 574,727	430,293 5,357,244 15,857,307 1,118,863 595,249	449,620 5,548,372 16,369,854 1,152,429 616,486
al outlays uction - Gas Turbines ation - Total uction - (E) IC Engines fits ad - Cass Turbines ad - (E) IC Engines						16,119,706 16,603, 4,373, 159, 2,654, 7,187, 485, 284,	297 794 4,571 675 161 379 2,750 847 7,490 977 500 931 300	8,840 17 0,682 2,85 0,030 7,80 7,834 53 5,631 31	8,411 0,374 2,1 3,874 8,1 0,565 6,708	188,405 952,893 3,0 167,055 8,4 558,417 5 328,099 5	198,838 058,999 3 545,002 8 587,463 339,889	209,727 3,168,813 3 3,938,276 9 617,748 352,090	221,090 282,463 3 347,456 9 649,323 364,718	232,947 3,400,080 9,773,143 1 682,235 377,787	245,316 3,520,964 0,269,825 722,616 391,218	258,217 3,646,042 0,787,512 764,806 405,116	271,672 3,775,455 11,327,017 808,877 419,495	285,702 3,909,351 11,889,184 854,903 434,372	300,329 4,047,883 12,297,381 883,241 449,765	314,405 4,192,238 12,694,287 909,738 465,804	329,055 4,341,610 13,103,939 937,030 482,401	344,301 4,496,172 13,526,746 965,141 499,575	360,166 4,656,101 13,963,127 994,096 517,345	376,673 4,821,578 14,413,517 1,023,918 535,731	393,847 4,994,056 14,879,626 1,054,636 554,895	411,711 5,172,542 15,360,729 1,086,275 574,727	430,293 5,357,244 15,857,307 1,118,863 595,249	449,620 5,548,372 16,369,854 1,152,429 616,486
al outlays uction - Gas Turbines ation - Total uction - (E) IC Engines fits ad - Cass Turbines ad - (E) IC Engines						16,119,706 16,603, 4,373, 159, 2,654, 7,187, 485, 284,	297 794 4,571 675 161 379 2,750 847 7,490 977 500 931 300	8,840 17 0,682 2,85 0,030 7,80 7,834 53 5,631 31	8,411 0,374 2,1 3,874 8,1 0,565 6,708	188,405 952,893 3,0 167,055 8,4 558,417 5 328,099 5	198,838 058,999 3 545,002 8 587,463 339,889	209,727 3,168,813 3 3,938,276 9 617,748 352,090	221,090 282,463 3 347,456 9 649,323 364,718	232,947 3,400,080 9,773,143 1 682,235 377,787	245,316 3,520,964 0,269,825 722,616 391,218	258,217 3,646,042 0,787,512 764,806 405,116	271,672 3,775,455 11,327,017 808,877 419,495	285,702 3,909,351 11,889,184 854,903 434,372	300,329 4,047,883 12,297,381 883,241 449,765	314,405 4,192,238 12,694,287 909,738 465,804	329,055 4,341,610 13,103,939 937,030 482,401	344,301 4,496,172 13,526,746 965,141 499,575	360,166 4,656,101 13,963,127 994,096 517,345	376,673 4,821,578 14,413,517 1,023,918 535,731	393,847 4,994,056 14,879,626 1,054,636 554,895	411,711 5,172,542 15,360,729 1,086,275 574,727	430,293 5,357,244 15,857,307 1,118,863 595,249	449,620 5,548,372 16,369,854 1,152,429 616,486
al outlays uction - Gas Turbines ation - Total uction - (E) IC Engines fits and Costs: ad - Gas Turbines ad - (E) IC Engines e						16,119,706 16,603, 16,119,706 16,603, 16,013,	297 794 4.571 675 161 379 2.751 847 7.491 977 50: 931 30: 411 1.532	8,840 17 0,682 2,85 0,030 7,80 7,834 53 5,631 33 7,031 1,60	8,411 0,374 2,1 3,874 8, 0,565 5 6,708 5 2,081 1,0	188,405 952,893 3,4 167,055 8,5 558,417 5 328,099 5 678,644 1,7	198,838 058,999 3 545,002 8 587,463 339,889 758,360 1	209,727 3,168,813 3 3,338,276 9 617,748 352,090 1,841,347 1	221,090 282,463 3 347,456 9 649,323 364,718 927,731 2	232,947 3,400,080 9,773,143 1 682,235 377,787 2,017,641	245,316 3,520,964 0,269,825 722,616 391,218 2,124,205	258,217 3,646,042 0,787,512 764,806 405,116 2,235,347	271,672 3,775,455 11,327,017 808,877 419,495 2,351,246	285,702 3,909,351 11,889,184 854,903 434,372 2,472,088	300,329 4,047,883 12,297,381 883,241 449,765 2,555,462	314,405 4,192,238 12,694,287 909,738 465,804 2,635,793	329,055 4,341,610 13,103,939 937,030 482,401 2,718,643	344,301 4,496,172 13,526,746 965,141 499,575 2,804,093	360,166 4,656,101 13,963,127 994,096 517,345 2,892,222	376,673 4,821,578 14,413,517 1,023,918 535,731 2,983,116	393,847 4,994,056 14,879,626 1,054,636 554,895 3,077,063	411,711 5,172,542 15,360,729 1,086,275 574,727 3,173,961	430,293 5,357,244 15,857,307 1,118,863 595,249 3,273,904	449,620 5,548,372 16,369,854 1,152,429 616,486 3,376,987
al outlays luction - Gas Turbines ation - Total luction - (E) IC Engines fits ing Costs: ad - Gas Turbines						16,119,706 16,603, 16,119,706 16,603, 16,013,	297 794 4.571 675 161 379 2.751 847 7.491 977 50: 931 30: 411 1.532	8,840 17 0,682 2,85 0,030 7,80 7,834 53 5,631 33 7,031 1,60	8,411 0,374 2,1 3,874 8, 0,565 5 6,708 5 2,081 1,0	188,405 952,893 3,4 167,055 8,5 558,417 5 328,099 5 678,644 1,7	198,838 058,999 3 545,002 8 587,463 339,889 758,360 1	209,727 3,168,813 3 3,938,276 9 617,748 352,090	221,090 282,463 3 347,456 9 649,323 364,718 927,731 2	232,947 3,400,080 9,773,143 1 682,235 377,787 2,017,641	245,316 3,520,964 0,269,825 722,616 391,218 2,124,205	258,217 3,646,042 0,787,512 764,806 405,116 2,235,347	271,672 3,775,455 11,327,017 808,877 419,495 2,351,246	285,702 3,909,351 11,889,184 854,903 434,372 2,472,088	300,329 4,047,883 12,297,381 883,241 449,765 2,555,462	314,405 4,192,238 12,694,287 909,738 465,804 2,635,793	329,055 4,341,610 13,103,939 937,030 482,401 2,718,643	344,301 4,496,172 13,526,746 965,141 499,575 2,804,093	360,166 4,656,101 13,963,127 994,096 517,345 2,892,222	376,673 4,821,578 14,413,517 1,023,918 535,731 2,983,116	393,847 4,994,056 14,879,626 1,054,636 554,895 3,077,063	411,711 5,172,542 15,360,729 1,086,275 574,727 3,173,961	430,293 5,357,244 15,857,307 1,118,863 595,249 3,273,904	449,620 5,548,372 16,369,854 1,152,429 616,486 3,376,987
al outlays Juction - Gas Turbines ation - Total Juction - (E) IC Engines Mis Ing Costs: and - Gas Turbines ad - (E) IC Engines re						16.119.706 16.603. 1.16.119.706 16.603. 1.15. 2.654. 7.187. 2.455. 2.455. 2.255.	297 794 4.57 675 161 379 2.751 847 7.491 977 50: 931 300 411 1.533 319 2.356	8,840 17 0,682 2,85 0,030 7,80 7,834 53 5,631 31 7,031 1,60 0,497 2,44	8,411 0,374 2,1 3,874 8, 0,565 4 6,708 2 2,081 1,0 9,355 2,1	188,405 952,893 3,1 167,055 8,3 558,417 9 328,099 3 678,644 1,3 565,161 2,0	198,838 058,999 3 545,002 8 587,463 339,889 758,360 1 685,711 2	209,727 3,168,813 3 3,938,276 9 617,748 352,090 1,841,347 1 2,811,186 2	221,090 282,463 3 347,456 9 649,323 364,718 927,731 2 941,771 3	232,947 3,400,080 9,773,143 1 682,235 377,787 2,017,641 8,077,662	245,316 3,520,964 0,269,825 722,616 391,218 2,124,205 3,238,039	258,217 3,646,042 0,787,512 764,806 405,116 2,235,347 3,405,269	271,672 3,775,455 11,327,017 808,877 419,495 2,351,246 3,579,618	285,702 3,909,351 11,889,184 854,903 434,372 2,472,088 3,761,363	300,329 4,047,883 12,297,381 883,241 449,765 2,555,462 3,888,468	314,405 4,192,238 12,694,287 909,738 465,804 2,635,793 4,011,335	329,055 4,341,610 13,103,939 937,030 482,401 2,718,643 4,138,075	344.301 4.496.172 13,526.746 965.141 499.575 2.804.093 4,268,809	360,166 4,656,101 13,963,127 994,096 517,345 2,892,222 4,403,662	376,673 4,821,578 14,413,517 1,023,918 535,731 2,983,116 4,542,766	393,847 4,994,056 14,879,626 1,054,636 554,895 3,077,063 4,686,594	411,711 5,172,542 15,360,729 1.086,275 574,727 3,173,961 4,834,963	430,293 5,357,244 15,857,307 1,118,863 595,249 3,273,904 4,988,016	449,620 5,548,372 16,369,854 1,152,429 616,486 3,376,987 5,145,901
al outlays uction - Gas Turbines ation - Total uction - (E) IC Engines fits and Costs: ad - Gas Turbines ad - (E) IC Engines e						16,119,706 16,603, 16,119,706 16,603, 16,013,	297 794 4.57 675 161 379 2.751 847 7.491 977 50: 931 300 411 1.533 319 2.356	8,840 17 0,682 2,85 0,030 7,80 7,834 53 5,631 31 7,031 1,60 0,497 2,44	8,411 0,374 2,1 3,874 8, 0,565 4 6,708 2 2,081 1,0 9,355 2,1	188,405 952,893 3,1 167,055 8,3 558,417 9 328,099 3 678,644 1,3 565,161 2,0	198,838 058,999 3 545,002 8 587,463 339,889 758,360 1 685,711 2	209,727 3,168,813 3 3,938,276 9 617,748 352,090 1,841,347 1 2,811,186 2	221,090 282,463 3 347,456 9 649,323 364,718 927,731 2 941,771 3	232,947 3,400,080 9,773,143 1 682,235 377,787 2,017,641	245,316 3,520,964 0,269,825 722,616 391,218 2,124,205	258,217 3,646,042 0,787,512 764,806 405,116 2,235,347	271,672 3,775,455 11,327,017 808,877 419,495 2,351,246	285,702 3,909,351 11,889,184 854,903 434,372 2,472,088	300,329 4,047,883 12,297,381 883,241 449,765 2,555,462	314,405 4,192,238 12,694,287 909,738 465,804 2,635,793 4,011,335	329,055 4,341,610 13,103,939 937,030 482,401 2,718,643 4,138,075	344,301 4,496,172 13,526,746 965,141 499,575 2,804,093	360,166 4,656,101 13,963,127 994,096 517,345 2,892,222 4,403,662	376,673 4,821,578 14,413,517 1,023,918 535,731 2,983,116 4,542,766	393,847 4,994,056 14,879,626 1,054,636 554,895 3,077,063 4,686,594	411,711 5,172,542 15,360,729 1.086,275 574,727 3,173,961 4,834,963	430,293 5,357,244 15,857,307 1,118,863 595,249 3,273,904 4,988,016	449,620 5,548,372 16,369,854 1,152,429 616,486 3,376,987 5,145,901
al outlays uction - Gas Turbines ation - Total uction - (E) IC Engines fits and Costs: ad - Gas Turbines ad - (E) IC Engines e						16.119.706 16.603. 1.16.119.706 16.603. 1.15. 2.654. 7.187. 2.455. 2.455. 2.255.	297 794 4.57 675 161 379 2.751 847 7.491 977 50: 931 300 411 1.533 319 2.356	8,840 17 0,682 2,85 0,030 7,80 7,834 53 5,631 31 7,031 1,60 0,497 2,44	8,411 0,374 2,1 3,874 8, 0,565 4 6,708 2 2,081 1,0 9,355 2,1	188,405 952,893 3,1 167,055 8,3 558,417 9 328,099 3 678,644 1,3 565,161 2,0	198,838 058,999 3 545,002 8 587,463 339,889 758,360 1 685,711 2	209,727 3,168,813 3 3,938,276 9 617,748 352,090 1,841,347 1 2,811,186 2	221,090 282,463 3 347,456 9 649,323 364,718 927,731 2 941,771 3	232,947 3,400,080 9,773,143 1 682,235 377,787 2,017,641 8,077,662	245,316 3,520,964 0,269,825 722,616 391,218 2,124,205 3,238,039	258,217 3,646,042 0,787,512 764,806 405,116 2,235,347 3,405,269	271,672 3,775,455 11,327,017 808,877 419,495 2,351,246 3,579,618	285,702 3,909,351 11,889,184 854,903 434,372 2,472,088 3,761,363	300,329 4,047,883 12,297,381 883,241 449,765 2,555,462 3,888,468	314,405 4,192,238 12,694,287 909,738 465,804 2,635,793 4,011,335	329,055 4,341,610 13,103,939 937,030 482,401 2,718,643 4,138,075	344.301 4.496.172 13,526.746 965.141 499.575 2.804.093 4,268,809	360,166 4,656,101 13,963,127 994,096 517,345 2,892,222 4,403,662	376,673 4,821,578 14,413,517 1,023,918 535,731 2,983,116 4,542,766	393,847 4,994,056 14,879,626 1,054,636 554,895 3,077,063 4,686,594	411,711 5,172,542 15,360,729 1.086,275 574,727 3,173,961 4,834,963	430,293 5,357,244 15,857,307 1,118,863 595,249 3,273,904 4,988,016	449,620 5,548,372 16,369,854 1,152,429 616,486 3,376,987 5,145,901
al outlays door - Cas Turbines door - Cas Turbines door - Cas Turbines te al - Cas Turbines d -						16.119.706 15.603. 16.013. 15.025 1.025	297 794 4.57 675 161 379 2.75 847 7.49 977 50 931 300 411 1.53 319 2.35 423 27 423 27 423 27 423 4.57 423 4.57 423 4.57 423 4.57 425 4.57 425 4.57 425 4.57 425 4.57 425 4.57 425 4.57 425 4.57 4.57 4.57 4.57 4.57 50 50 50 50 50 50 50 50 50 50	8,840 17 0,682 2,88 0,030 7,80 5,631 31 7,031 1,60 0,497 2,44 2,356 26	8.411 0.374 2.1 3.874 8. 0.565 9. 6.708 9. 9.355 2.1 0.526 2.	188,405 952,893 3,1 167,055 8,5 558,417 5 328,099 5 678,644 1,3 565,161 2,4 288,942 5 565,161 2,4 565,161 2,4 56	198,838 058,999 3 545,002 8 587,463 339,889 1 558,360 1 665,711 2 297,610	209.727 3,168,813 3 8,938,276 9 617,748 617,748 617,748 617,748 617,748 617,748 617,748 617,748 617,748 62,000 1,841,347 1 2,811,186 2 306,539	221,090 282,463 3 347,456 9 649,323 364,718 927,731 2 941,771 3 315,735	232.947 3,400.080 9,773,143 1 682.235 377.787 2,017,641 3,077,662 325,207	245,316 3,520,964 0,269,825 722,616 331,218 2,124,205 3,238,039 334,963	258,217 3,646,042 0,787,512 764,806 405,116 2,235,347 3,405,269 345,012	271,672 3.775,455 11,327,017 808,877 419,495 2.351,246 3.579,618 355,362	285,702 3,909,351 11,889,184 854,903 434,372 2,472,088 3,761,363 366,023	300,329 4,047,883 12,297,381 883,241 449,765 2,555,462 3,888,468 377,004	314.405 4.192.238 12.694.287 909.738 465.804 2.635.793 4.011.335 388.314	329.055 4,341.610 13,103.939 937.030 482.401 2,718,643 4,138,075 399.963	344,301 4,496,172 13,526,746 965,141 499,575 2,804,093 4,268,809 411,962	360,166 4,656,101 13,963,127 994,096 517,345 2,892,222 4,403,662 424,321	376,673 4,821,578 14,413,517 1,023,918 535,731 2,983,116 4,542,766 437,051	393,847 4,994,056 14,879,626 1,054,636 554,895 3,077,063 4,686,594 450,162	411,711 5,172,542 15,360,729 1,086,275 574,727 3,173,961 4,834,963 463,667	430,293 5,357,244 15,857,307 1,118,863 595,249 3,273,904 4,988,016 477,577	449.620 5.548.372 16,369.854 1.152.429 616.486 3.376.967 5.145.901 491.904
ul outlays stoon - Total stoon - Total stoon - Total Stoom - Total ad - Gas Turbines ad - Gas Turbines ad - Gas Turbines ad - (E) IC Engines a) e) na costs			7,161,075 7.37	.907 15,194,3	15,650,200	16,119,706 16,603, 16,119,706 16,603, 199, 2,854, 7,187, 4057, 244, 1,474, 2,255, 2,64, 2,74, 2,	297 794 4.577 675 161 379 2.759 847 7,491 977 500 931 3000 411 1.533 319 2.359 423 277 423 277	8,840 117 0,682 2,86 0,030 7,86 7,834 52 5,631 33 7,031 1,60 0,497 2,44 2,356 226 2,356 226	8,411 0,374 2, 3,874 8, 0,565 9 6,708 9 2,081 1,1 9,355 2,1 0,526 9 0,526 9	188,405 952,893 187,055 8,1 558,417 328,099 678,544 1,3 565,161 288,942 288,942 288,942	198,838 058,999 3 545,002 8 587,463 399,889 758,360 1 685,711 2 297,610 297,610	209.727 3,168,813 3 3,398,276 9 617,748 352,090 1,841,347 1 2,811,186 2 306,539 306,539	221,090 282,463 33 347,456 9 649,323 347,756 9 649,323 347,756 9 941,771 3 315,735 315,735	232,947 3,400,080 9,7773,143 1 682,235 377,787 2,017,641 3,077,662 325,207 325,207	245,316 3,520,964 0,269,825 722,616 331,218 2,124,205 3,238,039 334,963 334,963	258,217 3,646,042 0,787,512 764,806 405,116 2,235,347 3,405,269 345,012 345,012	271,672 3,775,455 11,327,017 808,877 419,495 2,351,246 3,579,618 355,362 355,362	285,702 3,909,351 11,889,184 11,889,184 854,903 434,372 2,472,088 3,761,363 3,761,363 366,023 366,023	300.329 4.047,883 12,297,381 883,241 449,765 2.555,462 3.888,468 377,004	314,405 4,192,238 12,694,287 909,738 465,804 2,635,793 4,011,335 388,314 388,314	329,055 4,341,610 13,103,939 937,030 482,401 2,718,643 4,138,075 399,963 399,963	344,301 4,496,172 13,526,746 965,141 499,575 2,804,093 4,268,809 411,962 411,962	360.166 4.656.101 13.963.127 994.096 517.345 2.892.222 4.403.662 424.321 424.321	376.673 4.821.578 14.413.517 1.023.918 535.731 2.983.116 4.542.766 437.051	333.847 4.994.056 114.879.626 1.054.636 554.895 3.077.063 4.686.594 450.162	411.711 5.172.542 15.360.729 1.086.275 574.727 3.173.961 4.834.963 463.667	430.293 5,357,244 15,857,307 1,118,863 595,249 3,273,904 4,988,016 477,577 477,577	449.620 5.548.372 16.369.854 1.152.429 616.466 3.376.987 5.145.901 491.904 491.904
al outlavs stion - Total stion - Total cution - (E) (C Engines ad - (E) (C Engines ad - (E) (C Engines e			7,161,075 7.37	.907 15,194,3	15,650,200	16.119.706 15.603. 16.013. 15.025 1.025	297 794 4.577 675 161 379 2.759 847 7,491 977 500 931 3000 411 1.533 319 2.359 423 277 423 277	8,840 117 0,682 2,86 0,030 7,86 7,834 52 5,631 33 7,031 1,60 0,497 2,44 2,356 226 2,356 226	8,411 0,374 2, 3,874 8, 0,565 9 6,708 9 2,081 1,1 9,355 2,1 0,526 9 0,526 9	188,405 952,893 187,055 8,1 558,417 328,099 678,544 1,3 565,161 288,942 288,942 288,942	198,838 058,999 3 545,002 8 587,463 399,889 758,360 1 685,711 2 297,610 297,610	209.727 3,168,813 3 3,398,276 9 617,748 352,090 1,841,347 1 2,811,186 2 306,539 306,539	221,090 282,463 33 347,456 9 649,323 347,756 9 649,323 347,756 9 941,771 3 315,735 315,735	232,947 3,400,080 9,7773,143 1 682,235 377,787 2,017,641 3,077,662 325,207 325,207	245,316 3,520,964 0,269,825 722,616 331,218 2,124,205 3,238,039 334,963 334,963	258,217 3,646,042 0,787,512 764,806 405,116 2,235,347 3,405,269 345,012 345,012	271,672 3,775,455 11,327,017 808,877 419,495 2,351,246 3,579,618 355,362 355,362	285,702 3,909,351 11,889,184 11,889,184 854,903 434,372 2,472,088 3,761,363 3,761,363 366,023 366,023	300.329 4.047,883 12,297,381 883,241 449,765 2.555,462 3.888,468 377,004	314,405 4,192,238 12,694,287 909,738 465,804 2,635,793 4,011,335 388,314 388,314	329,055 4,341,610 13,103,939 937,030 482,401 2,718,643 4,138,075 399,963 399,963	344,301 4,496,172 13,526,746 965,141 499,575 2,804,093 4,268,809 411,962 411,962	360.166 4.656.101 13.963.127 994.096 517.345 2.892.222 4.403.662 424.321 424.321	376.673 4.821.578 14.413.517 1.023.918 535.731 2.983.116 4.542.766 437.051	333.847 4.994.056 114.879.626 1.054.636 554.895 3.077.063 4.686.594 450.162	411.711 5.172.542 15.360.729 1.086.275 574.727 3.173.961 4.834.963 463.667	430.293 5,357,244 15,857,307 1,118,863 595,249 3,273,904 4,988,016 477,577 477,577	449.620 5.548.372 16.369.854 1.152.429 616.466 3.376.987 5.145.901 491.904 491.904
ul outlays stoon - Total stoon - Total stoon - Total Stoom - Total ad - Gas Turbines ad - Gas Turbines ad - Gas Turbines ad - (E) IC Engines a) e) na costs			7,161,075 7.37	.907 15,194,3	15,650,200	16,119,706 16,603, 16,119,706 16,603, 199, 2,854, 7,187, 4057, 244, 1,474, 2,255, 2,64, 2,74, 2,	297 794 4.577 675 161 379 2.759 847 7,491 977 500 931 3000 411 1.533 319 2.359 423 277 423 277	8,840 117 0,682 2,86 0,030 7,86 7,834 52 5,631 33 7,031 1,60 0,497 2,44 2,356 226 2,356 226	8,411 0,374 2, 3,874 8, 0,565 9 6,708 9 2,081 1,1 9,355 2,1 0,526 9 0,526 9	188,405 952,893 187,055 8,1 558,417 328,099 678,544 1,3 565,161 288,942 288,942 288,942	198,838 058,999 3 545,002 8 587,463 399,889 758,360 1 685,711 2 297,610 297,610	209.727 3,168,813 3 3,398,276 9 617,748 352,090 1,841,347 1 2,811,186 2 306,539 306,539	221,090 282,463 33 347,456 9 649,323 347,756 9 649,323 347,756 9 941,771 3 315,735 315,735	232,947 3,400,080 9,7773,143 1 682,235 377,787 2,017,641 3,077,662 325,207 325,207	245,316 3,520,964 0,269,825 722,616 331,218 2,124,205 3,238,039 334,963 334,963	258,217 3,646,042 0,787,512 764,806 405,116 2,235,347 3,405,269 345,012 345,012	271,672 3,775,455 11,327,017 808,877 419,495 2,351,246 3,579,618 355,362 355,362	285,702 3,909,351 11,889,184 11,889,184 854,903 434,372 2,472,088 3,761,363 3,761,363 366,023 366,023	300.329 4.047,883 12,297,381 883,241 449,765 2.555,462 3.888,468 377,004	314,405 4,192,238 12,694,287 909,738 465,804 2,635,793 4,011,335 388,314 388,314	329,055 4,341,610 13,103,939 937,030 482,401 2,718,643 4,138,075 399,963 399,963	344,301 4,496,172 13,526,746 965,141 499,575 2,804,093 4,268,809 411,962 411,962	360.166 4.656.101 13.963.127 994.096 517.345 2.892.222 4.403.662 424.321 424.321	376.673 4.821.578 14.413.517 1.023.918 535.731 2.983.116 4.542.766 437.051	333.847 4.994.056 114.879.626 1.054.636 554.895 3.077.063 4.686.594 450.162	411.711 5.172.542 15.360.729 1.086.275 574.727 3.173.961 4.834.963 463.667	430.293 5,357,244 15,857,307 1,118,863 595,249 3,273,904 4,988,016 477,577 477,577	449.620 5.548.372 16.369.854 1.152.429 616.466 3.376.987 5.145.901 491.904 491.904

rom Summary Sheet: Year of analysis Escalation rate Discount rate	2016 3.00% 2.00%	Risk adjustm	ents (+/- percent): Benefits Capital costs Running costs						20.847.600					Inland Em e Cycle Altern ative 4 - DG Al		nalysis (\$00													
	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2029	2029	Year 2030	2031	2022	2033	2024	2025	2026	2027	2028	2029	2040	2041	2042	2043	2044
pressed in 2016 dollars, unescala	ited	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2020	2029	2030	2031	2032	2033	2034	2035	2030	2037	2036	2039	2040	2041	2042	2043	2044
otal Outlays NG System			2,084,760	2,084,760	4.169.520	4,169,520	4,169,520	4,169,520																					
her				(I		(
her ber				(I		(
otal capital outlays			2.084.760	2.084.760	4.169.520	4.169.520	4.169.520	4.169.520																					
is: i Sales								441 775	448 187	454 598	470.452	486 305	502 158	518.012	533,865	543 572	553.279	562 985	572 692	582 399	592 909	603.419	613.928	624 438	634 948	642 875	650 801	658 728	666 655
LCFS Credits				(I		(390,087	395,749	401,410	415,409	429,407	443,406	457,404	471,403	479,974	488,545	497,116	505 687	514,258	523,538	532,819	542,099	551,379	560,659	567,658	574,658	581,657	588,656
3 RIN Credits er production - (E) IC Engines				(I		(I	-	515,404	522,884	530,365 2 184 574	548,860	2 200 896	585,851	604,347	622,842	634,167	645,492	656,816 2,284,212	668,141	679,465	691,727	703,988	716,250	728,511	740,773 2 371 897	750,020	759,268	768,516	777,764
tal benefits								3,505,520		3,570,947	3,631,951	3,692,954	3,753,957	3,814,960	3,875,964	3,917,685	3,959,408						4,218,795	4,263,536			4,383,208		
Running Costs: Maintenance		-						200.000	200.000	200.000	200,000	200.000	200.000	200.000	200.000	200.000	200,000	200.000	200.000	200.000	200.000	200.000	200.000	200.000	200,000	200.000	200.000	200,000	200.000
sitic Loads - IC Engines								239,806	241,268	242,730	244,137	245,543	246,949	248,355	249,761	251,108	252,455	253,801	255,148	256,495	257,904	259,314	260,724	262,134	263,544	265,021	266,498	267,975	269,452
tenance - IC Engines				<u> </u>				345,321	347,426	349,532	351,557	353,582	355,607	357,632	359,657	361,596	363,535	365,474	367,413	369,352	371,382	373,413	375,443	377,473	379,504	381,630	383,757	385,884	388,010
				(I		(
				(I		(
ar tal running costs								785 126	788 694	792.262	795.693	799 125	802 556	805 987	809 418	812 704	815 990	819.275	822 561	825 847	829 287	832 727	836 167	839 607	843.048	845 651	850.255	853,858	857.462
Costs:																													
				(I		(34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000	34,000
				(I		(
ar				(I		(
tal refurbishments						ļ		34.000			34.000	34.000			34.000	34.000			34.000						34.000	34.000	34.000		34.000
Benefit/(cost)	L	II	(2.084.760)	(2.084.760)	(4.169.520)	(4.169.520)	(4.169.520)	(1.483.127)	2.715.539	2.744.685	2.802.257	2.859.829	2.917.401	2.974.973	3.032.546	3.070.982	3.109.418	3.147.854	3.186.291	3.224.727	3.266.027	3.307.328	3.348.628	3.389.929	3.431.229	3.465.091	3.498.953	3.532.815	3.566.677
ressed in escalated dollars with	sensitivity adjust	stments																											
al Outlays G System			2,211,722	2,278,074	4 692 831	4 833 616	4.978.625	5,127,984																					
o oyananı			2,211,722	2,210,014	4,032,001	4,000,010	4,370,023	0,127,004																					
er						1 I																							
ier ier						1 1																							
er tal capital outlays				1																									
			2,211,722	2,278,074	4,692,831	4,833,616	4,978,625	5,127,984																					
ts:	[2,211,722	2,278,074	4,692,831	4,833,616	4,978,625																						
3 Sales			2,211,722	2,278,074	4,692,831	4,833,616	4,978,625	543,328	567,749 501.323	593,148 523,749	632,248 558,275	673,160 594.400	715,958 632,191	760,718 671,714	807,519 713,039	846,867 747,784	887,850 783,971	930,529 821,657	974,970 860,898	1,021,240	1,070,859	1,122,536	1,176,350	1,232,383	1,290,719	1,346,037	1,403,512	1,463,225	1,525,258
3 Sales 3 LCFS Credits 3 RIN Credits			2,211,722	2,278,074	4,692,831	4,833,616	4,978,625	543,328 479,758 633,882	501,323 662,374	523,749 692,006	558,275 737,622	594,400 785,353	632,191 835,284	671,714 887,504	713,039 942,105	747,784 988,012	783,971 1,035,825	821,657 1,085,617	860,898 1,137,465	901,755 1,191,447	945,569 1,249,336	991,199 1,309,626	1,038,717	1,088,194 1,437,780	1,139,704 1,505,838	1,188,550 1,570,376	1,239,302	1,292,028	1,346,803 1,779,467
3 Sales 3 LCFS Credits 3 RIN Credits tal benefits			2,211,722	2,278,074	4,692,831	4,833,616	4,978,625	543,328 479,758	501,323 662,374	523,749 692,006	558,275	594,400	632,191 835,284	671,714 887,504	713,039	747,784	783,971 1,035,825	821,657 1,085,617	860.898	901,755 1,191,447	945,569 1,249,336	991,199 1,309,626	1.038.717	1,088,194 1,437,780	1,139,704	1,188,550 1,570,376	1,239,302	1,292,028	1.346.803
3 Sales 3 LCFS Credits 3 RIN Credits tal benefits I Running Costs: 3 Maintenance			2,211,722	2,278,074	4,692,831	4,833,616	4,978,625	543,328 479,758 633,882 1,656,968 245,975	501,323 662,374 1,731,447 253,354	523,749 692,006 1,808,902 260,955	558,275 737,622 1,928,144 268,783	594,400 785,353 2,052,913 276,847	632,191 835,284 2,183,432 285,152	671,714 887,504 2,319,935 293,707	713,039 942,105 2,462,663 302,518	747,784 988,012 2,582,662 311,593	783,971 1,035,825 2,707,645 320,941	821,657 1,085,617 2,837,803 330,570	860,898 1,137,465 2,973,333 340,487	901,755 1,191,447 3,114,441 350,701	945,569 1,249,336 3,265,763 361,222	991,199 1,309,626 3,423,361 372,059	1,038,717 1,372,409 3,587,476 383,221	1,088,194 1,437,780 3,758,357 394,717	1,139,704 1,505,838 3,936,261 406,559	1,188,550 1,570,376 4,104,964 418,756	1,239,302 1,637,431 4,280,245 431,318	1,292,028 1,707,096 4,462,349 444,258	1,346,803 1,779,467 4,551,528 457,586
Ifis: G Sales G RLCFS Credits G RIN Credits stal benefits al Running Costs: G Maintenance astile Loads - IC Engines interaces - IC Engines			2,211,722	2,278,074	4,692,831	4,833,616	4,978,625	543,328 479,758 633,882 1,656,968 245,975 294,931	501,323 662,374 1,731,447 253,354 305,631	523,749 692,006 1,808,902 260,955 316,708	268,783 328,099	594,400 785,353 2,052,913 276,847 339,889	632,191 835,284 2,183,432 285,152 352,090	671,714 887,504 2,319,935 293,707 364,718	713,039 942,105 2,462,663 302,518 377,787	747,784 988,012 2,582,662 311,593 391,218	783,971 1,035,825 2,707,645 320,941 405,116	821,657 1,085,617 2,837,803 330,570 419,495	860,898 1,137,465 2,973,333 340,487 434,372	901,755 1,191,447 3,114,441 350,701 449,765	945,569 1,249,336 3,265,763 361,222 465,804	991,199 1,309,626 3,423,361 372,059 482,401	1,038,717 1,372,409 3,587,476 383,221 499,575	1,088,194 1,437,780 3,758,357 394,717 517,345	1,139,704 1,505,838 3,936,261 406,559 535,731	1,188,550 1,570,376 4,104,954 418,756 554,895	1,239,302 1,637,431 4,280,245 431,318 574,727	1,292,028 1,707,096 4,462,349 444,258 595,249	1,346,803 1,779,467 4,651,528 457,586 616,486
3 Sales S LCFS Credits S RIN Credits tal benefits al Running Costs: 3 Maintenance astic Loads - IC Engines			2,211,722	2,278,074	4,692,831	4,833,616	4,978,625	543,328 479,758 633,882 1,656,968 245,975	501,323 662,374 1,731,447 253,354	523,749 692,006 1,808,902 260,955	558,275 737,622 1,928,144 268,783	594,400 785,353 2,052,913 276,847	632,191 835,284 2,183,432 285,152	671,714 887,504 2,319,935 293,707	713,039 942,105 2,462,663 302,518	747,784 988,012 2,582,662 311,593	783,971 1,035,825 2,707,645 320,941	821,657 1,085,617 2,837,803 330,570	860,898 1,137,465 2,973,333 340,487	901,755 1,191,447 3,114,441 350,701	945,569 1,249,336 3,265,763 361,222	991,199 1,309,626 3,423,361 372,059	1,038,717 1,372,409 3,587,476 383,221	1,088,194 1,437,780 3,758,357 394,717	1,139,704 1,505,838 3,936,261 406,559	1,188,550 1,570,376 4,104,964 418,756	1,239,302 1,637,431 4,280,245 431,318	1,292,028 1,707,096 4,462,349 444,258	1,346,803 1,779,467 4,551,528 457,586
3 Sales 3 LCFS Credits 3 RIN Credits tal benefits al Running Costs: 3 Maintenance			2,211,722	2,278,074	4,692,831	4,833,616 ,	4,978,625	543,328 479,758 633,882 1,656,968 245,975 294,931	501,323 662,374 1,731,447 253,354 305,631	523,749 692,006 1,808,902 260,955 316,708	268,783 328,099	594,400 785,353 2,052,913 276,847 339,889	632,191 835,284 2,183,432 285,152 352,090	671,714 887,504 2,319,935 293,707 364,718	713,039 942,105 2,462,663 302,518 377,787	747,784 988,012 2,582,662 311,593 391,218	783,971 1,035,825 2,707,645 320,941 405,116	821,657 1,085,617 2,837,803 330,570 419,495	860,898 1,137,465 2,973,333 340,487 434,372	901,755 1,191,447 3,114,441 350,701 449,765	945,569 1,249,336 3,265,763 361,222 465,804	991,199 1,309,626 3,423,361 372,059 482,401	1,038,717 1,372,409 3,587,476 383,221 499,575	1,088,194 1,437,780 3,758,357 394,717 517,345	1,139,704 1,505,838 3,936,261 406,559 535,731	1,188,550 1,570,376 4,104,954 418,756 554,895	1,239,302 1,637,431 4,280,245 431,318 574,727	1,292,028 1,707,096 4,462,349 444,258 595,249	1,346,803 1,779,467 4,651,528 457,586 616,486
3 Sales 3 C/CS Credits 3 RIN Credits al benefits Harting Costs: 3 Maintenance sitic Loads - I/C Engines tenance - IC Engines			2,211,722	2,278,074	4,692,831	4,833,616	4,978,625	543,328 479,758 633,882 1,656,968 245,975 294,931	501,323 662,374 1,731,447 253,354 305,631	523,749 692,006 1,808,902 260,955 316,708	268,783 328,099	594,400 785,353 2,052,913 276,847 339,889	632,191 835,284 2,183,432 285,152 352,090	671,714 887,504 2,319,935 293,707 364,718	713,039 942,105 2,462,663 302,518 377,787	747,784 988,012 2,582,662 311,593 391,218	783,971 1,035,825 2,707,645 320,941 405,116	821,657 1,085,617 2,837,803 330,570 419,495	860,898 1,137,465 2,973,333 340,487 434,372	901,755 1,191,447 3,114,441 350,701 449,765	945,569 1,249,336 3,265,763 361,222 465,804	991,199 1,309,626 3,423,361 372,059 482,401	1,038,717 1,372,409 3,587,476 383,221 499,575	1,088,194 1,437,780 3,758,357 394,717 517,345	1,139,704 1,505,838 3,936,261 406,559 535,731	1,188,550 1,570,376 4,104,954 418,756 554,895	1,239,302 1,637,431 4,280,245 431,318 574,727	1,292,028 1,707,096 4,462,349 444,258 595,249	1,346,803 1,779,467 4,651,528 457,586 616,486
Sales LCFS Credits RIN Credits al benefits Running Costs: Maintenance site Loads - IC Engines tenance - IC Engines			2,211,722	2,278,074	4,692,831	4,833,616	4,978,625	543,328 479,758 633,882 1,656,968 245,975 294,931	501,323 662,374 1,731,447 253,354 305,631 440,109	523,749 692,006 1,808,902 260,955 316,708	558,275 737,622 1,928,144 268,783 328,099 472,463	594,400 785,353 2,052,913 276,847 339,889 489,440	632,191 835,284 2,183,432 285,152 352,090 507,010	671,714 887,504 2,319,935 293,707 364,718 525,194	713,039 942,105 2,462,663 302,518 377,787 544,013	747,784 988,012 2,582,662 311,593 391,218 563,354	783,971 1,035,825 2,707,645 320,941 405,116 583,367	821,657 1,085,617 2,837,803 330,570 419,495 604,073	860,898 1,137,465 2,973,333 340,487 434,372 625,496	901,755 1,191,447 3,114,441 350,701 449,765 647,661	945,569 1,249,336 3,265,763 361,222 465,804 670,758	991,199 1,309,626 3,423,361 372,059 482,401 694,658	1,038,717 1,372,409 3,587,476 383,221 499,575 719,388	1,088,194 1,437,780 3,758,357 394,717 517,345 744,976	1,139,704 1,505,838 3,936,261 406,559 535,731 771,452	1,188,550 1,570,376 4,104,964 418,756 554,895 799,049	1,239,302 1,637,431 4,280,245 431,318 574,727 827,607	1,292,028 1,707,096 4,462,349 444,258 595,249 857,159	1,346,803 1,779,467 4,651,528 457,586 616,486
3 Sales J CFS Credits J CFS Credits J RIN Credits all benefits Maintenance salie Loads - IC Engines stele Loads - IC Engines sterannce - IC Engines all numing costs Joats:			2,211,722	2,278,074	4,692,831	4,833,616	4,978,625	543,328 479,758 633,882 1,656,968 245,975 294,931 424,701 965,606	501,323 662,374 1,731,447 253,354 305,631 440,109 999,094	223,749 692,006 1,808,902 260,955 316,708 456,060 1,033,723	1,069,345	276,847 339,889 489,440 1,106,175	632,191 835,284 2,183,432 285,152 352,090 507,010 1,144,253	671,714 887,504 2,319,935 293,707 364,718 525,194 1,183,619	113,039 942,105 2,462,663 302,518 377,787 544,013	747,784 988,012 2,582,662 311,593 391,218 563,354 1,266,166	783,971 1,035,825 2,707,645 320,941 405,116 583,367 1,309,424	821,657 1,065,617 2,837,803 330,570 419,495 604,073 1,354,137	360,888 1,137,465 2,973,333 340,487 434,372 625,496 1,400,355	901,755 1,191,447 3,114,441 350,701 449,765 647,661 1,448,127	945,569 1,249,336 3,265,763 361,222 465,804 670,758 1,497,785	991,199 1,209,626 3,423,361 372,059 482,401 694,658 1,549,118	1,038,717 1,372,409 3,587,476 383,221 499,575 719,388 1,602,183	1,088,194 1,437,780 3,758,357 394,717 517,345 744,976 1,657,038	1,139,704 1,505,838 3,936,261 406,559 535,731 771,452 1,713,742	1,188,550 1,570,376 4,104,964 418,756 554,895 799,049 1,772,700	1,239,302 1,637,431 4,280,245 431,318 574,727 827,607 1,833,652	1,292,028 1,707,096 4,462,349 444,258 595,249 857,159 1,896,666	1,346,803 1,779,467 4,651,528 457,586 616,486 887,739 1,961,811
3 Sales S LCFS Credits S RIN Credits tal benefits al Running Costs: 3 Maintenance astic Loads - IC Engines			2,211,722	2,278,074	4,692,831	4,833,616	4,978,625	543,328 479,758 633,882 1,656,968 245,975 294,931 424,701	501,323 662,374 1,731,447 253,354 305,631 440,109	523,749 692,006 1,808,902 260,955 316,708 456,060	558,275 737,622 1,928,144 268,783 328,099 472,463	594,400 785,353 2,052,913 276,847 339,889 489,440	632,191 835,284 2,183,432 285,152 352,090 507,010	671,714 887,504 2,319,935 293,707 364,718 525,194	713,039 942,105 2,462,663 302,518 377,787 544,013	747,784 988,012 2,582,662 311,593 391,218 563,354	783,971 1,035,825 2,707,645 320,941 405,116 583,367	821,657 1,085,617 2,837,803 330,570 419,495 604,073	860,898 1,137,465 2,973,333 340,487 434,372 625,496	901,755 1,191,447 3,114,441 350,701 449,765 647,661	945,569 1,249,336 3,265,763 361,222 465,804 670,758	991,199 1,309,626 3,423,361 372,059 482,401 694,658	1,038,717 1,372,409 3,587,476 383,221 499,575 719,388	1,088,194 1,437,780 3,758,357 394,717 517,345 744,976	1,139,704 1,505,838 3,936,261 406,559 535,731 771,452	1,188,550 1,570,376 4,104,964 418,756 554,895 799,049	1,239,302 1,637,431 4,280,245 431,318 574,727 827,607	1,292,028 1,707,096 4,462,349 444,258 595,249 857,159	1,346,803 1,779,467 4,651,528 457,586 616,486 887,739
i Sales LCFS Credits SRIN Credits Jacherfits Jacherfits Maintenance sille Loads - IC Engines tenance - IC Engines r al numing costs Josts:			2,211,722	2,278,074	4,692,831	4,833,616	4,978,625	543,328 479,758 633,882 1,656,968 245,975 294,931 424,701 965,606	501,323 662,374 1,731,447 253,354 305,631 440,109 999,094	223,749 692,006 1,808,902 260,955 316,708 456,060 1,033,723	1,069,345	276,847 339,889 489,440 1,106,175	632,191 835,284 2,183,432 285,152 352,090 507,010 1,144,253	671,714 887,504 2,319,935 293,707 364,718 525,194 1,183,619	113,039 942,105 2,462,663 302,518 377,787 544,013	747,784 988,012 2,582,662 311,593 391,218 563,354 1,266,166	783,971 1,035,825 2,707,645 320,941 405,116 583,367 1,309,424	821,657 1,065,617 2,837,803 330,570 419,495 604,073 1,354,137	360,888 1,137,465 2,973,333 340,487 434,372 625,496 1,400,355	901,755 1,191,447 3,114,441 350,701 449,765 647,661 1,448,127	945,569 1,249,336 3,265,763 361,222 465,804 670,758 1,497,785	991,199 1,209,626 3,423,361 372,059 482,401 694,658 1,549,118	1,038,717 1,372,409 3,587,476 383,221 499,575 719,388 1,602,183	1,088,194 1,437,780 3,758,357 394,717 517,345 744,976 1,657,038	1,139,704 1,505,838 3,936,261 406,559 535,731 771,452 1,713,742	1,188,550 1,570,376 4,104,964 418,756 554,895 799,049 1,772,700	1,239,302 1,637,431 4,280,245 431,318 574,727 827,607 1,833,652	1,292,028 1,707,096 4,462,349 444,258 595,249 857,159 1,896,666	1,346,803 1,779,467 4,651,528 457,586 616,486 887,739 1,961,811
i Sales LCFS Credits IRIN Credits al benefits Running Costs: Maintenance site Loads - LC Engines sternance - IC Engines f al numing costs costs:			2,211,722	2,278,074	4,692,831	4,833,616	4,978,625	543,328 479,758 633,882 1,656,968 245,975 294,931 424,701 965,606	501,323 662,374 1,731,447 253,354 305,631 440,109 999,094 43,070	523,749 692,006 1,808,902 280,955 316,708 456,060 1,033,723 44,362	1,069,345	276,847 339,889 489,440 1,106,175	632,191 835,284 2,183,432 285,152 352,090 507,010 1,144,253	671,714 887,504 2,319,935 293,707 364,718 525,194 1,183,619	713,039 942,105 2,462,663 302,518 377,787 544,013 1,224,317 51,428	747,784 988,012 2,592,662 311,593 391,218 563,354 1,266,166 52,971	783,971 1,035,825 2,707,645 320,941 405,116 583,367 1,309,424	821,657 1,065,617 2,837,803 330,570 419,495 604,073 1,354,137 56,197	860,838 1,137,465 2,973,333 340,487 434,372 625,496 1,400,355 57,883	901,755 1,191,447 3,114,441 350,701 449,765 647,661 1,448,127 59,619	945,569 1,249,336 3,265,763 361,222 465,804 670,758 1,497,785 61,408	991,199 1,009,626 3,423,361 372,059 482,401 694,658 1,549,118 63,250	1,038,717 1,372,409 3,587,476 383,221 499,575 719,388 1,602,183 65,148	1,088,194 1,437,780 3,778,337 394,717 517,345 744,976 1,657,038 67,102	1,139,704 1,505,838 3,936,261 406,559 535,731 771,452 1,713,742	1,188,550 1,570,376 4,104,964 418,756 554,895 799,049 1,772,700	1,239,302 1,637,431 4,280,245 431,318 574,727 827,607 1,833,652	1,292,028 1,707,096 4,462,349 444,258 595,249 857,159 1,896,666	1,346,803 1,779,467 4,651,528 457,586 616,486 887,739 1,961,811
Sales CLFS Credits RIV Credits INFO Credits International Mainteance Mainteance set Loads - LC Engines from Inning costs osts: from Inning costs osts:								543,328 479,758 633,882 1,856,968 245,975 294,931 424,701 965,606 41,816 41,816	501,323 662,374 1,731,474 253,354 305,631 440,109 999,094 43,070 43,070	523,749 692,005 1,808,902 2260,955 316,708 456,060 1,033,723 44,362 44,362	558,275 737,622 1,928,144 266,783 328,099 472,463 1,069,345 45,693 45,693	594,400 785,353 2,052,913 276,847 339,889 489,440 1,106,175 47,064 47,064	632.191 835.284 2,183.432 285.152 352.090 507.010 507.010 1,144,253 48,476 48,476	671,714 887,504 2,319,335 293,707 364,718 525,194 1,183,619 49,930	713,039 942,105 2,462,663 302,518 377,787 544,013 1,224,317 51,428 51,428	747,784 988,012 2,552,662 3311,593 391,218 563,354 1,266,166 52,971 52,971	783.971 1.035.825 2.707.645 320.941 405.116 583.367 1.309.424 54.560 54.560	821,657 1.085,617 2,837,803 330,570 419,495 604,073 1,354,137 56,197 56,197	860,838 1,137,465 2,973,333 340,487 434,372 625,496 1,400,355 57,883 57,883	901,755 1,191,447 3,114,441 350,701 449,765 647,661 1,448,127 59,619 59,619	945,569 1,249,336 3,265,763 361,222 465,804 670,758 1,497,785 61,408 61,408	991,199 1,309,626 3,423,361 3,72,059 482,401 694,658 1,549,118 63,250 63,250	1,038,717 1,372,409 3,587,476 383,221 499,575 719,388 1,602,183 65,148 65,148	1,088,194 1,437,780 3,768,357 394,717 517,345 744,976 1,657,038 67,102 67,102	1,139,704 1,505,838 3,936,261 406,559 536,731 771,452 1,713,742 69,115 69,115	1,188,550 1,570,376 4,104,954 418,756 554,895 799,049 1,772,700 71,188 71,188	1,239,302 1,637,431 4,280,245 431,318 574,727 827,607 1,833,652 73,324 73,324	1,222,028 1,707,096 4,462,249 444,258 595,249 857,159 1,896,666 75,524 75,524	1,346,803 1,779,467 4,551,528 4,551,528 4,57,586 616,486 887,739 1,961,811 77,790 77,790
Sales CLFS Credits RIV Credits Ibenefits Harring Costs: Marineance C Engines enance - IC Engines nance - IC Engines				2.278.074				543,328 479,758 633,882 1,856,968 245,975 294,931 424,701 965,606 41,816 41,816	501,323 662,374 1,731,474 253,354 305,631 440,109 999,094 43,070 43,070	523,749 692,005 1,808,902 2260,955 316,708 456,060 1,033,723 44,362 44,362	558,275 737,622 1,928,144 266,783 328,099 472,463 1,069,345 45,693 45,693	594,400 785,353 2,052,913 276,847 339,889 489,440 1,106,175 47,064	632.191 835.284 2,183.432 285.152 352.090 507.010 507.010 1,144,253 48,476 48,476	671,714 887,504 2,319,935 293,707 364,718 525,194 1,183,619 49,930	713,039 942,105 2,462,663 302,518 377,787 544,013 1,224,317 51,428 51,428	747,784 988,012 2,552,662 3311,593 391,218 563,354 1,266,166 52,971 52,971	783.971 1.035.825 2.707.645 320.941 405.116 583.367 1.309.424 54.560 54.560	821,657 1,065,617 2,837,803 330,570 419,495 604,073 1,354,137 56,197	860,838 1,137,465 2,973,333 340,487 434,372 625,496 1,400,355 57,883 57,883	901,755 1,191,447 3,114,441 350,701 449,765 647,661 1,448,127 59,619 59,619	945,569 1,249,336 3,265,763 361,222 465,804 670,758 1,497,785 61,408 61,408	991,199 1,309,626 3,423,361 3,72,059 482,401 694,658 1,549,118 63,250 63,250	1,038,717 1,372,409 3,587,476 383,221 499,575 719,388 1,602,183 65,148 65,148	1,088,194 1,437,780 3,768,357 394,717 517,345 744,976 1,657,038 67,102 67,102	1,139,704 1,505,838 3,936,261 406,559 536,731 771,452 1,713,742 69,115 69,115	1,188,550 1,570,376 4,104,954 418,756 554,895 799,049 1,772,700 71,188 71,188	1,239,302 1,637,431 4,280,245 431,318 574,727 827,607 1,833,652 73,324 73,324	1,222,028 1,707,096 4,462,249 444,258 595,249 857,159 1,896,666 75,524 75,524	1,346,803 1,779,467 4,651,528 616,486 887,739 1,961,811 777,790
Sales (LPS on Call State LPS on Call State banellis Laurning Costs: Maintenance Inuming costs sts: Inuming costs sts: Inuming costs sts:								543,328 479,758 633,882 1,856,968 245,975 294,931 424,701 965,606 41,816 41,816	501,323 662,374 1,731,474 253,354 305,631 440,109 999,094 43,070 43,070	523,749 692,005 1,808,902 2260,955 316,708 456,060 1,033,723 44,362 44,362	558,275 737,622 1,928,144 266,783 328,099 472,463 1,069,345 45,693 45,693	594,400 785,353 2,052,913 276,847 339,889 489,440 1,106,175 47,064 47,064	632.191 835.284 2,183.432 285.152 352.090 507.010 507.010 1,144,253 48,476 48,476	671,714 887,504 2,319,335 293,707 364,718 525,194 1,183,619 49,930	713,039 942,105 2,462,663 302,518 377,787 544,013 1,224,317 51,428 51,428	747,784 988,012 2,552,662 3311,593 391,218 563,354 1,266,166 52,971 52,971	783.971 1.035.825 2.707.645 320.941 405.116 583.367 1.309.424 54.560 54.560	821,657 1.085,617 2.837,803 330,570 419,495 604,073 1.354,137 56,197 56,197	860,838 1,137,465 2,973,333 340,487 434,372 625,496 1,400,355 57,883 57,883	901,755 1,191,447 3,114,441 350,701 449,765 647,661 1,448,127 59,619 59,619	945,569 1,249,336 3,265,763 361,222 465,804 670,758 1,497,785 61,408 61,408	991,199 1,309,626 3,423,361 3,72,059 482,401 694,658 1,549,118 63,250 63,250	1,038,717 1,372,409 3,587,476 383,221 499,575 719,388 1,602,183 65,148 65,148	1,088,194 1,437,780 3,768,357 394,717 517,345 744,976 1,657,038 67,102 67,102	1,139,704 1,505,838 3,936,261 406,559 536,731 771,452 1,713,742 69,115 69,115	1,188,550 1,570,376 4,104,954 418,756 554,895 799,049 1,772,700 71,188 71,188	1,239,302 1,637,431 4,280,245 431,318 574,727 827,607 1,833,652 73,324 73,324	1,222,028 1,707,096 4,462,249 444,258 595,249 857,159 1,896,666 75,524 75,524	1,346,803 1,779,467 4,551,528 4,551,528 4,57,586 616,486 887,739 1,961,811 77,790 77,790
Sales (LPS Credits IRIN Credits Unanits Unanits Mainteances in Control C Engines in unning costs sats:			(2.211.722)		(4.692.831)	(4.833.610)	(4.978.625)	543,322 479,759 533,822 1,656,969 245,975 245,975 245,975 245,975 245,975 245,975 245,975 245,975 245,975 245,975 245,975 41,816 41,816 41,816 (4478,438)	501.323 562.374 1,731.447 253.354 305.531 440,109 999,094 43,070 689.282	523,749 692,005 1,808,902 2260,955 316,708 456,060 1,033,723 44,362 44,362	556,275 737,622 1,928,144 268,783 328,093 472,463 1,069,345 45,693 45,693 813,106	594,400 794,553 2052,915 2052,9152,913 2052,913 2052,913 2052,913 2052,913 2052,913	632,191 835,294 2,183,432 285,152 352,090 507,010 1,144,253 48,476 48,476 990,704	571,714 887,504 2,319,935 203,707 364,718 525,194 1,183,619 49,930 1,086,385	11,039 942,05 2462,65 302,518 377,787 544,013 1,224,317 51,428 51,428 51,428	747,784 988,012 2,562,662 311,593 391,218 563,354 1,266,166 52,971 1,263,525	763.971 1.035.975 2.707.645 320.941 405.116 583.367 1.309.424 54.560 1.343.662	821,657 1.085,617 2.837,803 330,570 419,495 604,073 1.354,137 56,197 56,197	80,088 1,137,465 2,973,333 340,487 434,372 625,496 1,400,355 57,883 1,515,095	901,755 1,191,441 350,701 492,765 647,661 1,448,127 59,619 59,619 1,606,695	945,569 1,249,36 3,265,763 361,222 465,804 670,758 1,497,785 61,408 61,408 1,706,571	991,199 1,200,623 3,423,361 3,423,361 3,72,059 482,401 694,658 1,549,118 63,250 63,250 1,810,993	1,038,717 1,372,409 3,857,476 383,221 499,575 719,388 1,602,183 65,148 65,148 1,920,145	1,088,194 1,437,780 3,758,357 304,717 517,345 744,976 1,657,038 67,102 67,102 2,034,217	1,132,704 1,502,803 3,336,241 3,336,241 405,559 5,35,731 771,452 1,713,742 69,115 69,115 2,153,404	1,188,850 1,570,376 4,104,964 418,756 554,895 799,049 1,772,700 71,188 71,188 2,261,076	1,239,302 1,637,431 4,280,245 4,280,245 431,318 574,727 827,607 1,833,652 73,324 73,324 2,373,269	1,292,028 1,707,096 4,462,349 444,258 505,249 857,159 1,896,666 75,524 75,524 75,524 2,490,159	1,346,803 1,779,467 4,651,528 6,16,486 8,87,739 1,961,811 77,790 77,790 2,611,927

From Summary Sheet: Year of analysis Escalation rate Discount rate	2016 3.00% 2.00%		ents (+/- percen Benefits Capital costs Running costs	t):										Inland Em e Cycle Alterna rnative 5 - DG		nalysis (\$000														
pressed in 2016 dollars, unescala	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044	2045
pital Outlays																														
CNG System Other Other Other Other Other			1,962,000	1,962,000	3,924,000	3,924,000	3,924,000	3,924,000																						
Total capital outlays			1.962.000	1.962.000	3.924.000	3.924.000	3.924.000	3.924.000																						
nefits: NG Sales								1 162 566	1 179 439	1 196 311	1 238 030	1 279 750	1 321 469	1.353.188	1 404 908	1 430 452	1 455 996	1.481.540	1 507 084	1 532 629	1 560 286	1 587 943	1.615.601	1 643 258	1.670.916	1 691 775	1 712 635	1 733 495	1 754 354	1 775 2
NG LCFS Credits NG RIN Credits								780,175		802,820	830,817		886,812 1,171,703				977,090 1,290,983		1,011,374	1,028,516	1,047,077	1,065,637	1,084,197	1,102,758	1,121,318	1,135,317	1,149,315	1,163,314	1,177,312	1,191,3
wer production - (E) IC Engines								2,158,253	2,171,414	2,184,574	2,197,230	2,209,886	2,222,542	2,235,198	2,247,853	2,259,973	2,272,093	2,284,212	2,296,332	2,308,451	2,321,140	2,333,830	2,346,519	2,359,208	2,371,897	2,385,189	2,398,481	2,411,772	2,425,064	2,438,3
otal benefits al Running Costs:								5,131,802	5,188,119	5,244,435	5,363,798	5,483,162	5,602,525	5,721,888	5,841,252	5,918,707	5,996,162	6,073,617	6,151,072	6,228,527	6,311,957	6,395,387	6,478,817	6,562,246	6,645,676	6,712,322	6,778,967	6,845,613	6,912,259	6,978,9
NG Maintenance								300,000		300,000				300,000	300,000		300,000		300,000	300,000		300,000			300,000					
antenance - IC Engines								239,806	241,268			245,543		248,355 357,632	249,761	251,108 361,596		253,801	255,148	256,495	257,904 371,382				263,544	265,021	266,498	267,975	269,452 388.010	270,92
								040,021	041,420	040,002	1001,007	000,002	000,007	001,002	000,007	501,550	565,555	000,014	501,415	503,552	011,002	010,010	010,440	011,410	010,004	001,000	000,101	505,004	300,010	550,1
ther ther																														
ther																														
otal running costs								885,126	888,694	892,262	895,693	899,125	902,556	905,987	909,418	912,704	915,990	919,275	922,561	925,847	929,287	932,727	936,167	939,607	943,048	946,651	950,255	953,858	957,462	961,0
Costs: R								64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.0
her		1 1				1	1	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,000	04,0
her																														
her otal refurbishments								64.000	64.000	64.000	64.000	64.000	64.000		64.000		64.000		64.000		64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.000	64.0
enefit/(cost)	-		(1 962 000)	(1 962 000)	(2 924 000)	(2.924.000)	(3.924.000)							64.000 4.751.901								5.398.660							5.890.797	
pressed in escalated dollars with pital Outlays ING System Ither	sen sitivity adjus	tments																												
Other Other Other			2,081,486	2,143,930	4,416,497	4,548,991	4,685,461	4,826,025																						
ther ther ther							4,685,461																							
ther ther ther fotal capital outlays efits:								4,826,025																						
her her her otal capital outlays afts: KG Sales G Sales G LCFS Credits								4,826,025 1,429,810 959,517	1,494,077	1,560,915 1,047,499	1,563,809	1,771,473	1,884,099	2,001,888	2,125,049 1,426,078	2,228,598	2,336,446 1,567,942	2,448,760 1,543,314	2,565,710	2,687,474	2,818,050	2,954,043	3,095,658 2,077,434	3,243,112 2,176,388	3,396,628 2,279,409	3,542,202 2,377,101	3,693,454 2,478,603	3,850,593 2,584,056	4,013,836 2,693,605	2,807,4
her her otal capital outfays fifte: IG Sales IG LCFS Credits IG RIN Credits								4,826,025 1,429,810 959,517 1,267,764	1,494,077 1,002,646 1,324,749	1,047,499 1,384,011	1,116,549	1,188,800	1,264,381 1,670,568	1,343,427 1,775,008	1,426,078 1,884,210	1,495,567 1,976,023	1,567,942 2,071,649	1,643,314 2,171,234	1,721,797 2,274,930	1,803,510 2,382,893	1,891,137 2,498,671	1,982,399 2,619,251	2,077,434 2,744,817	2,176,388 2,875,560	2,279,409 3,011,677	2,377,101 3,140,752	2,478,603 3,274,862	2,584,056 3,414,192	2,693,605 3,558,935	2,807,4
ther ther ther Total capital outlays sefts: NG Sales NG LCFS Credits NG RIN Credits Total benefits uai Running Costs:								4,826,025 1,429,810 959,517	1,494,077 1,002,646 1,324,749	1,047,499 1,384,011	1,116,549	1,188,800	1,264,381 1,670,568	1,343,427	1,426,078 1,884,210	1,495,567 1,976,023	1,567,942	1,643,314 2,171,234	1,721,797	1,803,510 2,382,893	1,891,137 2,498,671	1,982,399	2,077,434 2,744,817	2,176,388 2,875,560	2,279,409 3,011,677	2,377,101 3,140,752	2,478,603 3,274,862	2,584,056	2,693,605	2,807,40
ther ther for a capital outays entra: NG Sales NG Sales NG LCFS Credits NG RIN Credits cala banefits cala banefits and Running Costs: NG Maintenance								4,826,025 1,429,810 959,517 1,267,764 3,657,091 368,962	1,494,077 1,002,646 1,324,749 3,821,472 380,031	1,047,499 1,384,011 3,992,424 391,432	1,116,549 1,475,244 4,255,603 403,175	1,188,800 1,570,706 4,530,979 415,270	1,264,381 1,670,568 4,819,048	1,343,427 1,775,008 5,120,323 440,560	1,426,078 1,884,210 5,435,337 453,777	1,495,567 1,976,023 5,700,188 467,390	1,567,942 2,071,649 5,976,038 481,412	1,643,314 2,171,234 6,263,309 495,854	1,721,797 2,274,930 6,562,437 510,730	1,803,510 2,382,893 6,873,876	1,891,137 2,498,671 7,207,858 541,833	1,982,399 2,619,251 7,555,693 558,088	2,077,434 2,744,817 7,917,910 574,831	2,176,388 2,875,560 8,295,060 592,076	2,279,409 3,011,677 8,687,713 609,838	2,377,101 3,140,752 9,060,056 628,133	2,478,603 3,274,862 9,446,919 646,977	2,584,056 3,414,192 9,848,841 666,387	2,693,605 3,558,935 10,266,376 686,378	2,807,4 3,709,2 10,700,0 705,9
ther ther Total capital outfays effs:: NG Saltes NG LCFS Credits NG RIN Credits Total benefits call Rumring Costs:								4,826,025 1,429,810 959,517 1,267,764 3,657,091	1,494,077 1,002,646 1,324,749 3,821,472	1,047,499 1,384,011 3,992,424	1,116,549 1,475,244 4,255,603	1,188,800 1,570,706 4,530,979	1,264,381 1,670,568 4,819,048	1,343,427 1,775,008 5,120,323	1,426,078 1,884,210 5,435,337	1,495,567 1,976,023 5,700,188	1,567,942 2,071,649 5,976,038	1,643,314 2,171,234 6,263,309	1,721,797 2,274,930 6,562,437	1,803,510 2,382,893 6,873,876	1,891,137 2,498,671 7,207,858	1,982,399 2,619,251 7,555,693	2,077,434 2,744,817 7,917,910	2,176,388 2,875,560 8,295,060	2,279,409 3,011,677 8,687,713	2,377,101 3,140,752 9,060,056	2,478,603 3,274,862 9,446,919	2,584,056 3,414,192 9,848,841	2,693,605 3,558,935 10,266,376	2,807,4 3,709,2 10,700,0 706,9 638,4
her her Coal capital outays effer: NG LocpEd Credits NG LocpEd Credits NG INC Credits Crait benefits aus Running Costs: NG Maintenance animenance - IC Engines animenance - IC Engines her								4,826,025 1,429,810 959,517 1,267,764 3,657,091 368,962 294,931	1,494,077 1,002,646 1,324,749 3,821,472 380,031 305,631	1,047,499 1,384,011 3,992,424 391,432 316,708	1,116,549 1,475,244 4,255,603 403,175 328,099	1,188,800 1,570,706 4,530,979 415,270 339,889	1,264,381 1,670,568 4,819,048 427,728 352,090	1,343,427 1,775,008 5,120,323 440,560 364,718	1,426,078 1,884,210 5,435,337 453,777 377,787	1,495,567 1,976,023 5,700,188 467,390 391,218	1,567,942 2,071,649 5,976,038 481,412 405,116	1,643,314 2,171,234 6,263,309 495,854 419,495	1,721,797 2,274,930 6,562,437 510,730 434,372	1,803,510 2,382,893 6,873,876 526,052 449,765	1,891,137 2,498,671 7,207,858 541,833 465,804	1,982,399 2,619,251 7,555,693 558,088 482,401	2,077,434 2,744,817 7,917,910 574,831 499,575	2,176,388 2,875,560 8,295,060 592,076 517,345	2,279,409 3,011,677 8,687,713 609,838 535,731	2,377,101 3,140,752 9,060,056 628,133 554,895	2,478,603 3,274,862 9,446,919 646,977 574,727	2,584,056 3,414,192 9,848,841 666,387 595,249	2,693,605 3,558,935 10,266,376 686,378 616,486	2,807,4 3,709,2 10,700,0 706,9 638,4
her her her otal captal outays effs: viS Sales viS Sales viS Sales viS Rink Credits viS Rink Credits vid Innih Credits vid Innih Credits vid Maintenance traditic Lock's Engines intenance - U Engines her her								4,826,025 1,429,810 959,517 1,267,764 3,657,091 368,962 294,931	1,494,077 1,002,646 1,324,749 3,821,472 380,031 305,631	1,047,499 1,384,011 3,992,424 391,432 316,708	1,116,549 1,475,244 4,255,603 403,175 328,099	1,188,800 1,570,706 4,530,979 415,270 339,889	1,264,381 1,670,568 4,819,048 427,728 352,090	1,343,427 1,775,008 5,120,323 440,560 364,718	1,426,078 1,884,210 5,435,337 453,777 377,787	1,495,567 1,976,023 5,700,188 467,390 391,218	1,567,942 2,071,649 5,976,038 481,412 405,116	1,643,314 2,171,234 6,263,309 495,854 419,495	1,721,797 2,274,930 6,562,437 510,730 434,372	1,803,510 2,382,893 6,873,876 526,052 449,765	1,891,137 2,498,671 7,207,858 541,833 465,804	1,982,399 2,619,251 7,555,693 558,088 482,401	2,077,434 2,744,817 7,917,910 574,831 499,575	2,176,388 2,875,560 8,295,060 592,076 517,345	2,279,409 3,011,677 8,687,713 609,838 535,731	2,377,101 3,140,752 9,060,056 628,133 554,895	2,478,603 3,274,862 9,446,919 646,977 574,727	2,584,056 3,414,192 9,848,841 666,387 595,249	2,693,605 3,558,935 10,266,376 686,378 616,486	2,807,4 3,709,2 10,700,0 706,9 638,4
her her her discuted outlays drite: Vis CLPS Credits dis RNC Credits dis RNC Credits dis RNC redits and Ruming Cock and Ruming								4,826,025 1,429,810 959,517 1,267,764 3,657,091 368,962 294,931 424,701	1,494,077 1,002,646 1,324,749 3,821,472 380,031 305,631 440,109	1,047,499 1,384,011 3,992,424 391,432 316,708 456,060	1,116,549 1,475,244 4,255,603 403,175 328,099 472,463	1,188,800 1,570,706 4,530,979 415,270 339,889 489,440	1,264,381 1,670,568 4,819,048 427,728 352,090 507,010	1,343,427 1,775,008 5,120,323 440,560 364,718 525,194	1,426,078 1,884,210 5,435,337 453,777 377,787 544,013	1,495,567 1,976,023 5,700,188 467,390 391,218 563,354	1,567,942 2,071,649 5,976,038 481,412 405,116 583,367	1,643,314 2,171,234 6,263,309 495,854 419,495 604,073	1,721,797 2,274,930 6,562,437 510,730 434,372 625,496	1,803,510 2,382,893 6,873,876 526,052 449,765 647,661	1,891,137 2,498,671 7,207,858 541,833 465,804 670,758	1,982,399 2,619,251 7,555,693 558,088 482,401 694,658	2,077,434 2,744,817 7,917,910 574,831 499,575 719,388	2,176,388 2,875,560 8,295,060 592,076 517,345 744,976	2,279,409 3,011,677 8,687,713 609,838 535,731 771,452	2,377,101 3,140,752 9,060,056 628,133 554,895 799,049	2,478,603 3,274,862 9,446,919 646,977 574,727 827,607	2,584,056 3,414,192 9,848,841 666,387 595,249 857,159	2,693,605 3,558,935 10,256,376 686,378 616,486 887,739	2,807,4 3,709,2 10,700,0 706,9 638,4 919,3
rer ser ser ser de Cables de								4,826,025 1,429,810 959,517 1,267,764 3,657,091 368,962 294,931 424,701	1,494,077 1,002,646 1,324,749 3,821,472 380,031 305,631 440,109	1,047,499 1,384,011 3,992,424 391,432 316,708 456,060	1,116,549 1,475,244 4,255,603 403,175 328,099 472,463	1,188,800 1,570,706 4,530,979 415,270 339,889 489,440	1,264,381 1,670,568 4,819,048 427,728 352,090 507,010	1,343,427 1,775,008 5,120,323 440,560 364,718	1,426,078 1,884,210 5,435,337 453,777 377,787 544,013	1,495,567 1,976,023 5,700,188 467,390 391,218 563,354	1,567,942 2,071,649 5,976,038 481,412 405,116 583,367	1,643,314 2,171,234 6,263,309 495,854 419,495 604,073	1,721,797 2,274,930 6,562,437 510,730 434,372 625,496	1,803,510 2,382,893 6,873,876 526,052 449,765 647,661	1,891,137 2,498,671 7,207,858 541,833 465,804 670,758	1,982,399 2,619,251 7,555,693 558,088 482,401 694,658	2,077,434 2,744,817 7,917,910 574,831 499,575 719,388	2,176,388 2,875,560 8,295,060 592,076 517,345 744,976	2,279,409 3,011,677 8,687,713 609,838 535,731 771,452	2,377,101 3,140,752 9,060,056 628,133 554,895 799,049	2,478,603 3,274,862 9,446,919 646,977 574,727 827,607	2,584,056 3,414,192 9,848,841 666,387 595,249 857,159	2,693,605 3,558,935 10,256,376 686,378 616,486 887,739	2,807,4 3,709,2 10,700,0 706,9 638,4 919,3
her her ber diagnatia outlays afte: dis Cables dis Cables dis Cables dis Cables dis Cables container dis Cables container dis Maintenance rastile Loads. IC Engines mer her her her her her her her h								4,826,025 1,429,810 959,517 1,267,764 3,657,091 368,962 294,931 424,701	1,494,077 1,002,646 1,324,749 3,821,472 380,031 305,631 440,109	1,047,499 1,384,011 3,992,424 391,432 316,708 456,060	1,116,549 1,475,244 4,255,603 403,175 328,099 472,463	1,188,800 1,570,706 4,530,979 415,270 339,889 489,440	1,264,381 1,670,568 4,819,048 427,728 352,090 507,010	1,343,427 1,775,008 5,120,323 440,560 364,718 525,194	1,426,078 1,884,210 5,435,337 453,777 377,787 544,013	1,495,567 1,976,023 5,700,188 467,390 391,218 563,354	1,567,942 2,071,649 5,976,038 481,412 405,116 583,367	1,643,314 2,171,234 6,263,309 495,854 419,495 604,073	1,721,797 2,274,930 6,562,437 510,730 434,372 625,496	1,803,510 2,382,893 6,873,876 526,052 449,765 647,661	1,891,137 2,498,671 7,207,858 541,833 465,804 670,758	1,982,399 2,619,251 7,555,693 558,088 482,401 694,658	2,077,434 2,744,817 7,917,910 574,831 499,575 719,388	2,176,388 2,875,560 8,295,060 592,076 517,345 744,976	2,279,409 3,011,677 8,687,713 609,838 535,731 771,452	2,377,101 3,140,752 9,060,056 628,133 554,895 799,049	2,478,603 3,274,862 9,446,919 646,977 574,727 827,607	2,584,056 3,414,192 9,848,841 666,387 595,249 857,159	2,693,605 3,558,935 10,256,376 686,378 616,486 887,739	2,807,4 3,709,2 10,700,0 706,9 638,4 919,3 2,264,8
ver ver ver ver ver ver ver ver								4,826,025 1,429,810 959,517 1,267,764 3,657,091 368,962 294,931 424,701 1,088,594	1,494,077 1,002,646 1,324,749 3,821,472 380,031 305,631 305,631 440,109	1,047,499 1,384,011 3,992,424 391,432 316,708 456,060 1,164,200	1,116,549 1,475,244 4,255,603 403,175 328,099 472,463 1,203,737	1,188,800 1,570,706 4,530,979 415,270 339,889 489,440 1,244,599	1,264,381 1,670,568 4,819,048 427,728 352,090 507,010	1,343,427 1,775,008 5,120,323 440,560 364,718 525,194 1,330,472	1,426,078 1,884,210 5,435,337 453,777 377,787 544,013 1,375,576	1,495,567 1,976,023 5,700,188 467,390 391,218 563,354 1,421,963	1,567,942 2,071,649 5,976,038 481,412 405,116 583,367 1,469,894	1,543,314 2,171,234 6,263,309 495,854 419,495 604,073 1,519,422	1,721,797 2,274,930 6,562,437 510,730 434,372 625,496 1,570,598	1,803,510 2,382,893 6,873,876 526,052 449,765 647,661 1,623,478	1,891,137 2,498,671 7,207,858 541,833 465,804 670,758 1,678,396	1,982,399 2,619,251 7,555,693 558,088 482,401 694,658 1,735,147	2,077,434 2,744,817 7,917,910 574,831 499,575 719,388 1,793,793	2,176,388 2,875,560 8,295,060 592,076 517,345 744,976 1,854,397	2,279,409 3,011,677 8,687,713 609,838 535,731 771,452 1,917,022	2,377,101 3,140,752 9,060,056 628,133 554,895 799,049 1,982,077	2,478,603 3,274,862 9,446,919 646,977 574,727 827,607 2,049,311	2,584,056 3,414,192 9,848,841 666,387 595,249 857,159 2,118,795	2,693,605 3,558,935 10,266,376 686,378 616,486 887,739 2,190,604	2,807,4 3,709,2 10,700,0 706,9 638,4 919,3 2,264,8
ser or relacionaria o data ya ter de la constal o data ya de la constal data ya de la constal data ya de la constal constal: constal: constal: constal: del Makinterance al funcing Constal: del Makinterance de la constal constal: constal: constal: constal: constal: del makinterance del makintera								4,826,025 1,429,810 959,517 1,267,764 3,657,091 368,962 294,931 424,701 1,088,594	1,494,077 1,002,646 1,324,749 3,821,472 380,031 305,631 305,631 440,109	1,047,499 1,384,011 3,992,424 391,432 316,708 456,060 1,164,200	1,116,549 1,475,244 4,255,603 403,175 328,099 472,463 1,203,737	1,188,800 1,570,706 4,530,979 415,270 339,889 489,440 1,244,599	1,264,381 1,670,568 4,819,048 427,728 352,090 507,010	1,343,427 1,775,008 5,120,323 440,560 364,718 525,194 1,330,472	1,426,078 1,884,210 5,435,337 453,777 377,787 544,013 1,375,576	1,495,567 1,976,023 5,700,188 467,390 391,218 563,354 1,421,963	1,567,942 2,071,649 5,976,038 481,412 405,116 583,367 1,469,894	1,543,314 2,171,234 6,263,309 495,854 419,495 604,073 1,519,422	1,721,797 2,274,930 6,562,437 510,730 434,372 625,496 1,570,598	1,803,510 2,382,893 6,873,876 526,052 449,765 647,661 1,623,478	1,891,137 2,498,671 7,207,858 541,833 465,804 670,758 1,678,396	1,982,399 2,619,251 7,555,693 558,088 482,401 694,658 1,735,147	2,077,434 2,744,817 7,917,910 574,831 499,575 719,388 1,793,793	2,176,388 2,875,560 8,295,060 592,076 517,345 744,976 1,854,397	2,279,409 3,011,677 8,687,713 609,838 535,731 771,452 1,917,022	2,377,101 3,140,752 9,060,056 628,133 554,895 799,049 1,982,077	2,478,603 3,274,862 9,446,919 646,977 574,727 827,607 2,049,311	2,584,056 3,414,192 9,848,841 666,387 595,249 857,159 2,118,795	2,693,605 3,558,935 10,266,376 686,378 616,486 887,739 2,190,604	2,807,4 3,709,2 10,700,0 706,9 638,4 919,3 2,264,8
her her her her her her her her								4,826,025 1,429,810 959,517 1,267,764 3,657,091 368,962 294,931 424,701 1,088,594	1,494,077 1,002,646 1,324,749 3,821,474 3,851,474 3,05,631 440,109 1,125,771 81,073	1,047,699 1,384,011 3,992,424 331,432 316,708 456,060 1,164,200 83,505	1,116,549 1,475,244 4,255,603 403,175 328,099 472,463 1,203,737	1,188,800 1,570,706 4,530,979 415,270 339,889 489,440 1,244,599	1,284,381 1,670,563 4,819,048 427,728 352,090 507,010 1,286,829 91,249	1,343,427 1,775,008 5,120,323 440,560 364,718 525,194 1,330,472	1,426,078 1,884,210 5,435,337 453,777 377,787 544,013 1,375,576	1,495,567 1,976,023 5,700,188 467,390 391,218 563,354 1,421,963	1,567,942 2,071,649 5,976,038 481,412 405,116 583,367 1,469,894 102,701	1,543,314 2,171,234 6,223,309 495,854 419,495 604,073 1,519,422 105,782	1,721,797 2,274,930 6,562,437 510,730 434,372 625,496 1,570,598	1,803,510 2,382,893 6,873,876 526,052 449,765 647,661 1,623,478	1.891.137 2.498.671 7.207.858 541.833 465.804 670.758 1.678.396 115.591	1.982.399 2.619.251 7.555.693 558.088 482.401 694.658 1,735,147	2,077,434 2,744,817 7,917,910 574,831 499,575 719,388 1,793,793	2,176,388 2,875,560 8,295,060 592,076 517,345 744,976 1,854,397	2,279,409 3,011,677 8,687,713 609,838 535,731 771,452 1,917,022	2,377,101 3,140,752 9,060,056 628,133 554,895 799,049 1,982,077	2,478,603 3,274,862 9,446,919 646,977 574,727 827,607 2,049,311	2,584,056 3,414,192 9,848,841 666,387 595,249 857,159 2,118,795	2,693,605 3,558,935 10,266,376 686,378 616,486 887,739 2,190,604	706,93 638,44 919,31
ser or a ser Ser and a service of the service Service of the service of the service of the service service of the service of the service of the service service of the service of the service of the service of the service service of the service			2,081,486	2,143,930	4,416,497	4,548,991		4,826,025 1,628,810 96,8,177 3,867,7091 3,867,091 3,869,902 294,931 424,701 1,088,594 78,712 78,712	1,494,077 1,002,646 1,324,749 3,821,472 380,031 305,631 440,109 1,125,771 81,073 81,073	1,047,499 1,384,011 3,392,424 331,432 316,708 456,060 1,164,200 83,505 83,505	1,116,549 1,475,244 4,255,663 403,175 328,099 472,463 1,203,737 86,011 86,011	1,188,800 1,570,706 4,530,979 415,270 339,889 489,440 1,244,599 88,591 88,591	1,284,381 1,670,568 4,819,048 4,27,728 352,090 507,010 1,286,829 91,249 91,249	1.343,427 1.775,608 5,120,323 440,560 364,718 525,194 1,330,472 93,986 93,986	1,425,078 1,884,210 5,435,337 453,777 377,787 544,013 1,375,576 96,806 96,806	1,495,567 1,976,023 5,700,188 467,390 391,218 563,354 1,421,963 99,710 99,710	1,567,942 2,071,649 5,076,038 5,976,038 4,811,412 4,05,116 5,83,367 1,469,894 102,701 102,701	1,643,314 2,171,234 6,263,309 495,854 419,495 604,073 1,519,422 105,782	1,721,797 2,274,930 5,2274,930 5,10,730 434,372 625,496 1,570,598 108,956 108,956	1,803,510 2,342,893 6,873,876 526,052 449,765 647,661 1,623,478 112,224 112,224	1,891,137 2,498,671 7,207,858 541,833 465,804 670,758 1,678,396 115,591	1,982,399 2,619,251 7,555,693 558,088 482,401 694,658 1,735,147 119,059 119,059	2,077,434 2,274,817 7,917,910 574,831 499,575 719,388 1,793,793 122,531	2,176,388 2,875,560 8,295,060 592,076 517,345 744,976 1,854,397 126,310 126,310	2.279.409 3.011.677 8.687.713 609.838 535.731 771.452 1.917.022 130.099 130.099	2,377,101 3,140,752 9,060,056 628,133 554,895 799,049 1,962,077 134,002 134,002	2,478,603 3,274,862 9,446,919 646,917 574,727 827,607 2,049,311 138,022 138,022	2,584,056 3,414,192 9, 548,841 666,387 595,249 857,159 2,118,795 142,162 142,162	2,693,605 3,558,935 10,226,376 686,378 616,485 887,739 2,190,604 146,427 146,427	2,807,4/ 3,709,2/ 10,700,09 706,9: 638,4/ 919,3/ 2,264,8/ 150,8: 150,8:
er er er er er er er er er er			2,081,486	2,143,930	4,416,497	4,548,991	4,85,461	4,826,025 1,628,810 96,8,177 3,827,764 3,867,091 368,942 294,931 424,701 1,088,594 78,712 78,712	1,494,077 1,002,646 1,324,749 3,821,472 380,031 305,631 440,109 1,125,771 81,073 81,073	1,047,499 1,384,011 3,392,424 331,432 316,708 456,060 1,164,200 83,505 83,505	1,116,549 1,475,244 4,255,663 403,175 328,099 472,463 1,203,737 86,011 86,011	1,188,800 1,570,706 4,530,979 415,270 339,889 489,440 1,244,599 88,591 88,591	1,284,381 1,670,568 4,819,048 4,27,728 352,090 507,010 1,286,829 91,249 91,249	1.343,427 1.775,608 5,120,323 440,560 364,718 525,194 1,330,472 93,986 93,986	1,425,078 1,884,210 5,435,337 453,777 377,787 544,013 1,375,576 96,806 96,806	1,495,567 1,976,023 5,700,188 467,390 391,218 563,354 1,421,963 99,710 99,710	1,567,942 2,071,649 5,076,038 5,976,038 4,811,412 4,05,116 5,83,367 1,469,894 102,701 102,701	1,643,314 2,171,234 6,263,309 495,854 419,495 604,073 1,519,422 105,782	1,721,797 2,274,930 5,2274,930 5,10,730 434,372 625,496 1,570,598 108,956 108,956	1,803,510 2,342,893 6,873,876 526,052 449,765 647,661 1,623,478 112,224 112,224	1,891,137 2,498,671 7,207,858 541,833 465,804 670,758 1,678,396 115,591	1,982,399 2,619,251 7,555,693 558,088 482,401 694,658 1,735,147 119,059 119,059	2,077,434 2,274,817 7,917,910 574,831 499,575 719,388 1,793,793 122,531	2,176,388 2,875,560 8,295,060 592,076 517,345 744,976 1,854,397 126,310 126,310	2.279.409 3.011.677 8.687.713 609.838 535.731 771.452 1.917.022 130.099 130.099	2,377,101 3,140,752 9,060,056 628,133 554,895 799,049 1,962,077 134,002 134,002	2,478,603 3,274,862 9,446,919 646,917 574,727 827,607 2,049,311 138,022 138,022	2,584,056 3,414,192 9, 548,841 666,387 595,249 857,159 2,118,795 142,162 142,162	2,693,605 3,558,935 10,226,376 686,378 616,485 887,739 2,190,604 146,427 146,427	2,807,4 3,709,2 10,700,0 706,9 638,4 919,3 2,264,8 150,8
ri vi vi solati Solati Solati Solati Solati Solati Mannara Solati Mannara Solati Mannara Solati Mannara Solati Mannara Solati Mannara Solati Mannara Solati Mannara Solati			2.081.486	2,143,930	4,416,497	4,546,991 (4,548,991)	4,85,461	4,826,025 1,422,810 969,517 1,267,764 3,657,091 368,962 294,931 404,701 1,088,594 78,712 78,712 78,712 78,712	1,494,077 1002,646 1,324,749 3,8821,472 380,031 305,631 440,109 1,125,771 81,073 81,073 2,614,627	1.047.499 1.384.011 3.992.424 331.432 345.708 455.060 1.164.200 83.505 83.505 2.744.719	1,116,549 1,475,244 4,255,603 4,255,603 4,255,603 4,03,175 3,28,099 4,72,463 1,203,737 86,011 86,011 2,965,855	1,188,800 1,570,705 4,530,979 4,530,979 4,530,979 4,5270 339,889 489,440 1,244,599 88,591 88,591 3,197,790	1,264,381 1,670,581 1,670,585 4,819,048 427,728 352,209 507,010 507,010 1,286,829 91,249 91,249 91,249 3,440,971	1.343,427 1.775,608 5,120,323 440,560 364,718 3525,194 1.330,472 93,986 93,986 3.695,864	1,426,078 1,884,210 5,435,337 453,777 377,787 544,013 1,375,576 96,806 96,806 3,962,955	1,495,567 1,976,023 5,700,188 467,390 391,218 563,354 1,421,963 99,710 99,710 4,178,515	1 567 342 2 071 649 5,976,038 481,412 405,116 583,367 1,469,894 102,701 102,701 4,403,442	1,643,314 2,171,234 495,854 419,485 604,073 1,519,422 105,782 105,782 4,638,104	1,721,737 2,274,337 6,562,437 510,730 434,372 625,496 1,570,598 108,956 4,882,883	1,803,510 2,382,93876 6,873,876 526,052 449,765 647,661 1,623,476 112,224 112,224 5,138,174	1.801.137 2.498,671 7.207,858 541,833 465,804 670,758 1.678,396 1.678,396 115,591 115,591 5.413,872	1,982,399 2,619,251 7,555,693 558,088 452,401 694,658 1,735,147 119,059 5,701,487	2.077.434 2.744.817 7.947.940 574.831 499.575 719.388 1.793.793 122.631 122.631 6.001.486	2,175,288 2,875,560 592,076 517,245 744,976 1,854,397 126,310 126,310 6,314,354	2279.409 3.01167/13 6.687/13 609,838 535,731 771,452 1,917,022 130,099 6.640,593	2.377.01 3.140,752 628,133 554,995 799,049 1.982,077 134,002 134,002 6.943,976	2.478.603 3.274.862 9.446,919 646,977 574,727 827,807 2.049,311 138,022 7.259.586	2.584.055 3.414.192 9.848,841 9.848,841 9.848,841 9.848,841 9.857,159 2.118,795 142,162 142,162 7.587,884	2,603,605 3,558,935 10,266,376 616,486 616,486 887,739 2,190,604 146,427 146,427 7,929,345	2,807, 3,709, 10,700,1 706,5 538, 919,3 2,264,1 150,1 150,1 150,1 8,284,4

Digester Gas Utilization Alternatives

			Alt. 2: Existing REEP	+ New	Alt. 3A: Centralized	Cogeneration	Alt. 4: Utilize DG for	Pipeline	Alt. 5: Compressed I	Natural Gas for	
	Alt. 1: Expand REEP Ca	pacity	Cogeneration System	n	System		Injection (RNG)		Vehicle Fuel (CNG)		Notes
System Components	System Size	Cost	System Size	Cost	, System Size	Cost	System Size	Cost	System Size	Cost	
Capital Costs (for 2060 facilities)		L									
IC Engines			-	-	-	-	-	-	-	-	\$2000/kW
Microturbines	-	-	7 @ 250 kW each	10,329,000	-	-	-	-	-	-	
Gas Turbines	-	-	-	-	1 @ 4.6 MW	12,912,000	-	-	-	-	
Selective Catalytic Converter		1,002,000		1,002,000		1,002,000		1,002,000		1,002,000	
Basic Gas Conditioning @ RP-5	460 scfm (2035 quantity)	1,845,000	570 scfm	1,845,000	570 scfm	1,845,000	570 scfm	1,845,000	570 scfm	1,845,000	
Basic Gas Conditioning @ RP-1	-	-	-	-	800 scfm	2,767,000	-	-	-	-	
Microturbines Compression Stn	-	-	570 scfm	738,000	-	-	-	-	-	-	
Gas Turbines Compression Stn	-	-	-	-	1400 scfm, 250 psi	1,845,000	-	-	-	-	
Digester Gas Pipeline	-	-	-	-	8 miles, 12 inches	12,100,000	-	-	-	-	\$200/ft
CO ₂ Removal System	-	-	-	-	-	-	570 scfm	2,213,000	570 scfm	2,213,000	
RP-1 Compression Station	-	-	-	-	800 scfm, 10 psi	461,000	-	-	-	-	
High Pressure Compression	-	-	-	-	-	-	-	-	340 scfm, 4000 psi	1,845,000	
Low Pressure Compression	-	-	-	-	-	-	340 scfm, 100 psi	922,000	-	-	
Pipeline Injection Point of Receipt	-	-	-	-	-	-	340 scfm	2,420,000	-	-	
CNG Filling Station/storage	-	-	-	-	-	-	-	-	340 scfm, 4000 psi	1,845,000	
RNG Pipeline Extension							1 mile - RNG pipe extension	968,000			\$150/ft
Existing REEP Heat Recovery System											
Modifications		505,000		505,000		505,000		505,000		505,000	
SHF Gas Conditioning		654,000		654,000		654,000		654,000		654,000	
Base Cost		4,006,000		\$15,073,000		\$34,091,000		\$10,529,000		\$9,909,000	
Overhead & Profit, Inflation, Bonds &											
Insurances, Contingency		\$2,604,000		\$9,797,000		\$22,159,000		\$6,844,000		\$6,441,000	
Total Construction Cost		\$6,610,000		\$24,870,000		\$56,250,000		\$17,373,000		\$16,350,000	
Design & Administration		\$1,322,000		\$4,974,000		\$11,250,000		\$3,474,600		\$3,270,000	
Total Project Cost		\$7,932,000		\$29,844,000		\$67,500,000		\$20,847,600		\$19,620,000	
			-				-		-		
Annual Costs/Savings (in 2045)											
System Components	System Size	Savings	System Size	Savings	System Size	Savings	System Size	Savings	System Size	Savings	
			1.6 MW microturbines +		4.6 MW gas turbine +						\$0.125/kWh, \$0.50/Therm fo
Combined Heat and Power savings/ RNG			2.5 MW REEP, 500,000		2.5 MW REEP,		RNG sale - 320 scfm +		CNG sale - 320 scfm +		heat savings and RNG sales,
& CNG sale	3 MW	\$3,378,000	Therm/year	\$4,624,952	1,500,000 Therm/year	\$7,925,000	2.5 MW REEP	\$3,531,000	2.5 MW REEP	\$4,781,000	\$1.50/GGE for CNG
RIN Incentives		-		-		-		\$875,000		\$1,800,000	\$1.33 per GGE
LCFS Incentives		-		-		-		\$660,000		\$1,300,000	\$8.83 per MMBTU
			1.6 MW microturbines +		4.6 MW gas turbine +						
			2.7 MW REEP, 90%		2.7 MW REEP, 90%						
0&M	3 MW, 90% uptime	(\$970,000)	uptime	(\$1,417,000)	uptime	(\$1,521,000)	320 scfm	(\$1,009,000)	320 scfm	(\$1,059,000)	Power & Labor
Repair/Replacement		(\$66,500)		(\$140,000)		(\$215,000)		(\$34,000)		(\$64,000)	2% of equipment cost
Net Annual Savings (2045)		\$2,341,500		\$3,068,000		\$6,189,000		\$4,057,000		\$6,822,000	